

STATE OF NORTH CAROLINA
UTILITIES COMMISSION
RALEIGH

DOCKET NO. E-2, SUB 1321

BEFORE THE NORTH CAROLINA UTILITIES COMMISSION

In the Matter of)	
Application of Duke Energy Progress,)	DIRECT TESTIMONY OF
LLC Pursuant to G.S. 62-133.2 and)	JEFFREY FLANAGAN FOR
NCUC Rule R8-55 Relating to Fuel)	DUKE ENERGY PROGRESS,
and Fuel-Related Charge Adjustments)	LLC
for Electric Utilities)	

1 **Q. PLEASE STATE YOUR NAME AND BUSINESS ADDRESS.**

2 A. My name is Jeffrey Flanagan and my business address is 8320 East Highway 150,
3 Terrell, North Carolina.

4 **Q. BY WHOM ARE YOU EMPLOYED AND IN WHAT CAPACITY?**

5 A. I am employed by Duke Energy as General Manager III of the Carolinas
6 Dispatchable Generation - West Zone including the Marshall, Allen, Asheville and
7 WS Lee stations.

8 **Q. PLEASE BRIEFLY DESCRIBE YOUR EDUCATIONAL AND**
9 **PROFESSIONAL BACKGROUND.**

10 A. I graduated from NC State University with a Bachelor's Degree in Paper Science &
11 Engineering and a Bachelor's Degree in Chemistry. I also graduated from The
12 University of South Carolina with a Master's Degree in Business Administration. I
13 am a registered Professional Engineer in the state of South Carolina. My career began
14 with Duke Energy as an FGD Scrubber Engineer at Progress Energy. Since that time,
15 I have held various roles of increasing responsibility in generation projects,
16 engineering and operations areas, including Operations and Maintenance
17 Superintendent at Marshall Station and Station Manager at Smith Energy Complex. I
18 was named General Manager of Marshall and Allen Stations in July of 2021. I
19 assumed my current role in February of 2023.

20 **Q. WHAT ARE YOUR DUTIES AS GENERAL MANAGER III OF THE**
21 **CAROLINAS DISPATCHABLE GENERATION?**

22 A. I am responsible for the overall direction and management for over 4,000 megawatts
23 of Carolinas Dispatchable Generation coal, combined cycle and peaking generation,

1 providing strategic direction and leadership to station general managers including day
2 to day operations, business analysis, process development, O&M and capital budget
3 allocation and implementation and outage performance. I am also responsible for
4 operational excellence at all levels of the organization including continuous
5 improvement and competitive benchmarking. I interact with the public and private
6 sector to manage the overall business to maintain profitable and publicly positive
7 stations.

8 **Q. HAVE YOU TESTIFIED BEFORE THIS COMMISSION IN ANY PRIOR**
9 **PROCEEDINGS?**

10 A. Yes. I testified before the North Carolina Utilities Commission on behalf of the
11 Company in its Duke Energy Carolinas, LLC 2023 annual fuel rider proceeding in
12 Docket No. E-7, Sub 1282.

13 **Q. WHAT IS THE PURPOSE OF YOUR TESTIMONY IN THIS**
14 **PROCEEDING?**

15 A. The purpose of my testimony is to (1) describe DEP's Traditional and Renewable
16 (formerly called the Fossil/Hydro/Solar fleet) generation portfolio and changes
17 made since the 2022 fuel cost recovery proceeding, as well as those expected in the
18 near term; (2) discuss the performance of DEP's Traditional and Renewable
19 facilities during the period of April 1, 2022 through March 31, 2023 (the "review
20 period"); (3) provide information on significant Traditional/Renewable outages that
21 occurred during the review period; and (4) provide information concerning
22 environmental compliance efforts.

23 **Q. PLEASE DESCRIBE DEP'S TRADITIONAL/RENEWABLE**
24 **GENERATION PORTFOLIO FOR THE REVIEW PERIOD.**

1 A. The Company's Traditional/Renewables generation portfolio consists of 8,945
2 MWs of generating capacity, made up as follows:

3	Coal-fired -	3,143 MWs
4	Combustion Turbines -	2,404 MWs
5	Combined Cycle Turbines -	3,079 MWs
6	Hydro -	228 MWs
7	Solar -	87 MWs ¹
8	Battery Storage-	4 MWs

9

10 The 3,143 MWs of coal-fired generation represent two generating stations
11 and a total of five units. These units are equipped with emission control equipment,
12 including selective catalytic reduction ("SCR") equipment for removing nitrogen
13 oxides ("NO_x"), flue gas desulfurization ("scrubber") equipment for removing
14 sulfur dioxide ("SO₂"), and low NO_x burners. This inventory of coal-fired assets
15 with emission control equipment enhances DEP's ability to maintain current
16 environmental compliance and concurrently utilize coal with increased sulfur
17 content – providing flexibility for DEP to procure the most cost-effective options
18 for fuel supply. The Company has a total of 24 simple cycle combustion turbine
19 ("CT") units, the larger 14 of which provide 2,144 MWs, or 89% of CT capacity.
20 These 14 units are located at the Asheville, Darlington, Richmond County (Smith
21 Energy Complex), and Wayne County (H.F. Lee) facilities, and are equipped with
22 water injection and/or low NO_x burners for NO_x control. The 3,079 MWs shown
23 as "Combined Cycle Turbines" ("CC") represent six power blocks. The two

¹ This value represents the dependable capacity contribution to meeting summer peak demand, based on the Company's integrated resource planning metrics. The nameplate capacity of the Company's solar facilities is 141 MWs.

1 Asheville Combined Cycle power blocks have a configuration of one CT and one
2 steam turbine. The H.F. Lee Energy Complex CC power block has a configuration
3 of three CTs and one steam turbine. The two Richmond County power blocks
4 located at the Smith Energy Complex consist of two CTs and one steam turbine
5 each. The Sutton Combined Cycle at Sutton Energy Complex consists of two CTs
6 and one steam turbine. The six CC power blocks are equipped with SCR
7 equipment, and all eleven CTs have low NO_x burners. The steam turbines do not
8 combust fuel and, therefore, do not require NO_x controls. The Company's hydro
9 fleet consists of 15 units providing 228 MWs of capacity. The Company's solar
10 fleet consists of four sites providing 87 MWs of dependable capacity. 4 MWs of
11 battery storage includes the Asheville-Rock Hill battery and the Hot Springs
12 Microgrid battery.

13 **Q. DID ANY NOTABLE CHANGES OCCUR WITHIN THE**
14 **TRADITIONAL/RENEWABLES PORTFOLIO SINCE DEP'S 2022**
15 **ANNUAL FUEL PROCEEDING?**

16 A. The solar Contribution to Peak percentages increased to 62% for DEP, resulting
17 in a 52 MW increase in capacity. The increase was based on the updated ELCC
18 (Effective Load Carrying Capability) results. Two battery storage projects were
19 added to the fleet, adding 4 MWs to the generation total.

20 **Q. WHAT ARE DEP'S OBJECTIVES IN THE OPERATION OF ITS**
21 **TRADITIONAL/RENEWABLES FACILITIES?**

22 A. The primary objective of DEP's Traditional/Renewables generation department is
23 to provide safe, reliable, and cost-effective electricity to DEP's customers.

1 Operations personnel and other station employees are well-trained and execute their
2 responsibilities to the highest standards in accordance with procedures, guidelines,
3 and a standard operating model. Like safety, environmental compliance is a “first
4 principle,” and DEP works very hard to achieve high level results.

5 The Company achieves compliance with all applicable environmental
6 regulations and maintains station equipment and systems in a cost-effective manner
7 to ensure reliability. The Company also takes action in a timely manner to implement
8 work plans and projects that enhance the safety and performance of systems,
9 equipment, and personnel, consistent with providing low-cost power options for
10 DEP’s customers. Equipment inspection and maintenance outages are generally
11 scheduled during the spring and fall months when customer demand is reduced due
12 to milder temperatures. These outages are well-planned and executed with the
13 primary purpose of preparing the unit for reliable operation until the next planned
14 outage.

15 **Q. HOW MUCH GENERATION DID EACH TYPE OF GENERATING**
16 **FACILITY PROVIDE FOR THE REVIEW PERIOD?**

17 A. For the review period, DEP’s total system generation was 58,900,432 megawatt-
18 hours (“MWHs”), of which 29,905,327 MWHs, or approximately 51%, was
19 provided by the Traditional/Renewables fleet. The breakdown includes a 40%
20 contribution from gas facilities, 9% contribution from coal-fired stations, 1%
21 contribution from hydro sources, and 0.4% from solar facilities.

22 **Q. HOW DID DEP COST EFFECTIVELY DISPATCH THE DIVERSE MIX OF**
23 **GENERATING UNITS DURING THE REVIEW PERIOD?**

1 A. The Company's portfolio includes a diverse mix of units that, along with its nuclear
2 capacity, allows DEP to meet the dynamics of customer load requirements in a
3 logical and cost-effective manner. The addition of new CC units within the
4 Carolinas' portfolio in recent years has provided DEP with additional natural gas
5 resources that feature state-of-the-art technology for increased efficiency and
6 significantly reduced emissions. DEP also uses the Joint Dispatch Agreement with
7 DEC, which allows generating resources for DEP and DEC to be dispatched as a
8 single system to enhance dispatching the lowest cost resources available. The cost
9 and operational characteristics of each unit generally determine the type of customer
10 load situation (e.g., base and peak load requirements) that a unit would be called
11 upon or dispatched to support.

12 **Q. PLEASE EXPLAIN HEAT RATE AND WHAT WAS THE HEAT RATE**
13 **FOR DEP'S COMBINED CYCLE AND COAL-FIRED UNITS DURING THE**
14 **REVIEW PERIOD?**

15 A. Heat rate is a measure of the amount of thermal energy needed to generate a given
16 amount of electric energy and is expressed as British thermal units ("Btu") per
17 kilowatt-hour ("kWh"). A low heat rate indicates an efficient fleet that uses less heat
18 energy from fuel to generate electrical energy. Over the review period, the
19 Company's six combined cycle power blocks produced 69% of the
20 Traditional/Renewables generation, with an average heat rate of 7,205 Btu/kWh.
21 The five coal units produced 18% of the Traditional/Renewables generation, with
22 the average heat rate of 11,157 Btu/kWh.

1 **Q. PLEASE DISCUSS THE OPERATIONAL RESULTS FOR DEP'S**
2 **TRADITIONAL/RENEWABLES FLEET DURING THE REVIEW PERIOD.**

3 A. The Company's generating units operated efficiently and reliably during the review
4 period. Several key measures are used to evaluate the operational
5 performance depending on the generator type: (1) equivalent availability factor
6 ("EAF"), which refers to the percent of a given time period a facility was available
7 to operate at full power, if needed (EAF is not affected by the manner in which the
8 unit is dispatched or by the system demands; it is impacted, however, by planned
9 and unplanned maintenance (i.e., forced) outage time); (2) net capacity factor
10 ("NCF"), which measures the generation that a facility actually produces against
11 the amount of generation that theoretically could be produced in a given time period,
12 based upon its maximum dependable capacity (NCF is affected by the dispatch of
13 the unit to serve customer needs); (3) starting reliability ("SR"), which represents
14 the percentage of successful starts; and (4) equivalent forced outage factor ("EFOF")
15 – which quantifies the number of period hours in a year during which the unit is
16 unavailable because of forced outages and forced deratings.

17

1

DEP Comparison to NERC Five Year Average				
Generator Type	Measure	Review Period*	2017-2021	Number of Units
		DEP Operational Results	NERC Average	
<i>Coal Fired Test Period</i>	EAF	63.23%	78.77%	182
	NCF	19.79%	52.30%	
	EFOF	9.22%	n/a	
<i>Coal Fired Summer Peak**</i>	EAF	82.71%	n/a	n/a
<i>Total CC Average</i>	EAF	73.89%	84.41%	342
	NCF	65.70%	54.21%	
	EFOF	0.69%	n/a	
<i>Total CT Average</i>	EAF	76.22%	86.06%	680
	SR	99.15%	98.64%	
<i>Hydro</i>	EAF	68.95%	78.89%	909
<i>Solar</i>	NCF	20.31%	n/a	n/a

* Trailing 12 months ending 3/31/2023

** June, July, August

2

3 **Q. PLEASE DISCUSS SIGNIFICANT OUTAGES OCCURRING AT DEP'S**
4 **TRADITIONAL/RENEWABLES FACILITIES DURING THE REVIEW**
5 **PERIOD.**

6 A. In general, planned maintenance outages for all fossil and hydro units are scheduled
7 for the spring and fall to maximize unit availability during periods of peak demand.
8 Most units had at least one short, planned outage during this review period to inspect
9 and maintain plant equipment.

10 In the spring of 2022, Lee CC performed an outage to do a steam turbine
11 inspection, steam turbine generation inspection, and generator rotor winding repair.
12 Roxboro 1 had an outage to do the annual boiler certificate inspection and Flue Gas
13 Desulfurization (FGD) inlet expansion joint repairs. Lee CC performed an outage
14 to do a borescope inspection, compressor blade replacement, and compressor blade

1 ring alignment. Asheville CC performed a GE warranty outage and made turbine
2 rotor and packing repairs. Mayo 1 had an outage to tie in the aqueous ammonia
3 system, precipitator inspection and repair, and miscellaneous boiler valve and piping
4 repairs. Roxboro 3 had an outage to replace the top layer of SCR catalyst in two
5 SCR's, inspected the precipitator, did FGD inspections and miscellaneous boiler
6 valve and piping repairs.

7 Fall outages included an outage at Roxboro 3 to perform water pump repairs,
8 dry fly ash piping and valve repairs, ammonia skid vaporizer replacement, coal surge
9 bin inspections and cola reclaim chute repairs. The Company also performed an
10 outage a Mayo 1, to replace the air preheater baskets and seals, perform turbine valve
11 replacements and rebuilds, do High Energy Piping Non-Destructive Examination
12 evaluations, and perform miscellaneous Balance of Plant activities. The Heat
13 Recovery Steam Generator blowdown tanks and silencer end of life were replaced as
14 part of an outage at Richmond County CC units. An outage at Wayne County CT13
15 was performed to replace the exhaust stack. Finally, an outage at Wayne County
16 CT14 to conduct a Hot Gas Path Inspection and turning gear upgrade.

17 Forced outages with the highest equivalent hour impact during the test
18 period included an outage at Weatherspoon CT1, where the unit expander exhaust
19 case floor was broken at the center pin area and running toward the turning gear.
20 A forced outage occurred at Weatherspoon CT4 with damage on a first stage
21 rotating blade. Fuel nozzles caused a forced outage at Blewett CT2. Lastly,
22 Roxboro 3 had a broken turning gear housing on the 3B Boiler Feed Pump
23 Turbine that required a forced outage to repair.

1 **Q. HOW DOES DEP ENSURE EMISSIONS REDUCTIONS FOR**
2 **ENVIRONMENTAL COMPLIANCE?**

3 A. The Company has installed pollution control equipment on coal-fired units, as well
4 as new generation resources, to meet various current federal, state, and local
5 reduction requirements for NO_x and SO₂ emissions. The SCR technology that DEP
6 currently operates on the coal-fired units uses ammonia or urea for NO_x removal
7 and the scrubber technology employed uses crushed limestone or lime for SO₂
8 removal. SCR equipment is also utilized on power blocks 4 and 5 Smith Energy
9 Complex with aqueous ammonia (19% solution of NH₃) for NO_x removal.

10 Overall, the type and quantity of chemicals used to reduce emissions at the
11 plants varies depending on the generation output of the unit, the chemical
12 constituents in the fuel burned, and/or the level of emissions reduction required. The
13 Company is managing the impacts, favorable or unfavorable, because of changes to
14 the fuel mix and/or changes in coal burn and utilization of non-traditional coals.
15 Overall, the goal is to effectively comply with emissions regulations and provide the
16 optimal total-cost solution for operation of the unit. The Company will continue to
17 leverage new technologies and chemicals to meet both present and future state and
18 federal emissions requirements including the MATS rule. MATS chemicals that
19 DEP may use in the future to reduce emissions include, but may not be limited to,
20 activated carbon, mercury oxidation chemicals, and mercury re-emission prevention
21 chemicals. Company witness Harrington provides the cost information for DEP's
22 chemical use and forecast.

23

- 1 Q. DOES THAT CONCLUDE YOUR PRE-FILED DIRECT TESTIMONY?
- 2 A. Yes, it does.