PAT MCCRORY

Governor

DONALD R. VAN DER VAART

Secretary

S. JAY ZIMMERMAN

Director

December 1, 2016

Walter Douglas Brady Academy Field, LLC 805 Front Street Beaufort, NC 28516

Subject:

Water Resources

ENVIRONMENTAL QUALITY

Permit No. WQ0031180 Modification

Academy Field, LLC

Cape Point Village Sewer System

Wastewater Collection System Extension Permit

Carteret County

Dear Mr. Brady:

In accordance with your application received November 15, 2016, we are forwarding herewith Permit No. WQ0031180, dated December 1, 2016, to Academy Field, LLC (Permittee) for the construction and operation upon certification of the subject wastewater collection system extension. This permit shall be effective from the date of issuance until rescinded, shall void Permit No. WQ0031180 issued March 19, 2010, and shall be subject to the conditions and limitations as specified therein. This cover letter and supplement shall be considered a part of this permit and are therefore incorporated therein by reference.

This modification changes ownership from Barbour's Landing, LLC to Academy Field, LLC and changes the project scope from a 102 space recreational vehicle park to a 25-lot subdivision. It also includes a proposed lift station in place of the original onsite wastewater treatment facility (WQ0031070).

Please pay particular attention to the following conditions contained within this permit:

Condition II.1: This permit shall not be automatically transferable; a request must be made and

approved.

Condition II.4: Requires that the wastewater collection facilities be properly operated and maintained

in accordance with 15A NCAC 2T .0403 or any individual system-wide collection system

permit issued to the Permittee.

It shall be responsibility of the Permittee to ensure that the as-constructed project meets the appropriate design criteria and rules. Failure to comply may result in penalties in accordance with North Carolina General Statute §143-215.6A through §143-215.6C, construction of additional or replacement wastewater collection facilities, and/or referral of the North Carolina-licensed Professional Engineer to the licensing board.

Academy Field, LLC Permit No. WQ0031180 Modification

If any parts, requirements, or limitations contained in this permit are unacceptable, you have the right to request an adjudicatory hearing upon written request within 30 days following receipt of this permit. This request must be in the form of a written petition, conforming to Chapter 150B of North Carolina General Statutes, and filed with the Office of Administrative Hearings, 6714 Mail Service Center, Raleigh, NC 27699-6714. Unless such demands are made, this permit shall be final and binding.

If you need additional information concerning this matter, please contact Michael Leggett at (919) 807-6312 or via e-mail at michael.leggett@ncdenr.gov.

Sincerely,

for S. Jay Zimmerman, P.G.

Director, Division of Water Resources

by Deborah Gore, Supervisor

Pretreatment, Emergency Response, Collection System Unit

cc:

Ginger Y. Turner, PE – Stroud Engineering, PA (ecopy)

Mike Laws - HISCO (ecopy)

Wilmington Regional Office, Water Quality Section Regional Operations

Water Resources Central Files: WQ0031180

PERCS (electronic copy)



WASTEWATER COLLECTION SYSTEM EXTENSION PERMIT

In accordance with the provisions of Article 21 of Chapter 143, General Statutes of North Carolina as amended, and other applicable Laws, Rules, and Regulations, permission is hereby granted to

Academy Field, LLC

for the operation of approximately 993 linear feet of 8-inch gravity sewer (gravity sewer certified February 24, 2010); a 87-gallon per minute pump station with duplex pumps, on-site audible and visual high water alarms, telemetry, and a portable generator receptacle with telemetry; as well as approximately 189 linear feet of 3-inch force main to serve 25 single family residential units as part of the Cape Point Village Subdivision project, and the discharge of 12,000 gallons per day of collected domestic wastewater into the Harker's Island Sewer Company's existing sewerage system, pursuant to the application received November 15, 2016 and in conformity with the project plans, specifications, and other supporting data subsequently filed and approved by the Department of Environmental Quality and considered a part of this permit.

This modification changes ownership from Barbour's Landing, LLC to Academy Field, LLC and changes the project scope from a 102 space recreational vehicle park to a 25-lot subdivision. It also includes a proposed lift station in place of the original onsite wastewater treatment facility.

This permit shall be effective from the date of issuance until rescinded and shall be subject to the specified conditions and limitations contained therein.

for S. Jay Zimmerman, P.G.

Director, Division of Water Resources

By Authority of The Environmental Management Commission

Permit Number:

WQ0031180 Modification

Permit Issued:

December 1, 2016

Treatment Facility:

West Bay Wastewater Treatment Facility (WQ0024023)

SUPPLEMENT TO PERMIT COVER SHEET

The Permittee is hereby authorized to:

Construct, and then operate upon certification the aforementioned wastewater collection extension.

Permitting of this project does not constitute an acceptance of any part of the project that does not meet 15A NCAC 2T; the Division's Gravity Sewer Minimum Design Criteria adopted February 12, 1996 as applicable; and the Division's Minimum Design Criteria for the Fast-Track Permitting of Pump Stations and Force Mains adopted June 1, 2000 as applicable, unless specifically mentioned herein. Division approval is based on acceptance of the certification provided by a North Carolina-licensed Professional Engineer in the application. It shall be the Permittee's responsibility to ensure that the as-constructed project meets the appropriate design criteria and rules.

Construction and operation is contingent upon compliance with the Standard Conditions and any Special Conditions identified below.

I. SPECIAL CONDITIONS

- 1. Prior to operation of this facility, a change of ownership form shall be submitted to the Division requesting the transfer of ownership from Academy Field, LLC to Harkers Island Sewer Company, LLC in accordance with Condition II.1.
- 2. No flow in excess of the quantity permitted herein, 12,000 gallons per day, shall be made tributary to the subject sewer system until an application for permit modification for an increase in flow has been submitted to and approved by the Division. [15A NCAC 02T.0304(b)]
- 3. The Operational Agreement between the Permittee and the Environmental Management Commission is incorporated herein by reference and shall be a condition of this permit. Noncompliance with the terms of the Operational Agreement shall subject the Permittee to all sanctions provided by North Carolina General Statutes §143-215.6A to §143-215.6C for violation of or failure to act in accordance with the terms and conditions of this permit. [15A NCAC 02T.0115]
- 4. This permit shall be for the construction of the wastewater collection facilities only. No flow shall be made tributary to the subject facilities until a permit modification application is submitted (with the appropriate fee), a modified permit is issued, and the Engineer's Certification is received and approved by the Division. Only lots that can obtain a septic disposal system via the County health department may be developed until such time that the permit is modified and system permitted herein is placed into operation. [15A NCAC 02T.0116]
- 5. Each pump station shall be clearly and conspicuously posted using a weatherproof sign with a pump station identifying name/number, 24-Hour Emergency telephone number, and name of the owner/operator of the sewer system/pump station and instructions to call the number in the event of alarm activation or other emergency. Simplex pump stations or vacuum sewer pits serving a single-family residence may have a placard or sticker on the control panel in lieu of a sign. [15A NCAC 02T .0305(h)(2)]

- 6. The abandonment of any existing wastewater facilities including septic systems being replaced by new sewer infrastructure shall be done in accordance with the applicable agency having compliance oversight on such facilities. [15A NCAC 02T.0105(c)(6)]
- 7. The Permittee shall obtain all deeds, easements and encroachment agreements necessary for installation, operation, and maintenance of the system prior to operation. [15A NCAC 02T.0305(c)]

II. STANDARD CONDITIONS

- 1. This permit shall not be transferable. In the event there is a desire for the wastewater collection facilities to change ownership, or there is a name change of the Permittee, a formal permit request shall be submitted to the Division accompanied by documentation from the parties involved, and other supporting materials as may be appropriate. The approval of this request shall be considered on its merits and may or may not be approved. [15A NCAC 02T.0104; G.S. 143-215.1(d3)]
- 2. This permit shall become voidable unless the wastewater collection facilities are constructed in accordance with the conditions of this permit; 15A NCAC 2T; the Division's Gravity Sewer Minimum Design Criteria adopted February 12, 1996 as applicable; the Division's Minimum Design Criteria for the Fast-Track Permitting of Pump Stations and Force Mains adopted June 1, 2000 as applicable; and other supporting materials unless specifically mentioned herein. [15A NCAC 02T.0110]
- 3. This permit shall be effective only with respect to the nature and volume of wastes described in the application and other supporting data. [15A NCAC 02T .0110]
- 4. The wastewater collection facilities shall be properly maintained and operated at all times. The Permittee shall maintain compliance with an individual system-wide collection system permit for the operation and maintenance of these facilities as required by 15A NCAC 2T .0403. If an individual permit is not required, the following performance criteria shall be met: [15A NCAC 2T .0108(b)]
 - a. The sewer system shall be effectively maintained and operated at all times to prevent discharge to land or surface waters, and to prevent any contravention of groundwater standards or surface water standards.
 - b. A map of the sewer system shall be developed and shall be actively maintained.
 - c. An operation and maintenance plan including pump station inspection frequency, preventative maintenance schedule, spare parts inventory and overflow response has been developed and implemented.
 - d. Pump stations that are not connected to a telemetry system shall be inspected every day (i.e. 365 days per year). Pump stations that are connected to a telemetry system shall be inspected at least once per week.
 - e. High-priority sewer lines shall be inspected at least once per every six-months and inspections are documented.
 - f. A general observation of the entire sewer system shall be conducted at least once per year.
 - g. Overflows and bypasses shall be reported to the appropriate Division regional office in accordance with 15A NCAC 2B .0506(a), and public notice shall be provided as required by North Carolina General Statute §143-215.1C.
 - h. A Grease Control Program is in place as follows:
 - 1. For public owned collection systems, the Grease Control Program shall include at least biannual distribution of educational materials for both commercial and residential users and

the legal means to require grease interceptors at existing establishments. The plan shall also include legal means for inspections of the grease interceptors, enforcement for violators and the legal means to control grease entering the system from other public and private satellite sewer systems.

- 2. For privately owned collection systems, the Grease Control Program shall include at least biannual distribution of grease education materials to users of the collection system by the permittee or its representative.
- 3. Grease education materials shall be distributed more often than required in Parts (1) and (2) of this Subparagraph if necessary to prevent grease-related sanitary sewer overflows.
- i. Right-of-ways and easements shall be maintained in the full easement width for personnel and equipment accessibility.
- j. Documentation shall be kept for Subparagraphs (a) through (i) of this Rule for a minimum of three years with exception of the map, which shall be maintained for the life of the system.

5. Noncompliance Notification:

The Permittee shall report by telephone to a water resources staff member at the Wilmington Regional Office, telephone number (910) 796-7215, as soon as possible, but in no case more than 24 hours, following the occurrence or first knowledge of the occurrence of either of the following:

- Any process unit failure, due to known or unknown reasons, that renders the facility incapable of adequate wastewater transport, such as mechanical or electrical failures of pumps, line blockage or breakage, etc.; or
- b. Any SSO and/or spill over 1,000 gallons; or
- c. Any SSO and/or spill, regardless of volume, that reaches surface water

Voice mail messages or faxed information is permissible, but this shall not be considered as the initial verbal report. Overflows and spills occurring outside normal business hours may also be reported to the Division of Emergency Management at telephone number (800) 858-0368 or (919) 733-3300. Persons reporting any of the above occurrences shall file a spill report by completing and submitting Part I of Form CS-SSO (or the most current Division approved form) within five days following first knowledge of the occurrence. This report must outline the actions taken or proposed to be taken to ensure that the problem does not recur. Part II of Form CS-SSO (or the most current Division approved form) can also be completed to show that the SSO was beyond control. [G.S. 143-215.1C(a1)]

- 6. Construction of the gravity sewers, pump stations, and force mains shall be scheduled so as not to interrupt service by the existing utilities nor result in an overflow or bypass discharge of wastewater to the surface waters of the State. [15A NCAC 02T.0108(b)]
- 7. Upon completion of construction and prior to operation of these permitted facilities, the completed Engineering Certification form attached to this permit shall be submitted with the required supporting documents to the address provided on the form. A complete certification is one where the form is fully executed and the supporting documents are provided as applicable. Any wastewater flow made tributary to the wastewater collection system extension prior to completion of this Engineer's Certification shall be considered a violation of the permit and shall subject the Permittee to appropriate enforcement actions.

If the permit is issued to a private entity with an Operational Agreement, then a copy of the Articles of Incorporation, Declarations/Covenants/Restrictions, and Bylaws that have been appropriately filed with the applicable County's Register of Deeds office shall be submitted with the certification.

A complete certification is one where the form is fully executed and the supporting documents are provided as applicable. Supporting documentation shall include the following:

- a. One copy of the project construction record drawings (plan & profile views of sewer lines & force mains) of the wastewater collection system extension. Final record drawings should be clear on the plans or on digital media (CD or DVD disk) and are defined as the design drawings that are marked up or annotated with after construction information and show required buffers, separation distances, material changes, etc.
- b. Changes to the project that do not result in non-compliance with this permit, regulations, or the Minimum Design Criteria should be clearly identified on the record drawings, on the certification in the space provided, or in written summary form.

Prior to Certification (Final or Partial): Permit modifications are required for any changes resulting in non-compliance with this permit (including pipe length increases of 10% or greater, increased flow, pump station design capacity design increases of 5% or greater, and increases in the number/type of connections), regulations, or the Minimum Design Criteria. Requested modifications or variances to the Minimum Design Criteria will be reviewed on a case-by-case basis and each on its own merit. Please note that variances to the Minimum Design Criteria should be requested and approved during the permitting process prior to construction. After-construction requests are discouraged by the Division and may not be approved, thus requiring replacement or repair prior to certification & activation. [15A NCAC 02T .0116]

- 8. Gravity sewers installed greater than ten percent below the minimum required slope per the Division's Gravity Sewer Minimum Design Criteria shall not be acceptable and shall not be certified until corrected. If there is an unforeseen obstacle in the field where all viable solutions have been examined, a slope variance can be requested from the Division with firm supporting documentation. This shall be done through a permit modification with fee. Such variance requests will be evaluated on a case-by-case basis. Resolution of such request shall be evident prior to completing and submitting the construction certification. [15A NCAC 02T.0105(n)]
- 9. A copy of the construction record drawings shall be maintained on file by the Permittee for the life of the wastewater collection facilities. [15A NCAC 02T .0116]
- 10. Failure to abide by the conditions and limitations contained in this permit; 15A NCAC 2T; the Division's Gravity Sewer Design Criteria adopted February 12, 1996 as applicable; the Division's Minimum Design Criteria for the Fast-Track Permitting of Pump Station and Force Mains adopted June 1, 2000 as applicable; and other supporting materials may subject the Permittee to an enforcement action by the Division, in accordance with North Carolina General Statutes §143-215.6A through §143-215.6C, construction of additional or replacement wastewater collection facilities, and/or referral of the North Carolina-licensed Professional Engineer to the licensing board. [15A NCAC 02T .0104; 15A NCAC 02T .0108(b-c)]

- 11. In the event that the wastewater collection facilities fail to perform satisfactorily, including the creation of nuisance conditions, the Permittee shall take immediate corrective action, including those as may be required by this Division, such as the construction of additional or replacement facilities. [15A NCAC 02T .0108(b)]
- 12. The issuance of this permit shall not exempt the Permittee from complying with any and all statutes, rules, regulations, or ordinances that may be imposed by the Division any other Federal, State, or Local government agencies which have jurisdiction or obtaining other permits which maybe required by the Division or any other Federal, State, of Local government agencies. [G.S.143-215.1(b)]

ENGINEERING CERTIFICATION

Permittee: Academy Field, LLC
Permit No: WQ0031180 Modification

Project:

Cape Point Village Sewer System

Issue Date: December 1, 2016

County: Carteret

This project shall not be considered complete nor allowed to operate in accordance with Condition 7 of this permit until the Division has received this Certification and all required supporting documentation, which includes:

One copy of the project construction record drawings (plan & profile views of sewer lines & force mains)
of the wastewater collection system extension. Final record drawings should be clear on the plans or on
digital media (CD or DVD disk) and are defined as the design drawings that are marked up or annotated
with after construction information and show required buffers, separation distances, material changes,
etc.

Permit modifications are required for any changes resulting in non-compliance with this permit. A detailed description for partial certifications should be attached to this form along with any certification comments.

Certification should be submitted in a manner that documents the Division's receipt. The Permittee is responsible for tracking all partial certifications up until a final certification is received.

PERMITTEE'S CERTIFICATION

Date
<u>N</u>
ngineer in the State of North Carolina, having me) the construction of the project name and that, to the best of my abilities, due care and a 87-gallon per minute pump station with etry, and a portable generator receptacle with main, and in conformity with the project plans, tently filed and approved. I certify that the filt within substantial compliance and intent of
ng ma th n: eti na