



July 14, 2023

Ms. A. Shonta Dunston, Chief Clerk
North Carolina Utilities Commission
4325 Mail Service Center
Raleigh, NC 27699-4325

Via Electronic Delivery

Re: W-218, Sub 592
The Sanctuary at Lake Wheeler
Water
Wake County

Dear Ms. Dunston:

Please find attached the amended service area page for The Sanctuary at Lake Wheeler in Wake County.

If you have any questions, please contact me at 919-653-6963.

Sincerely,

A handwritten signature in cursive script that reads "Barbara Brantley".

Barbara Brantley
New Business Coordinator

OFFICIAL COPY

Jul 14 2023

SERVICE AREA

Fill in one column for each subdivision or service area. If more columns are needed for additional subdivisions or service areas, attach supplementary sheets.

		New System	Existing System
1.	Name of subdivision or service area	The Sanctuary at Lake Wheeler	
2.	County (or Counties)	Wake	
3.	Type of Service (water, sewer, etc.)	Water	
4.	If water is purchased, list from whom	N/A	
5.	Source of water supply (wells, etc.)	Well	
6.	Number of wells in service	1	
7.	Pumping capacity of each pump in service	48 gpm	
8.	Elevated storage tank capacity (gals.)	N/A	
9.	Pressure tank capacity (gals.)	7,500 gallons	
10.	Types of water treatment (chlorine, etc.)	Fe/Mn Filtration; NaClO	
11.	Number of hydrants installed	N/A	
12.	Is sewage disposal by septic tanks or by sewer system?	Septic	
13.	If disposal is by sewer system, is sewage treated by utility company or by others?	N/A	
14.	Capacity of company's sewage treatment plant (gallons per day)	N/A	
15.	Is service metered? (yes or no)	Yes	
16.	Number of water meters in use	0	
17.	Number of service taps in use (List number of each size)	Water 43 - 3/4"	
		Sewer N/A	
18.	Number of customers at the end of test year	Water 13 Sewer N/A	
19.	Number of customers that can be served by mains already installed (including present customers, vacant lots, etc.)	Water 13 Sewer N/A	
20.	Number of customers that can be served by pumping capacity	Water 86 @ 0.555pgm/lot	
21.	Number of customers that can be served by storage tank capacity	Water 144	
22.	Number of customers that can be served by treatment plant capacity	Sewer N/A	
23.	Name nearest water/sewer utility system	Millstone Landing	N/A
24.	Distance to nearest water/sewer utility system	<0.5 miles	N/A
25.	Does any other person or utility seek to furnish the service(s) proposed herein? (yes or no)	No	No
26.	a. DEHNR System I.D. No.	Water NC4092207	
	b. NPDES or Nondischarge Permit No.	Sewer N/A	N/A