

PUBLIC / REDACTED

**STATE OF NORTH CAROLINA
UTILITIES COMMISSION
RALEIGH**

In the Matter of
Biennial Consolidated Carbon Plan and)
Integrated Resource Plans of Duke)
Energy Carolinas, LLC, and Duke) Docket No. E-100, Sub 190
Energy Progress, LLC, Pursuant to)
N.C.G.S. § 62-110.9 and§ 62-110.1(c)

DIRECT TESTIMONY OF
JOHN MICHAEL HAGERTY

ON BEHALF OF
**CAROLINAS CLEAN ENERGY BUSINESS
ASSOCIATION**

MAY 28, 2024

OFFICIAL COPY

May 29 2024

TABLE OF CONTENTS

I. Duke’s Filing Demonstrates that Solar PV and Storage are Cost Effective Components of All Least Cost Resource Portfolios5

II. Proactive Transmission Planning is Key to Keeping Ratepayer Costs Low16

III. Effective Implementation of MVST Will Support Identification of Proactive Transmission Upgrades24

IV. Proactive Transmission Planning Will Improve Generation Interconnection and Resource Planning.....33

STATE OF NORTH CAROLINA
UTILITIES COMMISSION
RALEIGH

DOCKET NO. E-100, SUB 190

BEFORE THE NORTH CAROLINA UTILITIES COMMISSION

In the Matter of)	DIRECT TESTIMONY OF JOHN MICHAEL HAGERTY ON BEHALF OF CAROLINAS CLEAN ENERGY BUSINESS ASSOCIATION
Biennial Consolidated Carbon Plan and)	
Integrated Resource Plans of Duke)	
Energy Carolinas, LLC, and Duke)	
Energy Progress, LLC, Pursuant to)	
N.C.G.S. § 62-110.9 and § 62-110.1(c))	

1 **Q: PLEASE STATE YOUR NAME, JOB TITLE, EMPLOYER AND BUSINESS**
2 **ADDRESS.**

3 A: My name is John Michael Hagerty. I am a Principal at The Brattle Group. My
4 business address is 1800 M Street Northwest, Washington, DC 20036.

5 **Q: PLEASE SUMMARIZE YOUR EDUCATIONAL BACKGROUND AND**
6 **PROFESSIONAL QUALIFICATIONS.**

7 A: I earned an M.S. in Technology and Policy from the Massachusetts Institute of
8 Technology and a B.S. in Chemical Engineering from the University of Notre
9 Dame. I have 11 years of experience at The Brattle Group in utility and electric
10 power industry planning and regulatory analysis, including utility resource
11 planning, transmission planning, valuation of renewable energy, storage, and
12 transmission assets, wholesale market design to achieve resource adequacy
13 requirements, and optimized approaches to economy-wide deep decarbonization.

14 Since 2021, I have analyzed the future resource needs in the Duke Energy
15 Carolinas (“DEC”) and Duke Energy Progress (“DEP”) service territories

OFFICIAL COPY
May 29 2024

1 (collectively referred to as “Duke”) to reliably serve load and achieve the policy
2 objectives included in House Bill 951 (“HB 951”) of reducing carbon dioxide
3 emissions from generation resources located in North Carolina by 70% relative to
4 2005 emissions. I have also actively participated in the 2023 and 2024 North
5 Carolina Transmission Planning Collaborate (“NCTPC”) transmission planning
6 studies.

7 In addition to my experience in North Carolina, I have experience
8 supporting transmission developers, generation developers, utilities, state
9 regulators and agencies, and regional transmission operators with transmission
10 planning processes and benefits analyses in CAISO, ERCOT, SPP, MISO,
11 NYISO, PJM and ISO-NE. I have recently also evaluated interconnection
12 processes across the country.

13 **Q: WHAT ARE YOUR RESPONSIBILITIES IN YOUR CURRENT**
14 **POSITION?**

15 A: I provide economic and financial analysis for a broad set of clients in the electric
16 utility industry that are mostly focused on the drivers for new infrastructure
17 investment in a decarbonizing world, including renewable energy and gas-fired
18 generation resources as well as transmission assets. My clients include electric
19 utilities, renewable energy and storage developers, transmission developers,
20 system operators, environmental organizations, and state agencies.

21 **Q: HAVE YOU PREVIOUSLY TESTIFIED BEFORE THE COMMISSION?**

1 A: Yes, I testified previously before the North Carolina Utility Commission in
2 Docket No. E-100, Sub 179, concerning the 2022 Biennial Integrated Resource
3 Plan and Carbon Plan on behalf of the Clean Power Suppliers Association.

4 **Q: ON WHOSE BEHALF ARE YOU TESTIFYING?**

5 A: The Carolinas Clean Energy Business Association (CCEBA).

6 **Q: ARE YOU SUBMITTING ANY EXHIBITS WITH YOUR TESTIMONY?**

7 A: I have attached my CV as Exhibit A. All other references are cited in text with
8 hyperlinks.

9 **Q: WHAT IS THE PURPOSE OF YOUR DIRECT TESTIMONY?**

10 A: The purpose of my testimony is to: (1) demonstrate based on Duke’s resource
11 planning analysis, that large-scale additions of solar photovoltaic (“PV”)
12 generation and battery storage resources currently are and are projected to remain
13 an essential resource in least-cost portfolios that achieve the requirements of HB
14 951 in the best interest of Duke’s ratepayers; and (2) identify opportunities for
15 Duke to improve its transmission planning and interconnection processes that will
16 lower customer costs by proactively identifying transmission upgrades, shortening
17 and de-risking the generation interconnection, and increasing access to cost-
18 effective resources.

19 **Q: PLEASE PROVIDE A BRIEF SUMMARY OF YOUR CONCLUSIONS.**

20 A: My testimony reaches the following conclusions:

- 21 ▶ Solar PV and battery storage are cost effective resources in the Duke system
22 now and through 2035;

- 1 ▶ Additional solar PV beyond the amount in Duke’s portfolios will further
2 reduce ratepayer costs if Duke can increase the rate at which those resources
3 are added to its system;
- 4 ▶ Duke limits solar PV interconnection rate due to its analysis of constraints on
5 the existing transmission system and the pace at which it can upgrade its
6 system to interconnect new resources;
- 7 ▶ With the Commission’s support, Duke has improved its transmission planning
8 and interconnection processes to enable more rapid and lower cost additions
9 of solar PV and battery storage, including through the development of Red
10 Zone Expansion Plan ("RZEP") projects and the addition of the Multi-Value
11 Strategic Transmission ("MVST") planning process;
- 12 ▶ Duke has not coordinated the future resource mix identified in its resource
13 planning modeling with the transmission planning studies to identify cost-
14 effective upgrades in advance of need, which results in the Duke system being
15 perpetually constrained when new resources request interconnection;
- 16 ▶ Duke can further improve its transmission planning and interconnection
17 processes by proactively identifying transmission investments that result in
18 lower total costs to ratepayers, leveraging best practices from the
19 Midcontinent Independent System Operator ("MISO") and the Southwest
20 Power Pool ("SPP") and others;
- 21 ▶ Effective implementation of the MVST planning processes will be critical to
22 meeting the future system needs at least cost to ratepayers, for the following
23 reasons;

- 1 • Improved transmission planning that adds proactive transmission upgrades
- 2 to Duke’s annual transmission plan will create needed headroom on
- 3 Duke’s system;
- 4 • Additional headroom built in advance of interconnection requests will
- 5 reduce schedule and costs risks of interconnecting solar PV up to Duke’s
- 6 solar PV interconnection limits, and ultimately allow for the
- 7 interconnection of higher volumes of cost-effective solar PV;
- 8 • Implementing the MVST effectively should shift the identification of cost-
- 9 effective transmission upgrades, like the RZEP projects and future
- 10 proactive upgrades, from the near-term, just-in-time interconnection
- 11 process to a more efficient long-term proactive planning process;
- 12 ▶ The Commission has already played a key role in identifying the need for
- 13 Duke to improve its transmission planning and interconnection processes and
- 14 should continue to oversee and as needed scrutinize the implementation phase
- 15 to ensure that cost effective upgrades are identified and constructed to reduce
- 16 ratepayer costs.

17 **I. DUKE’S FILING DEMONSTRATES THAT SOLAR PV AND STORAGE**

18 **ARE COST EFFECTIVE COMPONENTS OF ALL LEAST COST**

19 **RESOURCE PORTFOLIOS**


20 **Q: PLEASE SUMMARIZE THE NEW SOLAR PV AND BATTERY STORAGE**

21 **CAPACITY THAT DUKE INCLUDES IN ITS 2023 CAROLINAS**

22 **RESOURCE PLAN PORTFOLIOS.**

1 A: In the 2023 Carolinas Resource Plan, Duke projects several future resource
2 portfolios that most cost effectively meet customers' electricity needs, subject to
3 carbon dioxide emission requirements and transmission-related constraints. All of
4 the portfolios in the base analysis (P1 Base, P2 Base, and P3 Base) and
5 supplemental analysis (P3 Fall Base) include large amounts of new solar PV and
6 battery storage. By 2035, the total solar PV additions range from 11,800 MW in
7 P2 Base to 14,900 MW in P1 Base, as shown in Figure 1 below. The P3 Fall Base
8 portfolio developed in Duke's supplemental analysis includes 12,600 MW of
9 solar PV by 2035.

10 **FIGURE 1: SOLAR PV CAPACITY ADDITIONS BY PORTFOLIO (MW)**




11
12 The difference in the total solar PV additions across the scenarios is driven
13 by two factors: (1) the target date for achieving 70% reductions; and (2) the
14 annual limit Duke sets on new solar PV additions. The most solar PV is built in
15 P1 Base with the earliest date for achieving the policy objective and the highest
16 annual build limit. However, in all of these portfolios, Duke's economic modeling

1 selects large capacity of solar PV additions over an eight-year period from 2028
 2 to 2035 with annual additions ranging from [REDACTED] to [REDACTED] per year up
 3 to the target HB 951 compliance date.

4 Duke’s modeling caps the annual addition of new solar PV additions
 5 based on Duke’s consideration of its ability to interconnect solar capacity each
 6 year, and not based on its analysis of whether additional solar is cost-effective to
 7 build. For example, the figure below shows that in the P3 Base case, the annual
 8 solar additions (yellow bars) were equal to the interconnection cap (brown dashed
 9 line) in each year: 1,350 MW per year in 2028 to 2030 and 1,575 MW per year in
 10 2031 to 2035. Duke’s modeling economically chooses solar volumes right up to
 11 the assumed interconnection limit indicating that solar PV is cost effective and
 12 that the model would economically select more solar PV if allowed.

13 **FIGURE 2: P3 BASE SOLAR PV ADDITIONS VERSUS ANNUAL INTERCONNECTION**
 14 **CAP**



15 Duke’s modeling also shows that battery storage is an essential component
 16 of least-cost portfolios for the future Duke system. By 2035, Duke’s modeling
 17 projects 4,300 MW of battery storage in P3 Base, 6,700 MW in P2 Base, and
 18

1 5,100 MW in P3 Fall Base. Because battery storage is added as a cost-effective
2 resource to achieve Duke's reserve requirements, annual battery storage additions
3 vary more year-to-year than solar and appear to depend on annual coal plant
4 retirements, natural gas additions and load growth.

5 **Q: DOES DUKE'S ANALYSIS ACCOUNT FOR THE COST INCREASES IN**
6 **GENERATING RESOURCES, INCLUDING SOLAR PV AND BATTERY**
7 **STORAGE, OVER THE PAST SEVERAL YEARS?**

8 A: Yes, Duke included updated cost assumptions for all of the resources included in
9 its analysis. For solar PV, Duke updated its 2023 capital cost estimate based on
10 recent cost analysis by Burns & McDonnell that was cross-checked with costs for
11 solar PV projects in Duke's territory submitted into the 2022 solar procurement
12 process.¹ For projecting future costs, Duke developed a cost trend forecast based
13 on several sources, including the 2023 Energy Information Administration Annual
14 Energy Outlook (EIA AEO) cost projections, and cost decline curves developed
15 by Guidehouse and EPRI. Duke further updated solar capital costs for the
16 supplemental analysis to reflect the most recent market trends based on cost
17 information from the 2023 Solar Request for Proposal submissions.²

18 Based on these considerations, the projected capital costs in the 2023
19 Carolinas Resource Plan for new solar PV entering in 2028 to 2035 are REDACTED

¹ Duke, 2023 Carolinas Resource Plan, Appendix E: Screening of Generation Alternatives, 2023, pp. 7-8.

² Duke, 2023 Carolinas Resource Plan, Supplemental Planning Analysis, 2024, p. 23

1 higher than solar PV capital costs in the 2022 Carbon Plan analysis.³ Battery
2 storage costs are projected to be [REDACTED] higher, all in nominal terms.

3 The projected 2024 costs of gas-fired combined-cycle, gas-fired
4 combustion turbines, offshore wind, and onshore wind have all increased from the
5 2022 Carbon Plan analysis. Duke assumes that the cost of these resources returns
6 to previously projected costs by 2026 but assumes that solar and storage remain
7 elevated relative to the earlier projections. This treatment is inconsistent about the
8 common cost drivers amongst technologies including materials, electrical
9 equipment, labor, and general inflation. It is also inconsistent with PJM's latest
10 Cost of New Entry study conducted by The Brattle Group and Sargent & Lundy,
11 which projects gas-fired generation resource costs to continue to increase with
12 inflation at least through the 2026-2027 delivery year (and the indexes for
13 materials, equipment, and labor the studies identified for updating the costs over
14 time have also continued to increase).⁴ In my view, Duke's assumptions result in
15 an overly optimistic outlook for the costs of resources other than solar PV and
16 battery storage.

17 **Q: HAVE THESE COST INCREASES CHANGED THE OUTLOOK THAT**
18 **LARGE VOLUMES OF SOLAR PV AND BATTERY STORAGE ARE**
19 **ECONOMICALLY SELECTED AS MAJOR COMPONENTS OF ALL**
20 **COMPLIANT PORTFOLIOS?**

³ For example, the projected capital costs for Solar PV bifacial single axis tracking entering in 2032 in the 2023 Carolinas Resource Plan is [REDACTED] compared to [REDACTED] in the 2022 Carbon Plan.

⁴ Newell, Samuel, et al., [PJM CONE 2026/2027 Report](#), April 21 2022.

1 A: No. Accounting for the recent costs for solar PV and battery storage reflected in
2 the 2022 and 2023 procurements, solar PV and battery storage remain cost-
3 effective resources in the Duke system and essential components to least-cost
4 compliance portfolios. In fact, solar resources are selected and built up to the
5 maximum annual interconnection limit that Duke sets on new solar additions in
6 every year and every portfolio up to that portfolios HB 951 compliance date, with
7 the exception of 2030 in the P3 Fall Base when [REDACTED] is added, [REDACTED] less
8 than the limit. Duke's modeling selects this scale of solar PV and other resources
9 for the portfolios because those resources are critical components of meeting the
10 reliability requirements and emissions requirements at least cost to ratepayers.

11 Further, by selecting the maximum amount of solar PV up to the annual
12 interconnection, Duke's modeling demonstrates not only that the amount of solar
13 PV included in the portfolios is cost effective but that even more would be cost
14 effective, if it were possible for Duke to add more to its system (and Duke's
15 model were to allow it). That is, in the absence of a limit on solar builds or in the
16 case with a higher limit, Duke's modeling would select an even higher amount of
17 solar PV to enter and avoid the need for higher cost resources.

18 **Q: WHY DOES DUKE'S MODELING SELECT LARGE VOLUMES OF**
19 **SOLAR PV AS A COST-EFFECTIVE RESOURCE IN ALL OF THE**
20 **LEAST-COST COMPLIANCE PORTFOLIOS?**

21 A: Duke's modeling selects the large volumes of solar PV I noted above because
22 solar PV is one of the least cost sources of generation overall and the least cost
23 source of zero carbon generation resources. [REDACTED] below shows the levelized

1 costs of generation and transmission of solar PV, onshore wind, offshore wind,
2 and nuclear SMRs based on Duke’s assumed capital costs.^{5,6} The levelized costs
3 shown here are an indication of the relative cost effectiveness of alternative
4 resource types, but it does not account for operational characteristics of each
5 resource other than its annual projected output and each resource’s contribution to
6 reserve requirements. However, as clean energy resources are entering to provide
7 low-cost, low-carbon generation to the Duke system to meet carbon dioxide
8 emissions limits, solar PV’s low levelized costs supports the Duke system reduce
9 emissions at least cost to ratepayers.

10 [REDACTED]

11 [REDACTED]

12 [REDACTED]

13 [REDACTED]

⁵ Confidential Data Response to PSDR2-11 and PSDR6-9.

⁶ Duke, 2023 Carolinas Resource Plan, Appendix C: Quantitative Analysis, 2023, Figure C-34

1 Solar PV is also the only zero-carbon clean energy resource currently
2 deployed at scale in the Duke service territory. The 2023 interconnection studies
3 (Resource Solicitation Cluster and DISIS) in DEC and DEP include about 3,000
4 MW of solar PV capacity and no capacity for onshore wind, offshore wind, or
5 nuclear SMR.⁷ Less than 20 MW of biomass and hydro are included in the latest
6 interconnection studies.

7 **Q: ARE YOU SAYING THAT DUKE CAN MEET THE REQUIREMENTS OF**
8 **HB 951 IN A LEAST-COST MANNER WITH SOLAR PV ALONE?**

9 **A:** No. Certainly not. It is clear that other resources provide benefits that solar PV
10 cannot on its own provide. However, solar PV is the cheapest source of carbon-
11 free electrons on the grid now and for the foreseeable future. All things being
12 equal, the more generation (in kWhs) that Duke can get from solar PV instead of
13 other resources, the cheaper it will be for Duke to comply with carbon reduction
14 targets.

15 **Q: DID YOU REVIEW THE RESULTS OF THE PORTFOLIOS WITH NO**
16 **CARBON CONSTRAINTS?**

⁷ Interconnection study reports accessed via OASIS websites for [DEC](http://www.oasis.oati.com/duk/) (<http://www.oasis.oati.com/duk/>) and [DEP](http://www.oasis.oati.com/cpl/) (<http://www.oasis.oati.com/cpl/>). Specific reports can be accessed: [http://www.oasis.oati.com/woa/docs/DUK/DUKdocs/DEC_2023_Resource_Solicitation_Cluster_\(Phase_1\)_Report.pdf](http://www.oasis.oati.com/woa/docs/DUK/DUKdocs/DEC_2023_Resource_Solicitation_Cluster_(Phase_1)_Report.pdf); [https://www.oasis.oati.com/woa/docs/CPL/CPLdocs/2023_DEP_Resource_Solicitation_Cluster_\(Phase_1\)_Study_Report.pdf](https://www.oasis.oati.com/woa/docs/CPL/CPLdocs/2023_DEP_Resource_Solicitation_Cluster_(Phase_1)_Study_Report.pdf); http://www.oasis.oati.com/woa/docs/CPL/CPLdocs/DEP_DISIS_2023_Phase_2_Study_Report.pdf; [http://www.oasis.oati.com/woa/docs/DUK/DUKdocs/2023_DEC_Definitive_Interconnection_System_Impact_Study_Cluster_\(Phase_2\)_Report.pdf](http://www.oasis.oati.com/woa/docs/DUK/DUKdocs/2023_DEC_Definitive_Interconnection_System_Impact_Study_Cluster_(Phase_2)_Report.pdf).

1 A: Yes, I reviewed the results of the No Carbon Constraints Supplemental Portfolio
2 and the SP SC No CO2 Constraints Fall Supplemental Portfolio. At the request of
3 the South Carolina Public Service Commission, Duke simulated its future power
4 system without the limit on carbon dioxide emissions generation facilities in
5 North Carolina required by H591. Both portfolios are very different from the
6 portfolios discussed above that meet the goals of HB 951, with 12 to 13 GW less
7 solar, no nuclear SMRs, and 5 to 7 GW more gas-fired capacity compared to
8 portfolios with the carbon constraint, and higher emissions than what is allowed
9 by HB 951.^{8,9}

10 **Q: DOES REMOVING CARBON CONSTRAINTS FROM THE MODEL**
11 **RESULT IN SIGNIFICANT COST SAVINGS TO RATEPAYERS?**

12 A: No, it does not. Replacing solar PV and other clean energy resources primarily
13 with gas-fired capacity, as Duke's modeling does in the No Carbon Constraints
14 Supplemental Portfolio, results in an estimated 1.5% reduction in costs to
15 ratepayers compared to the P3 Base case, as shown in Figure 4 below.¹⁰ However,
16 the No Carbon Constraints Supplemental Portfolio exposes Duke's ratepayers to
17 the significant risk of higher costs. For example, Duke's sensitivity analysis for
18 P3 Base demonstrates that natural gas commodity price risk in the P3 Base
19 portfolio greatly exceeds the relatively minor base case cost savings shown in the

⁸ Duke, 2023 Carolinas Resource Plan, Supplemental Planning Analysis Technical Appendix, 2024.

⁹ Duke, 2023 Carolinas Resource Plan, Appendix C: Quantitative Analysis, 2023, p. 101

¹⁰ Duke, 2023 Carolinas Resource Plan, Appendix C: Quantitative Analysis, 2023, p. 101. The No Carbon Constraints Supplemental Portfolio present value of revenue requirements ("PVRR") are about \$65 billion through 2038, which is 1.5% lower than the P3 Base PVRR of \$66 billion.

1 No Carbon Constraints Supplemental Portfolio.¹¹ The P3 Base Capital/High Fuel
2 sensitivity case assumes higher gas costs [REDACTED] from 2028
3 to 2040 exposing ratepayers to [REDACTED] in higher costs than the case with base
4 case with gas costs [REDACTED] an [REDACTED] increase in ratepayer costs
5 (compared to the [REDACTED] cost savings without a carbon constraint).¹² But, this is an
6 underestimate of the natural gas cost risks to ratepayers of the No Carbon
7 Constraints Supplemental Portfolio. The No Carbon Constraints Supplemental
8 Portfolio has much higher natural gas demand than the P3 Base portfolio ([REDACTED]
9 [REDACTED]) which makes it even more sensitive to
10 gas price spikes.¹³ Indeed, such spikes in natural gas commodity prices have
11 happened in recent years, with Henry Hub natural gas prices in 2022 remaining on
12 average over \$6/MMBtu for the full year.¹⁴

13 By contrast, portfolios *with* the carbon constraints in line with HB 951
14 include more renewable and nuclear resources that provide ratepayers a valuable
15 hedge against volatility in their electricity bills with fluctuations in natural gas
16 commodity prices, in addition to lowering carbon dioxide emissions and local air
17 pollutants.


¹¹ Duke, 2023 Carolinas Resource Plan, Appendix C: Quantitative Analysis, 2023, p. 91.

¹² Modeled natural gas prices are calculated from the EnCompass output files.

¹³ Natural gas demand is calculated from the EnCompass output files.

¹⁴ U.S. Energy Information Administration, [Henry Hub Natural Gas Spot Price](#), May 22, 2024.

1 **FIGURE 4: PVRR THROUGH 2038 OF P3 BASE SENSITIVITY CASES (\$ BILLION)**



2
3 Source: Duke, 2023 Carolinas Resource Plan Appendix C Quantitative Analysis, 2023, p.

4 91.

5 The SP SC No CO2 Constraints Fall Supplemental Portfolio results in
6 slightly higher cost savings relative to the P3 Fall Base Portfolio of about 5%.¹⁵
7 But the increased demand for national gas will further expose Duke ratepayers to
8 the gas price risk noted above. Duke did not complete similar sensitivity analysis
9 of the P3 Fall Base portfolio at higher and lower national gas prices to
10 demonstrate the scale of the natural gas cost risks to ratepayers.

¹⁵ Duke, 2023 Carolinas Resource Plan, Supplemental Planning Analysis Technical Appendix, 2024, pp. 8, 16.

1 **II. PROACTIVE TRANSMISSION PLANNING IS KEY TO KEEPING**
2 **RATEPAYER COSTS LOW**

3 **Q: WHAT ARE THE INTERCONNECTION AND TRANSMISSION**
4 **BARRIERS TO ADDING MORE ECONOMIC SOLAR TO DUKE’S**
5 **SYSTEM?**

6 A: As noted above, Duke’s models would select even higher volumes of solar if
7 allowed to do so, but Duke caps the annual solar PV interconnection rate based on
8 its assessment of the limitations it faces in interconnecting new solar PV capacity.
9 Duke identifies the number of transmission outages required for interconnecting
10 new solar PV during the spring and fall seasons as the key limiting factor.¹⁶
11 However, Duke cites two factors in its supplemental analysis that will increase the
12 maximum interconnection rate of solar additions. First, Duke increases the
13 interconnection rate in the supplemental analysis from 1,350 MW to 1,575 MW in
14 2031 based on “continued success in proactively achieving transmission additions
15 through the Red Zone Expansion Project 2.0 projects.”¹⁷ Second, Duke supports
16 increasing the interconnection rate further to 1,800 MW per year in 2032 if
17 developers can increase the size of new renewable energy capacity to limit the
18 number of interconnections required.¹⁸

¹⁶ Duke, 2023 Carolinas Resource Plan, Appendix L Transmission System Planning and Grid Transformation, 2023, pp. 20-21. Duke provides limited information to assess the validity of this claim, including the basis for the amount of line outages that would be required for interconnecting solar resources, the amount of time needed for those outages, and the amount of time they have available for additional interconnection-related outages.

¹⁷ Duke, 2023 Carolinas Resource Plan, Supplemental Planning Analysis, 2024, p. 25.

¹⁸ Duke, 2023 Carolinas Resource Plan, Supplemental Planning Analysis, 2024, p. 25.

1 **Q: WHAT APPROACHES CAN DUKE TAKE TO EASE THE CHALLENGES**
2 **OF INTERCONNECTING COST-EFFECTIVE NEW RESOURCES,**
3 **INCLUDING SOLAR PV?**

4 **A:** Duke has recently made several significant improvements to its transmission
5 planning and interconnection processes, many at the urging of the Commission,
6 including the development of RZEP projects, implementation of cluster studies in
7 the interconnection process (including a separate cluster for its solar PV
8 solicitations), and the introduction of the MVST planning process. Changes to its
9 interconnection study process have reduced the amount of time required to
10 complete interconnection studies from four years to two years.¹⁹ Building on
11 these improvements, Duke should continue to implement these processes
12 effectively and make additional changes to its processes to improve its ability to
13 incorporate cost-effective resources into its system and reduce ratepayer costs
14 while achieving the carbon dioxide emissions reductions goals.

15 In particular, Duke needs to proactively plan its transmission system for
16 the future market conditions identified in the 2023 Carolinas Resource Plan
17 portfolios, incorporating both the projected changes in demand and the resource
18 mix into its planning studies. Up to now, Duke has not coordinated the future
19 resource mix identified in its resource planning modeling with the transmission
20 planning studies to identify cost effective upgrades in advance of need. This
21 approach results in a perpetually constrained system that has to play “catch-up”

¹⁹ Direct Testimony of Dewey S. Roberts and Jing Shi on Behalf of Duke Energy Carolinas, LLC and Duke Energy Progress, LLC (“Roberts & Shi”), Docket No. E-100, Sub 190, September 1, 2023, p. 23.

1 when new resources are studied in the interconnection process, particularly in the
2 areas of the system with the most development opportunities. As discussed below,
3 a proactive approach should enable higher volumes of interconnection at lower
4 costs to ratepayers. In addition, as discussed in CCEBA witness Miller's
5 testimony, solar PV QFs with expiring PPAs offer an opportunity for using
6 existing interconnections to expand grid resources at lower cost and with shorter
7 timelines. Duke should also continue to seek ways to improve its interconnection
8 process to identify only the upgrades needed to deliver output to the system, rely
9 on lower-cost approaches to providing reliable delivery than building
10 transmission upgrades, and improve its approach to outage coordination.

11 **Q: HOW DOES DUKE CURRENTLY IDENTIFY THE NECESSARY**
12 **TRANSMISSION UPGRADES TO ACCOMMODATE NEW RESOURCES?**

13 A: Duke currently does not study in its transmission planning process how to cost
14 effectively build out its system to accommodate new resources in the 2023
15 Carolinas Resource Plan portfolios, but instead identifies necessary upgrades for
16 new resources through the interconnection process. When resources seek
17 interconnection into a system with limited available headroom, interconnection
18 studies become more complicated and take more time, creating schedule and cost
19 uncertainty for developers and delaying the addition of cost-effective resources. I
20 agree with Duke witnesses Roberts and Shi on this point.²⁰ Once the necessary

²⁰ “[T]he Companies also anticipate that the pace, scope, and scale of the significant resource additions identified as needed in the CPIRP will drive increasingly complex interconnections and the need for significant transmission upgrades to enable these generator interconnections.” Roberts & Shi, p. 22.

1 upgrades are identified in the interconnection studies, Duke must then build those
2 upgrades prior to the new resources coming online, adding the potential for
3 additional delays in interconnecting cost-effective resources.

4 Recently, Duke has identified two portfolios of RZEP projects based on
5 the upgrades that have been repeatedly identified in interconnection studies as
6 necessary upgrades to integrate new resources. The RZEP projects are near-term
7 proactive projects that reflect system needs for the scale and location of resources
8 included in recent cluster studies and will ease the interconnection of those
9 resources and potentially more in the future. I fully support the use of
10 interconnection studies to identify RZEP network upgrades that provide broader
11 benefits to the system. However, relying solely on this “bottom-up” process is
12 inherently reactive and will not identify the longer-term needs of the transmission
13 system and opportunities to improve it at scale. Using the interconnection process
14 alone to identify network upgrades also slows down the interconnection process
15 and increase the development timeframe for solar PV projects substantially.

16 By contrast, the NCTPC 2023 Public Policy Study identified upgrades
17 necessary to interconnect over 14 GW of new solar PV, onshore wind, and
18 offshore wind resources.²¹ Duke used the 2023 Public Policy study to validate the
19 projects included in both the RZEP 1.0 portfolio and the RZEP 2.0 portfolio, but

²¹ North Carolina Transmission Planning Collaborative, [Report on the NCTPC 2023 Public Policy Study](http://www.nctpc.org/nctpc/document/REF/2024-05-17/NCTPC%202023%20Public%20Policy%20Study%20Draft%20Report%2005172024.pdf), Draft Report, May 17, 2024 (<http://www.nctpc.org/nctpc/document/REF/2024-05-17/NCTPC 2023 Public Policy Study Draft%20Report%2005172024.pdf>).

1 did not identify additional long-term proactive upgrades based solely on the 2023
2 Public Policy study.²²

3 **Q: SHOULD INTERCONNECTION STUDIES BE THE PRIMARY SOURCE**
4 **OF IDENTIFYING THE TRANSMISSION UPGRADES NEEDED FOR**
5 **NEW RESOURCE ADDITIONS?**

6 A: No. Relying primarily on the interconnection process to identify transmission
7 upgrades will result in higher costs to customers because it builds the system out
8 in a piecemeal fashion, studying the system needs only for the deliverability of a
9 specific set of resources. Instead, areas that are constantly constrained and
10 specific upgrades repeatedly identified as necessary in the interconnection study
11 process should be incorporated into and evaluated in the long-term proactive
12 planning process along with other driver of long-term transmission expansion
13 value.

14 **Q: CAN YOU PLEASE EXPLAIN A MORE COST-EFFECTIVE APPROACH**
15 **TO PLANNING THE FUTURE TRANSMISSION SYSTEM?**

16 A: Duke should instead identify and build cost effective, least-regrets transmission
17 upgrades through a longer-term, proactive transmission planning process that: (1)
18 incorporates the full set of resources needed to achieve future reliability and
19 policy requirements rather than just the next set of resources that are seeking
20 interconnection to the system; (2) considers a broader range of benefits of
21 transmission upgrades, such as reducing system congestion and other cost savings

²² Following the 2023 Public Policy study, the NCTPC added a project to the RZEP 2.0 portfolio that had previously been identified as needed in interconnection studies.

1 for ratepayers; and (3) creates headroom on the system in advance of the
2 resources seeking interconnection. The transmission planning process should
3 focus on identifying system-level, least-regrets upgrades that are beneficial across
4 a range of future scenarios and support the delivery of multiple future resource
5 additions.

6 Proactively planning and building upgrades will have several benefits to
7 Duke ratepayers. First, proactive planning reduces the total costs of upgrades by
8 finding larger scale, more cost-effective upgrades that support wider set of new
9 resources. Second, it streamlines the interconnection process by creating
10 headroom on the system prior to interconnection requests, so that interconnection
11 studies are simpler and resources can utilize the newly created headroom on the
12 system that has been built (or in the process of being built). Interconnection
13 studies would then primarily identify local interconnection facilities at the point
14 of interconnection. Third, by implementing proactive transmission planning,
15 Duke can foresee the upgrades needed to meet future goals and build out the
16 facilities in advance of need, instead of having to build the facilities “just in time”
17 to interconnect new resources.

18 By planning ahead and reducing the total amount of required upgrades,
19 proactive planning will require fewer outages. Duke witnesses Roberts and Shi
20 came to the same conclusions on the benefits of proactive planning for improving
21 the interconnection process: “The real-world limitations on generator
22 interconnections required to execute the resource additions identified in the Plan
23 can be reduced through interconnecting larger facilities and through strategic

1 identification and proactive construction of transmission network upgrades that
2 enable a more efficient interconnection process.”²³

3 **Q: HAS PROACTIVE TRANSMISSION PLANNING PROVIDED**
4 **RATEPAYER BENEFITS AND SAVINGS ELSEWHERE?**


5 A: Yes. The benefits of proactive transmission planning have been demonstrated
6 across multiple transmission planning studies and planning regions. MISO has
7 been studying the long-term benefits of proactive upgrades on its system since
8 2010 and approved an initial set of Multi-Value Projects (“MVP”) in 2011 that
9 provide a broad range of benefits to its system. Importantly, MISO has continued
10 to confirm net benefits of the MVP projects to its system since they were initially
11 approved through triennial reviews. MISO recently re-started its proactive
12 planning through its Long-Range Transmission Planning (“LRTP”) process and
13 identified portfolio of Tranche 1 upgrades that provide benefits that are 2.6 – 4.1
14 times the costs across the northern portion of its system.²⁴ That means for every
15 dollar ratepayers will spend on Tranche 1 transmission upgrades will result in
16 \$2.60 - \$4.10 of ratepayer cost savings from lower production costs, lower capital
17 costs for new generation, avoided reliability outages, and avoided future
18 transmission project costs.

²³ Roberts & Shi, p. 21.

²⁴ MISO, [MTEP21 Report Addendum: Long Range Transmission Planning Tranche 1: Executive Summary](https://cdn.misoenergy.org/MTEP21%20Addendum-LRTP%20Tranche%201%20Report%20with%20Executive%20Summary625790.pdf), 2022, p. 3 (<https://cdn.misoenergy.org/MTEP21%20Addendum-LRTP%20Tranche%201%20Report%20with%20Executive%20Summary625790.pdf>).

1 The figure below highlights seven cases across a broad set of planning
 2 regions, including MISO, SPP, NYISO, CAISO, and ATC in Wisconsin, in which
 3 proactive transmission planning have identified beneficial transmission projects or
 4 portfolios of projects through a multi-value framework. My colleagues and I
 5 documented the industry's experience in proactive transmission planning in the
 6 report *Transmission Planning for the 21st Century: Proven Practices that*
 7 *Increase Value and Reduce Costs* that is included as an exhibit to my testimony.

8 **FIGURE 5: EXAMPLES OF BENEFICIAL PROACTIVE TRANSMISSION PLANNING**



9 Source: Pfeifenberger, Johannes, et al., [Transmission Planning for the 21st](#)
 10 [Century: Proven Practices that Increase Value and Reduce Costs](#), October
 11 2021, p. 33.

13 **Q: HOW CAN DUKE ENSURE THAT LONG-TERM PLANNING**
 14 **PROCESSES RESULT IN COST-EFFECTIVE UPGRADES WITHOUT**
 15 **KNOWING AT THE TIME EXACTLY WHICH RESOURCES WILL BE**
 16 **INTERCONNECTING TO THE SYSTEM?**

17 **A:** One of the primary challenges that transmission planners face with proactive
 18 planning is specifying the type and locations of the future resource mix that will

1 be necessary to meet its future system needs. In this case, Duke has already
2 developed several portfolios that can be studied in the transmission planning
3 process and identified high likelihood regions for development in previous
4 studies. Additional analysis will be necessary for identifying the future location of
5 resources and Duke can learn from the best practices utilized by other
6 transmission planning regions. Each of the planning entities noted above have
7 developed an approach to do so that resulted in sufficient buy in from its
8 stakeholders and regulators for approving the projects. Similar to its approach for
9 identifying near-term proactive RZEP projects, Duke will need to develop an
10 effective long-term planning process for identifying cost-effective, least-regrets
11 upgrades that will provide benefits to the system across a range of future
12 scenarios.

13 **III. EFFECTIVE IMPLEMENTATION OF MVST WILL SUPPORT**
14 **IDENTIFICATION OF PROACTIVE TRANSMISSION UPGRADES**

15 **Q: CAN DUKE IMPLEMENT A PROACTIVE PLANNING PROCESS**
16 **THROUGH THE MVST PROCESS?**

17 **A:** Yes, Duke developed the MVST process over the past two years with the support
18 of the Commission and had its tariff revisions for the MVST process approved by
19 the Federal Energy Regulatory Commission (“FERC”) earlier this year.²⁵ The
20 key aspects of the MVST include: an updated stakeholder meeting process to

²⁵ *Order Adopting Initial Carbon Plan and Providing Direction for Future Planning*, Docket No. E-100, Sub 179, December 30, 2022, at 134.

1 review assumptions, needs, and solutions; a forward-looking, proactive approach
2 to planning; the use of scenarios to account for different possible futures; and the
3 consideration of multiple benefits of transmission. Duke has a great opportunity
4 over the next year to improve its transmission planning process through the
5 development and completion of the first MVST planning process. In my
6 experience, the details of the implementation of the transmission planning process
7 are very important and will ultimately determine whether the MVST assists Duke
8 in the necessary transformation of its transmission system over the next 10-15
9 years.

10 **Q: DO YOU HAVE RECOMMENDATIONS FOR HOW DUKE CAN MAKE**
11 **THE MVST PROCESS AS EFFECTIVE AS POSSIBLE?**

12 A: Yes. Implementing an efficient and effective MVST process that identifies
13 proactive, multi-value transmission upgrades will be critical to cost effectively
14 transforming Duke's system for the projected changes in demand and resource
15 mix. Planning the transmission system to meet the future resource needs and
16 including cost-effective transmission upgrades into the annual transmission plan
17 will (1) reduce the total costs of the future power system to ratepayers, (2) create
18 headroom on the network to reduce the complexity and uncertainty of the
19 interconnection process, and (3) provide more accurate inputs into the resource
20 planning process.

21 There are several key elements for Duke, stakeholders, and the
22 Commission to focus on to make the MVST process as effective as possible.

23 These elements are based on recommendations in the report I co-authored titled

1 *Transmission Planning for the 21st Century: Proven Practices that Increase*
2 *Value and Reduce Costs.*²⁶

- 3 ▶ **Proactively plan for future generation and load** by incorporating realistic
4 projections of the anticipated generation mix, load levels, and load profiles
5 over the lifespan of the transmission investment. Developing a stakeholder-
6 vetted process for selecting the locations of new resources on the Duke system
7 will be important to building confidence that the identified transmission
8 upgrades are needed.
- 9 ▶ **Account for the full range of transmission projects' benefits** and use multi-
10 value planning to comprehensively identify investments that cost-effectively
11 address all categories of needs and benefits. As reported by the CTPC to the
12 Transmission Advisory Group in its May meeting, the first step of identifying
13 which benefit metrics to quantify in the MVST is underway, including
14 production cost savings, avoided energy losses, reliability benefits, avoided
15 generation capacity due to a reduction in peak losses, avoided transmission
16 upgrades, and avoided upgrades of end-of-life assets. In addition to these
17 benefit metrics, Duke should consider the benefits of providing access to
18 portions of its system that will reduce the costs of resources identified as
19 necessary in its resource planning process. The approaches that Duke uses for

²⁶ Pfeifenberger, Johannes, et al., [Transmission Planning for the 21st Century: Proven Practices that Increase Value and Reduce Costs](https://www.brattle.com/wp-content/uploads/2021/10/2021-10-12-Brattle-GridStrategies-Transmission-Planning-Report_v2.pdf), October 2021 (https://www.brattle.com/wp-content/uploads/2021/10/2021-10-12-Brattle-GridStrategies-Transmission-Planning-Report_v2.pdf).

1 analyzing each of these metrics will be important for accurately quantifying
2 the benefits of transmission projects.

3 ▶ **Address uncertainties and high-stress grid conditions explicitly through**
4 **scenario-based planning** that takes into account a broad range of plausible
5 long-term futures as well as real-world system conditions, including
6 challenging and extreme events. Incorporating the market events that tend to
7 stretch the capability of the system, including generation and transmission
8 outages and heat waves, will be a key input into quantification of benefits.
9 Duke should review recent challenging market conditions, such as Winter
10 Storm Elliot, and real-time uncertainty in demand or renewable generation to
11 capture the benefits of transmission under these circumstances.

12 ▶ **Use comprehensive transmission network portfolios** to address system
13 needs and cost allocation more efficiently than a project-by-project approach.
14 The MVST should focus on identifying systemwide needs and developing a
15 portfolio of projects that can more cost effectively integrate new resources,
16 instead of focusing on the benefits of each upgrade separately.

17 ▶ **Jointly plan across neighboring interregional systems** to recognize regional
18 interdependence, increase system resilience, and take full advantage of
19 interregional scale economics and geographic diversification benefits. While
20 this point is less relevant to the Duke local transmission planning process, it
21 does emphasize the importance of Duke using its MVST process as an
22 example for improving regional and interregional planning through SERTP.

1 **Q: DO YOU HAVE ANY TAKEAWAYS FROM THE RESULTS OF THE 2023**
2 **PUBLIC POLICY STUDY THAT SHOULD BE ADDRESSED IN**
3 **DEVELOPING AND IMPLEMENTING THE MVST PROCESS?**

4 A: Yes. At a high-level, the results are very promising. NCTPC identified that the
5 addition of 14.5 GW of renewable energy resources (12.5 GW of solar and 2 GW
6 of onshore/offshore wind) will require \$2.5 billion in transmission upgrades, or
7 \$170/kW.²⁷ All of the identified upgrades are either reconductoring or upsizing
8 existing transmission facilities on existing rights-of-ways, though the NCTPC
9 suggested that a greenfield 230 kV network in DEC may be a long-term potential
10 solution to consider in future studies. The costs that NCTPC included are below
11 the current assumption for solar transmission cost adders in the CPIRP modeling
12 based on recent interconnection study results, and demonstrate that proactive
13 planning can identify cost-effective upgrades for a much larger amount of
14 renewable energy capacity.

15 Three additional aspects of the 2023 Public Policy study are worth
16 considering while developing and implementing the MVST process. First,
17 completing the additional analyses for a multi-value, scenario-based planning
18 process will require Duke to devote significant resources to the MVST study. In
19 the 2023 NCTPC Public Policy study, stakeholders requested the NCTPC to
20 complete reliability studies for six scenarios. The stakeholders requested six

²⁷ North Carolina Transmission Planning Collaborative, [Report on the NCTPC 2023 Public Policy Study](#), Draft Report, May 17, 2024. The cost estimates do not include upgrades required at the point of interconnection for the additional resources.

1 scenarios to account for two levels of solar capacity (5.5 GW and 12.6 GW) and
2 three alternative sets of locations so that the NCTPC could identify least-regrets
3 near-term and long-term upgrades. Initially, the NCTPC planned to model two
4 levels of solar capacity with a single set of locations scenarios, but ultimately only
5 modeled a single scenario due to staff and time constraints. I am providing this as
6 an example of the amount of work that will be required for completing the MVST
7 process that will include reliability studies for more than one scenario and the
8 additional analyses required for capturing a broad range of benefits of
9 transmission upgrades. Duke will need to devote additional staff and other
10 resources to the MVST for it to be successful.

11 Second, the results of the 2023 Public Policy study provided limited
12 details for stakeholders to review and provide feedback. The study summarized
13 the high-level results in terms of the network upgrades identified and their costs,
14 but no information on the specific reliability violations that required network
15 upgrades, the alternative upgrades or other solutions considered to resolve the
16 violations, and the rationale for including the identified transmission upgrades in
17 the RZEP 2.0 portfolio or not. Instead, the study concluded with several vague
18 findings that (1) the results are driven by the assumptions, (2) the results provide
19 no commitment to building identified upgrades, (3) developers should submit
20 interconnection requests to identify required upgrades, and (4) Duke will continue
21 to study the impacts of a changing resource mix and load additions. Duke should
22 focus on increasing its transparency of its planning process in the MVST to
23 ensure that the most cost-effective solutions can be identified for meeting future

1 system needs and clearly articulate the basis by which they will decide on whether
2 to build upgrades identified in the MVST study from the beginning.

3 Third, the 2023 reliability study and public policy studies identified two
4 separate portfolios of upgrades without an explanation of whether the portfolios
5 include the same upgrades, whether the policy upgrades are incremental to the
6 reliability studies, or the policy study portfolio avoids upgrades identified as
7 necessary in the reliability study portfolio. This is very important for
8 understanding the costs for interconnecting future resources, as well as
9 determining if upgrades included in the reliability-driven portfolio may be
10 unnecessary in a future with the additional resources modeled in this study. If the
11 upgrades are unnecessary in a future with the CPIRP modeling resource mix,
12 Duke should complete additional analysis to ensure those upgrades need to be
13 built for reliability purposes accounting for both load growth and the future
14 resources.

15 **Q: ARE THERE PROACTIVE TRANSMISSION PLANNING PROCESSES**
16 **THAT DUKE AND THE COMMISSION SHOULD REVIEW WHILE**
17 **DEVELOPING ITS MVST PROCESS?**

18 A: Yes. I would recommend that Duke consider the Southwest Power Pool (SPP)²⁸
19 and Midcontinent Independent System Operator (MISO)²⁹ planning processes in

²⁸ See Southwest Power Pool, 2021 Integrated Transmission Planning Assessment: Report & Addendum, Version 2.0, December 9, 2022 (<https://www.spp.org/documents/66812/2021%20itp%20report%20&%20addendum%20v2.0.pdf>).

²⁹ See Midcontinent Independent System Operator, MTEP21 Report Addendum: Long Range Transmission Planning Tranche 1 Portfolio Report: Executive Summary, 2022

1 particular. Both regions develop long-term scenarios for the future demand and
2 resource mix assumptions and then convert those scenarios into details for
3 running detailed reliability and economic planning studies. They then review
4 several potential drivers of transmission needs including reliability, economic,
5 and policy drivers for developing a portfolio of upgrades to consider. Finally, they
6 evaluate several portfolios of projects based using a multi-value framework to
7 identify the most beneficial portfolio of projects to approve and include in their
8 regional transmission plan. For developing detailed assumptions for the locations
9 of future resources, I would also recommend that Duke review the approach the
10 California Public Utilities Commission and California Energy Commission to
11 mapping the resource portfolios approved by the California Public Utilities
12 Commission to specific locations on the CAISO system.³⁰ They consider several
13 important considerations, including access to transmission, land use impacts,
14 community impacts, and commercial interest. I include representative reports
15 from each of these entities as exhibits to my testimony.

16 **Q: DOES THE RECENTLY RELEASED FERC ORDER NO. 1920 IMPACT**
17 **THIS PROCESS?**

<https://cdn.misoenergy.org/MTEP21%20Addendum-LRTP%20Tranche%201%20Report%20with%20Executive%20Summary625790.pdf>).

³⁰ See California Public Utilities Commission, Integrated Resource Planning (IRP) Proposed Portfolios for the 24-25 Transmission Planning Process (TPP) and Preliminary Busbar Mapping: Workshop, October 20, 2023 (https://www.cpuc.ca.gov/-/media/cpuc-website/divisions/energy-division/documents/integrated-resource-plan-and-long-term-procurement-plan-irp-ltpp/2023-irp-cycle-events-and-materials/tpp-psp_10-20-23_workshop_tppbusbarslides.pdf).

1 A: FERC's new Order No. 1920 requires regional transmission providers to include a
2 20-year long-term regional planning study using many of the elements discussed
3 above. While Order No. 1920 that will not directly impact Duke's local
4 transmission planning process, it will have an impact on the Southeast Regional
5 Transmission Planning ("SERTP") regional planning process, of which Duke is a
6 member. Duke will need to work with the other members of SERTP to prepare a
7 plan for compliance with Order No. 1920. In many ways, Duke's MVST can be
8 example of an approach to comply with many of the requirements included in
9 Order No. 1920. Duke may also wish to review Order No. 1920 to determine
10 whether any additional modifications to the MVST process would be worth
11 implementing.

12 One especially important consideration in Order No. 1920 is on the role of
13 states to participate in and contribute to transmission planning processes. FERC
14 closely considered the role for states in the long-term regional planning process
15 and concluded that states play an important role throughout the process, including
16 in identifying which state policies to include in the planning studies, which
17 benefits to analyze and how to do so, and determining the cost allocation
18 approach for approved transmission projects. The Commission should better
19 understand this role for participating in the SERTP process, but also for
20 continuing to identify opportunities for Duke to improve its local transmission
21 planning process.

1 **IV. PROACTIVE TRANSMISSION PLANNING WILL IMPROVE**
2 **GENERATION INTERCONNECTION AND RESOURCE PLANNING**

3 **Q: HOW WILL PROACTIVE TRANSMISSION PLANNING IMPROVE THE**
4 **GENERATION INTERCONNECTION PROCESS?**

5 A: Proactive transmission planning will improve the generation interconnection
6 process in three ways. First, generation developers will have better information
7 earlier in the development cycle about where there is headroom on the system that
8 will result in lower interconnection costs and less schedule risks. Second, the
9 interconnection studies will be less complex and require less time as
10 interconnection studies will identify fewer incremental upgrades and the upgrades
11 will primarily be upgrades at or near the point of interconnection. Third, fewer
12 incremental network upgrades will mitigate the schedule risks to developers of
13 interconnecting new resources and reduce outage coordination challenges for
14 Duke.

15 **Q: ARE THERE ADDITIONAL IMPROVEMENTS TO GENERATION**
16 **INTERCONNECTION THAT DUKE SHOULD IMPLEMENT?**

17 A: Yes. Proactive transmission planning is an important aspect of improving
18 generation interconnection, but there is more Duke can do to improve the process
19 and continue to maintain the same level of reliability at lower costs to ratepayers.
20 Additional improvements to the interconnection process include: (1) consideration
21 of lower cost solutions than network upgrades, such as economic re-dispatch,
22 simple Remedial Action Schemes (“RAS”), and grid-enhancing technologies, to

1 maintain system reliability especially during lower probability system conditions,
2 such as TPL-001 P3 contingencies; (2) providing developers a sufficiently
3 differentiated interconnection service option through Energy Resource
4 Interconnection Service (“ERIS”) in which developers can choose to take on the
5 higher risks of curtailment and lower resource adequacy value while reducing the
6 costs and schedule risks of Network Resource Interconnection Service (“NRIS”);
7 (3) reduce the challenges of transmission outages during the construction of
8 network upgrades through the use of grid-enhancing technologies and
9 transmission shoo-flies;³¹ and (4) expand the use of provisional interconnection
10 service to allow resources to come online prior to the completion of all identified
11 network upgrades.

12 **Q: SHOULD DUKE CONTINUE TO IDENTIFY AREAS OF NEED FOR**
13 **DEVELOPING PROACTIVE PROJECTS BASED ON THE**
14 **INTERCONNECTION STUDIES?**

15 A: Yes, interconnection queues and interconnection study results should continue to
16 be an important source of information for the types, amount, and location of
17 resources that are currently in development and the transmission system upgrades
18 necessary to integrate those resources. Ideally, those needs and the associated
19 upgrades would be considered in the MVST process and either validated, like
20 they have been in the recent 2023 public policy study, or replaced by larger and

³¹ “GETs can minimize impact during construction by avoiding an outage altogether, or preventing congestion caused by transmission outages that occur while interconnecting the new projects. Topology Control software could also be used to identify the least impactful outage options.” Tsuchida, et al., [Building a Better Grid: How Grid-Enhancing Technologies Complement Transmission Buildouts](#), April 20, 2023, p. 15.

1 more cost-effective upgrades that can support interconnection of new resources
2 and provide other benefits to the Duke system.

3 **Q: HOW WOULD IMPROVED TRANSMISSION PLANNING IMPACT THE**
4 **RESOURCE PLANNING PROCESS?**

5 A: In its CPIRP process, Duke develops portfolios of the future resources needed to
6 serve load using a power market model, EnCompass, that simulates resource
7 additions and retirements and resource operations to meet future hourly demand
8 and reserve requirements. Duke generates resource portfolios that consider a
9 range of important assumptions, including two assumptions related to the
10 transmission system: (1) the capital costs of new resources include projected
11 network upgrade costs required for interconnecting each resource type to the
12 system; and (2) as noted above, annual solar additions are limited based on
13 assumed challenges implementing network upgrades for each new project and
14 coordinating outages on the existing system.

15 Currently, neither of these assumptions are informed by the long-term
16 transmission planning process. Network upgrade cost adders in the 2023 CPIRP
17 simulations of \$0.21/Watt in DEP and \$0.35/Watt in DEC (2023 dollars) are
18 based on near-term network upgrades costs identified in recent interconnection
19 studies.³² Similarly, Duke relied on its recent experience coordinating
20 transmission outages for setting the annual build limit of 1,575 MW per year on

³² Duke develops estimates from other sources for resources that have not recently completed interconnection studies.

1 solar PV through 2031, rising to 1,800 MW per year due to the impacts of
2 proactive RZEP projects and rising solar capacity per project, as described above.

3 In its next iteration of CPIRP modeling, Duke could instead rely on the
4 results from the 2023 Public Policy study and future transmission planning studies
5 for estimating network upgrade cost adders in resource planning studies. The
6 2023 Public Policy study identified upgrade costs of about \$0.17/W, based on
7 \$2,531 million (2023 dollars) for 14.5 GW of incremental solar and wind
8 capacity, lower than the costs recently modeled for solar and other resources in
9 the CPIRP. For setting solar addition limits, Duke should review the findings of
10 the 2023 Public Policy study to identify how the number of upgrades and related
11 outages will change if these projects are included in future transmission plans and
12 how that impacts the rate of solar additions.

13 **Q: WHAT IS THE ROLE OF THE COMMISSION IN IMPROVING**
14 **TRANSMISSION PLANNING AND INTERCONNECTION PROCESS TO**
15 **ACHIEVE LEAST-COST OUTCOMES FOR RATEPAYERS?**

16 **A:** The Commission should continue to review Duke's transmission planning and
17 interconnection processes to identify opportunities for improving the processes
18 and reducing costs to ratepayers while maintaining system reliability. The
19 Commission's recommendations in the 2022 Carbon Plan proceeding played an
20 important role in Duke recently reforming these processes and the Commission
21 should continue to track those reforms to ensure that are implemented effectively.
22 In particular for the large-scale of upgrades required to transform the transmission
23 network, the Commission should ensure that Duke provides a clear and

1 transparent justification for the scenarios and contingencies tested in
2 interconnection and transmission planning studies and the alternative solutions
3 considered for maintaining reliability at least cost to ratepayers.

4 **Q: DOES THIS CONCLUDE YOUR TESTIMONY?**

5 A: Yes.