

SANFORD LAW OFFICE, PLLC
Jo Anne Sanford, Attorney at Law

January 7, 2022

Ms. A. Shonta Dunston, Chief Clerk
North Carolina Utilities Commission
4325 Mail Service Center
Raleigh, North Carolina 27699-4325

Via Electronic Delivery

Re: Aqua North Carolina, Inc.
Docket No. W-218, Sub 526A
Application for Approval of Water and Sewer System Improvement
Charge Rate Adjustments Pursuant to G.S. 62-133.12
Revised Appendix B ANCW-5 Replacement Page

Dear Ms. Dunston:

Aqua North Carolina, Inc. hereby files a Revised Appendix B ANCW-5 replacement page with respect to the Company's pending WSIC/SSIC application which was filed in this docket on November 1, 2021. The purpose of this filing is to delete from consideration for WSIC surcharge cost recovery proposed Funding Project FP35801022853 - WSIC Cold Springs Water Main Extension. The Public Staff has advised the Company that the Staff will propose an adjustment to Aqua's WSIC revenue requirement based upon a challenge to the WSIC eligibility of this project. Aqua does not oppose the Public Staff's proposed adjustment for this project and, for that reason, submits the attached Revised Appendix B ANCW-5 replacement page.

I hereby certify that I have served a copy of this filing on the parties of record to this docket.

As always, we thank you and your staff for your assistance; please feel free to contact me if there are questions or if additional information is required.

Electronically Submitted

/s/Jo Anne Sanford

North Carolina State Bar No. 6831

Attorney for Aqua North Carolina, Inc.

ANCW-5

APPENDIX B
AQUA NORTH CAROLINA, INC.
WSIC Filing Summary - W-218, Sub 526A
Rate Entity: Aqua North Carolina Water
Project Scope For period ending September 30, 2021

Funding Project	Project Description	Project Scope	Ref
FP35801016126	WSIC 20/21 Meter Rplc	The replacement of meters and/or appurtenances inside the meter box, including the box and lid, due to malfunction, damage or age deterioration. Aqua replaced manually read meters with RF meters to maximize efficiency of operations. G.S. 62-133.12(c)(1) Eligible Water System Improvements.	Paragraph 14/15 of the Application
FP35800017070	WSIC Lynnhaven Valve Rplc	The replacement of four 3" gate valves in the Lynnhaven distribution system due to failure. G.S. 62-133.12(c)(1) Eligible Water System Improvements.	Paragraph 14/15 of the Application
FP35800015310	WSIC Whitetail Farm FeMn Filter	Installation of Manganese Dioxide Media filter system at Whitetail Farms in an effort to minimize the impact of secondary water quality concerns from customers. G.S. 62-133.12(c)(4) Eligible Water Systems Improvements.	Paragraph 14/15 of the Application
FP35800007593	WSIC Shannon Wds FeMn Filter	Installation of Manganese Dioxide Media filter system at Well #4 in Shannon Woods in an effort to minimize the impact of secondary water quality concerns from customers. G.S. 62-133.12(c)(4) Eligible Water Systems Improvements.	Paragraph 14/15 of the Application
FP35100014319	WSIC Blue Water Cove OCCT	The installation of treatment to remove primary contaminants to comply with primary drinking water standards. This single treatment is addressing the potential for lead and or copper corrosion of household plumbing, but is also removing Fe. G.S. 62-133.12(c)(3) Eligible Water System Improvements.	Paragraph 14/15 of the Application
FP35800081523	WSIC Carlyle Manor FeMn Filter	Installation of a combined Manganese Dioxide Media filter system for Carlyle Manor #1 and #7 in an effort to minimize the impact of secondary water quality concerns from customers. G.S. 62-133.12(c)(4) Eligible Water Systems Improvements.	Paragraph 14/15 of the Application
FP35800081522	WSIC Enclave BCB FeMn Filter P75	Installation of Manganese Dioxide Media filter system at Enclave at Barton Creek Bluffs in an effort to minimize the impact of secondary water quality concerns from customers. G.S. 62-133.12(c)(4) Eligible Water Systems Improvements	Paragraph 14/15 of the Application

AQUA NORTH CAROLINA, INC.
 WSIC Filing Summary - W-218, Sub 526A
 Rate Entity: Aqua North Carolina Water
 Project Scope For period ending September 30, 2021

ANCW-5

Funding Project	Project Description	Project Scope	Ref
FP35800051784	WSIC High Meadows Fe/Mn Filter	Installation of Manganese Dioxide Media filter system for Wells #2 and #3 at High Meadows in an effort to minimize the impact of secondary water quality concerns from customers. G.S. 62-133.12(c)(4) Eligible Water Systems Improvements	Paragraph 14/15 of the Application
FP35800042136	WSIC Royal Senter FeMn Fitr Well 2	Installation of a combined Manganese Dioxide Media filter system for wells #2 and #3 at Royal Senter Ridge in an effort to minimize the impact of secondary water quality concerns from customers. G.S. 62-133.12(c)(4) Eligible Water Systems Improvements	Paragraph 14/15 of the Application
FP35800007400	WSIC Royal Senter Rdg #1 FeMn Fltr	Installation of Manganese Dioxide Media filter system at Well #1 at Royal Senter Ridge in an effort to minimize the impact of secondary water quality concerns from customers. G.S. 62-133.12(c)(4) Eligible Water Systems Improvements	Paragraph 14/15 of the Application
FP35800018686	WSIC Well Meter Replace - Central	The replacement of well meters and/or chambers that are located inside the well house, due to digital display life span. These type of meters have an average life span of 10 years. Aqua found it more cost effective and efficient to replace chambers where we could but in some cases both the meter and chamber required replacement. G.S. 62-133.12(c)(1) Eligible Water System Improvements.	Paragraph 14/15 of the Application
Various	WSIC Well Pump Replacement	The replacement of pumping equipment due to failure. G.S. 62-133.12(c)(1) Eligible Water System Improvements.	Paragraph 14/15 of the Application