

head calculations. Underground piping would be in trenches. Figure 6-88d is a conceptual representation of a pipeline trench. Extraction well discharge headers would connect each well to the groundwater extraction system and would discharge extracted groundwater to duplex pump stations. Extracted groundwater would flow to the pump stations via gravity drain. Force mains would transfer groundwater from force mains to the Cliffside WWTP via the pipe rack that crosses Suck Creek. Aboveground piping would be insulated and heated seasonally to prevent freezing.

Wastewater Discharge Piping To Basement Basin (Holding Cell) (STEP 6b)

(CAP Content Section 6.E.b.i)

Extracted groundwater would be conveyed through existing storm water piping. According to Cliffside plant personnel, the storm water piping tracks to the northwest and along the road to the Basement Basin (Holding Cell) where it is comingled with process water before being treated and discharged.

Treatment of Extracted Groundwater (STEP 7)

(CAP Content Section 6.E.b.i)

Extracted groundwater would be directed to storm sewer piping located between Cooling Towers A and B. Extracted groundwater would be discharged to a new manhole (Figure 6-88a) that would be tied into existing piping that is routed the Basement Basin. There it would mix with process water and would be transferred to the Cliffside WWTP, which is a physical/chemical treatment system consisting of pH adjustment, coagulation and flocculation. Solids are removed from the wastewater using high-rate clarifiers and polishing filters, if necessary. Wastewater is discharged to the Broad River through NPDES Outfall 005. There is no indication that any permit parameters would be exceeded (Table 6-35).

Electrical and Instrumentation Design

(CAP Content Section 6.E.b.i)

The design package would provide the necessary plans and specifications for procurement of materials and construction purposes. This would include Site layout drawings, plans and profiles, well enclosure details, trench and discharge piping outlet details, well construction schematics, piping and instrumentation diagrams/drawings and complete equipment, materials and construction specifications.

Existing power near the system might not be adequate for the anticipated number of wells. Additional power might need to be a component of the design. Control panels might also be necessary for each distinct area of the well systems. The control systems would be equipped with system shutdown notification.

Design Documents

(CAP Content Section 6.E.b.i)

The design package would provide the necessary plans and specifications for procurement of materials and construction purposes. This would include Site layout drawings, plans and profiles, well enclosure details, trench and discharge piping outlet details, well construction schematics, piping and instrumentation diagrams/drawings and complete equipment, materials and construction specifications.

System Operation and Maintenance

(CAP Content Section 6.E.b.i)

Groundwater extraction well and source control trench performance would be monitored and tracked to determine if there is a loss in pumping efficiency due to mineral and/or biological fouling. If well performance monitoring indicates a decrease in flow rate, the well would be inspected for fouling and the screens would be cleaned as appropriate.

In addition to well performance monitoring and maintenance, other system elements, such as pumps controls, would receive routine maintenance in accordance with the manufacturer's recommendations. Groundwater samples would be collected from the following monitoring wells to evaluate treatment effectiveness:

- GWA-36S
- GWA-37S
- MW-38S
- GWA-36D
- GWA-4D
- MW-38D
- MW-38BR

6.26.2.2 Design Assumptions, Calculations, and Specifications

(CAP Content Section 6.E.b.ii)

Design calculations are presented in **Appendix N**.

6.26.2.3 Permits

(CAP Content Section 6.E.b.iii)

Discharge of extracted groundwater extracted under Alternative 3 would require modification of NPDES Permit NC0005088 to include discharge of groundwater. When modified, NPDES Permit NC0005088 would allow for the discharge of groundwater at Outfall 005.

6.26.2.4 Construction Schedule and Cost of Implementation

(CAP Content Section 6.E.e.i)

The time to construct Groundwater Alternative 3 is estimated to be 2 months. Duke Energy would provide construction reports monthly from the beginning of construction until construction is complete.

Reporting would include:

- Health and Safety/Man Hours.
- Tasks completed for the month prior.
- Problems affecting schedule (*e.g.*, inclement weather).
- Measures taken to achieve construction milestones (*e.g.*, increase number of drilling crews).
- Contingencies.
- Tasks to be completed by next reporting period.
- Provide updated schedule/Gantt chart.

Progress reports would be prepared and submitted to NCDEQ monthly.

The cost estimate for this alternative is based on capital costs for design and implementation. Implementation includes pumping tests, installation of extraction wells, submersible pumps, instrumentation, piping, and telemetry system. Long term O&M costs include groundwater monitoring costs, analytical costs, reporting costs, periodic redevelopment and replacement of monitoring wells, and periodic replacement of submersible pumps

A detailed cost estimate for this Alternative is provided in **Appendix K**. The cost estimate is based on capital costs for design and implementation, and the operations, maintenance (O&M) and monitoring costs. The design costs

include work plans, design documents and reports necessary for implementation of the alternative. Implementation costs include procurement and construction. O&M costs are based on annual routine labor, materials and equipment to effectively conduct monitoring, routine annual and 5-year reporting, and routine and non-routine maintenance costs.

6.26.2.5 Measure to Ensure Health and Safety

(CAP Content Section 6.E.b.v)

There is no measurable difference between evaluated Site risks and risks indicated by background concentrations; therefore, no material increases in risks to human health related to the ash basin have been identified. The groundwater corrective action is being planned to address regulatory requirements. The risk assessment (**Appendix E**) identified no current human health or ecological risk associated with groundwater downgradient of the U5 AB. Water supply wells are located upgradient of the ash basin and municipal water connections have been provided to those who selected this option. Surface water quality standards downgradient of the COI-affected plume are also met. Based on the absence of receptors, it is anticipated that groundwater extraction would create conditions that continue to be protective of human health and the environment because the COI concentrations will diminish with time.

6.26.2.6 Description of All Other Activities and Notifications Being Conducted to Ensure Compliance with O2L, CAMA, and Other Relevant Laws and Regulations

(CAP Content Section 6.E.b.vi)

The CAP provides a description of activities related to compliance with O2L, CAMA, in regard to the U5 AB.

6.26.3 Requirements for O2L .0106(l) – MNA

(CAP Content Section 6.E.c)

The requirements for implementing corrective action by MNA, under O2L .0106(l), are provided in **Section 6.23.1** and **Appendix I**. MNA is not applicable at this time for Cliffside as described in **Section 6.23.1**.

6.26.4 Requirements for 02L .0106(k) – Alternate Standards

(CAP Content Section 6.E.d)

Regulation 02L .0106(k), states that a request may be made for approval of a corrective action plan that uses standards other than the 02L groundwater quality standards. G.S. Section 130A, Article 9, Part 8 allows risk-based remediation as a clean-up option where the use of remedial actions and land use controls can manage properties safely for intended use. Risk-based corrective action is where constituent concentrations are remediated to an alternative standard based on the actual posed risks rather than applicable background-levels or regulatory standards. The requirements for implementing corrective action by remediating to alternate standards, under 02L .0106(k), are as follows:

- *Sources are removed or controlled;*
- *Time and direction of contaminant travel can be predicted with reasonable certainty;*
- *COIs have and will not migrate onto adjacent properties unless specific conditions are met (i.e., alternative water sources, written property owner approval, etc.);*
- *Standards specified in Rule .0202 of this Subchapter will be met at a location no closer than one year time of travel upgradient of an existing or foreseeable receptor, based on travel time and the natural attenuation capacity of subsurface materials or on a physical barrier to groundwater migration that exists or will be installed by the person making the request;*
- *If contaminant plume is expected to intercept surface waters, the groundwater discharge will not possess contaminant concentrations that would result in violations of standards for surface waters contained in 15A NCAC 02B .0200;*
- *Public notice of the request has been provided in accordance with Rule .0114(b) of this Section; and*
- *Proposed corrective action plan would be consistent with all other environmental laws*

Because historical and ongoing assessment indicates that there is not the potential for off-Site groundwater flow, Cliffside meets the requirements for implementing corrective action under 02L .0106(k) at this time.

6.26.5 Sampling and Reporting

(CAP Content Section 6.E.e)

An EMP has been developed as part of this CAP consistent with 02L .0106(h)(4). The EMP is designed to monitor groundwater conditions at the CSS and document progress towards the remedial objectives over time. This plan is designed to be adaptive over the project life cycle and can be modified as the groundwater remediation system design is prepared, completed, or evaluated for termination.

Duke Energy implemented an IMP after the plan was submitted to NCDEQ on October 23, 2018. Additional modifications to the plan were approved by NCDEQ on April 4, 2019 (**Appendix A**). The IMP includes the locations of groundwater wells sampled quarterly and semiannually.

The EMP is required by G.S. Section 130A-309.211(b)(1)(e). The IMP will be replaced by the EMP upon NCDEQ approval of the CAP Update. Either submittal of the EMP, or the pilot test work plan and permit applications (as applicable), will fulfill G.S. Section 130A-309.209(b)(3).

The EMP, presented in **Appendix O**, is designed to be adaptable and target key areas where changes to groundwater conditions are most likely to occur due to corrective action and ash basin closure activities. The EMP will be used to evaluate progress towards remediation. EMP key areas for monitoring are based on the following considerations:

1. Include background locations
2. Include designated flow paths with area of groundwater remediation
3. Within areas of observed or anticipated changing Site conditions, and/or have increasing constituent concentration trends
4. Will effectively monitor COIs plume stability and model simulation verification

EMP elements including well systems, locations, frequency, parameters, schedule and reporting evaluation are summarized below and outlined on **Table 6-40**. Effectiveness monitoring well locations are illustrated on **Figure 6-91**. The EMP will be implemented 30 days after CAP approval, and will continue until there is a total of three years of data confirming COIs are below applicable standards at or beyond the compliance boundary, at which time a request for completion of active remediation will be filed with NCDEQ. If applicable

standards are not met, the EMP will continue and transition to post-closure monitoring, if necessary.

After ash basin closure and following ash basin closure certification, a post-closure groundwater monitoring plan (PCMP) will be implemented at the Site for a minimum of 30 years in accordance with G.S. Section 130A-309.214(a)(4)k.2. If groundwater monitoring results are below applicable standards at the compliance boundary for three years, Duke Energy may request completion of corrective action in accordance with G.S. Section 130A-309.214(a)(3)b. If groundwater monitoring results are above applicable standards, the PCMP will continue. An EMP work flow and optimization process is outlined on a flow chart on **Figure 6-92**.

Optimization of the plan to help determine the remedy's performance, appropriate number of sample locations, sampling frequency, and laboratory analytes, and statistical analysis to evaluate the plume stability conditions would be conducted during EMP review periods. The optimization process would be conducted using software designed to improve long-term groundwater monitoring programs such as Monitoring and Remediation Optimization System (MAROS).

6.26.5.1 Progress Reports and Schedule

(CAP Content Section 6.E.e.i)

The effectiveness monitoring plan for Source Area 3 will be consistent with the EMP presented in **Section 6.8.5.1** and provided in **Appendix O**.

6.26.5.2 Sampling and Reporting Plan During Active Remediation

(CAP Content Section 6.E.e.ii)

See **Section 6.8.6.2** regarding sampling and reporting during active remediation for Source Area 3.

6.26.6 Termination of Groundwater Remediation Alternative

(CAP Content Section 6.E.e.iii)

Termination of the proposed remedial alternative would be consistent with and implemented in accordance with NCDEQ 15A NCAC 02L .106 (m). A flow chart of the request and review timeline for termination is outlined on **Figure 6-93**. Completion of this phase might also provide stakeholders with an opportunity to evaluate terminating the system, as appropriate, near the well or wells where groundwater restoration completion is being evaluated.

Groundwater remediation effectiveness monitoring would transition to the attainment monitoring phase when NCDEQ determines that the remediation monitoring phase is complete at a particular well or area.

6.26.7 Interim Activities

(CAP Content Section 6.E.a.iv; 6.E.a.v; 6.E.f)

Bench Scale Testing

(CAP Content Section 6.E.f)

Bench scale testing would evaluate media that might have the potential to neutralize acidic surface water flowing west of the southernmost cooling tower. Media to be evaluated might include limestone, recycled concrete, or similar. The bench scale testing would also evaluate the minimum residence time versus media surface area to neutralize the acidic surface water. Bench scale testing results would be used to develop the final design of the infiltration trench.

6.26.8 Implementation Schedule

In accordance with requirements of G.S. Section 130A-309.211(b)(3), implementation of the proposed corrective action for Source Area 3 will begin within 30 days of NCDEQ approval of the CAP Update.

During pilot testing, extracted groundwater will be collected and analyzed for geochemical parameters consistent with the NPDES permit.

Additional interim activities to be conducted prior to implementation of the corrective action remedy include:

- Implementation of the EMP within 30 days of CAP approval
- Submittal of permit and registration applications to NCDEQ, as applicable.

6.26.9 Contingency Plan

(CAP Content Section 6.E.g)

The purpose of the Contingency Plan is to monitor changes in conditions and operations to effectively reach the remedial action objectives. The contingency plan addresses operations, groundwater conditions and performance.

The Contingency Plan will be defined in greater detail as design elements of the system are finalized. A groundwater monitoring program to measure and track the effectiveness of the proposed extraction and infiltration system for Source Area 3 is described in **Appendix O**. This plan is designed to be adaptive and can

be modified as the groundwater remediation system design is prepared, completed, or evaluated for termination. The contingency plan for Source Area 3 will be similar to the contingency plan proposed for Source Area 1 as described in **Section 6.8.9**.

6.27 SA3 Corrective Action Approach Summary

This CAP Update includes a proposed remedial alternative that would address COIs in groundwater beyond the U5 AB compliance boundary to the northeast. This CAP Update provides:

- A screening and ranking process of three potential groundwater corrective action alternatives.
- A selection and description of the proposed targeted corrective action: Groundwater Remedial Alternative 3, Groundwater Extraction and Source Control.
- Specific plans, including engineering details where applicable, for restoring groundwater quality.
- An EMP for evaluating the performance and effectiveness of the proposed targeted corrective action and its effect on the movement of the affected groundwater plume. The EMP uses an optimized groundwater monitoring system with multiple groundwater flow paths in the area of corrective action that would monitor geochemical and physical conditions.
- A schedule for the implementation and operation of the proposed groundwater corrective action strategy.
- Planned activities prior to full-scale implementation include pumping tests. A pumping test work plan would be submitted to NCDEQ within 30 days of CAP approval to fulfill G.S. Section 130A-309.211(b)(3).

6.28 Summary and Conclusions

This CAP Update meets the corrective action requirements under G.S. and Subchapter 02L.0106 and to addresses Subchapter 02L .0106(j). This CAP Update proposes a remedy for COIs in groundwater associated with the AAB, U1-4 AB, U5 AB, and ASA that are at or beyond the compliance boundaries. This CAP Update provides:

- Groundwater remediation approaches that can be implemented under either closure scenario (closure-in-place or closure-by-excavation).

- A screening process of multiple potential groundwater corrective action alternatives that would address areas requiring corrective action.
- A selection and description of the favored corrective action groundwater remedy for the AAB and ASA: **Alternative 2 – Groundwater Extraction Combined with Clean Water Infiltration and Treatment.**
- A selection and description of the favored corrective action groundwater remedy for the U1-4 AB: **Alternative 2 – Continued Monitoring with Phytoremediation and TreeWell™ Technology.**
- A selection and description of the favored corrective action groundwater remedy for the U5 AB: **Alternative 3 - Groundwater Extraction.**
- Specific plans, including engineering design details, for restoring groundwater quality.
- A schedule for the implementation and operation of the corrective action strategies.
- A monitoring plan for evaluating the performance and effectiveness of corrective action groundwater remedies, and their effect on the restoration of groundwater quality.

Planned activities prior to full-scale implementation include pilot testing in selected areas and water treatment testing. Pilot test work plan(s) will be submitted to NCDEQ within 30 days of CAP approval to fulfill G.S. Section 130A-309.211(b)(3).

7.0 PROFESSIONAL CERTIFICATIONS

(CAP Content Section 7)

Certification for the Submittal of a Corrective Action Plan

Responsible Party and/or Permittee: Duke Energy Progress, LLC

Contact Person: Paul Draovitch

Address: 526 South Church Street

City: Charlotte **State:** NC **Zip Code:** 28202

Site Name: Cliffside Steam Station

Address: 573 Duke Power Road


City: Mooresboro **State:** NC **Zip Code:** 28114-7754

Groundwater Incident Number (applicable): NA/Coal Ash Management Act CAP

We, Scott A. Spinner, **Professional Geologist** and James E. Clemmer, a **Professional Engineer** for SynTerra Corporation (firm or company of employment) do hereby certify that the information indicated below is enclosed as part of the required Corrective Action Plan (CAP) and that to the best of my knowledge the data, assessments, conclusions, recommendations and other associated materials are correct, complete and accurate.

(Affix Seal and Signature)

Sworn to and subscribed
before me this
27 day of December, 2019



8.0 REFERENCES

(CAP Content Section 8)

- Ademeso, O.A. et.al. 2012. *The Inter-relationship of Bulk Density and Porosity of Some Crystalline Basement Rocks: A Case Study of Some Rock Types in Southwestern Nigeria.* IOSR Journal of Engineering, April 2012, Vol.2(4) pp: 555-562.
- AECOM. 2016. *Ash Basin Closure Plan Report, 100% Draft Closure Plan for CCR Posting- Cliffside Steam Station.* Mooresboro, NC.
- AECOM. 2018a. *Rogers Energy Complex - Cliffside Steam Station Active Ash Basin - Closure Options Analysis - Summary Report.*
- AECOM. 2018b. *Rogers Energy Complex - Cliffside Steam Station Unit 5 Inactive Ash Basin - Closure Options Analysis - Summary Report.*
- Amec. 2015. *Natural Resources Technical Report.*
- Arcadis. 2019. *Saturated Ash Thickness and Underlying Groundwater Boron Concentrations – Allen, Belews Creek, Cliffside, Marshall, Mayo, and Roxboro Sites.* March 2019.
- ATSDR. 2010. *Toxicological Profile for Boron.* Agency for Toxic Substance & Disease Registry. November 2010.
<https://www.atsdr.cdc.gov/ToxProfiles/tp.asp?id=453&tid=80>
- Casentini, B., et al. 2016. *Arsenic Removal by Discontinuous ZVI Two Steps System for Drinking Water Production at Household Scale.* Water Research, Pergamon.
- Chu, Jacob, et al. 2017. *An Approach to Using Geochemical Analysis to Evaluate the Potential Presence of Coal Ash Constituents in Drinking Water.* 2017 World of Coal Ash (WOCA) . Lexington, KY.
- Domenico, Patrick A., and Franklin W. Schwartz. 1988. *Physical and Chemical Hydrogeology.* Vol. 44. New York: Wylie.
- Duke Energy. 2017. *Excavation Soil Sampling Plan Rogers Energy Complex Units 1-4 Inactive Ash Basin for Ash Basin Excavation, Rev. 0.*
- Duke Energy. 2018a. *Rogers Energy Complex (Cliffside Steam Station) HB 630 Provision of Permanent Water Supply Completion Documentation.*

Duke Energy. 2018b. *Coal Combustion Residual (CCR) Visual Removal Verification, Rogers Energy Complex – Cliffside Steam Station, Units 1-4 Inactive Ash Basin.*

Du Pont Water Solutions. 2019. *Separation of Boron from Liquid Media*; website accessed July 13, 2019: <https://www.dupont.com/water/periodic-table/boron.html>.

Ellington-DTD. 2019. Letters from Brian Younkin and Dan Ombalski of Ellington-DTD to James E. Clemmer of SynTerra Corporation dated October 23, 2019 and November 14, 2019.

Ellington-DTD. 2004. *Horizontal Environmental Well Handbook*. Prepared by Directed Technologies Drilling, Inc., December 2004

EPRI. 1995. *Coal ash disposal manual: Third edition - January*. Palo Alto, CA: Electric Power Research Institute, TR-104137.

EPRI 2005. *Chemical Constituents in Coal Combustion Product Leachate: Boron*. EPRI, Palo Alto, CA: 2005. 1005258 Technical Report

EPRI 2006. *Groundwater Remediation of Inorganic Constituents at Coal Combustion Product Management Sites: Overview of Technologies, Focusing on Permeable Reactive Barriers*. Electric Power Research Institute, Palo Alto, CA: 2006. 1012584

EPRI 2012. *Groundwater Quality Signatures for Assessing Potential Impacts from Coal Combustion Product Leachate*. EPRI, Palo Alto, CA: 2012. 1017923 Final Report

Exponent. 2018. *Community Impact Analysis of Ash Basin Closure Options at Cliffside Steam Station*. Mooresboro, NC.

Falta Environmental et al. 2018. *Preliminary Updated Groundwater Flow and Transport Modeling Report - Cliffside Steam Station* .

Farhat, S.K., C.J. Newell, and E.M. Nichols, 2011. *Mass Flux Toolkit User's Manual*. Version 2.0, 131p. <https://www.gsi-net.com/en/software/free-software/mass-flux-toolkit.html>

Freeze, R. A., & Cherry, J. A. 1979. *Groundwater*. Englewood Cliffs, NJ: Prentice-Hall.

Gale, J.E. 1982. *Assessing the Permeability Characteristics of Fractured Rock*. Geological Society of America Special paper 189.

Geosyntec Consultants. 2019b. *Evaluation of Potential Application of Engineered Phytoremediation and Conceptual Design-Cliffside Units 1-4*. Technical Memorandum (Privileged & Confidential-for Recipients Use Only). November 4, 2019.

Haley & Aldrich, 2015. *Evaluation of NCDEQ Private Well Data*. December 2015.

Harned, D., and C. Daniel. 1992. *The Transition Zone Between Bedrock and Regolith: Conduit for Contamination*. In Daniel, C.C., White, R., and Stone, P., eds., Groundwater in the Piedmont, Proceedings of a Conference on Ground Water in the Piedmont of the Eastern United States, Charlotte, N.C., Oct. 16-18, 1989. Clemson, SC: Clemson University (336-348).

HDR and SynTerra. 2017. *Revised Statistical Methods for Developing Reference Background Concentrations for Groundwater and Soil at Coal Ash Facilities*. HDR Engineering, Inc. and SynTerra Corporation.

HDR. 2014a. *Cliffside Steam Station Ash Basin Drinking Water Supply Well and Receptor Survey*. HDR.

HDR. 2014b. *Cliffside Steam Station Ash Basin Supplement to Drinking Water Supply Well and Receptor Survey*. HDR.

HDR. 2015a. *Comprehensive Site Assessment Report Cliffside Steam Station Ash Basin*. HDR.

HDR. 2015b. *Corrective Action Plan Part 1 Cliffside Steam Station Ash Basin*. HDR.

HDR. 2016a. *Corrective Action Plan Part 2 Cliffside Steam Station Ash Basin*. HDR.

HDR. 2016b. *Cliffside Steam Station Ash Basin Draft Drinking Water Supply Well and Receptor Survey*. HDR.

HDR. 2016c. *Comprehensive Site Assessment Supplement 2 Cliffside Steam Station Ash Basin*. HDR.

Indraratna et al. 2010. *Treatment of acidic groundwater in acid sulfate soil terrain using recycled concrete: column experiments*. University of Wollongong, Australia. Journal of Environmental Engineering, 137(6), 2011, pp 433-443.

ITRC 2017. *Remediation Management of Complex Sites*. Website. <https://rmcs-1.itrcweb.org/>.

ITRC, 2009, *Phytotechnology Technical and Regulatory Guidance and Decision Trees, Revised*, The Interstate Technology & Regulatory Council (ITRC), February 2009.

ITRC, 2003, *Technical and Regulatory Guidance Document for Constructed Treatment Wetlands*, December 2003

Izquierdo et al. 2012. *Leaching Behavior of Elements from Coal Combustion Fly Ash: An Overview*. International Journal of Coal Geology 94 (2012), pp 54-66.

Johnson et al. 2005. *Acid Mine Drainage remedial options: a review*. School of Biological Sciences, University of Wales, Bangor LL57 2UW, UK.

LeGrand, H. 1988. *Region 21, Piedmont and Blue Ridge*. In: J. Black, J. Rosenshein, P. Seaber, ed. Geological Society of America, 0-2, pp 201-207.

LeGrand, H. 1989. *A conceptual model of ground water settings in the Piedmont region, in groundwater in the Piedmont*. In: Daniel C., White, R., Stone, P., ed. " *Ground Water in the Piedmont of the Eastern United States*. Clemson, SC: Clemson University, pp 317-327.

LeGrand, H. 2004. *A master conceptual model for hydrogeological site characterization in the Piedmont and Mountain Region of North Carolina: A guidance manual*. North Carolina Department of Environment and Natural Resources, Division of Water Quality, Groundwater Section Raleigh, NC, 55.

Lipson, et.al. 2005. *Matrix Diffusion-Derived Plume Attenuation in Fractured Bedrock*. National Groundwater Association. Volume 43, Issue 1, pp 30-39.

Löfgren. 2004. *Diffusive Properties of Granitic Rock as Measured by In-Situ Electrical Methods*. Doctoral Thesis. Department of Chemical Engineering and Technology, Divisions of Chemical Engineering, Royal Institute of Technology. Stockholm, Sweden. ISSN 1104-3466.

Miller. 1996. *Horizontal Wells*. prepared by Ralinda R. Miller for Ground-Water Remediation Technologies Analysis Center, 615 William Pitt Way, Pittsburgh, PA 15238.

NCDEQ. 2018. *Corrective Action Plan Content for Duke Energy Coal Ash Facilities - April, 27, 2018*.

NCDEQ, 2019. *Closure Options Evaluation, Saturated Ash Considerations*. Web page: <https://files.nc.gov/ncdeq/Coal%20Ash/2019-april-decision/Saturated-Ash.pdf>.

NCDEQ. 2017. *Monitored Natural Attenuation for Inorganic Constituents in Groundwater: Guidance for Developing Corrective Action Plans Pursuant to NCAC 15A.0106(I): Companion guidance to the '15A NCAC 2L Implementation Guidance,' Division of Environmental Management, December, 1995*. North Carolina Department of Environmental Quality, Division of Water Quality. October, 2017.

NCDENR. 2003. *Guidelines for Performing Screening Level Ecological Risk Assessments Within the North Carolina Division of Management*. North Carolina Department of Environmental Quality. Division of Waste Management.

NCDWM. 2000. *Guidance on Developing a Monitored Natural Attenuation Remedial Proposal for Chlorinated Organics in Ground Water*; North Carolina Division of Waste Management. Hazardous Waste Section. October 4, 2000.

Neretnieks, I. 1985. *Transport in fractured rocks. Hydrology of Rocks of Low Permeability. Memoirs*. International Association of Hydrogeologists, v. XVII, part 1 of 2, pp 301-318.

Park. 2002. *Global biogeochemical cycle of boron*. Division of Earth and Ocean Sciences, Nicholas School of the Environment and Earth Sciences, Duke University, Durham, North Carolina, USA and published in *Global Biochemical Cycles*, Vol. 16, No. 4, pp. 1072, 2002.

Pulford, I.D., and C. Watson. 2003. *Phytoremediation of heavy metal-contaminated land by trees—a review*. Environment International, Volume 29, Issue 4, pp 529-540.

SAMCO. 2019. *What to Know About Ion Exchange Resin Regeneration – December 18, 2017*; website accessed July 13, 2019: <https://www.samcotech.com/know-ion-exchange-resin-regeneration/>.

Sajad, A., and Muhammad. 2013. *Phytoremediation of heavy metals—Concepts and applications*.

Snow, D.T. 1968. Rock Fracture Spacing, Openings, and Porosities. American Society Civil Engineers Proceedings, Journal Soil Mechanics and Foundation. DIV94:1. Pp 1273-1289

Suponik, T., and M. Blanco. 2014. *Removal of heavy metals from groundwater affected by acid mine drainage*. Physicochemical Problems of Mineral Processing. 50, pp 359-372.

SynTerra. 2017. *Surface Water Sampling to Assess 15A NCAC 2B Compliance for Implementation of Corrective Action Under 15A NCAC 02L .0106 – Cliffside Steam Station – March 2017*. Mooresboro, NC.

SynTerra. 2018a. *2018 Comprehensive Site Assessment Update – Cliffside Steam Station – January 31, 2018*. Mooresboro, NC.

SynTerra. 2018b. *Human Health and Ecological Risk Assessment Summary Update - Cliffside Steam Station*. Mooresboro, NC.

SynTerra. 2019a. *Ash Basin Pumping Test Report for Cliffside Steam Station – January 2019*. Mooresboro, NC.

SynTerra. 2019b. *CCR Assessment of Corrective Measures Report – Active Ash Basin – Rogers Energy Complex – April 10, 2019*. Mooresboro, NC.

SynTerra. 2019c. *CCR Assessment of Corrective Measures Report – Inactive Units 1-4 Ash Basin – Rogers Energy Complex – April 10, 2019*. Mooresboro, NC.

SynTerra. 2019d. *CCR Assessment of Corrective Measures Report – Unit 5 Inactive Ash Basin – Rogers Energy Complex – April 10, 2019*. Mooresboro, NC.

SynTerra. 2019e. *2018 Annual Interim Monitoring Report for Rogers Energy Complex – April 30, 2019*. Mooresboro, NC.

SynTerra. 2019f. *Updated Background Threshold Values for Constituent Concentrations in Soil and Groundwater*.

Takano. 2006. *The Arabidopsis Major Intrinsic Protein NIP5;1 Is Essential for Efficient Boron Uptake and Plant Development under Boron Limitation*; published in The Plant Cell, Vol. 18, 1498–1509, June 2006, www.plantcell.org, 2006, American Society of Plant Biologists.

Thustoš et al. 2007. *Variation in the uptake of Arsenic, Cadmium, Lead, and Zinc by different species of willows Salix spp. grown in contaminated soils*. Central European Journal of Biology.

USDA. 2019. *Web Soil Survey*; website accessed June 20, 2019:
<https://websoilsurvey.nrcs.usda.gov/app/WebSoilSurvey.aspx>.

USEPA, 1982, Benefits and Implementation Potential of Wastewater Aquaculture, U.S. Environmental Protection Agency, January 1982.

USEPA. 1988. *Guidance for Collecting Remedial Investigations and Feasibility Studies Under CERCLA*.

USEPA. 1989. *Risk Assessment Guidance for Superfund*. Volume 1: Human Health Evaluation Manual, Part A. EPA/5401S40/1-89/002. Office of Emergency and Remedial Response, Washington, D.C. December.

USEPA. 1991a. Guidelines for Developmental Toxicity Risk Assessment. U.S. Environmental Protection Agency. Federal Register 56(234):63798-63826.

USEPA. 1994. *Engineering Bulletin – In Situ Vitrification Treatment*. EPA/540/S-94/504, Office of Emergency and Remedial Response, Washington, DC 20460.

USEPA. 1995. *In Situ Remediation Technology Status Report: Hydraulic and Pneumatic Fracturing*. EPA542-K-94-005, Office of Solid Waste and Emergency Response, Washington DC 20460.

USEPA. 1996. *Soil Screening Guidance: Technical Background Document*. Office of Emergency and Remedial Response. U.S. Environmental Protection Agency. Washington, D.C. Publication 9355.4-17A. May 1996.

USEPA. 1997. *Permeable Reactive Subsurface Barriers for the Interception and Remediation of Chlorinated Hydrocarbon and Chromium (VI) Plumes in Ground Water*. U.S. EPA Remedial Technology Fact Sheet (EPA/600/F-97/008). National Risk Management Research Laboratory Ada, OK 74820.

USEPA. 1998. *Guidelines for Ecological Risk Assessment*. U.S. Environmental Protection Agency. EPA/630/R-95/002F. April 1998.

USEPA. 1999. *Use of Monitored Natural Attenuation at Superfund, RCRA Corrective Action, and Underground Storage Tank Sites*; Office of Solid Waste and Emergency Response Directive 9200.4-17P. April 21, 1999.

USEPA. 2002. *Advances in Encapsulation Technologies for the Management of Mercury-Contaminated Hazardous Wastes*; prepared by Battelle, 505 King Avenue, Columbus, OH 43201-2693. August 30, 2002.

- USEPA. 2007. *Monitored natural attenuation of inorganic contaminants in ground water technical basis for assessment, volume I*, October 2007. United States Environmental Protection Agency. EPA/600/R-07/139.
- USEPA. 2009. *Assessing the Use and Application of Zero-Valent Iron Nanoparticle Technology for Remediation at Contaminated Sites*; prepared by Sean M. Cook, Jackson State University for USEPA Office of Superfund Remediation and Technology Innovation, Washington, DC.
- USEPA. 2011. *Environmental Cleanup Best Management Practices: Effective Use of the Project Life Cycle Conceptual Site Model*, July 2011. United States Environmental Protection Agency. EPA 542-F-11-011.
- USEPA. 2012a. 2012 Edition of the Drinking Water Standard and health Advisories. Office of Water, Washington, D.C. EPA 822-S-12-001.fre
- USEPA. 2012b. The Impact of Coal Combustion Fly Ash Used as a Supplemental Cementitious Material on the Leaching Constituents from Cements and Concretes. EPA 600/R-12/704.
- USEPA. 2015. *Comprehensive Site Assessment Report – Cliffside Steam Station Ash Basin*. United States Environmental Protection Agency.
- USEPA. 2017a. *National Functional Guidelines for Organic Superfund Methods Data Review*.
- USEPA. 2017b. *National Functional Guidelines for Inorganic Superfund Methods Data Review*.
- USEPA, 2018a. National Recommended Water Quality Criteria-Aquatic Life Criteria Table. Website <https://www.epa.gov/wqc/national-recommended-water-quality-criteria-aquatic-life-criteria-table>
- USEPA, 2018b. National Recommended Water Quality Criteria-Human Health Criteria Table. Website <https://www.epa.gov/wqc/national-recommended-water-quality-criteria-human-health-criteria-table>
- USEPA. 2018c. *Superfund task Force Recommendation #3: Broaden the Use of Adaptive Management*; Memorandum from J.E. Woolford, Director of Superfund Remediation and Technology Innovation to Superfund National Program Managers, Regions 1-10; July 3, 2018.

USGS. 2008. *Hydrogeologic Setting, Ground-Water Flow, and Ground-Water Quality at the Langtree Peninsula Research Station, Iredell County, North Carolina, 2000-2005*. North Carolina Department of Environment and Natural Resources, Division of Water Quality.

Wright et al. 2003. *PIMS: an Apatite II Permeable Reactive Barrier to Remediate Groundwater Containing Zn, Pb and Cd*. Published in Environmental Geosciences (2003); Judith Wright, PIMS NW, Inc., 201 N. Edison, Kennewick, WA 99336.

Zhou el.al. 2008. *Synthesis, Characterization and Crystal Structure of a Porous Crystalline Material*. Crystal Research & Technology. Published online <https://doi.org/10.1002/crat.2008002367>.

Zimmerman. 2016. *CCR Surface Impoundment Closure Guidelines for Protection of Groundwater*.

TABLES

(CAP Content Section 9)

Table ES-1
Summary of CSS Assessment
Documentation

Included in Executive Summary text

Table ES-2
Summary of CSS Assessment Activities
Included in Executive Summary text

Table ES-3

Components of Source Control, Active Remediation, and Monitoring

Included in Executive Summary text

TABLE 1-1
SUMMARY OF ONSITE INCIDENTS
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

Station Name	Station Location	DEQ Section	Incident Number	Occurrence Date	Status	Closure Date	Release Type	Latitude	Longitude	Proximity to Basins (ft)	Notes
Cliffside	Mooresboro	UST	3693	7/15/1988	Closed	6/23/1997	Petroleum	35.220833	-81.7575	400	
Cliffside	Mooresboro	UST	28482	10/9/2006	Closed	2/5/2007	Petroleum	35.218611	-81.759722	496	Incident Name: Duke Dozer Diesel
Cliffside	Mooresboro	UST	28594	12/17/2007	Closed	3/7/2008	Petroleum	35.208056	-81.770556	1,251	Incident Name: Duke Energy Parcel 6
Cliffside	Mooresboro	UST	28595	12/13/2007	Closed	3/7/2008	Petroleum	35.207778	-81.765556	548	Incident Name: Duke Energy Parcel 33
Cliffside	Mooresboro	UST	28596	12/21/2007	Closed	3/7/2008	Petroleum	35.208899	-81.77	1,019	Incident Name: Duke Energy Parcel 34
Cliffside	Mooresboro	UST	41322	11/5/2014	Open	NA	Petroleum	35.22	-81.76	560	Incident Name: #5 Fuel Oil Release

Notes:

Onsite incident records provided by Duke Energy

DEQ - Department of Environmental Quality

ft - feet

UST - Underground Storage Tank

NA - Not Available

Prepared By: TIG Checked By: SAS

TABLE 3-1
SUMMARY OF ONSITE FACILITIES
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

Facility Name	Evaluated as Source Area in CAP Update	CSA Schedule	Operational Status	Source Material	Area or Capacity	Rationale for Evaluation
Active Ash Basin	Yes	NA	Inactive	Coal Ash/NPDES Permitted waste streams	86 acres	CAMA regulated unit
Ash Storage Area	Yes	NA	Inactive	Coal Ash	7 acres	Adjacent to and within same groundwater flow regime as AAB
Unit 5 Inactive Ash Basin	Yes	NA	Inactive	Coal Ash	46 acres	CAMA regulated unit
Former Units 1-4 Ash Basin	Yes	NA	Closed	Coal Ash	14 acres	CAMA regulated unit
Unit 6 Source Area	No	March 2020	Not Applicable	Unknown	Unknown	In separate groundwater flow regime from ash basins; select monitoring data included in CAP figures and modeling since certain CAMA wells monitor nearby groundwater. This area has been determined to be a separate source area from the AAB (groundwater is not underflowing Suck Creek at this location contributing to groundwater standard exceedances). Area will be assessed on a separate timeline.
CCP Landfill	No	NA	Operational	Coal Ash and operational waste	Phase 1 – 23.3 acres Phase 2 – 16.9 acres	Not hydrologically connected to the ash basins and with NCDEQ DWM regulatory oversight
Coal Pile	No	March 2020	Operational	Coal	22 acres	Upgradient of U1-4 AB
Gypsum Stack-out Area	No	March 2020	Operational	Gypsum	1 acre	Upgradient of U1-4 AB
Unit 5 Switchyard	No	March 2020	Not Applicable	Coal Ash	Unknown	Not hydrologically connected to the ash basins (north of Broad River)

Prepared by: SAS

Checked by: TJG

Notes:

CSA Schedule - applicable only for units identified in the letter "Final Comprehensive Site Assessment and Corrective Action Plans Approvals for Duke Energy Coal Ash Facilities" (April 5, 2019)

CAMA – North Carolina Coal Ash Management Act of 2014

CAP – Corrective Action Plan

DWM – Division of Waste Management

NA – not applicable

NCDEQ – North Carolina Department of Environmental Quality

TABLE 4-1
BACKGROUND SOIL SAMPLE SUMMARY
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

Soil Boring	Depth Range (ft bgs)	Number of Sampled Intervals
BG-1D	(3.5-10)	2
BG-2D	(3.5-30)	4
MW-30D	(3.5-30)	4
MW-32D	(3.5-20)	3
MW-32S	(22.5-24)	1
MW-42D	(28.5-30)	1
GWA-25D	(8.5-10)	1
BGSB-BG-01	(6-20)	3
BGSB-BG-02	(2-7)	2
BGSB-GWA-25	(6-15)	2
BGSB-MW-30	(6-25)	3
BGSB-MW-32	(2-15)	2

Prepared by: TJG

Checked by: SAS

Note:

ft bgs – feet below ground surface

TABLE 4-2
BACKGROUND VALUES FOR SOIL
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

Constituent	Reporting Unit	PSRG Protection of Groundwater	2018 Background Threshold Value ¹	2019 Updated Background Threshold Value ²	Piedmont Background Threshold Value Range ³
pH*	S.U.	NE	4.0 - 6.8	4.0 - 6.8	2.3 - 9.8
Aluminum	mg/kg	110,000	61,758	81,619	25,978 - 61,758
Antimony	mg/kg	0.9	0.64	0.64	0.177 - 0.9
Arsenic	mg/kg	5.8	7.8	10.26	1.2 - 43.13
Barium	mg/kg	580	198.2	304	122.2 - 1,063
Beryllium	mg/kg	63	1.8	1.769	1.2 - 4.52
Boron	mg/kg	45	31	30	14.4 - 56.3
Cadmium	mg/kg	3	0.03	0.49	0.03 - 1
Calcium	mg/kg	NE	282	1,300	282 - 8,769
Chloride	mg/kg	NE	17	400	12 - 423
Chromium	mg/kg	3.8	142.4	142	20 - 440
Cobalt	mg/kg	0.9	48	47.53	27 - 81.68
Copper	mg/kg	700	40	40	17.4 - 216
Iron	mg/kg	150	74,362	74,362	24,500 - 85,345
Lead	mg/kg	270	44	44.37	7.5 - 95.23
Magnesium	mg/kg	NE	8,225	17,119	760 - 51,829
Manganese	mg/kg	65	672	1,078	370 - 3,388
Mercury	mg/kg	1	0.1	0.10	0.04 - 0.113
Molybdenum	mg/kg	7.1	7.7	4.1	1.83 - 12
Nickel	mg/kg	130	72	72	9.2 - 237
Nitrate (as N)	mg/kg	NE	0.26	0.26	0.25 - 31.2
Nitrate	mg/kg	NE	---	49	40.3 - 43.7
Potassium	mg/kg	NE	13,697	13,697	427 - 35,600
Selenium	mg/kg	2.1	3.8	6.857	1.58 - 5.348
Sodium	mg/kg	NE	198	1,200	198 - 1,500
Strontium	mg/kg	1,500	9.9	9.9	7.1 - 200
Sulfate	mg/kg	1,438 [^]	13	400	12 - 437
Thallium	mg/kg	0.28	1.1	1	0.166 - 2.132
Total Organic Carbon	mg/kg	NE	---	4,960	742 - 4,070
Vanadium	mg/kg	350	161	163.3	42 - 230.9
Zinc	mg/kg	1,200	140	160	60.5 - 325.5

Prepared by: TJG Checked by: VJH

Notes:

2018 Background threshold values were approved by North Carolina Department of Environmental Quality (NCDEQ) on May 14, 2018.

[^] - PSRG Protection of Groundwater value was calculated using the equation shown in **Section 6**

* - Upper and lower threshold values calculated for parameter

¹ - Background threshold values were calculated using data from background unsaturated soil samples collected February 2015 to May 2015.

² - Updated background threshold values were calculated using data from background unsaturated soil samples collected February 2015 to August 2017. The background threshold value updates retained extreme outlier concentrations in background unsaturated soil datasets (SynTerra, 2019).

³ - Piedmont background threshold value ranges include the Duke Energy calculated 2017⁴ and 2019⁵ background threshold values from 10 Duke Energy facilities located in the Piedmont physiographic region (Allen Steam Station⁵, Belews Creek Steam Station⁵, Buck Steam Station⁴, Cape Fear Steam Electric Plant⁴, Cliffside Steam Station⁵, Dan River Steam Station⁴, Marshall Steam Station⁵, Mayo Steam Electric Plant⁵, Riverbend Steam Station⁴, and Roxboro Steam Electric Plant⁵).

--- - 2018 background threshold value was not calculated for constituent.

mg/kg - milligrams per kilogram

NE - not established

S.U. - standard unit

PSRG - preliminary soil remediation goals

TABLE 4-3
BACKGROUND VALUES FOR GROUNDWATER
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

Constituent	Reporting Unit	15A NCAC 02L Standard	2017 Background Threshold Values ¹			2019 Updated Background Threshold Values ²			Piedmont Background Threshold Values Range ³
			Shallow Flow Zone	Deep Flow Zone	Bedrock Flow Zone	Shallow Flow Zone	Deep Flow Zone	Bedrock Flow Zone	
pH	S.U.	6.5 - 8.5	4.4 - 6.1	4.8 - 6.1	5.4 - 7.4	4.0 - 6.0	4.9 - 7.2	4.5 - 7.5	3.6 - 9
Alkalinity	mg-CaCO ₃ /L	NE	14	20	53	19	54	56	19 - 379
Aluminum	µg/L	NE	253	290	208	820	483	309	100 - 1,238
Antimony	µg/L	1*	1	1	1	0.5	0.5	1	0.5 - 2.9
Arsenic	µg/L	10	1	1	1	0.2	2	1	0.2 - 6.35
Barium	µg/L	700		23	19	94	44	19	10.52 - 840
Beryllium	µg/L	4*	0.2	0.2	1	0.2	0.2	0.2	0.0625 - 1
Bicarbonate	mg-CaCO ₃ /L	NE	14	18	69	19	58	59	19 - 388
Boron	µg/L	700	50	50	50	50	50	50	50 - 176.8
Cadmium	µg/L	2	1	1	1	0.09	1	1	0.08 - 1
Calcium	mg/L	NE	3	11	16	4	13	17	4 - 111
Carbonate	mg-CaCO ₃ /L	NE	5	5	5	5	5	5	5 - 10
Chloride	mg/L	250	8	5	9	8	8	8	3.34 - 250
Chromium	µg/L	10	4	2	4	26	2	3	43,491
Chromium (VI)	µg/L	NE	0.5	0.2	0.1	4	0.6	0.7	0.03 - 12
Cobalt	µg/L	1*	11	5	1	21	5	2	0.088 - 88.85
Copper	µg/L	1,000	7	10	5	9	8	5	0.5 - 17.15
Fluoride	mg/L	2	---	---	---	0.1	0.1	0.1	0.1 - 1.8
Iron	µg/L	300	684	515	6,220	1,700	1,840	7,680	56.3 - 37,500
Lead	µg/L	15	1	1	1	1	0.3	1	0 - 2
Lithium	µg/L	NE	---	---	---	3	12	11	2 - 95.39
Magnesium	mg/L	NE	2	2	2	2	2	2	1 - 45
Manganese	µg/L	50	169	78	89	969	260	113	2,655,496
Mercury	µg/L	1	0.2	0.2	0.2	0.2	0.2	0.2	0.05 - 0.5
Methane	µg/L	NE	10	3	10	10	10	10	1 - 2,505
Molybdenum	µg/L	NE	1	1	2	0.6	4	2	0.5 - 26.2
Nickel	µg/L	100	6	13	5	12	13	7	0.87 - 48
Nitrate + Nitrite	mg-N/L	NE	9	3	1	4	3	1	0.02 - 6.3
Potassium	mg/L	NE	5	5	5	5	6	5	1.609 - 18.8
Selenium	µg/L	20	1	1	1	0.5	1	1	0.5 - 2.4
Sodium	mg/L	NE	6	4	7	6	9	8	6 - 190
Strontium	µg/L	NE	37	56	107	34	69	93	27 - 2,120
Sulfate	mg/L	250	1	10	15	4	15	17	1.2 - 510
Sulfide	mg/L	NE	0.1	0.1	0.1	0.1	0.1	0.1	0.1 - 2
TDS	mg/L	500	75	71	120	57	107	120	50 - 1,200
Thallium	µg/L	0.2*	0.1	0.1	0.2	0.2	0.2	0.2	0.1 - 0.2
TOC	mg/L	NE	1	1	1	1	2	1	1 - 12.3
Total Radium	pCi/L	NE	3	2	3	2	2	3	0.494 - 35
Total Uranium	µg/mL	NE	0.0005	0.0005	0.0005	0.0005	0.0005	0.0005	0.0002 - 0.864
Vanadium	µg/L	0.3*	1	1	0.4	1	11	1	0.33 - 25.8
Zinc	µg/L	1,000	15	15	10	26	14	15	5 - 140

Prepared by: HES

Checked by: JHG

Notes:

2017 background threshold values (BTVs) approved by North Carolina Department of Environmental Quality (NCDEQ) on September 1, 2017.

Background threshold values (BTVs) have been rounded to similar levels of precision as 15A North Carolina Administrative Code (NCAC) 02L Standard or Interim Maximum Allowable Concentration (IMAC).

--- - BTV was not calculated for constituent.

* - IMAC of the 15A NCAC 02L Standard, Appendix 1, April 1, 2013.

¹ - BTVs were calculated using data from background groundwater samples collected June 2015 to September 2017

² - Updated BTVs were calculated using data from background groundwater samples collected February 2010 to December 2018

³ - Piedmont background threshold value ranges include the Duke Energy calculated 2017¹ and 2019² background threshold values from 10 Duke Energy facilities located in the Piedmont physiographic region (Allen Steam Station², Belews Creek Steam Station², Buck Steam Station¹, Cape Fear Steam Electric Plant¹, Cliffside Steam Station², Dan River Steam Station², Marshall Steam Station², Mayo Steam Electric Plant², Riverbend Steam Station¹, and Roxboro Steam Electric Plant²).

µg/L - micrograms per liter

µg/mL - micrograms per milliliter

mg/L - milligrams per liter

mg-CaCO₃/L - milligrams calcium carbonate per liter

mg-N/L - milligrams nitrogen per liter

NE - not established

pCi/L - picocuries per liter

S.U. - standard units

TDS - total dissolved solids

TOC - total organic carbon

TABLE 4-4
BACKGROUND DATASET RANGES FOR SURFACE WATER
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

Constituent	Reporting Unit	Comparison Criteria	Background Range
Constituents with 15A NCAC 02B (Class Water Supply: WS-IV) Standards			
pH	S.U.	6.0-9.0	6.0 - 8.7
Dissolved Oxygen	mg/L	≥ 4	4.3 - 12.4
Temperature	deg C	≤ 32	5.5 -30.0
Turbidity	NTU	≤ 50	2.5 - 114.0
Arsenic	µg/L	10	0.0002 j - <10
Arsenic (Dissolved)	µg/L	acute: 340, chronic: 150	0.077 j - <1
Barium	µg/L	1000	<5 - 39
Beryllium (Dissolved)	µg/L	acute: 65, chronic: 6.5	<0.01 - <0.2
Cadmium (Dissolved) ¹	µg/L	acute: 0.82, chronic: 0.15	<0.05 - <1
Chloride	mg/L	250	0.0043 j - 20.4
Chromium (III) (Dissolved) ^{1,2}	µg/L	acute: 180, chronic: 24	NA
Chromium (VI) (Dissolved)	µg/L	acute: 16, chronic: 11	NA
Copper (Dissolved) ¹	µg/L	acute: 3.6, chronic: 2.7	<0.11 - 8.2
Fluoride	mg/L	1.8	0.000064 j - <0.5
Lead (Dissolved) ¹	µg/L	acute: 14, chronic: 0.54	0.044 j - <1
Mercury	µg/L	chronic: 0.012	0.000532 B - <0.2
Nickel	µg/L	25	0.2 j - <10
Nickel (Dissolved) ¹	µg/L	acute: 140, chronic: 16	0.16 j - 2.7
Nitrate + Nitrite	mg-N/L	10	<0.02 - 1
Selenium	µg/L	chronic: 5	0.133 j - <10
Silver (Dissolved) ¹	µg/L	acute: 0.3, chronic: 0.06	<0.07 - <1
Sulfate	mg/L	250	0.62 j - 75
Thallium	µg/L	2	<0.015 - <10
Total Dissolved Solids	mg/L	500	<25 - 10,000
Total Hardness	mg/L	100	10.7 - 18.8
Zinc (Dissolved) ¹	µg/L	acute: 36, chronic: 36	<2.5 - 18 j+
Constituents with USEPA National Recommended Water Quality Criteria			
Alkalinity	mg/L	chronic: 20	5.2 - 64.2
Aluminum	µg/L	acute: 620, chronic: 300	69.2 j - 1,760 M1
Antimony	µg/L	5.6	<0.1 - <5
Iron	µg/L	1000	225 - 3,630
Manganese	µg/L	50	17.8 - 160
Constituents without 02B or USEPA Criteria			
Bicarbonate	mg-CaCO ₃ /L	NE	8.3 - 64.2
Boron	µg/L	NE	3.39 j - <50
Cadmium	µg/L	NE	0.035 j - <1
Calcium	mg/L	NE	2.12 - 44.3
Carbonate Alkalinity	mg-CaCO ₃ /L	NE	<1 - 11
Chromium	µg/L	NE	0.0008 j - <10
Chromium (VI)	µg/L	NE	0.021 j - <0.6
Cobalt	µg/L	NE	0.0013 j - 2.1
Copper	µg/L	NE	<0.11 - 2.71 j
Lead	µg/L	NE	0.083 j - <10
Lithium	µg/L	NE	0.45 j - 0.61
Magnesium	mg/L	NE	1.06 - 5.67

TABLE 4-4
BACKGROUND DATASET RANGES FOR SURFACE WATER
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

Constituent	Reporting Unit	Comparison Criteria	Background Range
Constituents without 02B or USEPA Criteria (Continued)			
Methane	µg/L	NE	2.2 j - 344
Molybdenum	µg/L	NE	<0.11 - 1.7
Potassium	mg/L	NE	1.56 - 11.2
Sodium	mg/L	NE	1.57 - 10
Strontium	µg/L	NE	16.3 - 59.3
Sulfide	mg/L	NE	<0.1
Total Organic Carbon	mg/L	NE	0.51 j - 7.7
Total Radium	pCi/L	NE	NA
Total Uranium	µg/mL	NE	NA
Vanadium	µg/L	NE	<0.3 - 5.5
Zinc	µg/L	NE	1.71 j - 47.2 B

Prepared by: LWD Checked by: GRK

Notes:

Background locations were approved by North Carolina Department of Environmental Quality (NCDEQ).

All samples are subject to Class C water quality standards.

¹ Standard value dependent on hardness. Calculated hardness dependent metal standards represent most conservative value. Standards are calculated using 25 mg/L hardness, regardless if actual instream hardness values are greater than 25 mg/L.

² Chromium speciation is not performed for trivalent chromium (Cr(III)). Trivalent values are derived by subtracting hexavalent chromium values from dissolved chromium values. Where a dissolved chromium value is less than the detection limit ("<"), it is considered a whole number for purposes of deriving a trivalent chromium value.

acute - "Compliance with acute instream metals standards shall only be evaluated using an average of two or more samples collected within one hour." Reference 15A NCAC 02B .0211

chronic - "Compliance with chronic instream metals standards shall only be evaluated using averages of a minimum of four samples taken on consecutive days, or as a 96-hour average" Reference 15A NCAC 02B .0211.

< - concentration not detected at or above the adjusted reporting limit.

B - Target analyte detected in method blank at or above the reporting limit. Target analyte concentration in sample is less than 10X the concentration in the method blank. Analyte concentration in sample could be due to blank contamination.

j - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

j+ - Estimated concentration, biased high.

M1 - Matrix spike recovery was high: the associated Laboratory Control Spike (LCS) was acceptable.

Deg C - Degrees Celsius

mg/L - milligrams per liter

µg/L - micrograms per liter

µg/mL - micrograms per milliliter

mg-CaCO₃/L - milligrams calcium carbonate per liter

mg-N/L - milligram nitrogen per liter

NA - not available

NE - not established

NTU - Nephelometric Turbidity Unit

pCi/L - picocuries per liter

S.U. - standard unit

TABLE 4-5
BACKGROUND DATASET RANGES FOR SEDIMENT
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

Constituent	Reporting Unit	Background Range
pH	S.U.	6.2 - 6.7
Aluminum	mg/kg	12,000 - 18,000
Antimony	mg/kg	<0.68 - <0.9
Arsenic	mg/kg	1.4 - 1.5
Barium	mg/kg	47 - 110
Beryllium	mg/kg	0.48 - 1.1
Boron	mg/kg	<3.7 - <4.3
Cadmium	mg/kg	0.052 j - 0.25
Calcium	mg/kg	590 - 1,100
Chloride	mg/kg	9.8 j - <19
Chromium	mg/kg	16 - 26
Chromium (III)	mg/kg	NA
Cobalt	mg/kg	3.6 - 10
Copper	mg/kg	5.2 - 13
Iron	mg/kg	8,300 - 18,000
Lead	mg/kg	7.4 - 12
Magnesium	mg/kg	1,700 - 3,400
Manganese	mg/kg	41 - 350
Mercury	mg/kg	<0.13 - <0.16
Molybdenum	mg/kg	<3 - <3.4
Nickel	mg/kg	5.9 - 10
Nitrate (as N)	mg/kg	<0.35 - <0.41 M
Nitrate	mg/kg	NA
Potassium	mg/kg	1,400 - 2,800
Selenium	mg/kg	<1.8 - <2.3
Silver	mg/kg	<0.74 - <0.86
Sodium	mg/kg	<370 - <430
Strontium	mg/kg	3.5 - 6.9
Sulfate	mg/kg	<18 - <20
Sulfide	mg/kg	<39.8 - <42.9
Thallium	mg/kg	0.22 j - 0.33
Total Organic Carbon	mg/kg	10,300 - 26,900
Vanadium	mg/kg	28 - 51
Zinc	mg/kg	23 - 48

Prepared by: LWD Checked by: GRK

Notes:

Background locations were approved by North Carolina Department of Environmental Quality (NCDEQ).

< - concentration not detected at or above the adjusted reporting limit.

j - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

mg/kg - milligrams per kilogram

M - Matrix spike / matrix spike dup failure.

NA - not available

S.U. - standard unit

TABLE 5-1
APRIL 2019 WATER LEVEL MEASUREMENTS AND ELEVATIONS
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

Well ID	Top of Casing Elevation (ft. NAVD 88)	Top of Screen Elevation (ft. NAVD 88)	Bottom of Screen Elevation (ft. NAVD 88)	April 2019 Measured Water Level (ft. BOTC)	April 2019 Water Elevation (ft. NAVD 88)	Screened Interval (Ft-BGS)	Monitoring Zone Flow
AB-1BROR	773.58	647.39	597.89	61.10	712.48	-	-
AB-1D	773.44	652.30	647.23	61.60	711.84	121.5	126.5
AB-1S	773.19	719.80	704.80	39.65	733.54	54.0	69.0
AB-2BRO	773.47	694.53	624.53	30.66	742.81	-	-
AB-2D	773.00	700.97	695.97	38.13	734.87	72.5	77.5
AB-2S	772.92	729.53	724.53	30.62	742.30	44.0	49.0
AB-3-LA15	796.86	726.08	721.08	-	-	67.5	72.5
AB-3-MA15	796.78	737.52	732.52	35.31	761.47	56.2	61.2
AB-3BR	796.55	617.91	607.91	36.86	759.69	175.5	185.5
AB-3BRA	796.18	--	646.35	74.86	721.32	-	147.5
AB-3BRUA	796.02	668.26	663.26	83.92	712.10	125.0	130.0
AB-3I	795.97	701.62	691.62	34.32	761.65	92.0	102.0
AB-3S	795.64	771.66	756.66	Below Pump	-	22.0	37.0
AB-3SL	796.02	732.36	722.36	34.49	761.53	62.2	72.2
AB-3SLA	796.90	733.75	723.75	-	-	60.0	70.0
AB-4LA15	771.10	735.68	730.68	10.53	760.57	32.4	37.4
AB-4UA15	771.62	753.32	748.32	11.38	760.24	14.9	19.9
AB-4BR	770.66	664.06	659.06	14.48	756.18	104.5	109.5
AB-4D	770.59	713.54	708.54	9.67	760.92	55.0	60.0
AB-4S	770.59	763.51	748.51	10.14	760.45	5.0	20.0
AB-4SL	770.61	739.71	729.71	9.98	760.63	28.7	38.7
AB-5BR	772.13	677.90	673.00	9.45	762.68	91.2	96.1
AB-5BRU	771.81	709.31	704.31	7.32	764.49	60.5	65.5
AB-5S	771.74	763.88	748.88	8.10	763.64	5.0	20.0
AB-6BR	770.61	672.76	667.76	10.61	760.00	96.0	101.0
AB-6D	770.68	702.89	697.89	5.59	765.09	65.8	70.8
AB-6S	770.56	763.38	748.38	6.20	764.36	5.0	20.0
AB-7BR	795.19	607.18	597.18	35.46	759.73	185.5	195.5
AB-7BRU	795.90	646.15	636.15	48.00	747.90	147.0	157.0
AB-7S	795.80	746.15	736.15	34.84	760.96	47.0	57.0
AB-8BR	774.93	655.11	650.11	13.41	761.52	117.0	122.0
AB-8BRU	775.13	685.18	675.18	13.68	761.45	87.0	97.0
AB-8I	774.99	715.21	705.21	13.31	761.68	57.0	67.0
AB-8S	774.91	759.69	749.69	13.01	761.90	12.5	22.5
AB-9BR	771.15	659.30	649.30	11.50	759.65	109.0	119.0
AB-9D	771.04	710.71	700.71	10.87	760.17	57.5	67.5
AB-9S	770.81	754.12	744.12	10.52	760.29	14.0	24.0
AS-1D	809.41	701.52	696.52	77.20	732.21	106.0	111.0
AS-1SB	809.20	723.83	708.83	75.81	733.39	83.0	98.0
AS-2BR	698.74	604.44	599.44	38.61	660.13	92.0	97.0
AS-2D	697.26	640.43	635.43	28.92	668.34	55.0	60.0
AS-2S	697.84	680.23	665.23	22.45	675.39	15.5	30.5
AS-3BRU	754.16	704.11	699.11	49.08	705.08	48.5	53.5
AS-4D	837.71	740.59	735.59	90.29	747.42	95.0	100.0
AS-4S	837.49	751.30	741.30	91.72	745.77	84.4	94.4
AS-5BR	739.77	664.80	659.80	34.16	705.61	75.1	80.1
AS-5BRU	740.45	685.59	680.59	37.68	702.77	55.0	60.0
AS-5S	739.72	710.70	695.70	34.82	704.90	29.3	44.3
AS-6BRA	822.29	665.36	660.36	97.25	725.04	153.5	158.5
AS-6D	818.30	694.17	689.17	93.56	724.74	123.0	128.0
AS-6S	817.74	729.13	714.13	92.70	725.04	86.0	101.0
AS-7BR	742.70	618.29	613.29	35.15	707.55	122.0	127.0
AS-7BRA	737.25	614.37	604.37	46.55	690.70	120.0	130.0
AS-7BRB	746.11	632.21	622.21	52.83	693.28	111.0	121.0
AS-7BRL	733.79	--	--	32.77	701.02	-	-
AS-7D	742.90	658.27	653.27	34.06	708.84	82.5	87.5
AS-7I	735.66	675.89	670.89	30.43	705.23	57.0	62.0
AS-7S	742.06	711.33	696.33	27.56	714.50	28.5	43.5
AS-8BR	725.18	635.51	625.51	94.86	630.32	90.0	100.0
AS-8D	724.95	662.14	657.14	31.12	693.83	62.9	67.9
AS-8S	724.79	702.09	687.09	20.14	704.65	23.0	38.0
AS-9BR	727.49	648.76	638.76	68.90	658.59	79.4	89.4
AS-9D	727.07	693.77	683.77	22.75	704.32	34.0	44.0

TABLE 5-1
APRIL 2019 WATER LEVEL MEASUREMENTS AND ELEVATIONS
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

Well ID	Top of Casing Elevation (ft. NAVD 88)	Top of Screen Elevation (ft. NAVD 88)	Bottom of Screen Elevation (ft. NAVD 88)	April 2019 Measured Water Level (ft. BOTC)	April 2019 Water Elevation (ft. NAVD 88)	Screened Interval (Ft-BGS)	Monitoring Zone Flow
BG-1BRA	806.00	709.84	704.84	24.16	781.84	93.0	98.0
BG-1D	802.63	734.40	729.40	21.02	781.61	66.5	71.5
BG-1S	802.67	780.71	765.71	20.74	781.93	20.0	35.0
BG-2D	846.51	795.65	790.65	42.56	803.95	49.0	54.0
CCPMW-1D	875.89	824.19	819.19	30.56	845.33	49.0	54.0
CCPMW-1S	875.58	843.34	833.34	30.01	845.57	30.0	40.0
CCPMW-2D	842.38	774.91	769.91	35.33	807.05	65.0	70.0
CCPMW-2S	842.24	808.17	798.17	34.29	807.95	32.0	42.0
CCPMW-3D	811.74	786.74	781.74	11.01	800.73	26.0	31.0
CCPMW-3S	811.56	801.54	796.54	9.65	801.91	9.0	14.0
CCPMW-4	845.95	792.62	777.62	22.14	823.81	50.0	65.0
CCPMW-5	858.63	793.23	783.23	38.40	820.23	62.5	72.5
CCPMW-6D	854.35	801.27	791.27	31.86	822.49	50.0	60.0
CCPMW-6S	854.38	817.65	807.65	31.88	822.50	33.5	43.5
CCPTW-1D	838.53	775.30	770.30	23.72	814.81	61.0	66.0
CCPTW-1S	838.92	812.14	802.14	22.21	816.71	25.0	35.0
CCPTW-2	842.18	804.55	794.55	38.05	804.13	35.0	45.0
CCR-7S	790.54	753.30	738.30	38.90	751.64	34.5	49.5
CCR-7D	790.40	701.22	696.22	37.33	753.07	86.0	91.0
CCR-11D	736.83	709.40	704.40	5.62	731.21	24.5	29.5
CCR-11S	737.07	729.27	714.27	6.56	730.51	4.5	20.0
CCR-12S	770.82	734.57	719.57	31.90	738.92	33.0	48.0
CCR-12D	770.10	707.61	702.61	31.25	738.85	59.0	64.0
CCR-12BR	770.85	668.00	663.00	34.64	736.21	100.0	105.0
CCR-13D	787.75	757.37	752.37	25.21	762.54	27.0	32.0
CCR-14D	805.14	754.70	749.70	45.83	759.31	47.0	52.0
CCR-15D	780.40	763.56	758.56	15.69	764.71	15.0	20.0
CCR-16D	780.13	716.90	711.90	13.82	766.31	63.0	68.0
CCR-16S	780.00	762.48	747.48	13.48	766.52	18.0	33.0
CCR-17BR	789.52	716.88	711.88	42.72	746.80	75.2	77.0
CCR-3BR	763.00	620.69	615.69	39.19	723.81	51.5	56.5
CCR-4D	781.43	761.12	756.12	23.98	757.45	17.5	22.5
CCR-5D	784.10	753.75	748.75	25.14	758.96	29.5	34.5
CCR-6D	793.86	732.21	727.21	34.90	758.96	58.5	63.5
CCR-6S	793.69	765.34	750.34	34.40	759.29	29.0	44.0
CCR-8BR	801.98	718.87	713.87	41.62	760.36	80.4	85.4
CCR-8D	798.99	751.13	746.13	38.34	760.65	44.5	49.5
CCR-9D	752.89	727.19	722.19	17.10	735.79	22.5	27.5
CCR-CCP-10DA	853.09	783.12	778.12	30.06	823.03	66.7	71.7
CCR-CCP-10S	853.67	820.17	805.17	30.58	823.09	30.2	45.2
CCR-CCP-11BR	862.61	793.01	788.01	40.38	822.23	71.0	76.0
CCR-CCP-12D	859.70	791.42	786.42	38.33	821.37	68.0	73.0
CCR-CCP-12S	859.59	822.57	807.57	37.45	822.14	37.0	52.0
CCR-CCP-13D	857.00	820.53	815.53	30.45	826.55	33.0	38.0
CCR-CCP-14D	859.86	816.18	811.18	36.74	823.12	39.0	44.0
CCR-CCP-15D	880.12	815.00	810.00	47.22	832.90	66.1	71.1
CCR-CCP-15S	880.10	838.41	828.41	44.60	835.50	44.0	54.0
CCR-CCP-16BR	814.21	699.35	689.35	34.38	779.83	112.1	122.1
CCR-CCP-16S	913.90	771.16	761.16	28.19	885.71	40.0	50.0
CCR-CCP-1D	878.84	820.59	815.59	45.79	833.05	55.0	60.0
CCR-CCP-2D	870.51	815.20	810.20	44.11	826.40	51.0	56.0
CCR-CCP-3DA	858.41	791.03	786.03	49.71	808.70	64.6	69.6
CCR-CCP-3S	862.17	810.01	795.01	50.24	811.93	50.0	65.0
CCR-CCP-4D	855.36	798.88	793.88	47.58	807.78	53.0	58.0
CCR-CCP-5D	847.09	773.51	768.51	41.64	805.45	70.0	75.0
CCR-CCP-5S	847.46	794.88	779.88	42.40	805.06	49.0	64.0
CCR-CCP-6D	834.50	744.09	739.09	24.31	810.19	90.0	95.0
CCR-CCP-6S	834.19	788.68	773.68	18.90	815.29	45.0	60.0
CCR-CCP-7D	841.56	818.53	808.53	22.81	818.75	23.0	33.0
CCR-CCP-8D	845.48	829.08	819.08	24.20	821.28	17.0	27.0
CCR-CCP-9D	842.30	777.37	772.37	21.78	820.52	61.8	66.8
CCR-CCP-9S	841.97	805.88	790.88	23.02	818.95	30.3	45.3
CCR-IB-1S	668.91	663.22	653.22	7.81	661.10	6.0	16.0
CCR-IB-1D	668.76	648.62	643.62	7.37	661.39	20.0	25.0

TABLE 5-1
APRIL 2019 WATER LEVEL MEASUREMENTS AND ELEVATIONS
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

Well ID	Top of Casing Elevation (ft. NAVD 88)	Top of Screen Elevation (ft. NAVD 88)	Bottom of Screen Elevation (ft. NAVD 88)	April 2019 Measured Water Level (ft. BOTC)	April 2019 Water Elevation (ft. NAVD 88)	Screened Interval (Ft-BGS)	Monitoring Zone Flow
CCR-IB-3S	678.74	666.63	651.63	16.68	662.06	12.0	27.0
CCR-IB-3D	678.92	640.67	635.67	17.85	661.07	38.0	43.0
CCR-U5-3S	695.90	686.91	676.91	6.21	689.69	7.0	17.0
CCR-U5-3D	694.88	670.63	665.63	10.54	684.34	22.0	27.0
CCR-IB-3BR	682.56	609.34	604.34	20.91	661.65	69.9	74.9
CCR-U5-10D	785.63	745.25	740.25	22.54	763.09	36.0	41.0
CCR-U5-10S	784.93	763.83	753.83	21.79	763.14	18.0	28.0
CCR-U5-1D	782.01	737.58	732.58	36.68	745.33	41.0	46.0
CCR-U5-2D	775.22	710.40	705.40	63.37	711.85	60.5	65.5
CCR-U5-4BR	696.27	616.98	611.98	8.48	687.79	79.8	84.8
CCR-U5-4D	699.62	664.07	659.07	18.17	681.45	31.0	36.0
CCR-U5-4S	698.27	684.92	669.92	16.85	681.42	10.0	25.0
CCR-U5-5D	768.89	698.49	693.49	57.76	711.13	66.0	71.0
CCR-U5-6DA	719.04	697.59	692.59	8.97	710.07	21.5	26.5
CCR-U5-6S	717.69	708.29	698.29	7.80	709.89	6.0	16.0
CCR-U5-8D	759.63	700.73	695.73	6.00	753.63	58.5	62.5
CCR-U5-8S	760.48	745.96	730.96	7.10	753.38	11.0	26.0
CCR-U5-9S	763.11	754.08	739.08	6.45	756.66	6.0	21.0
CLMW-1	789.08	738.28	728.28	36.84	752.24	47.5	57.5
CLMW-2	728.92	683.84	673.84	36.85	692.07	43.0	53.0
CLMW-3D	774.92	679.47	669.47	44.70	730.22	93.0	103.0
CLMW-3S	775.07	723.62	713.62	44.80	730.27	49.0	59.0
CLMW-5D	775.39	681.39	671.39	-	-	94.0	104.0
CLMW-5S	773.78	723.97	713.97	35.88	737.90	50.0	60.0
CLMW-6	770.86	747.77	737.77	3.50	767.36	20.0	30.0
CLP-1	730.78	700.90	690.90	24.00	706.78	25.0	35.0
CLP-2	672.66	662.39	652.39	15.38	657.28	8.0	18.0
CLP-3	789.33	753.91	743.91	ABD	-	30.0	40.0
CLP-4	794.45	758.81	718.81	36.50	757.95	33.0	73.0
GWA-10D	679.74	632.44	627.44	18.12	661.62	47.6	52.6
GWA-10S	679.55	667.85	652.85	18.32	661.23	12.0	27.0
GWA-11BR	679.48	607.02	602.02	18.96	660.52	69.1	74.1
GWA-11BRL	678.87	504.90	494.90	14.52	664.35	171.0	181.0
GWA-11BRU	674.99	638.20	633.20	13.95	661.04	37.0	42.0
GWA-11S	674.98	663.24	648.24	13.78	661.20	12.0	27.0
GWA-12BRU	719.66	669.95	664.95	35.74	683.92	48.0	53.0
GWA-12S	719.40	698.59	683.59	26.64	692.76	19.0	34.0
GWA-13BR	724.12	643.88	638.88	22.26	701.86	80.5	85.5
GWA-14BR	712.55	593.73	583.73	30.23	682.32	118.5	128.5
GWA-14D	712.52	664.85	659.85	29.86	682.66	48.0	53.0
GWA-14S	712.41	691.41	676.41	DRY	-	21.3	36.3
GWA-1BRU	781.29	756.51	751.51	12.25	769.04	22.8	27.8
GWA-20BR	736.61	679.26	675.26	7.09	729.52	54.0	59.0
GWA-20D	736.24	709.31	704.31	12.21	724.03	25.0	30.0
GWA-20S	736.13	729.68	714.68	8.30	727.83	4.5	19.5
GWA-21BR	672.98	609.66	604.66	0.00	672.98	60.6	65.6
GWA-21BRL	673.22	546.50	536.50	0.00	673.22	125.0	135.0
GWA-21BRU	672.91	650.72	645.72	10.99	661.92	20.0	25.0
GWA-21S	673.32	665.87	655.87	10.50	662.82	5.5	15.5
GWA-22BRU	665.19	646.26	641.26	9.52	655.67	17.0	22.0
GWA-22S	665.19	660.64	650.64	7.40	657.79	2.6	12.6
GWA-23D	786.80	781.34	756.34	27.07	759.73	23.5	28.5
GWA-24BR	798.92	730.95	725.95	13.12	785.80	65.0	70.0
GWA-24D	794.94	765.02	760.02	14.52	780.42	28.0	33.0
GWA-24S	794.47	778.52	768.52	15.68	778.79	14.0	24.0
GWA-25D	792.01	753.49	748.49	21.35	770.66	36.5	41.5
GWA-25S	791.81	779.64	764.64	21.18	770.63	10.0	25.0
GWA-26D	782.98	712.58	707.38	14.62	768.36	68.6	73.8
GWA-26S	783.36	771.23	756.23	15.35	768.01	10.2	25.2
GWA-27BR	805.50	699.21	694.21	48.65	756.85	103.9	108.9
GWA-27DA	805.48	751.95	746.95	49.70	755.78	51.0	56.0
GWA-28BR	757.90	670.91	665.91	44.05	713.85	85.0	90.0
GWA-28BRU	758.35	702.39	697.39	38.80	719.55	53.9	58.9
GWA-28S	757.74	733.48	718.48	31.28	726.46	22.5	37.5

TABLE 5-1
APRIL 2019 WATER LEVEL MEASUREMENTS AND ELEVATIONS
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

Well ID	Top of Casing Elevation (ft. NAVD 88)	Top of Screen Elevation (ft. NAVD 88)	Bottom of Screen Elevation (ft. NAVD 88)	April 2019 Measured Water Level (ft. BOTC)	April 2019 Water Elevation (ft. NAVD 88)	Screened Interval (Ft-BGS)	Monitoring Zone Flow
GWA-29BRA	679.76	638.04	633.04	15.68	664.08	48.4	58.4
GWA-29D	679.56	628.54	618.54	20.63	658.93	20.5	25.5
GWA-2BR	685.43	619.22	614.22	12.43	673.00	63.0	68.0
GWA-2BRA	685.64	625.54	615.54	12.80	672.84	58.0	68.0
GWA-2BRU	685.35	650.86	645.86	12.37	672.98	32.4	37.4
GWA-2S	685.56	677.34	662.34	10.55	675.01	6.0	21.0
GWA-30BR	806.90	740.01	735.01	34.46	772.44	65.0	70.0
GWA-30BRU	806.72	766.88	761.88	25.47	781.25	38.0	43.0
GWA-30S	806.89	787.49	777.49	21.77	785.12	17.5	27.5
GWA-31BRA	757.13	637.16	627.16	45.62	711.51	116.5	126.5
GWA-31D	754.89	742.54	737.54	16.46	738.43	10.4	15.4
GWA-32BR	698.56	636.58	631.58	27.07	671.49	60.0	65.0
GWA-32D	698.53	661.67	656.67	27.20	671.33	35.0	40.0
GWA-33BR	722.94	636.10	631.10	20.83	702.11	85.0	90.0
GWA-33D	722.88	695.11	690.11	4.18	718.70	26.0	31.0
GWA-33S	722.71	715.81	705.81	3.12	719.59	5.0	15.0
GWA-34S	715.88	698.25	683.25	4.50	711.38	14.3	29.3
GWA-34BR	715.38	661.48	651.48	0.00	715.38	51.0	61.0
GWA-35D	697.74	633.25	628.25	23.69	674.05	62.0	67.0
GWA-35S	698.04	675.69	660.69	23.31	674.73	20.0	35.0
GWA-36D	710.53	624.52	619.52	6.33	704.20	83.0	88.0
GWA-36S	710.53	700.80	685.80	7.40	703.13	7.0	22.0
GWA-37D	710.47	612.67	607.67	35.99	674.48	95.0	100.0
GWA-37S	710.56	667.59	652.59	40.02	670.54	40.0	55.0
GWA-38D	760.01	704.28	699.28	52.99	707.02	53.0	58.0
GWA-38S	760.01	721.85	706.85	53.44	706.57	35.0	50.0
GWA-39S	723.41	717.17	715.17	3.08	720.33	3.0	5.0
GWA-3D	757.53	694.08	689.08	56.51	701.02	62.0	67.0
GWA-40S	723.09	716.07	713.07	6.53	716.56	4.0	7.0
GWA-42S	724.65	717.94	712.94	8.76	715.89	4.0	9.0
GWA-43D	725.10	679.85	674.85	15.64	709.46	42.5	47.5
GWA-43S	725.19	716.05	701.05	7.08	718.11	6.0	21.0
GWA-44BR	769.03	671.86	666.86	30.82	738.21	94.1	99.1
GWA-44D	769.07	696.02	691.02	39.62	729.45	70.0	75.0
GWA-44S	768.88	729.71	714.71	41.45	727.43	36.0	51.0
GWA-45D	816.59	730.11	725.11	62.12	754.47	84.0	89.0
GWA-45S	816.55	769.93	759.93	53.02	763.53	45.5	55.5
GWA-46D	788.60	767.55	762.55	25.01	763.59	18.0	23.0
GWA-47D	805.18	752.53	747.53	43.81	761.37	50.0	55.0
GWA-48BR	808.89	723.53	718.53	19.41	789.48	82.0	87.0
GWA-4D	711.64	677.84	672.84	4.06	707.58	32.0	37.0
GWA-4S	711.61	704.83	689.83	2.58	709.03	5.0	20.0
GWA-51D	792.99	734.79	729.79	52.74	740.25	55.5	60.5
GWA-54D	765.03	655.31	650.31	41.51	723.52	107.0	112.0
GWA-54-BRO	764.65	640.01	576.51	41.57	723.08	112.0	175.0
GWA-54S	763.76	723.81	708.81	42.19	721.57	37.0	52.0
GWA-56D	708.70	641.99	636.99	29.78	678.92	67.0	72.0
GWA-56S	708.58	683.82	668.82	27.05	681.53	25.0	40.0
GWA-57BR	730.26	651.42	641.42	32.27	697.99	76.0	86.0
GWA-57BRU	729.66	691.09	681.09	25.60	704.06	36.0	46.0
GWA-57S	729.43	713.28	708.28	11.24	718.19	14.0	19.0
GWA-58BR	732.56	654.03	644.03	27.30	705.26	76.0	86.0
GWA-58BRU	731.83	698.60	693.60	16.46	715.37	31.0	36.0
GWA-58S	731.74	724.20	714.20	14.39	717.35	4.8	14.8
GWA-59BR	756.06	679.82	674.82	27.98	728.08	73.9	78.9
GWA-59D	756.53	717.42	707.42	28.65	727.88	36.2	46.2
GWA-5-BRU	776.73	734.69	729.69	21.38	755.35	40.0	45.0
GWA-5S	777.01	760.93	745.93	20.81	756.20	14.0	29.0
GWA-60BR	763.87	706.40	696.40	23.75	740.12	55.5	65.5
GWA-60BRU	763.99	739.67	729.67	18.17	745.82	22.0	32.0
GWA-61BR	763.74	672.84	667.84	33.04	730.70	88.4	93.4
GWA-61BRU	764.08	715.35	705.35	37.62	726.46	46.4	56.4
GWA-62BR	735.10	679.30	669.30	62.56	672.54	56.0	66.0

TABLE 5-1
APRIL 2019 WATER LEVEL MEASUREMENTS AND ELEVATIONS
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

Well ID	Top of Casing Elevation (ft. NAVD 88)	Top of Screen Elevation (ft. NAVD 88)	Bottom of Screen Elevation (ft. NAVD 88)	April 2019 Measured Water Level (ft. BOTC)	April 2019 Water Elevation (ft. NAVD 88)	Screened Interval (Ft-BGS)	Monitoring Zone Flow
GWA-62BRU	734.65	713.08	708.08	7.89	726.76	22.0	27.0
GWA-63BRU	815.37	746.86	736.86	51.80	763.57	66.0	76.0
GWA-63S	815.08	767.29	762.29	50.29	764.79	46.0	51.0
GWA-64BRL	762.45	534.46	524.46	44.91	717.54	225.0	235.0
GWA-65BR	754.33	685.12	675.12	23.73	730.60	66.1	76.1
GWA-65BRL	754.07	401.23	391.23	15.22	738.85	350.0	360.0
GWA-66BRL	771.11	513.29	493.29	22.93	748.18	254.0	274.0
GWA-67BRL	696.23	586.70	571.70	1.92	694.31	106.5	121.5
GWA-67BRL	692.88	521.06	511.06	0.00	692.88	169.6	179.6
GWA-68BRL	699.30	346.25	336.25	4.97	694.33	350.0	360.0
GWA-6D	809.97	766.30	761.30	30.33	779.64	42.0	47.0
GWA-6S	810.00	777.33	767.33	29.03	780.97	31.0	41.0
IB-6D	675.76	621.41	616.41	17.06	658.70	51.2	56.2
IB-6S	676.14	652.55	642.55	17.43	658.71	20.5	30.5
IB-7S	681.44	658.79	648.79	18.72	662.72	39.8	44.8
IB-7D	681.43	638.73	633.73	19.03	662.40	19.6	29.6
MW-10D	785.50	750.06	745.06	27.41	758.09	32.8	37.8
MW-10S	785.81	763.70	748.70	27.63	758.18	19.7	34.7
MW-11BRL	767.462	469.05	459.05	60.79	706.67	295.2	305.2
MW-11BRO	764.96	709.05	589.05	12.36	752.60	-	-
MW-11D	763.67	723.45	718.45	-	-	37.9	42.9
MW-11DA	765.02	717.43	712.43	30.76	734.26	45.0	50.0
MW-11S	764.51	747.10	732.10	28.45	736.06	15.0	30.0
MW-20D	665.20	656.13	641.13	6.25	658.95	6.5	21.5
MW-20DR	665.38	650.26	600.26	0.00	665.38	12.5	62.5
MW-21BR	777.56	694.40	689.40	14.35	763.21	81.1	86.1
MW-21D	777.51	768.83	754.23	3.80	773.71	6.6	21.2
MW-22BR	821.11	732.66	727.66	25.24	795.87	86.0	91.0
MW-22DR	821.81	778.19	728.39	25.65	796.16	40.4	90.2
MW-23D	734.08	695.09	685.09	16.61	717.47	36.0	46.0
MW-23DR	733.80	685.69	635.69	15.63	718.17	45.0	95.0
MW-23S	733.62	720.94	705.94	15.51	718.11	10.0	25.0
MW-24D	816.36	779.93	760.13	12.90	803.46	33.2	53.0
MW-24DR	816.28	753.01	708.21	8.80	807.48	60.3	105.1
MW-25DR	667.05	627.23	577.53	9.18	657.87	37.3	87.0
MW-2DA	730.62	656.45	651.45	34.08	696.54	71.0	76.0
MW-30D	833.26	745.02	740.02	40.05	793.21	86.1	91.1
MW-30DA	835.05	741.64	736.64	43.57	791.48	87.0	92.0
MW-30S	833.73	798.79	783.79	39.46	794.27	32.7	47.7
MW-32BR	839.40	769.42	764.42	24.30	815.10	62.5	72.5
MW-32D	839.28	788.65	783.65	25.01	814.27	48.5	53.5
MW-32S	839.71	817.64	802.64	26.46	813.25	20.0	35.0
MW-34BRU	751.66	705.94	700.94	28.40	723.26	43.7	48.7
MW-34S	751.87	735.49	720.49	25.08	726.79	14.4	29.4
MW-36BRU	678.40	598.35	593.35	8.58	669.82	77.6	82.6
MW-36S	678.87	672.93	657.93	7.73	671.14	4.0	19.0
MW-38BR	707.70	610.47	605.47	38.68	669.02	97.5	102.5
MW-38D	707.68	638.90	633.90	37.18	670.50	69.0	74.0
MW-38S	707.60	670.17	655.17	38.43	669.17	37.7	52.7
MW-40BRU	709.56	679.69	674.69	4.09	705.47	30.4	35.4
MW-40S	709.38	704.64	689.64	5.29	704.09	5.0	20.0
MW-42DA	812.02	759.44	754.44	34.26	777.76	49.3	54.3
MW-42S	811.47	781.47	771.47	32.73	778.74	28.0	38.0
MW-8D	736.64	704.11	699.11	9.37	727.27	29.8	34.8
MW-8S	736.27	730.88	715.88	6.13	730.14	2.9	17.9
MW-7D	807.35	771.09	766.09	40.74	766.61	33.5	38.5
U5-1D	802.94	746.00	741.00	41.11	761.83	55.0	60.0
U5-1S	802.71	761.82	746.82	40.26	762.45	39.0	54.0
U5-2BR	795.06	700.06	695.06	59.44	735.62	100.3	105.3
U5-2D	793.73	719.99	714.99	56.34	737.39	72.0	77.0
U5-2S-SLA	795.42	742.39	727.39	50.97	744.45	50.0	65.0
U5-2S-SLB	795.56	742.09	727.09	52.21	743.35	51.0	66.0
U5-4BR	765.06	639.90	634.90	75.85	689.21	125.1	130.1

TABLE 5-1
APRIL 2019 WATER LEVEL MEASUREMENTS AND ELEVATIONS
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

Well ID	Top of Casing Elevation (ft. NAVD 88)	Top of Screen Elevation (ft. NAVD 88)	Bottom of Screen Elevation (ft. NAVD 88)	April 2019 Measured Water Level (ft. BOTC)	April 2019 Water Elevation (ft. NAVD 88)	Screened Interval (Ft-BGS)	Monitoring Zone Flow
U5-4BRA	765.11	636.34	626.34	17.80	747.31	129.0	139.0
U5-4D	764.99	661.23	656.23	53.83	711.16	104.2	109.2
U5-4S	764.82	705.59	690.59	50.60	714.22	59.8	74.8
U5-5BR	765.66	660.12	655.12	62.35	703.31	105.5	110.5
U5-5D	765.40	700.98	695.98	57.69	707.71	65.5	69.5
U5-6D	765.19	708.93	703.93	46.36	718.83	56.5	61.5
U5-6S	765.28	728.64	713.64	46.92	718.36	37.0	52.0
U5-8BR	770.31	649.64	644.64	3.28	767.03	120.9	125.9
U5-8D	770.25	699.57	694.57	7.40	762.85	71.0	76.0
U5-8S	770.29	765.63	750.63	5.54	764.75	5.0	20.0

Prepared by: AKM

Checked by: VJH

Notes:

-- not measured or not available

BGS - below ground surface

Ft - Feet

NAVD 88 - North American Vertical Datum 1988

TABLE 5-2
GROUNDWATER BALANCE SUMMARY
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

Modeling Scenario	Pre-Decanting	Closure-in-Place		Closure-by-Excavation	
		Flow in (gpm)	Flow out (gpm)	Flow in (gpm)	Flow out (gpm)
Water Balance Components					
Recharge from capped areas					
Flow removed by Unit 5	10			56	10
Leakage from AAB to GW	65				18
Flow removed by streams or drains in AAB and ASA				114	54
Recharge from Suck Creek to groundwater system	4		17		9
Flow removed by surface water and private wells		337		251	287
Recharge from watershed	562			567	511
Flow removed by General Head Edge of model		24		24	26

Prepared by: SAS

Checked by: TIG

Notes:

- 1) Drainage includes streams, seeps, ditch, channel, canal, etc. Drainage streams included are depending on the scenario, where the pre-decanting scenario includes streams present prior to closure and closure-by excavation includes streams that form within the excavated ash basin footprint after closure.
- 2) Other refers to groundwater flow in/out the watershed that are not accounted in the above categories
Flow in refers to recharge to the groundwater system
Flow out refers to discharge from the groundwater system
gpm - gallons per minute

TABLE 5-3
SURFACE WATER CLASSIFICATIONS
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

Adjacent Surface Water Body	Surface Water Classification (15A NCAC 02B .0300)
Broad River	Class WS-IV
Suck Creek	Class WS-IV
Unnamed Tributary west of U5 AB	Class WS-IV

Prepared by: SAS Checked by: TJG

Notes:

1. Class C waters are protected for uses such as secondary recreation, fishing, wildlife, fish consumption, aquatic life including propagation, and survival.
2. Class WS-IV waters are protected as water supplies that are generally in moderately to highly developed watersheds. WS-IV waters are also subject to Class C water quality standards.

Source Area 1

(Active Ash Basin and Ash Storage Area)

TABLE 6-1
BORON CONCENTRATIONS IN GROUNDWATER BELOW SOURCE AREA
ACTIVE ASH BASIN
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

Well Beneath Ash (Flow Zone)	Number of Sample Events	Time Period of Record	Boron Concentration Range in Groundwater ($\mu\text{g}/\text{L}$)	Boron Concentration Range in Overlying Pore Water ($\mu\text{g}/\text{L}$)
AB-3BRA (Bedrock)	3	11/2018 – 04/2019	<50 ¹	
AB-3BRU/BRUA (Deep)	17	06/2015 – 04/2019	<50 – 72.5	<50 – 4,990 (~30' saturated ash)
AB-3I (Shallow)	16	06/2015 – 04/2019	<50 – 94.4	
AB-4BR (Bedrock)	15	06/2015 – 04/2019	<50 – 70	
AB-4D (Deep)	16	06/2015 – 04/2019	<50 ¹	449 – 3,000 (~25' saturated ash)
AB-5BR (Bedrock)	12	03/2016 – 01/2019	<50 ¹	
AB-5BRU (Deep)	14	06/2015 – 01/2019	<50 ¹	2,940 – 6,150 (~45' saturated ash)
AB-6BR (Bedrock)	15	06/2015 – 01/2019	<50 ¹	
AB-6D (Deep)	15	06/2015 – 01/2019	<50 (one anomalous concentration of 114)	1,960 – 11,300 (~35' saturated ash)
AB-7BR (Bedrock)	2	04/2019 – 06/2019	90 – 93	
AB-7BRU (Deep)	3	04/2019 – 07/2019	89.7 – 100	1,630 – 1,890 (~25' saturated ash)
AB-8BR (Bedrock)	2	03/2019 – 06/2019	331 – 341	
AB-8BRU (Deep)	2	03/2019 – 06/2019	417 – 459	4,330 – 4,390 (~35' saturated ash)
AB-8I (Shallow)	2	03/2019 – 06/2019	807 – 811	
AB-9BR (Bedrock)	2	03/2019 – 06/2019	<50 ¹	
AB-9D (Deep)	2	03/2019 – 06/2019	73 – 81	5,600 – 6,220 (~15' saturated ash)

Prepared by: TJG Checked by: SAS

Notes:

< – Concentration not detected at or above the adjusted reporting limit

¹ – Concentrations have not been detected at or above the adjusted reporting limit across all sampling events

TABLE 6-2
SOIL PSRG POG STANDARD EQUATION PARAMETERS AND VALUES
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

$C_{\text{soil}} = C_{\text{gw}} [K_d + (\theta_w + \theta_a H')/P_b]df$			
Inorganic Parameters	Parameter Definition	Default Values	Units
C_{soil}	Calculated source concentrations for soil	NA	mg/kg
C_{gw}	Applicable groundwater target concentration: 15A NCAC 02L Standard	15A NCAC 02L Standard	mg/L
df	Dilution factor ¹	20	unitless
K_d	Soil -water partition coefficient for inorganics (range)	Constituent Specific ⁴	L/kg
θ_w	Effective porosity - water filled soil porosity vadose soils ²	0.3	L _{water} /L _{soil}
θ_a	Total porosity - Air filled soil porosity - vadose soils ³	0.13	L _{air} /L _{soil}
P_b	dry bulk density ²	1.6	kg/L
H'	Henry's law constant-dimensionless where: H' = Henry's law constant (atm - m ³ /mole) x conversion factor of 41	Constituent Specific ^{3,5}	unitless

Prepared by: SAS Checked by: TJG

Notes:

¹ - Default value from Soil Screening Guidance: Technical Background Document (USEPA, 1996)

² - Site specific value (Falta et al., 2019). Effective porosity represents unconsolidated material.

³ - DEQ default value appropriate for North Carolina

⁴ - Constituent Specific- Soil water partition coefficients (K_d) were obtained from the Groundwater Quality Signatures for Assessing Potential Impacts from Coal Combustion Product Leachate (EPRI, 2012). Sulfate K_d ranges from 0.1 to 2.1, based on sands/sediments and a pH range of 4.6 to 7.2

⁵ - a value of 0 is used for sulfate

NA - Not applicable

NCAC - North Carolina Administrative Code

mg/kg - milligrams per kilogram

mg/L - milligrams per liter

L/kg - liters per kilogram

L_{water}/L_{soil} - volume of water filled spaces per volume of soil

L_{air}/L_{soil} - volume of air filled spaces per volume of soil

kg/L - kilogram per liter

TABLE 6-3
SUMMARY OF UNSATURATED SOIL ANALYTICAL RESULTS
ACTIVE ASH BASIN
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

Analytical Parameters		pH	Arsenic	Boron	Cobalt	Iron	Manganese	Strontium	Sulfate	Thallium	Vanadium
Reporting Units		S.U.	mg/kg	mg/kg	mg/kg	mg/kg	mg/kg	mg/kg	mg/kg	mg/kg	mg/kg
PSRG Protection of Groundwater		NE	5.8	45	0.9	150	65	1,500	1,438	0.28	350
Background Threshold Values		4.0-6.8	7.8	31	48	74,362	672	9.9	13	1.1	161
Sample ID	Sample Collection Date	Analytical Results									
Background											
BGSB-BG-1 (6-7)	10/19/2017	5.0	1.2	<5.1	23	40,000 B	260	1.5	13	0.64	84
BGSB-BG-1 (13-14)	10/19/2017	4.8	0.49	<5.2	6	16,000 B	130	1 j	<11	0.4	42
BGSB-BG-1 (19-20)	10/19/2017	4.6	3	<25	5.2	38,000 B	48	<9.9	<12	0.33	40
BGSB-BG-2 (2-3)	10/19/2017	5.1	6.8	<11	4.1	47,000 B	100	1.2	47	0.29	110
BGSB-BG-2 (6-7)	10/19/2017	5.2	1.3	<12	13	49,000 B	200	<4.7	<13	0.19	120
BGSB-GWA-25 (6-7)	10/19/2017	4.9	1.5	<13	15	52,000 B,M	93	3.7 j	<12	0.65	120
BGSB-GWA-25 (14-15)	10/19/2017	5.2	2.8	<5.1	23	15,000 B	850	1.7 j	<12 M	0.3	44
GWA-25D (8.5 - 10)	05/11/2015	5.1 j	<5.6	<14	11.8	23,500	254	<2.8	<268	<5.6	51.4
Beyond Ash Basin Waste Boundary											
AS-1D (3.5 - 5)	05/13/2015	5.3 j	<7.1	9 j	8.6	12,800	357	<3.5	<347	<7.1	15.8
AS-1D (28.5 - 30)	05/13/2015	6.1 j	<7	16.6 j	10.4	22,800	300	3 j	<356	<7	32.4
AS-1D (58.5 - 60)	05/13/2015	7.2 j	<6.9	<17.2	<6.9	3,120	22.4	8.2	<338	<6.9	<6.9
AS-1D (68.5 - 70)	05/13/2015	5.5 j	<7	<17.4	<7	4,310	30	4.3	<350	<7	<7
AS-4D (63.5 - 65)	05/05/2015	5.6 j	<6.6	<16.6	<6.6	6,690	148	2.1 j	<323	<6.6	<6.6
AS-5BRU (33.5 - 35)	04/10/2015	6.5 j	<6.1	<15.3	<6.1	3,280	95.7	<3.1	<295	<6.1	<6.1
AS-6D (48.5 - 50)	04/30/2015	5.3 j	5.7 j	12.4 j	22.1	14,700	944	<3.1	<323	<6.3	20.9
AS-7D (3.5 - 5)	05/18/2015	5.1 j	<7.7	14.5 j	6.5 j	20,900	168	<3.9	<374	<7.7	24.6
BG-1D (3.5 - 5)	02/23/2015	5.4 j	<3	<3	7.5	35,900	75.2	4.4	<314	<1.2	59.7
BG-1D (8.5 - 10)	02/23/2015	5.7 j	1.4	<13.3	8.1	17,400	64.7	7.6	<267	0.7 j	31
GWA-20D (3 - 5)	04/23/2015	7.8 j	<5	<12.6	2.9 j	5,150	225	2.1 j	<264	<5	10.2
GWA-21BRU (5 - 5)	05/08/2015	7.8 j	2.9 j	<14	7.1	19,200	242	5.4	224 j-	<5.6	22.7
GWA-21BRU (10 - 10)	05/08/2015	5.5 j	3.6 j	<14.8	31.3	23,600	243	3.9	239 j-	<5.9	26.7
GWA-22S (3 - 5)	05/04/2015	9.2 j	<8.1	<20.2	6.6 j	27,900	256	3.9 j	<407	<8.1	50.4
GWA-23D (15.8 - 15.8)	05/08/2015	4.2 j	<5.1	<12.7	21.2	36,800	170	<2.5	<256	<5.1	22.4
GWA-26D (13.5 - 15)	05/07/2015	5.9 j	<6.3	<15.7	5.9 j	16,200	189	<3.1	<322	<6.3	17.8
GWA-27D (13.5 - 15)	03/03/2015	5.5 j	0.95 j	16.1	73.3	17,600	1,240	0.39 j	<292	0.74 j	23.8
GWA-27D (24.9 - 24.9)	06/08/2015	5.6 j	4.8 j	<12.7	73.8	24,900	1,190	<2.5	<252	<5.1	30.3

Prepared by: TJG Checked by: VJH

Notes:

- Bold highlighted concentration indicates exceedance of the Inactive Hazardous Sites Branch PSRG Table (May 2019) for Protection of Groundwater or the Background Threshold Value (BT), whichever is higher.

< - Concentration not detected at or above the adjusted reporting limit.

B - Target analyte detected in method blank at or above the reporting limit. Target analyte concentration in sample is less than 10X the concentration in the method blank. Analyte concentration in sample could be due to blank contamination.

j - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

j- Estimated concentration, biased low.

M - Matrix spike / matrix spike dup failure.

mg/kg - milligrams per kilogram

NE - not established

PSRG - preliminary soil remediation goals

S.U. - standard units

TABLE 6-4
SOURCE AREA INTERIM ACTIONS
ACTIVE ASH BASIN
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

Groundwater Remedy Component	Rationale
Active Ash Basin Decanting	Active source remediation by removing ponded water in the AAB. Decanting will lower the hydraulic head within the coal ash basin and reduce hydraulic gradients, reducing groundwater seepage velocities and COI transport potential. Decanting will return the groundwater flow system to its approximate condition, prior to construction of the ash basin, with the re-establishment of the former Suck Creek stream channel.
Source Area Stabilization	AAB downstream dam modifications including spillway and riser repair and the installation of a new spillway.

Prepared by: SAS Checked by: TJG

Notes:

COI – Constituent of Interest

**TABLE 6-5
MEANS OF GROUNDWATER COIS - JANUARY 2018 TO JUNE 2019**

ACTIVE ASH BASIN	CORRECTIVE ACTIVE PLAN UPDATE	CLIFFSIDE STEAM STATION	DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

TABLE 6-5
MEANS OF GROUNDWATER COIS - JANUARY 2018 TO JUNE 2019
ACTIVE ASH BASIN
CORRECTIVE ACTIVE PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

	Analytical Parameter	pH	Arsenic	Boron	Chromium (VI)	Chromium	Cobalt	Iron	Lithium	Manganese	Strontrium	Sulfate	Thallium	Total Dissolved Solids	Total Radium	Total Uranium	Vanadium
Reporting Units	S.U.	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	pCi/L	µg/L	µg/L	
15A (NCAC) [21] Standard	6.5 - 6.5	10	700	NE	10	1*	21	21	3	969	34	4	0.2	500	0.2*	500	0.3*
2017 Background Threshold Values (Shallow Flow Zone) ¹	4.4 - 6.1	1	50	0.5	4	26	1700	3	169	37	1	0.1	75	3	0.00005	1	0.00005
2019 Background Dataset Range (Shallow Flow Zone) ²	3.3 - 6.1	<0.1 - 0.73	<50	<0.05 - 4.8	<0.5 - 26.2	0.16 - 22.9	<0.5 - 5750	<0.5 - 4.6	6.7 - 1000	6.8 - 103	<1 - 5.5	<0.1 - 0.3	<25 - 10700	0.0976 - 1.961	<0.0002 - <0.0005	<0.3 - 1.9	
2019 Background Threshold Values (Deep Flow Zone) ²	4.8 - 6.1	1	50	0.2	2	5	515	5	515	78	10	0.1	71	2	0.00005	1	0.00005
2019 Background Threshold Values (Deep Flow Zone) ²	4.9 - 7.2	2	50	0.6	2	1840	12	260	69	15	0.2	107	2	0.00005	11	0.00005	
2019 Background Dataset Range (Deep Flow Zone) ²	3.8 - 7.3	<0.1 - 2	<50 - 150	<0.025 - 1.2	<0.1 - 6.1	<0.5 - 3200	1.5 - 134	5.2 - 408	6.3 - 70.5	<1 - 18.5	<0.1 - <0.2	<25 - 407	0.017 - 2.323	<0.0005	<0.3 - 12.2		
2017 Background Threshold Values (Bedrock Flow Zone) ¹	5.4 - 7.4	1	50	0.1	4	1	6220	NE	89	107	15	0.2	120	3	0.00005	0.4	0.00005
2019 Background Threshold Values (Bedrock Flow Zone) ²	4.5 - 7.5	1	50	0.7	3	7680	11	113	93	17	0.2	120	3	0.00005	1	0.00005	
2019 Background Dataset Range (Bedrock Flow Zone) ²	4.8 - 7.6	<0.1 - 1.2	<50 - 83	<0.025 - 0.8	<0.5 - 10.5	<0.1 - 2.6	<50 - 11000	1.1 - 7.3	5 - 134	16.6 - 116	<1 - 17.6	<0.1 - 0.5	<25 - 330	0 - 3.46	<0.0005	<0.3 - 1.5	
Mean, Geometric or Median Result ³																	
Sample ID		Flow Zone															
Within the Waste Boundary Locations (Continued)																	
AE-088R	Bedrock	6.4	0.8	336	<0.025	0.9	1.3	2095	8.3	577	164	13	<0.1	246	1.101	0.0010	0.2
AE-098R	Bedrock	7.4	0.3	<50	<0.025	0.6	0.2	2035	8.3	91	93	15	<0.1	117	0.661	0.0001	0.3
Between Waste Boundary and Compliance Boundary																	
Upgradient of the Ash Basin																	
GWA-23D	Deep	5.2	<0.1	<50	0.062	<0.5	0.8	<50	1.7	9	16	<1	<0.1	61	-	-	<0.3
MW-21D	Deep	5.1	0.1	<50	0.077	<0.5	0.9	1.78	1.5	12	22	2	<0.1	33	-	-	<0.3
MW-24D	Deep	5.2	0.2	<50	0.059	<0.5	0.1	<50	1.6	26	<1	<0.1	41	0.427	<0.0005	<0.3	
CCR-17BR	Bedrock	6.0	<0.1	<50	<0.125	2.0	2.0	143	2.1	47	33	6	<0.1	68	0.906	-	0.3
GWA-48BR	Bedrock	6.7	<0.1	<50	<0.025	0.6	<0.1	2300	6.3	49	66	11	<0.1	91	-	-	0.3
MW-21BR	Bedrock	6.9	0.2	<50	0.029	<0.5	<0.1	<50	4.0	55	53	8	<0.1	99	-	-	0.3
Downgradient of the Ash Basin																	
CCR-06S	Shallow	4.3	7.0	1317	-	2.5	97.6	-	9.1	2.5	50.8	0.5	817	-	-	-	-
CCR-07S	Shallow	6.6	0.2	2714	0.042	0.6	3.0	70	0.9	5496	2648	495	0.5	1153	-	-	<0.3
CCR-11S	Shallow	7.1	0.1	1107	-	<0.5	0.5	-	0.8	125	<0.1	476	0.776	-	-	-	
CCR-12S	Shallow	5.0	0.4	1144	3.475	4.7	16.5	300	3.7	3512	74	47	0.2	2310	-	-	<0.3
CCR-16S	Shallow	4.4	0.9	2580	-	1.1	77.5	-	2.8	-	76	0.2	174	1.493	-	-	<0.3
CLMW-01	Shallow	4.7	0.8	1420	0.203	3.1	2.4	224	1.2	213	895	111	0.5	318	1.446	<0.0005	<0.3
CLMW-06	Shallow	5.0	<0.1	50	0.123	<0.5	11.5	144	1.1	165	17	<1	<0.1	34	-	-	<0.3
GWA-21S	Shallow	6.4	0.2	283	0.104	0.6	13.3	968	<0.5	6013	149	92	<0.1	349	0.487	<0.0005	<0.3
GWA-24S	Shallow	4.8	0.1	<50	0.032	0.6	0.8	243	1.1	22	<5	<1	<0.1	25	-	-	<0.3
GWA-28S	Shallow	4.8	0.2	<50	0.109	1.1	2.3	244	1.8	35	5	2	0.1	30	-	-	0.3
GWA-42S	Shallow	5.3	<0.1	29	0.120	<0.5	0.7	41	-	14	87	49	<0.1	81	-	-	<0.3
GWA-43S	Shallow	5.1	0.1	79	0.464	0.9	1.3	174	0.9	21	167	44	<0.1	92	-	-	<0.3
GWA-57S	Shallow	5.5	0.1	<50	<0.025	0.5	14.5	246	2.9	1895	132	99	<0.1	207	0.518	-	0.3
GWA-58S	Shallow	5.6	0.1	<50	1.700	1.4	4.2	40	2.2	1890	175	245	0.1	510	<1.14	<0.0005	0.3
GWA-63S	Shallow	5.8	<0.1	<50	31.6	2.8	188	2.4	485	13	1	0.1	32	<0.355	<0.0005	<0.3	
MW-08S	Shallow	7.0	0.3	206	0.025	1.0	3.6	1123	<0.5	2910	134	57	<0.1	310	0.976	0.0002	0.4
MW-10S	Shallow	5.1	0.5	216	0.552	1.0	1.6	334	2.1	197	56	60	0.1	189	0.652	-	0.3
MW-11S	Shallow	5.3	0.2	766	1.617	6.0	1.2	235	2.1	1754	47	40	<0.1	230	0.672	<0.0005	<0.3
CCR-04D	Deep	5.4	0.1	36	-	0.5	0.8	-	1.0	-	-	22	0.1	84	0.753	-	-
CCR-05D	Deep	5.2	0.2	55	-	<0.5	10.7	-	1.7	4.0	-	12	0.1	88	0.570	-	-
CCR-06D	Deep	5.0	1.4	1464	-	2.6	5.9	-	4.0	1.1	99	-	196	0.4	361	1.077	-
CCR-07D	Deep	5.6	<0.1	616	0.139	<0.5	<0.1	<50	1.1	895	155	35	0.3	146	1.247	-	<0.3
CCR-08D	Deep	5.2	7.2	11991	0.051	<0.5	4.4	294	<50	4.4	-	2.1	1350	1.5	673	<0.0005	<0.3
CCR-09D	Deep	4.7	2.1	838	-	0.7	83.0	-	4.4	-	-	321	0.1	461	0.716	-	-
CCR-11D	Deep	6.8	0.1	1210	-	<0.5	2.1	-	<0.5	-	-	94	0.2	379	0.837	-	-
CCR-12D	Deep	6.2	0.2	373	0.028	1.2	9.4	12890	6.6	1037	76	25	<0.1	173	-	-	<0.3
CCR-13D	Deep	5.0	<0.1	54	0.028	1.5	82	2.0	35	14	3	<0.1	41	<0.346	-	<0.3	
CCR-14D	Deep	4.7	0.3	1095	-	1.6	-	3.5	-	65	0.2	259	1.260	-	-	<0.3	
CCR-15D	Deep	4.8	<0.1	117	<0.025	1.0	3.6	<50	0.9	102	10	<0.1	39	<0.326	-	<0.3	
CCR-16D	Deep	6.2	0.1	30	-	<0.5	0.2	-	4.4	-	3	<0.1	68	0.716	-	-	<0.3
GWA-20D	Deep	5.7	0.2	921	0.041	<0.5	100	1664	2.0	6015	549	178	0.7	433	1.551	<0.0005	<0.3
GWA-21DA	Deep	5.1	0.2	980	0.127	0.7	0.7	97	1.5	1296	107	65	0.2	261	0.510	<0.0005	<0.3
GWA-28BRU	Deep	6.3	0.3	<50	0.128	0.7	0.3	21.5	<50	53	50	11	<0.1	98	-	-	<0.3
GWA-43D	Deep	6.3	0.1	<50	0.128	0.7	0.7	0.3	<50	165	81	<0.1	253	-	-	-	0.3
GWA-51D	Deep	5.1	1.2	796	0.526	1.9	71.3	141	3.4	8184	237	229	0.3	486	5.815	<0.0005	0.3

TABLE 6-5
MEANS OF GROUNDWATER COIS - JANUARY 2018 TO JUNE 2019
ACTIVE ASH BASIN
CORRECTIVE ACTIVE PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

	Analytical Parameter	pH	Arsenic	Boron	Chromium (VI)	Chromium	Cobalt	Iron	Lithium	Manganese	Strontrium	Sulfate	Thallium	Total Dissolved Solids	Total Radium	Total Uranium	Vanadium
	Reporting Units	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	pCi/L	µg/L	µg/L	
2017 Background Threshold Values (Shallow Flow Zone) ¹	4.4 - 6.1	1	0.2	50	4	26	21	1700	3	969	34	4	0.2	500	0.2*	0.3*	
2019 Background Dataset Range (Shallow Flow Zone) ²	3.3 - 6.1	<0.1 - 0.73	<50	<0.05 - 4.8	<0.5 - 26.2	0.16 - 22.9	<0.5 - 5750	<0.5 - 4.6	6.7 - 1000	6.8 - 103	<1 - 5.5	<0.1 - 0.3	<25 - 10700	0.0976 - 1.961	<0.0002 - <0.0005	<0.3 - 1.9	
2017 Background Threshold Values (Deep Flow Zone) ¹	4.8 - 6.1	1	0.2	50	0.2	2	5	515	78	56	10	0.1	71	2	0.00005	1	
2019 Background Threshold Values (Deep Flow Zone) ²	3.8 - 7.2	2	50	0.6	2	1840	12	260	69	15	0.2	107	2	0.00005	11		
2019 Background Dataset Range (Deep Flow Zone) ²	3.8 - 7.2	<0.1 - 2	<50 - 150	<0.025 - 1.2	<0.1 - 6.1	<0.5 - 3200	1.5 - 134	5.2 - 408	6.3 - 70.5	<1 - 18.5	<0.1 - <0.2	<25 - 407	0.017 - 2.323	<0.0005	<0.3 - 12.2		
2017 Background Threshold Values (Bedrock Flow Zone) ¹	5.4 - 7.4	1	0.1	50	4	1	1	6220	NE	89	107	15	0.2	120	3	0.0005	0.4
2019 Background Threshold Values (Bedrock Flow Zone) ²	4.5 - 7.5	1	0.1	50	0.7	3	2	7680	11	113	93	17	0.2	120	3	0.0005	1
2019 Background Dataset Range (Bedrock Flow Zone) ²	4.8 - 7.6	<0.1 - 1.2	<50 - 83	<0.025 - 0.8	<0.5 - 10.5	<0.1 - 2.6	<50 - 11000	1.1 - 7.3	5 - 134	16.6 - 116	<1 - 17.6	<0.1 - 0.5	<25 - 330	0 - 3.46	<0.0005	<0.3 - 1.5	
Sample ID		Mean / Geometric or Median Result³															
Flow Zone																	
Downgradient of the Ash Basin (Continued)																	
GWA-57BRU	Deep	6.9	1.3	78	<0.025	<0.5	3.3	1330	15.1	286	293	167	<0.1	492	15.405	0.0083	0.9
GWA-58BRU	Deep	5.9	0.3	<50	<0.025	<0.5	11.7	3140	5.0	720	274	260	0.1	507	1.769	0.0006	<0.3
GWA-59D	Deep	5.5	0.7	597	0.166	1.2	118	1210	7.4	9850	200	187	0.3	379	1.933	0.0001	0.4
GWA-63BRU	Deep	6.6	0.4	1.15	<0.125	1.6	643	10.3	91	8	<0.1	153	0.558	0.0002	<0.3		
MW-68D	Deep	6.0	<0.1	130	0.034	<0.5	4.8	35460	10.7	5336	106	52	<0.1	212	4.600	<0.0005	<0.3
MW-10D	Deep	6.0	<0.1	153	0.120	0.9	2.0	193	9.4	252	51	16	0.1	69	0.858	-	0.3
MW-11DA	Deep	6.9	0.5	79	0.048	2.2	51.0	5012	9.4	145	36	<0.1	327	2.833	-	-	
CCR-03BR	Bedrock	6.1	0.5	12	-	3.7	0.8	-	7	<0.1	110	1.124	0.4	243	1.332	<0.0005	<0.3
CCR-12BR	Bedrock	6.3	0.3	901	<0.025	1.2	4.7	541	1.4	2265	306	65	0.725	179	0.725	<0.0005	<0.3
GWA-20BR	Bedrock	8.3	0.7	258	0.027	<0.5	0.3	8625	27.7	489	524	82	<0.1	283	3.673	0.0002	<0.3
GWA-27BR	Bedrock	6.5	0.3	258	0.029	1.4	0.1	997	19.0	29	206	5	<0.1	198	1.255	0.0019	<0.3
GWA-28BR	Bedrock	6.6	0.1	<50	0.031	0.4	0.4	5662	5.3	83	80	7	<0.1	119	-	-	<0.3
GWA-57BR	Bedrock	7.2	0.1	231	<0.025	2.6	0.6	305	3.2	965	199	64	<0.1	324	5.715	0.0009	0.6
GWA-56BR	Bedrock	6.7	<0.1	<50	<0.125	0.6	0.3	19350	11.0	1034	241	124	<0.1	342	10.370	0.0004	<0.3
GWA-59BR	Bedrock	5.8	0.2	593	<0.025	2.1	4760	15.9	922	304	144	<0.1	366	3.221	0.0001	<0.3	
GWA-64BR	Bedrock	7.8	0.6	236	<0.025	0.1	5675	43.5	576	436	21	<0.1	348	3.220	-	-	
GWA-65BR	Bedrock	10.9	-	381	-	-	-	-	-	-	-	-	-	-	-	-	
GWA-65BRL	Bedrock	12.8	-	33	-	-	-	-	-	-	-	-	-	-	-	-	
GWA-66BRL	Bedrock	7.5	0.1	403	<0.025	<0.5	0.2	1480	28.8	299	395	17	<0.1	292	7.135	0.0001	<0.3
MW-11BRL	Bedrock	10.8	-	38	-	-	-	-	-	-	-	-	-	-	-	-	
NW-11BRO	Bedrock	6.6	<0.1	108	<0.025	0.9	0.3	11700	6.5	1497	129	8	<0.1	279	4.270	-	0.3
Near or Beyond Compliance Boundary																	
AS-07S	Ash Pore Water	7.2	83.7	1447	<0.025	1.6	3.5	14176	85.9	12196	2828	497	1.3	1078	0.650	0.0051	1.8
AS-08S	Ash Pore Water	6.7	58.2	147	0.067	0.7	2.4	44114	6.4	293	1318	222	0.2	247	-	0.5	
AS-015B	Shallow	4.3	6.1	1596	0.158	1.4	14.5	8.3	913	113	273	0.6	527	-	0.0011	<0.3	
AS-02S	Shallow	4.5	5.6	1003	0.609	1.6	16.8	<50	2.4	9650	202	315	0.4	524	0.823	<0.0005	<0.3
AS-04S	Shallow	5.9	0.3	<50	0.255	14.8	2.0	336	3.4	107	45	3	0.1	-	-	0.5	
AS-05S	Shallow	5.3	0.3	<50	0.057	1.0	0.2	215	2.9	19	7	<1	<0.1	28	-	<0.0005	<0.3
AS-07I	Shallow	5.4	<0.1	<50	0.150	2.5	0.3	219	1.7	12	100	12	<1	33	0.474	<0.3	
CLMN-02	Shallow	5.5	3.9	645	0.029	<0.5	15.5	3913	4.9	6477	177	209	0.7	447	-	0.0002	<0.3
CLMN-03S	Shallow	4.1	1.1	538	0.105	0.8	18.5	88	5.6	1550	92	226	0.4	451	-	<0.0005	<0.3
CLP-01	Shallow	5.2	0.3	204	0.110	0.6	2.2	127	9.3	345	36	253	0.2	458	<0.333	<0.0005	0.4
CLP-02	Shallow	5.7	0.1	47	<0.025	5.9	2.5	368	-	101	36	14	0.2	58	-	-	0.5
GWA-21S	Shallow	9.4	104	158	0.453	1.5	0.6	23	204	123	27	18	<0.1	70	-	-	0.3
GWA-22S	Shallow	5.5	0.1	264	0.032	1.3	1.6	468	1.2	43	67	3	<0.1	103	0.507	0.0006	6.2
GWA-33S	Shallow	4.9	0.2	<50	1.1	14.6	6.2	6566	546	142	97	<0.1	179	-	0.0000	1.1	
GWA-54S	Shallow	4.9	<0.1	75	0.044	1.0	6.9	137	2.8	219	21	<1	0.2	58	1.219	<0.0005	0.4
MW-23S	Shallow	4.9	0.1	<50	2.360	3.0	1.1	150	2.2	64	120	121	0.1	-	-	<0.3	
AS-01D	Deep	5.5	0.1	672	0.444	2.1	0.4	157	2.5	291	186	56	0.3	167	1.367	<0.0005	0.3
AS-02D	Deep	7.3	1.3	343	0.072	1.5	0.5	286	28.5	471	533	217	<0.1	463	-	0.0002	0.7
AS-03BRU	Deep	5.2	<0.1	<50	<0.025	0.9	0.1	229	1.8	13	19	<1	<0.1	36	-	<0.3	
AS-04D	Deep	5.4	0.1	<50	1.3	0.7	0.2	107	6.2	39	29	1	<0.1	62	0.710	-	0.4
AS-05BRU	Deep	5.8	0.2	<50	0.068	1.8	0.2	271	0.8	12	22	<1	<0.1	41	-	<0.0005	0.3
AS-06D	Deep	5.6	<0.1	<50	0.068	0.9	0.2	126	0.9	11	29	<1	<0.1	50	0.747	-	<0.3

TABLE 6-5
MEANS OF GROUNDWATER COIs - JANUARY 2018 TO JUNE 2019
ACTIVE ASH BASIN
CORRECTIVE ACTIVE PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

Analytical Parameter	pH	Arsenic	Boron	Chromium (VI)	Chromium	Cobalt	Iron	Lithium	Manganese	Strontrium	Sulfate	Thallium	Total Dissolved Solids	Total Radium	Total Uranium	Vanadium
Reporting Units	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	mg/L	µg/L	pCi/L	µg/L	µg/L	
2017 Background Threshold Values (Shallow Flow Zone) ¹	4.4 - 6.1	1	50	0.5	4	26	21	1700	3	969	34	4	0.2	500	0.2*	
2019 Background Dataset Range (Shallow Flow Zone) ²	3.3 - 6.1	<0.1 - 0.73	<50	<0.05 - 4.8	<0.5 - 26.2	0.16 - 22.9	<0.5 - 5750	<0.5 - 4.6	6.7 - 1000	6.8 - 103	<1 - 5.5	<0.1 - 0.3	<25 - 10700	0.00005	<0.0002 - <0.0005	
2019 Background Threshold Values (Deep Flow Zone) ¹	4.8 - 6.1	1	50	0.2	50	2	5	515	NE	37	1	0.1	75	3	1	
2019 Background Threshold Values (Deep Flow Zone) ²	4.9 - 7.2	2	50	0.6	2	1840	12	260	69	15	0.2	107	2	11	<0.3*	
2019 Background Dataset Range (Deep Flow Zone) ¹	3.8 - 7.2	<0.1 - 2	<50 - 150	<0.025 - 1.2	<0.1 - 6.1	<0.5 - 3200	1.5 - 134	5.2 - 408	6.3 - 70.5	<1 - 18.5	<0.1 - <0.2	<25 - 407	0.017 - 2.323	<0.0005	<0.3 - 12.2	
2017 Background Threshold Values (Bedrock Flow Zone) ¹	5.4 - 7.4	1	50	0.1	4	1	6220	NE	89	107	15	0.2	120	3	0.4	
2019 Background Threshold Values (Bedrock Flow Zone) ²	4.5 - 7.5	1	50	0.7	3	2	7680	11	113	93	17	0.2	120	3	1	
2019 Background Dataset Range (Bedrock Flow Zone) ¹	4.8 - 7.6	<0.1 - 1.2	<50 - 83	<0.025 - 0.8	<0.5 - 10.5	<0.1 - 2.6	<50 - 11000	1.1 - 7.3	5.0 - 134	16.6 - 116	<1 - 17.6	<0.1 - 0.5	<25 - 330	0 - 3.46	<0.3 - 1.5	
Sample ID		Mean / Geometric or Median Result ³														
Flow Zone		Mean / Geometric or Median Result ³														
Downgradient of the Ash Basin (Continued)																
AS-07D	Deep	5.5	0.2	836	0.266	1.5	0.3	122	7.7	1950	259	0.1	305	-	< 0.3	
AS-08D	Deep	6.1	0.5	798	<0.025	2.0	8.2	4310	3.8	4968	280	0.15	429	-	< 0.3	
AS-09D	Deep	5.9	0.4	138	0.107	4.2	30.8	265	1.6	470	34	4	73	< 0.366	0.5	
CLIMW-03D	Deep	5.2	0.2	912	0.135	1.1	0.2	283	4.2	295	28.0	< 0.1	529	< 0.0005	0.3	
GWA-21BRU	Deep	6.5	< 0.1	156	< 0.025	< 0.5	1.0	516	1.9	168	174	33	0.1	200	1.184	
GWA-22BRU	Deep	8.0	0.3	< 50	0.069	0.7	< 0.1	174	11.7	11	128	4	< 0.1	146	0.536	
GWA-33D	Deep	6.1	0.2	< 50	0.044	0.4	0.4	709	24.2	89	169	106	< 0.1	278	-	
GWA-47D	Deep	5.3	0.1	333	0.064	0.9	1.1	161	2.8	140	70	< 1	0.1	88	0.6	
GWA-54D	Deep	7.3	0.5	74	0.047	1.0	0.1	851	4.9	210	230	48	< 0.1	292	< 0.3	
GWA-52BRU	Deep	6.5	0.6	72	0.361	2.1	3.8	959	36.0	573	160	146	< 0.1	353	< 1.4	
NW-20D	Deep	6.5	0.2	442	< 0.025	1.5	1.1	3723	2.8	282	148	15	< 0.1	189	< 1.53	
NW-23D	Deep	6.9	0.8	< 50	0.026	0.8	0.7	1028	19.6	632	323	33.5	< 0.1	649	-	
AS-02BR	Bedrock	8.0	2.0	418	0.050	1.3	0.1	1028	12.4	363	222	97	< 0.1	289	< 0.3	
AS-05BR	Bedrock	6.9	0.7	0.928	1.8	< 0.1	12.4	9	47	7	< 0.1	79	-	1.6		
AS-06BRA	Bedrock	6.6	0.3	< 50	0.044	0.8	0.8	99	6.1	26	60	4	< 0.1	96	0.955	
AS-07BRB	Bedrock	7.6	1.6	72	0.127	2.4	0.3	84	2.8	24	78	40	< 0.1	166	0.601	
AS-07BRL	Bedrock	12.0	-	< 50	-	-	-	148	3.8	-	-	-	-	-	-	
AS-08BR	Bedrock	7.3	0.6	43	0.310	1.7	0.2	63	1.3	44	133	71	< 0.1	268	0.760	
AS-09BR	Bedrock	8.1	6.5	< 50	0.057	1.8	0.2	202	4.8	40	49	7	< 0.1	124	< 0.164	
GWA-21BIR	Bedrock	7.2	< 0.1	133	< 0.025	< 0.5	0.4	3630	7.0	410	271	< 1	< 0.1	237	6.116	
GWA-21BRL	Bedrock	7.2	0.4	213	< 0.025	< 0.5	0.2	3520	9.8	662	267	2	< 0.1	268	3.440	
GWA-33BIR	Bedrock	8.2	< 0.1	160	< 0.025	< 0.5	< 0.1	1304	31.1	334	204	79	< 0.1	282	-	
GWA-54BRO	Bedrock	6.6	0.9	92	0.042	4.1	0.2	965	13.9	54	165	109	< 0.1	310	0.878	
GWA-62BIR	Bedrock	9.2	-	307	-	-	-	-	-	-	-	-	-	-	-	
NW-02DA	Bedrock	6.6	0.8	< 50	0.066	1.4	1.6	1609	21.7	801	140	21	< 0.1	143	< 0.3	
NW-20DR	Bedrock	7.1	0.3	< 50	< 0.125	< 0.5	< 0.1	301	8.3	53	106	25	< 0.1	283	< 0.3	
NW-23DR	Bedrock	7.1	0.3	< 50	< 0.125	< 0.5	< 0.1	992	7.3	53	106	25	< 0.1	152	< 0.3	
NW-25DR	Bedrock	6.4	0.6	< 50	0.196	0.6	1.0	53	2.1	10	51	2	< 0.1	70	-	

Prepared by: TIG Checked by: TAW

¹ Background threshold values were calculated using data from background groundwater samples collected June 2015 to September 2017.

² • Background threshold values were calculated using data from background groundwater samples collected March 2011 to December 2018.

³ Mean / geometric, median, or median calculated from data ranging from January 2018 to June 2019. Ash pore water results are not compared to groundwater standards or criteria.

Mean or geometric results were used based on the central tendency of the data set.

Means were calculated for wells with four or more valid sample results. The most recent valid sample data was used.

Means were calculated for wells with four or more valid sample results. Sample results were excluded from calculations.

If turbidity > 10 NTU (for COs other than boron)

2) If a result was non-detect at a reporting limit (RL) greater than the normal laboratory RL

3) If constituent concentration exceeds applicable comparison criteria.

• bold highlighted concentration indicates value is greater than the 15A NACAC 02L, 0202 Standard and INAC is April 1, 2013

Mean or geometric results were used based on the central tendency of the data set.

Means were calculated for wells with four or more valid sample results. Sample results were excluded from calculations.

1) If turbidity > 10 NTU (for COs other than boron)

2) If a result was non-detect at or above the adjusted reporting limit.

• bold highlighted concentration indicates value is either within range of background threshold values for constituents where there is no regulatory standard or within range of background threshold values for constituents where there is no regulatory standard or within range of background threshold value and the regulatory standard

• - indicates not detected or not established

mg/L = milligrams per liter

pCi/L = picocuries per liter

µg/L = micrograms per liter

S.U. = standard unit

Note:
¹ Background threshold values were calculated using data from background groundwater samples collected June 2015 to September 2017.

² • Background threshold values were calculated using data from background groundwater samples collected March 2011 to December 2018.

Mean / geometric, median, or median calculated from data ranging from January 2018 to June 2019. Ash pore water results are not compared to groundwater standards or criteria.

Mean or geometric results were used based on the central tendency of the data set.

Means were calculated for wells with four or more valid sample results. The most recent valid sample data was used.

Means were calculated for wells with four or more valid sample results. Sample results were excluded from calculations.

If turbidity > 10 NTU (for COs other than boron)

2) If a result was non-detect at or above the adjusted reporting limit.

• bold highlighted concentration indicates value is either within range of background threshold values for constituents where there is no regulatory standard or within range of background threshold values for constituents where there is no regulatory standard or within range of background threshold value and the regulatory standard

• - indicates not detected or not established

mg/L = milligrams per liter

pCi/L = picocuries per liter

S.U. = standard unit

TABLE A-6
COI MATRIX
ACTIVE ASH BASIN
CORRECTIVE ACTION PLAN UPDATE
DUKE ENERGY CAROLINES, LLC, WORCESTER, NC

Corrective Action Plan Update Criteria	Reference Criteria	Groundwater 2000 Statistically Derived Background Value ^a (mg/L)	Cliffside Stream Concentrations Data Table Name ^b (All Flow Zones)	Flow Zone	2017	2019	Constituent Standards and Values - 021 Criterion			Lines of Evidence (LoE) - 021 Criterion		
							Maximum Mean Concentration Near Boundary ^c	Background Value Range	Exceedance Ratio ^d	Y	Y	Y
Rationale for Selection of COIs for Corrective Action Evaluation (to contribute where no means or greater than comparative criteria in all flow zones and/or straightforward to the source area, no corrective action is warranted)												
Antimony	10 (µg/L)	Shallow	1	0.2	<0.1 - 2	0.1 - 6.35	10.40	1.04	1	Y	Y	Y
	Groundwater Zone Borehole	1	1				5.50	0.65	0	0	0	N
Boron	700 (mg/L)	Shallow	50	50	<50 - 150	50	1.96	2.28	3	Y	Y	Y
	Tension Zone Borehole	50	50				912	1.30	3	1	1	Y
Chromium (Total)	10 (µg/L)	Shallow	2	2	<0.5 - 26.2	1 - 26	4.23	0.65	0	0	0	N
	Groundwater Zone Borehole	4	3				4.3	0.72	0.42	0	0	N
Iron	3000 (mg/L)	Shallow	684	700	<50 - 11000	56.1 - 37950	6566	3.86	2	Y	Y	Y
	Tension Zone Borehole	620	700				4310	2.34	2	0	0	Y
Manganese	50 (µg/L)	Shallow	149	961	<260 - 1000	7 - 9170	9610	9.96	4	Y	Y	Y
	Tension Zone Borehole	89	117				4988	19.11	8	6	2	Y
Sulfate	4500 (mg/L)	Shallow	1	4	<1 - 18.5	1.2 - 510	801	9.00	6	AS-218, GWA-2188, GWA-2188, GWA-218A, GWA-218B	Y	Y
	Tension Zone Borehole	10	15				315	1.26	3	AS-218, GWA-2188, GWA-218A, GWA-218B	Y	Y
Total Dissolved Solids	5000 (mg/L)	Shallow	71	57	<25 - 10700	50 - 1200	109	1.19	0	AS-15, AS-210	Y	Y
	Tension Zone Borehole	120	125				649	1.30	2	CWAW-10, MW-210	Y	Y
Colibacil	1 (µg/L)	Shallow	11	21	<0.1 - 22.9	0.2 - 88.85	37.1	1.77	1	AS-85, AS-90	Y	Y
	Groundwater Zone Borehole	5	5				30.8	6.16	0	Y	2	Y
Thallium	0.2 (µg/L)	Shallow	0.1	0.2	<0.1 - 0.5	0.1 - 0.2	0.7	3.50	6	AS-SLS-A5-26, AS-71, CLOW-2, CLOW-2, GWA-218, GWA-218S	Y	Y
	Tension Zone Borehole	0.1	0.2				0.3	1.50	1	AS-10	1	Y
Vanadium	0.3 (µg/L)	Shallow	-	1	<0.3 - 13.4	2 - 95.39	0.1	0.1	0	GWA-18, GWA-218, GWA-218B	Y	Y
	Groundwater Zone Borehole	0.4	1				6.20	0.88	7	AS-18, AS-45, AS-88	Y	Y
Chromium (Hexavalent)	NE (µg/L)	Shallow	0.5	4	<0.1 - 22.9	0.2 - 88.85	0.5	1.77	1	CLOW-1, AS-90	Y	Y
	Groundwater Zone Borehole	0.2	0.2				0.80	0	0	Y	2	Y
Lithium	NE (µg/L)	Shallow	-	3	<0.5 - 13.4	2 - 95.39	9.3	3.14	7	AS-SLS-A5-45, AS-71, CLOW-2, CLOW-2, GWA-218, GWA-218S	Y	Y
	Tension Zone Borehole	-	12				36.0	3.00	4	AS-20, AS-218, GWA-218, GWA-218B, MW-210, MW-210B	Y	Y
Selenium	NE (µg/L)	Shallow	37	34	<0.3 - 12	0.38 - 26	31.1	2.83	4	AS-18, AS-218, GWA-218, GWA-218B	Y	Y
	Groundwater Zone Borehole	56	69				204	6.00	9	AS-218, GWA-218, GWA-218B	Y	Y
Total Radium	NE (µg/L)	Shallow	107	107	<0.5 - 13.4	2 - 95.39	51	3.70	8	AS-20, AS-218, GWA-218, GWA-218B, MW-210, MW-210B	Y	Y
	Tension Zone Borehole	2	2				1.4	0.68	0	Y	1	Y
Total Uranium	NE (µg/L)	Shallow	3	3	<0 - 3.46	1 - 35	6.1	2.04	2	GWA-218, GWA-218B	Y	Y
	Groundwater Zone Borehole	100	100				0.0111	2.20	0	AS-18, AS-218, GWA-218, GWA-218B	Y	Y
Total Manganese	NE (µg/L)	Shallow	10005	10005	<0.0005 - 0.0005	0.0002 - 0.0007	0.0005	0.0005	0	AS-20, AS-218, GWA-218, GWA-218B	Y	Y
	Groundwater Zone Borehole	10005	10005				8.80	0.0044	8.80	Y	5	Y

^a Reference Criteria
^b Groundwater Data Table Name
^c Concentration Near Boundary
^d Exceedance Ratio = Concentration Near Boundary / Reference Criteria

¹ Corrective Action Plan Update Criteria
² Sediment and soil were collected from the site in 2013 and analyzed by the laboratory in 2014.
³ Used to evaluate if the ground water value is greater than the reference criteria.
⁴ The exceedance ratio is calculated as the measured concentration divided by the reference criteria.

⁵ Appropriate corrective actions are not identified for this criterion.
⁶ Includes:
CQA - Corrective Action Plan Update
RMC - Resource Management Committee
TAC - Treatment and Control
TCR - Treatment and Control Request
TSC - Treatment System Closure
TTS - Treatment System Transfer
V - Vessel

^a Reference Criteria
^b Groundwater Data Table Name
^c Concentration Near Boundary
^d Exceedance Ratio = Concentration Near Boundary / Reference Criteria

¹ Corrective Action Plan Update Criteria
² Sediment and soil were collected from the site in 2013 and analyzed by the laboratory in 2014.
³ Used to evaluate if the ground water value is greater than the reference criteria.
⁴ The exceedance ratio is calculated as the measured concentration divided by the reference criteria.

⁵ Appropriate corrective actions are not identified for this criterion.
⁶ Includes:
CQA - Corrective Action Plan Update
RMC - Resource Management Committee
TAC - Treatment and Control
TCR - Treatment and Control Request
TSC - Treatment System Closure
TTS - Treatment System Transfer
V - Vessel

Y = Yes

TABLE 6-7
SUMMARY TREND ANALYSIS RESULTS
FOR MONITORING WELLS
ACTIVE ASH BASIN
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

Wells Within the Waste Boundary										Wells Between Waste Boundary and Compliance Boundary										Wells Downgradient of the Source Area Near or Beyond Compliance Boundary									
Well ID	Boron	Lithium	Sulfate	Total Dissolved Solids	Well ID	Boron	Lithium	Sulfate	Total Dissolved Solids	Well ID	Boron	Lithium	Sulfate	Total Dissolved Solids	Well ID	Boron	Lithium	Sulfate	Total Dissolved Solids	Well ID	Boron	Lithium	Sulfate	Total Dissolved Solids					
Ash Pure Water																													
Ab-01S	NT	S	NT	NT	Ab-01S	ND	NT	NT	D	Ab-01S	ND	NE	NE	NE	Ab-01S	ND	NT	D	D										
Ab-23EL	1 (12.0)	NE	D	S	CCR-06S	1 (65.)	NT	NT	S	GWA-08D	1	S	S	S	GWA-08D	ND	NT	D	S										
Ab-03SLA	S	S	S	S	CCR-07S	1 (158.)	S	NT	D	Ab-02D	1	NT	S	I	CCR-05D	ND	ND	NT	S										
Ab-04L1S	NT	NE	D	NT	CCR-12S	S	NT	NT	I	CCR-09D	NT	NT	S	S	CLWW-02	I	I (45.3)	I	I (31.3)										
Ab-04S	I	NT	S	NT	CCR-16S	S	D	D	S	CCR-12D	NT	I (8.5)	S	I	CLWW-03	I (621.)	I (250)	I (51.8)	NW-20DR										
Ab-04SL	NT	S	NT	S	CLWW-04L	S	NT	NT	S	GWA-51D	S	S	D	S	CLWW-03S	I (1000.)	S	I (272.)	I (549.)										
Ab-05S	S	S	S	S	CLWW-05S	1 (47.9)	NT	NT	S	GWA-07D	S	NT	D	I	GWA-22S	I (419.)	S	I	S										
Ab-06S	NT	I (1.30)	NT	D	GWA-20S	ND	S	I	I	GWA-08D	S	I (7.9.)	S	S	GWA-23S	S	S	D	D										
Ab-07S	D	S	D	S	GWA-21S	1 (37.5)	D	NT	S	CCR-06D	I (1490.)	S	I (7.9.)	S	MW-23S	S	NT	S	S										
Shallow Flow Zone																													
Ab-C3A	D	S	D	S	GWA-20S	ND	NE	NE	NT	CCR-05D	NT	NT	NT	NT	Deep Flow Zone	NT	NT	NT	S										
Ab-03BRUA	I	NE	NE	NE	GWA-41S	S	NT	NT	S	CCR-04D	S	NT	S	S	Ab-02D	I	NT	S	I (509.)										
Ab-04D	ND	S	ND	ND	GWA-41S	S	NT	NT	S	CCR-04D	S	NT	S	S	Ab-01D	I (62.)	S	I	I										
Ab-05BRU	ND	S	NT	S	MW-04S	S	I	S	NT	Ab-01BRU	S	NE	NT	I (424.)	Ab-03BRU	ND	S	ND	I										
Ab-06D	ND	S	D	S	MW-04S	D	NT	NT	S	Ab-02BRU	S	NT	S	S	Ab-04D	ND	D	D	S										
Bedrock Flow Zone																													
Ab-04BR	S	S	S	S	Deep Flow Zone	Ab-01D	NT	NT	S	CCR-03BR	ND	S	D	S	Ab-06D	ND	S	NT	NT										
Ab-05BR	ND	S	D	NT	Ab-01D	S	NT	NT	S	CCR-04BR	S	NT	S	S	Ab-07D	I (94.)	NT	I (134.)	I (328.)										
Ab-06BR	ND	S	S	S	CCR-13D	NT	S	S	I (345.)	CCR-07BR	ND	D	S	S	Ab-08D	S	S	S	I (56.1)										
CCR-14D	I (112.0)	D	NT	NT	GWA-20BR	I (359.)	S	S	S	GWA-20BR	I	S	S	S	Ab-09D	NE	NE	NE	NE										
CCR-15D	S	NT	ND	S	GWA-21BR	I (381.)	S	D	S	GWA-21BR	I (381.)	S	D	S	CLWW-03D	I (1170.)	S	I (303.)	I (575.)										
GWA-20D	I (118.0)	NT	I (2.25)	S	GWA-27BR	I (744.)	S	S	S	NW-11BRD	S	S	S	S	GWA-22BRU	ND	S	I	I										
GWA-21BRU	S	NT	D	S	GWA-27DA	S	S	D	I (29.)	GWA-33D	ND	S	I	I	GWA-33D	ND	S	I	I (23.)										
GWA-28BRU	ND	NT	S	S	GWA-41BRD	I (290.)	S	S	I (290.)	GWA-47D	I (399.)	S	ND	S	GWA-47D	I (399.)	S	S	S										
GWA-44D	S	S	I	I (266.)	GWA-54D	I	D	D	I (343.)	MW-20D	I (600.)	S	I	D	MW-20D	I (600.)	S	I	I										
MW-04D	ND	NE	I	S	MW-21D	ND	S	D	D	MW-21D	ND	S	D	D	MW-21D	ND	S	D	NT										
MW-11DA	S	D	D	D	MW-23D	ND	S	S	S	MW-23D	ND	S	S	S	MW-23D	ND	S	S	D										
Bedrock Flow Zone																													
Ab-02BR	S	S	S	S	Ab-02BR	S	S	S	S	GWA-54BR	S	S	S	S	GWA-54BR	S	S	S	S										
GWA-54BR	S	S	S	S	MW-02DA	ND	NE	I	I	MW-02DA	ND	NE	I	I	MW-02DA	ND	NE	I	I										

Notes:

- Summary of results and trends are presented for samples collected from 2008 – 2019.
- Trend results are presented when at least four samples were available and frequency of detection was >50%. Statistically significant trends are reported at the 90% confidence level.
- Variability Index (VI) is calculated as the (maximum - minimum) / median concentration and is calculated using detected concentrations only. Values less than 1 indicate low variability in the dataset.
- For pH, statistically significant, increasing trend with a maximum recent result: (2018 – 2019) Less than the lower end of the standard range or greater than the upper end of the standard range. Maximum detected result for 2018 and 2019 time period shown in parentheses.
5. Wells had insufficient samples collected (n<4) for all four constituents removed from table. See designation NE.

ND = Greater than 50 percent of constituent concentrations were non-detect

D = Statistically significant, decreasing concentration trend

S = Stable, no significant trend and variability is low (VI ≤ 1)

NT = No significant trend and variability is high (VI > 1)

I = Statistically significant, increasing concentration trend

NE = Insufficient number of samples to evaluate trend (n < 4)

TABLE 6-8
SEEP CORRECTIVE ACTION STRATEGY
ACTIVE ASH BASIN
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

Seep ID	Regulatory Program	General Location	Approximate Average Present Flow (cfs)	Anticipated Seep Corrective Action Strategy
S-04	NPDES	Channel flow north of ash storage area	0.05	This location is to be covered by the NPDES permit and designated as Outfall #104.
S-06	NPDES	Channel flow north of toe of AAB downstream dam	0.1	This location is to be covered by the NPDES permit and designated as Outfall #106.
S-07	SOC	Northeast of AAB downstream dam	0.001	As decanting continues, the portion of flow from the AAB to this seep location is expected to be reduced or eliminated. If seep S-7 sustains near its average flow rate after AAB decanting is complete, it is expected that the COI concentrations are reduced. Under these circumstances, the current proposed action for this area is continued monitoring.
S-14	SOC	Toe of AAB upstream dam	<0.001	Location is associated with the AAB upstream dam. Decanting has been effective in reducing visible standing water at the seep location. Further decanting and groundwater corrective action might cause the volume of water at the toe of the AAB upstream dam to reduce more or be eliminated. If the seep continues to have low flow conditions, and is not dispositioned after decanting is complete, phytoremediation technology could be implemented to capture and extract shallow groundwater to reduce or eliminate flow at this seep location.
S-15	SOC	Toe of AAB upstream dam	<0.001	Location is associated with the AAB upstream dam. Decanting has been effective in reducing visible standing water at the seep location. Further decanting and groundwater corrective action might cause the volume of water at the toe of the AAB upstream dam to reduce more or be eliminated. If the seep continues to have low flow conditions, and is not dispositioned after decanting is complete, phytoremediation technology could be implemented to capture and extract shallow groundwater to reduce or eliminate flow at this seep location.

TABLE 6-8
SEEP CORRECTIVE ACTION STRATEGY
ACTIVE ASH BASIN
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

Seep ID	Regulatory Program	General Location	Approximate Average Present Flow (cfs)	Anticipated Seep Corrective Action Strategy
S-16	SOC	Toe of AAB upstream dam	<0.001	Location is associated with the AAB upstream dam. Decanting has been effective in reducing visible standing water at the seep location. Further decanting and groundwater corrective action might cause the volume of water at the toe of the AAB upstream dam to reduce more or be eliminated. If the seep continues to have low flow conditions, and is not dispositioned after decanting is complete, phytoremediation technology could be implemented to capture and extract shallow groundwater to reduce or eliminate flow at this seep location.
S-21	SOC	Toe of AAB upstream dam	<0.001	Location is associated with the AAB upstream dam. Decanting has been effective in reducing visible standing water at the seep location. Further decanting and groundwater corrective action might cause the volume of water at the toe of the AAB upstream dam to reduce more or be eliminated. If the seep continues to have low flow conditions, and is not dispositioned after decanting is complete, phytoremediation technology could be implemented to capture and extract shallow groundwater to reduce or eliminate flow at this seep location.

Notes:

cfs- cubic feet per second

NPDES - National Pollution Discharge Elimination System

SOC - Special Order by Consent

Prepared by: SAS Checked by: TIG

TABLE 6-9
WATER SUPPLY WELL ANALYTICAL RESULTS SUMMARY
CORRECTIVE ACTIVE PLAN UPDATE
CLIFFSIDE STEAM STATION, INC

Sample ID	Sample Date	Analytical Parameter	pH	Turbidity	Boron	Chromium (VI)	Cobalt	Iron	Lithium	Manganese	Sulfate	Thallium	Total Dissolved Solids	Total Radon	Total Uranium	Vanadium	
C1 Well 2	02/04/2015	Reporting Units	NUIS	NTU/s	$\mu\text{g/L}$	$\mu\text{g/L}$	$\mu\text{g/L}$										
15A Nuis	02/04/2015	6.5 - 8.5 NE	10	NE	100	1	300	1	50	50	250	0.2*	500	NE	<5		
2017 Background Values (Bedrock Flow Zone)	5/4 - 7/4 NE	1	50	0.1	4	6220	NE	89	107	15	0.2	120	3	0.0005	<0.4		
2019 Background Dataset Values (Bedrock Flow Zone)	4/5 - 7/5 NE	1	50	0.7	3	7880	11	113	93	17	0.2	120	3	0.0005	1		
Cliffside Background Dataset Range (Bedrock Flow Zone)*	4/8 - 7/6 NE	<0.1 - 1.2	<50 - 83	<0.025 - 0.8	<0.5 - 10.5	<0.1 - 2.6	<50 - 110,000	1.1 - 7.3	5 - 134	16.6 - 116	<1 - 17.6	<0.1 - 0.5	<25 - 330	0 - 3.46	<0.3 - 1.5		
Piedmont Background Value Range (Bedrock Flow Zone)*	4/5 - 9/0 NE	1.0 - 6.0	49.1 - 50	0.03 - 8	2.3 - 11	0.2 - 18	147 - 7680	NE	7 - 17,73	93 - 2272	2 - 130	0.1 - 0.2	120 - 675	1.0 - 6.0	0.0005 - 0.006	0.38 - 26	
Analytical Results																	
C1-001: 2891 Riverfront	10/18/2016	6.4	2.2	0.44	<25	<0.3	<0.5	540	NA	7.6	26	13	NA	42	NA	<5	
C-1002: 2901 Fox Place	10/18/2016	6.2	6.4	0.19	<25	<0.3	<0.5	218	NA	13.1	50.1	9	NA	53	NA	<1	
C-1003	10/18/2016	7.6	<1	0.98	<25	<0.3	<0.5	210	NA	11	48	8.5	NA	60	NA	<5	
C-1004: C2800 Riverfront	05/07/2014	7.0	2.2	1.3	<5	<0.5	<2.3	650	NA	42	39	8.1	NA	54	NA	<5	
C-1005: C2801 Riverfront	10/17/2016	6.4	2.2	0.44	<25	<0.3	<0.5	59	NA	49.6	30.2	7.6	NA	79	NA	<1	
C-1005: 52	10/17/2016	6.1	5.2	0.17	<25	<0.3	<0.5	78	NA	NA	33	2	NA	NA	NA	NA	
C-1005: 54	10/17/2016	7.0	10.8	0.73	<25	<0.5	<0.5	289	NA	47.3	5.9	NA	62	NA	NA	<5	
C-1005: 55	10/17/2016	6.9	4.1	<0.1	<25	<0.3	<0.5	2970	NA	27.6	30.1	15.3	NA	63	NA	<0.3	
C-1005 V1	10/17/2016	5.3	<1	<0.1	<25	<0.3	<0.5	0.46	NA	8.3	65.1	6.1	NA	108	NA	<0.3	
C-1005 V2	10/17/2016	6.1	<1	0.56	<25	<0.3	<0.5	NA	<50	NA	NA	20	NA	NA	NA	ND	
C-1005: V3	10/17/2016	7.0	<1	<0.1	<25	<0.3	<0.5	NA	<50	NA	1.5	20.4	<2	NA	27	NA	
C-1006: 2910 Fox Place	11/03/2016	6.8	1.1	0.3	<25	<0.3	<0.5	311	NA	23.5	41.1	NA	108	NA	NA	<0.3	
C-1007: 433 Dyer Place	10/17/2016	6.1	5.2	0.17	<25	<0.3	<0.5	161	NA	5.4	2.9	NA	36	NA	NA	<0.4	
C-1008B	03/31/2017	7.4	<1	0.23	<25	<0.5	<0.5	540	NA	1.0	20.5	<2	NA	NA	NA	1.1	
C1 Downriver	04/09/2014	5.4	1	<0.1	<25	<0.3	<0.5	1670	NA	56.9	20.4	2.4	NA	43	NA	0.32	
C11	05/01/2015	6.6	4.2	<0.5	<25	<0.3	<0.5	483	NA	56.9	20.4	2.3	NA	34	NA	0.41	
C15	02/04/2015	8.0	2.3	1	<25	<0.3	<0.5	392	NA	59.1	5.4	NA	65	NA	NA	1.1	
C16	02/04/2015	6.6	4.9	<1	<25	<0.5	<0.5	754	NA	34.9	5.5	NA	92	NA	NA	<0.3	
C17	02/04/2015	7.4	<1	0.23	<25	<0.5	<0.5	81.6	NA	14.3	50.9	10.3	NA	104	NA	0.3	
C18	02/04/2015	7.4	1.2	0.25	<25	<0.5	<0.5	166	NA	16.6	53.3	12.7	NA	98	NA	<0.3	
C19	02/04/2015	7.6	2.4	<1	<25	<0.5	<0.5	173	NA	61.5	12	<0.1	115	NA	NA	<0.3	
C23	05/27/2015	6.9	1.1	<0.5	<25	<0.5	<0.5	453	NA	12.3	18.4	<2	NA	<25	NA	<0.3	
C24	08/18/2015	6.4	<1	<0.5	<25	<0.5	<0.5	NA	<50	NA	320	NA	NA	6.8	NA	NA	
C24	09/27/2015	6.4	1	<0.5	<25	<0.5	<0.5	NA	<50	NA	3	35.3	<2	NA	NA	<0.3	
C25	05/27/2015	6.7	<1	<0.5	<25	<0.5	<0.5	2200	NA	230	140	11	NA	190	NA	<0.3	
C26	05/27/2015	6.5	3.9	<1	<25	<0.5	<0.5	380	NA	<5	30	2.6	NA	38	NA	<0.3	
C27	08/17/2015	6.4	1.2	<0.5	<25	<0.5	<0.5	3200	NA	630	81	1.2	NA	350	NA	<0.3	
C28	05/01/2015	6.1	<1	<0.5	<25	<0.5	<0.5	240	NA	<5	2.5	NA	25	NA	NA	<0.3	
C29	05/01/2015	6.2	1.5	<0.5	<25	<0.5	<0.5	110	NA	3.1	15.7	<2	NA	44	NA	<1	
C30	05/01/2015	5.6	<1	<0.5	<25	<0.5	<0.5	40.3	NA	71.4	2.2	NA	101	NA	NA	<1	
C31	02/04/2015	6.4	1	<0.5	<25	<0.5	<0.5	NA	<50	NA	60.8	2	NA	101	NA	<0.3	
C32	05/27/2015	6.5	<1	<0.5	<25	<0.5	<0.5	360	NA	20	51	4.8	NA	48	NA	<0.3	
C33	05/27/2015	6.5	<1	<0.5	<25	<0.5	<0.5	50	NA	2.7	50.2	2.9	NA	90	NA	<0.3	
C34	05/27/2015	6.5	3.9	<1	<0.5	<25	<0.5	540	NA	3.6	2.8	5.6	NA	53	NA	<0.3	
C35	08/17/2015	6.4	1.2	<0.5	<25	<0.5	<0.5	50	NA	28.2	4.8	NA	NA	<1	NA	<0.3	
C36	05/27/2015	6.1	<1	<0.5	<25	<0.5	<0.5	188	NA	2.7	26	3.5	NA	41	NA	<0.3	
C37	05/01/2015	6.2	1.5	<0.5	<25	<0.5	<0.5	57.5	NA	NA	27.1	3	NA	61	NA	<0.3	
C38	05/01/2015	7.2	<1	<0.5	<25	<0.5	<0.5	360	NA	20	51	4.8	NA	48	NA	<0.3	
C39	05/01/2015	5.7	<1	<0.5	<25	<0.5	<0.5	141	NA	2.7	50.5	4.4	NA	36	NA	<0.3	
C40	05/01/2015	7.1	<1	<0.5	<25	<0.5	<0.5	324	NA	11	2.5	NA	NA	<10	NA	<0.3	
C41	05/01/2015	7.0	210	<1	27	<20	6.7	50	NA	3200	NA	11	24	7	NA	160	ND
C42	05/01/2015	6.6	<1	<0.5	2.2	<2	0.5	NA	<50	NA	1	20.2	2.3	NA	80	NA	<0.3
C43	05/01/2015	7.6	<1	<0.5	0.9	<0.5	0.5	NA	<50	NA	33	NA	2	NA	94	NA	<0.3
C44	05/01/2015	6.2	<1	<0.5	0.74	0.86	0.72	NA	<50	NA	11	1.6	<2	NA	59	NA	<0.3
C45	05/01/2015	5.6	34.8	<0.5	6.5	<0.3	2.2	1.6	<50	NA	16.0	14.9	5.9	NA	45	NA	<0.3
C46	05/01/2015	5.7	<1	<0.5	6.2	0.01	2.2	0.05	<50	NA	2.3	2.6	NA	32	NA	<1	ND
C47	05/01/2015	7.1	<1	<0.5	<0.3	<0.5	<0.5	749	NA	32.4	48.9	6.2	NA	97	NA	<1	No

Prepared by On Behalf Of Duke Energy.

Printed by On Behalf Of Duke Energy.

Reviewed by On Behalf Of Duke Energy.

Approved by On Behalf Of Duke Energy.

Final Review by On Behalf Of Duke Energy.

Final Approval by On Behalf Of Duke Energy.

Submitted by On Behalf Of Duke Energy.

Received by On Behalf Of Duke Energy.

Accepted by On Behalf Of Duke Energy.

Revised by On Behalf Of Duke Energy.

Revised by On Behalf Of Duke Energy.

Revised by On Behalf Of Duke Energy.

mL/min/mile

kg/mile

µg/L

kg/m³

mg/L

µg/L

mg/L

ppb

ppb

ppb

ppb

ppb

ppb

ppb

ppm

ppm

ppm

ppm

ppm

ppm

ppm

ppb

TABLE 6-10
NPDES PERMIT LIMITS AND ANTICIPATED GROUNDWATER REMEDIATION PARAMETER LEVELS
ACTIVE ASH BASIN
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

NPDES Outfalls	Outfall 002 ¹		Outfall 005		Maximum Detected Concentrations by Flow Zone²		
Effluent Limitations and Monitoring Requirements							
Parameter	Monthly Average	Daily Maximum	Monthly Average	Daily Maximum	Saprolite	Transition Zone	Bedrock
Flow (MGD)	NS	1 MGD	NS	NS	NA	NA	NA
Oil & Grease	15.0 mg/L	20.0 mg/L	15.0 mg/L	20.0 mg/L	NA	NA	NA
TSS	30.0 mg/L	50.0 mg/L	30.0 mg/L	50.0 mg/L	23.2 mg/L	14.7 mg/L	15.8 mg/L
Total Chromium	0.2 mg/L	0.20 mg/L	0.2 mg/L	0.2 mg/L	0.008 mg/L	0.02 mg/L	0.02 mg/L
Total Zinc	1.0 mg/L	1.0 mg/L	1.0 mg/L	1.0 mg/L	0.07 mg/L	0.04 mg/L	0.04 mg/L
pH	From 6.0 to 9.0 S.U.		From 6.0 to 9.0 S.U.		4.1 - 5.8 S.U.	4.4 - 9.7 S.U.	6.4 - 8.3 S.U.
Total Copper ³	NA	NA	251 µg/L	272 µg/L	3.6 µg/L	5.3 µg/L	4.9 µg/L
Chronic Toxicity	NA	NA	Note 4		NA	NA	NA
Total Iron ³	NA	NA	1.0 mg/L	1.0 mg/L	4.58 mg/L	9.37 mg/L	2.55 mg/L
Total Residual Chlorine	NA	NA	NS	28 µg/L	NA	NA	NA
5-day BOD; 20° C	NA	NA	30.0 mg/L	45.0 mg/L	NA	NA	NA
Fecal Coliform (geo. Mean)	NA	NA	200/100 mL	400/100 mL	NA	NA	NA
Temperature	NA	NA	NS	100° F	NA	NA	NA

Prepared by: VTV

Checked by TIG

Notes:

- 1 - Effective beginning on the commencement of the dewatering operation and lasting until permit expiration.
- 2 - Downgradient groundwater monitoring wells in area of groundwater remediation; Q1 2018 through Q2 2019 data.
- 3 - Monitoring shall be per occurrence of chemical metal cleaning and sample from a representative discharge.
- 4 - Chronic Toxicity (Ceriodaphnia) P/F at 3.14%; March, June, September, and December.

MGD - million gallons per day

NS - not specified

NA - not analyzed

TSS - total suspended solids

S.U. - standard units

BOD - biological oxygen demand

mg/L - milligrams per liter

µg - micrograms per liter

mL - milliliters

TABLE 6-11
FEATURE IRRIGATION SYSTEM SETBACK
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

Feature	Irrigation System Setback (feet)	
	Spray	Drip
Private residence	400	100
Place of assembly owned by permittee	200	15
Surface waters	100	100
Property line	150	50

Prepared by: VTV Checked by: TJG

TABLE 6-12
REMEDIAL TECHNOLOGY SCREENING SUMMARY
ACTIVE ASH BASIN
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

Summary of Remedial Technology Screening		Retain Technology for Further Consideration	
Technology	Yes/No	Rationale	
Monitored Natural Attenuation (MNA)	Yes	COIs pose no unacceptable risk to human health or the environment under conservative exposure scenarios. MNA could be implemented in conjunction with source control measures.	
In-Situ Technologies			
Low Permeability Barriers (LPB)	No	Technically challenging and costly.	
Groundwater Flushing	Yes	Possible application to enhance capture of mobile COIs (e.g., boron) or to add amendments to immobilize certain COIs.	
Encapsulation	No	No area where COIs are concentrated.	
Permeable Reactive Barrier (PRB)	No	Boron is not amenable to treatment in a PRB.	
Groundwater Extraction Technologies			
Vertical Extraction Wells	Yes	Commonly used technology for groundwater extraction.	
Horizontal or Angular Extraction Wells	No	Modeling indicates that vertical extraction wells are sufficient.	
Extraction Trenches	No	Modeling indicates that vertical extraction wells are sufficient.	
Hydraulic Fracturing	No	Not warranted based upon the limited extent of COIs in bedrock.	
Phytoremediation	No	Limited additional mass removal.	
Groundwater Treatment Technologies			
pH Adjustment	Yes	Retained for remedial alternatives that include groundwater extraction.	
Precipitation	Yes	Part of the treatment in the WWTP associated with Outfall 005.	
Ion Exchange	No	Expensive and not expected to be needed to meet discharge requirements.	
Membrane Filtration	No	Expensive and not expected to be needed to meet discharge requirements.	

TABLE 6-12
REMEDIAL TECHNOLOGY SCREENING SUMMARY
ACTIVE ASH BASIN
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

Summary of Remedial Technology Screening		Retain Technology for Further Consideration	
Technology	Yes/No	Rationale	
Management of Extracted Groundwater			
NPDES Permitted Discharge	Yes	Potential to discharge at Outfall 002 or 005; must modify permit to include discharge of extracted groundwater	
Publicly Owned Treatment Works (POTW)	No	Would require installation of infrastructure; NPDES is a better option.	
Non-Discharge Permit/Infiltration Gallery	No	Site soils have limited capacity to transmit water.	
Non-Discharge Permit/Land Application	No	Will not be considered as long as disposal via NPDES permitted outfall is a viable option.	
Beneficial Reuse			
Fire Protection	No	Limited application. Storage is problematic	
Non-Contact Cooling Water	No	Limited application.	
Dust Suppression and Truck Wash	No	Limited application.	

Prepared by: JEC Checked by: TJG

TABLE 6-13
REMEDIAL ALTERNATIVE 2 GROUNDWATER EXTRACTION
AND CLEAN WATER INFILTRATION WELL SUMMARY
ACTIVE ASH BASIN
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

Groundwater Extraction Well System		
Number of Wells	Flow Zone	Total Depth (ft bgs)
3	Saprolite	54 - 60
4	Saprolite/Transition Zone	92 - 112
16	Saprolite/Transition Zone/Bedrock	69 - 153
Total Extraction Well Count: 23		
Groundwater extraction system flow and operation assumptions: Modeled groundwater extraction rate: 0.4 to 7.8 gpm per well; average 5.3 gpm per well. Estimated total system groundwater extraction rate: 122 gpm. Groundwater extraction wells operate to maintain water level near top of the submersible pump.		
Groundwater Infiltration Well System		
Number of Wells	Flow Zone	Total Depth (ft bgs)
21	Saprolite	30 - 79
17	Saprolite/Transition Zone	70 - 108
8	Saprolite/Transition Zone/Bedrock	87 - 134
1 Horizontal Well	Saprolite	5
Total Infiltration Well Count: 47		
Groundwater infiltration system flow and operation assumptions: Modeled groundwater extraction rate: 1.6 to 5.7 gpm per well; average 3 gpm per well. Modeled horizontal well groundwater infiltration rate: 44.7 gpm per well. Estimated total system groundwater infiltration rate: 184 gpm.		

Prepared by: RAG

Checked by: GTC

Notes:

ft bgs – feet below ground surface

gpm – gallons per minute

TABLE 6-14
ENVIRONMENTAL SUSTAINABILITY COMPARISONS FOR REMEDIATION ALTERNATIVES
ACTIVE ASH BASIN
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS LLC, MOORESBORO, NC

Remedial Alternative	Remedial Alternative 1 – Groundwater Remediation by MNA	Remedial Alternative 2 – Groundwater Remediation by Extraction and Clean Water Infiltration	Remedial Alternative 3 – Groundwater Remediation by Extraction and Clean Water Infiltration Wells and Galleries
Emissions	Units		
CO ₂ Emissions	metric ton	2.07E+01	4.57E+03
Onsite NO _x emissions	metric ton	2.43E-02	1.26E+01
Onsite SO _x Emissions	metric ton	2.48E-03	1.29E+00
Onsite PM ₁₀ Emissions	metric ton	2.19E-03	1.14E+00
Total NO _x emissions	metric ton	4.25E-02	2.21E+01
Total SO _x Emissions	metric ton	1.34E-02	8.84E+00
Total PM ₁₀ Emissions	metric ton	3.88E-03	5.85E+00
Total Energy Used	MMBTU	3.88E+03	7.50E+05
Total Emissions	metric ton	2.08E+01	4.62E+03

Notes:

CO₂ - Airborne emissions of carbon dioxide

MMBTU - Million British Thermal Units

NO_x - Airborne emissions of nitrogen oxides (combination of nitrogen monoxide and nitrogen dioxide)

SO_x - Airborne emissions of sulfur oxides (combination of sulfur monoxide, sulfur dioxide, sulfur trioxide, and others)

PM₁₀ - Airborne emissions of particulate matter that is 10 micrometers or less in diameter

Prepared by: GTC

Checked by: SJB

TABLE 6-15
MODELED CLEAN WATER INFILTRATION WELL DETAILS
ACTIVE ASH BASIN
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

Well ID	Easting	Northing	Approximate Ground Surface Elevation (feet)	Pressure at Well Head (ft of Head Above Ground Surface)	Well Depth (ft BGS)	Targeted Flow Zones	Total Simulated Flow (gpm)
Vertical Clean Water Infiltration Wells							
IW-1	1177609.77	544864.72	776	10	129	Saprolite/Transition Zone/Bedrock	5.4
IW-2	1177669.80	544866.70	770	10	125	Saprolite/Transition Zone/Bedrock	5.4
IW-3	1177844.15	544863.18	745	10	103	Saprolite/Transition Zone/Bedrock	5.4
IW-4	1177961.75	544866.28	732	10	87	Saprolite/Transition Zone/Bedrock	5.4
IW-5	1178072.26	544864.91	747	10	98	Saprolite/Transition Zone/Bedrock	5.4
IW-6	1178183.46	544866.51	792	10	133	Saprolite/Transition Zone/Bedrock	5.4
IW-7	1178279.21	544863.41	799	10	128	Saprolite/Transition Zone/Bedrock	5.4
IW-8	1178368.50	544864.30	815	10	134	Saprolite/Transition Zone/Bedrock	5.7
IW-9	1178187.90	545042.20	758	10	101	Saprolite/Transition Zone	4.3
IW-10	1178125.00	545045.70	729	10	83	Saprolite/Transition Zone	4.3
IW-11	1178187.40	545163.00	736	10	86	Saprolite/Transition Zone	4.3
IW-12	1178243.25	545157.33	754	10	98	Saprolite/Transition Zone	4.3
IW-13	1178188.54	545270.10	721	10	65	Saprolite/Transition Zone	4.3
IW-14	1178240.34	545272.30	734	10	75	Saprolite/Transition Zone	4.3
IW-15	1177802.60	545097.50	730	10	70	Saprolite	1.9
IW-16	1177849.10	545097.50	720	10	61	Saprolite	1.9
IW-17	1177782.00	545044.50	744	10	79	Saprolite	1.9
IW-18	1177850.40	545040.60	731	10	65	Saprolite	1.9
IW-19	1177785.10	544939.30	750	10	78	Saprolite	1.9
IW-20	1177844.90	544938.30	739	10	66	Saprolite	1.9
IW-21	1178237.57	545099.15	759	10	60	Saprolite	1.9
IW-22	1178180.00	545242.80	725	10	33	Saprolite	1.6
IW-23	1178233.30	545244.60	734	10	37	Saprolite	1.6
IW-24	1178135.60	545185.10	721	10	34	Saprolite	1.6
IW-25	1178186.20	545187.80	733	10	39	Saprolite	1.6
IW-26	1178239.50	545187.80	746	10	44	Saprolite	1.6
IW-27	1178134.70	545130.00	726	10	37	Saprolite	1.6
IW-28	1178188.00	545132.70	740	10	43	Saprolite	1.6
IW-29	1178232.40	545127.40	753	10	49	Saprolite	1.6
IW-30	1178142.70	545076.80	737	10	43	Saprolite	1.6
IW-31	1178188.00	545075.90	752	10	50	Saprolite	1.6
IW-32	1178236.00	545072.30	766	10	56	Saprolite	1.6
IW-33	1177845.50	545126.88	719	10	70	Saprolite/Transition Zone	3.1
IW-34	1177776.10	545370.60	714	10	79	Saprolite/Transition Zone	3.1
IW-35	1177733.70	545332.40	728	10	91	Saprolite/Transition Zone	3.1
IW-36	1177715.30	545299.80	740	10	99	Saprolite/Transition Zone	3.1
IW-37	1177677.10	545270.10	745	10	103	Saprolite/Transition Zone	3.1
IW-38	1177664.40	545244.70	753	10	108	Saprolite/Transition Zone	3.1
IW-39	1177653.10	545192.30	757	10	107	Saprolite/Transition Zone	3.1
IW-40	1177603.60	545130.10	760	10	104	Saprolite/Transition Zone	3.1
IW-41	1177565.40	545074.90	764	10	102	Saprolite/Transition Zone	3.1
IW-42	1177798.80	545401.10	702	10	70	Saprolite/Transition Zone	3.1
IW-43	1177832.60	545447.30	696	10	66	Saprolite/Transition Zone	3.1
IW-44	1178182.70	545300.50	721	10	30	Saprolite	1.6
IW-45	1178237.70	545300.50	729	10	35	Saprolite	1.6
IW-46	1178136.50	545242.80	715	10	30	Saprolite	1.6
Horizontal Clean Water Infiltration Wells							
HW-1	NA	NA	752-765	10	10-15	Saprolite	44.7

Prepared by: GTC

Checked by: RAG

Notes:

All depths are approximated and may change depending on site conditions.

Flowrates are approximate and may change depending on site conditions.

DTW - depth to water

ft - feet

ft BGS - feet below ground surface

gpm - gallons per minute

NA - Not applicable

TABLE 6-16
MODELED GROUNDWATER EXTRACTION WELL DETAILS
ACTIVE ASH BASIN
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

Well ID	Easting	Northing	Approximate Ground Surface Elevation (feet)	Operational DTW Maintained In Well (ft BGS)	Well Depth (ft BGS)	Targeted Flow Zones	Total Simulated Flow (gpm)
Vertical Extraction Wells							
EX-1	1177675.17	544940.59	766	25	127	Saprolite/Transition Zone/Bedrock	5.6
EX-2	1177792.42	544977.73	747	15	115	Saprolite/Transition Zone/Bedrock	5.6
EX-3	1177908.52	544976.93	725	5	95	Saprolite/Transition Zone/Bedrock	5.6
EX-4	1178026.12	544980.03	726	5	91	Saprolite/Transition Zone/Bedrock	5.6
EX-5	1178136.63	544978.66	749	18	105	Saprolite/Transition Zone/Bedrock	5.6
EX-6	1178247.83	544980.26	780	39	126	Saprolite/Transition Zone/Bedrock	5.6
EX-7	1178343.59	544977.16	793	43	133	Saprolite/Transition Zone/Bedrock	5.6
EX-8	1178432.87	544978.05	819	69	153	Saprolite/Transition Zone/Bedrock	5.6
EX-9	1178135.50	545099.80	731	15	97	Saprolite/Transition Zone/Bedrock	5.6
EX-10	1178188.50	545104.30	748	27	109	Saprolite/Transition Zone/Bedrock	5.6
EX-11	1178138.90	545219.30	718	15	83	Saprolite/Transition Zone/Bedrock	5.6
EX-12	1178182.90	545215.90	728	18	89	Saprolite/Transition Zone/Bedrock	5.6
EX-13	1178244.90	545217.10	746	26	102	Saprolite/Transition Zone/Bedrock	5.6
EX-14	1178129.90	545332.00	710	13	69	Saprolite/Transition Zone/Bedrock	5.6
EX-15	1178185.10	545329.80	716	15	70	Saprolite/Transition Zone/Bedrock	5.6
EX-16	1178243.70	545328.70	730	20	83	Saprolite/Transition Zone/Bedrock	5.6
EX-17	1177798.90	545070.60	733	13	97	Saprolite/Transition Zone	7.8
EX-18	1177857.40	545158.40	718	12	92	Saprolite/Transition Zone	7.8
EX-19	1177690.74	544972.35	758	18	112	Saprolite/Transition Zone	7.8
EX-20	1177750.80	545007.50	755	24	109	Saprolite/Transition Zone	7.8
EX-21	1177846.70	545520.40	682	12	54	Saprolite	0.4
EX-22	1177788.80	545520.40	685	14	60	Saprolite	0.4
EX-23	1177729.90	545521.30	683	14	58	Saprolite	0.4

Prepared by: GTC

Checked by: RAG

Notes:

All depths are approximated and may change depending on site conditions.

Flowrates are approximate and may change depending on site conditions.

DTW - depth to water

ft - feet

ft BGS - feet below ground surface

gpm - gallons per minute

NA - Not applicable

TABLE 6-17
EFFECTIVENESS MONITORING PLAN ELEMENTS
ACTIVE ASH BASIN
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

Effectiveness Monitoring Plan (EMP) Implemented 30 days after CAP Approval			Post-Closure Monitoring Plan (PCMP) Implemented after completion of ash basin closure activities						
EMP Groundwater Well Monitoring Network (background, downgradient of source areas)			PCMP Groundwater Well Monitoring Network (background, downgradient of source areas)						
Performance Monitoring Network									
AS-2S	PMW-1BR	PMW-4D							
AS-2D	PMW-2S	PMW-4BR							
AS-2BR	PMW-2D	PMW-5S							
CCR-7S	PMW-2BR	PMW-5D							
CCR-7D	PMW-3S	PMW-5BR							
CCR-7BR*	PMW-3D	PMW-6S							
PMW-1S	PMW-3BR	PMW-6D							
PMW-1D	PMW-4S	PMW-6BR							
Continued Monitoring Network									
GWA-20S	GWA-28BR	GWA-59BR							
GWA-20D	GWA-33S	GWA-62BRU							
GWA-20BR	GWA-33D	GWA-62BR							
GWA-21S	GWA-33BR	MW-11S							
GWA-21BRU	GWA-43S	MW-11DA							
GWA-21BR	GWA-43D	MW-11BRO							
GWA-21BRL	GWA-43BR*	MW-20D							
GWA-22S	GWA-57S	MW-20DR							
GWA-22BRU	GWA-57BRU	MW-23S							
GWA-22BR*	GWA-57BR	MW-23D							
GWA-28S	GWA-59D	MW-23DR							
GWA-28BRU									
Background Monitoring Wells¹									
BG-1S	GWA-24D	MW-22DR							
BG-1D	GWA-24BR	MW-22BR							
GWA-24S	GWA-25S	MW-24DR							
EMP Groundwater Quality^{3, 4} (Semi-Annual Sampling Frequency)			PCMP Groundwater Quality (Sampling frequency to be determined)						
Alkalinity	Iron ²	Strontium ²							
Aluminum	Lithium ²	Sulfate ²							
Arsenic ²	Magnesium	Thallium ²							
Bicarbonate Alkalinity	Manganese ²	Total Dissolved Solids ²							
Boron ²	Nitrate + Nitrite	Total Organic Carbon							
Calcium	Potassium	Total Uranium ²							
Cobalt ²	Sodium	Vanadium ²							
Ferrous Iron									
CMP and PCMP Groundwater Field Parameters									
Water Level	Specific Conductivity		Temperature						
pH	Oxidation Reduction Potential		Dissolved Oxygen						
EMP Review			PCMP Review						
Annual Effectiveness Monitoring Evaluation and Reporting			Annual Evaluation and Reporting:						
1) Summary of annual groundwater monitoring results			1) Summary of annual groundwater monitoring results						
2) Evaluate statistical concentration trends			2) Evaluate statistical concentration trends						
3) Evaluation of compliance with applicable Standards			3) Evaluation of O2L compliance						
4) Evaluation of system performance and effectiveness			4) Recommend plan adjustments, if applicable						
4) Recommend plan adjustments, if applicable, to optimize the remedial action			<u>At a frequency no greater than 5 years:</u>						
5-Year Performance Review Reporting			1) Update background analysis						
1) Update background analysis			2) Confirm Risk Assessment assumptions remain valid						
2) Confirm Risk Assessment assumptions remain valid			3) Verify model results, update if needed						
3) Re-evaluate effectiveness of technology									
4) Verify modeling results, update model if needed									
5) Modify corrective action approach, as needed, to achieve compliance goal established									
EMP Duration			PCMP Duration						
30 days after CAP approval, the EMP will be implemented at the Site and will continue until there is a total of three years of data confirming COIs are below applicable Standards at or beyond the compliance boundary, at which time a request for completion of active remediation will be filed with NCDEQ.			After ash basin closure and following ash basin closure certification, a PCMP will be implemented at the Site for a minimum of 30 years in accordance with G. S. 130A-309.214(4)(k)(2).						
If applicable standards are not met, the EMP will continue and transition to post-closure monitoring if necessary.			Early termination: If groundwater monitoring results are below applicable Standards at the compliance boundary for three years, Duke Energy will request completion of corrective action in accordance with G.S. 130A-309.214(a)(3)b. If groundwater monitoring results are above applicable Standards, the PCMP will continue.						

¹ Approved background groundwater monitoring locations

² Corrective action COIs to monitor plume stability and physical attenuation either from active remedy or natural dilution/dispersion

³ The number of monitoring wells and parameters may be adjusted based on additional data and the effects of corrective action.

⁴ Groundwater standards may be modified over time in accordance with O2L .0106(k)

* Proposed well

Proposed performance monitoring well clusters PMW-1 through PMW-6 are considered replacement wells for well clusters AS-1, AS-7, AS-8, AS-9, CLMW-3, and MW-2, which will be abandoned prior to excavation of the ash storage area. The location of the replacement well clusters has been optimized for performance monitoring.

Italicized parameters - parameters for general water quality to evaluate monitoring data quality

Wells indicated in red will have geochemical sondes placed to monitor geochemical conditions

Source Area 2 (Former Units 1-4 Ash Basin)

TABLE 6-18
BORON CONCENTRATIONS IN GROUNDWATER BELOW SOURCE AREA
FORMER UNITS 1-4 ASH BASIN
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

Well Beneath Ash (Flow Zone)	Number of Sample Events	Time Period of Record	Boron Concentration Range in Groundwater ($\mu\text{g}/\text{L}$)	Boron Concentration Range in Overlying Pore Water ($\mu\text{g}/\text{L}$)
IB-1D (Deep)	5	06/2015 – 04/2016	<50 ¹	165 – 241 (~5' saturated ash)
IB-2AL (Shallow - Alluvial)	2	06/2015 – 09/2015	480 – 490	220 – 240 (~12' saturated ash)
IB-2BRU (Deep)	2	06/2015 – 09/2015	<50 ¹	
IB-2I (Shallow)	2	06/2015 – 09/2015	99	320 – 390 (~13' saturated ash)
IB-4BR (Bedrock)	3	06/2015 – 09/2015	52 – 57	
IB-4D (Deep)	2	06/2015 – 09/2015	<50 ¹	

Prepared by: TJG Checked by: SAS

Notes:

< – concentration not detected at or above the adjusted reporting limit

¹ – Concentrations have not been detected at or above the adjusted reporting limit across all sampling events

TABLE 6-19
SUMMARY OF UNSATURATED SOIL ANALYTICAL RESULTS
FORMER UNITS 1-4 ASH BASIN
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

Analytical Parameters		pH	Arsenic	Boron	Cobalt	Iron	Manganese	Strontium	Sulfate	Thallium	Vanadium
Reporting Units		S.U.	mg/kg	mg/kg	mg/kg	mg/kg	mg/kg	mg/kg	mg/kg	mg/kg	mg/kg
PSRG Protection of Groundwater	NE	5.8	45	0.9	150	65	1,500	1,438	0.28	350	
Background Threshold Values	4.0-6.8	7.8	31	48	74,362	672	9.9	13	1.1	161	
Sample ID	Sample Collection Date	Analytical Results									
Background											
BGSB-MW-30 (6-7)	10/17/2017	5.2	4.3 B	<9.6 M	6.2	73,000 M	160	16	<13	0.39	180 B
BGSB-MW-30 (14-15)	10/17/2017	5.2	2.7 B	<5.9	30	49,000	190	0.89 j	<13	0.32	130 B
BGSB-MW-30 (24-25)	10/17/2017	5.6	0.73 B	<15	12	38,000	390	<6.2	<13 M	0.41	83 B
BGSB-MW-32 (2-3)	10/19/2017	4.8	12	<14	2.4	44,000 B	40	6.9	35	0.31	89
BGSB-MW-32 (14-15)	10/19/2017	4.4	6.4	<4.8	2.6	40,000 B	130	0.6 j	<12	0.15	71
MW-30D (3.5 - 5.5)	02/23/2015	5.9 j	3.2 j	<3.9	7.3	48,500	145	1.1	<394	<1.6	97.8
MW-30D (8.5 - 10)	02/23/2015	6.0 j	2.4 j	<4.1	3.3 j	27,300	89	1.6	<396	<4.1	70.3
MW-30D (18.5 - 20)	02/23/2015	5.0 j	3.5 j	<4.7	2.4 j	60,600	215	<0.94	<488	<1.9	125
MW-30D (28.5 - 30)	02/23/2015	6.1 j	3.6 j	27.3 j	36.1	38,700	979	<7.7	<380	1 j	93.8
MW-32D (3.5 - 5)	02/23/2015	5.2 j	3.8	<30.1	5.7	48,700	148	1.4	204 j	<1.2	96.7
MW-32D (8.5 - 10)	02/25/2015	6 j	1.9 j	<30.6	6.7	44,800	107	2	<309	<1.2	74.5
MW-32D (18.5 - 20)	02/25/2015	5.9 j	1.7	<3.3	3.2	2,760	62	13.3	<321	<1.3	3
MW-32S (22.5 - 24)	03/12/2015	6.3 j	7.9	<38.9	33.8	46,400	910	1.4 j+	<387	<3.9	90.1
Beyond Ash Basin Waste Boundary											
GWA-10D (13.5 - 15)	04/21/2015	7.6 j	10.3	11.1 j	5.4 j+	11,100	208	4.2	228 j	<6.8	20.2
GWA-12BRU (20 - 23.5)	03/31/2015	6.5 j	<2.7	6.8 j	3	7,640	152	<2.7	<266	<2.7	5
GWA-13BR (13 - 14.5)	03/04/2015	5.9 j	2.2	24.8 j	22.9	34,700	624	<7.7	<377	0.85 j	73.7
GWA-29D (16.2 - 16.2)	05/07/2015	6.6 j	<5	<12.4	9.2	20,000	174	<2.5	<258	<5	17.3

Prepared by: TJG

Checked by: VJH

Notes:

- Bold highlighted concentration indicates exceedance of the Inactive Hazardous Sites Branch PSRG Table (May 2019) for Protection of Groundwater or the Background Threshold Value (BTM), whichever is higher.

< - Concentration not detected at or above the adjusted reporting limit.

B - Target analyte detected in method blank at or above the reporting limit. Target analyte concentration in sample is less than 10X the concentration in the method blank. Analyte concentration in sample could be due to blank contamination.

j - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

j+ - Estimated concentration, biased high.

M - Matrix spike / matrix spike dup failure.

mg/kg - milligrams per kilogram

NE - not established

PSRG - preliminary soil remediation goals

S.U. - standard units

TABLE 6-20
MEANS OF GROUNDWATER COIS - JANUARY 2018 TO JUNE 2019
FORMER UNITS 1-4 ASH BASIN
CORRECTIVE ACTIVE PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

Analytical Parameter		Sample ID	Flow Zone	Background Locations	Background Dataset Range	Reporting Units	pH	Arsenic	Boron	Chromium (VI)	Chromium	Cobalt	Iron	Lithium	Manganese	Strontronium	Sulfate	Thallium	Total Dissolved Solids	Total Radium	Total Uranium	Vanadium
Sample ID	Flow Zone	Background Locations	Background Dataset Range	Reporting Units	pH	Arsenic	Boron	Chromium (VI)	Chromium	Cobalt	Iron	Lithium	Manganese	Strontronium	Sulfate	Thallium	Total Dissolved Solids	Total Radium	Total Uranium	Vanadium		
GW-A-30S	Shallow	Shallow	5.7	0.1	<50	0.041	1.3	5.0	264	1.1	269	24	<1	0.2	43	-	-	-	<0.3			
MW-A-30S	Shallow	Shallow	5.3	0.1	<50	0.142	3.0	0.4	159	1.2	8	10	<0.1	0.190	-	-	-	-	<0.3			
MW-A-30A	Shallow	Shallow	5.0	0.1	<50	0.177	0.6	1.1	73	2.5	37	27	<0.1	0.1	59	1.07	-	-	<0.3			
MW-A-30D	Shallow	Shallow	5.3	0.1	<50	0.079	0.5	<0.1	1.1	1.1	6	61	<0.1	1.6	107	1.333	-	-	<0.3			
MW-A-30A	Deep	Deep	6.0	0.2	<50	0.6	2	5	515	NE	78	56	10	0.1	71	-	-	-	<0.3			
MW-A-30D	Deep	Deep	5.0	0.2	<50	0.6	2	5	1840	12	260	69	15	0.2	107	2	0.0005	11	-			
MW-A-30A	Deep	Deep	4.9	0.7	<50	0.6	2	5	<50 - 150	1.5 - 6.1	<50 - 3200	1.5 - 13.4	5.2 - 408	6.3 - 70.5	<1 - 18.5	<0.1 - <0.2	<25 - 407	0.017 - 2.323	<0.3 - 1.2			
MW-A-30D	Deep	Deep	7.3	0.7	<50	0.1	4	1	6220	NE	89	107	15	0.2	120	3	0.0005	0.4	-			
MW-A-30A	Bedrock	Bedrock	5.4	0.7	<50	0.7	3	2	7680	11	113	93	17	0.2	120	3	0.0005	1	-			
MW-A-30D	Bedrock	Bedrock	4.5	0.7	<50	0.1	2	2	<50 - 1000	1.1 - 7.3	5 - 134	16.6 - 116	<1 - 17.6	<0.1 - 0.5	<25 - 330	0 - 3.46	<0.0005	<0.3 - 1.5				
MW-A-32RR	Bedrock	Bedrock	4.3	0.7	<50	0.8	<0.1 - 0.5	<0.1 - 0.5	<0.1 - 2.6	<0.1 - 2.6	<50 - 1000	1.1 - 7.3	5 - 134	<0.1 - 0.5	<25 - 330	0 - 3.46	<0.0005	<0.3 - 1.5				
Mean, Geometric, or Median Result³																						
Between Waste Boundary and Compliance Boundary																						
Upgradation of the Ash Basin																						
GW-A-14S	Shallow	Shallow	6.0	0.2	63	1.300	2.1	0.4	392	-	19	95	85	0.1	217	-	-	-	-			
GW-A-14D	Deep	Deep	5.9	0.2	101	0.986	1.3	0.4	79	0.7	6	228	186	<0.1	413	-	-	-	0.5			
GW-A-14BR	Bedrock	Bedrock	6.5	0.2	<50	<0.025	0.2	1.0	0.1	5674	1.7	249	157	52	0.1	321	-	-	0.4			
Downgradient of the Ash Basin																						
GW-A-10S	Shallow	Shallow	5.2	0.6	97	0.043	<0.5	5.9	182	5.0	1038	227	131	0.2	259	-	-	-	<0.3			
GW-A-12S	Shallow	Shallow	5.6	0.1	<50	0.042	1.0	0.2	117	0.6	6	18	13	<0.1	86	-	-	-	<0.3			
GW-A-10D	Deep	Deep	5.9	<0.1	<50	0.780	1.1	0.2	21	<50	62	174	139	<0.1	125	<0.573	-	-	<0.3			
GW-A-12D	Deep	Deep	6.0	0.1	<50	<0.025	<0.5	503	2.7	43	49	9	<0.1	101	-	-	-	<0.3				
Near Compliance Boundary																						
Downgradient of the Ash Basin																						
CCR-B-015	Shallow	Shallow	5.8	0.2	151	0.028	0.6	2.8	858	<0.5	1706	395	79	<0.1	196	<1.14	-	-	<0.3			
CCR-B-015S	Shallow	Shallow	6.3	0.2	109	270	0.022	0.9	16.6	470	157	2068	898	200	0.1	471	<1.09	-	<0.3			
GW-A-11S	Shallow	Shallow	5.9	1.2	398	<0.025	0.6	1.6	621	2.6	1970	554	105	<0.1	299	0.456	<0.0005	-	1.2			
GW-A-10S	Shallow	Shallow	5.5	0.1	500	0.039	0.5	1.6	18.3	605	32	2723	219	0.1	457	1.20	<0.0005	-	<0.3			
GW-A-10Z	Shallow	Shallow	5.7	1.6	268	<0.025	1.4	10.5	16.3	1.0	1627	305	109	0.2	307	1.240	<0.0005	-	0.5			
CCR-B-01D	Shallow	Shallow	5.8	0.2	300	0.027	0.7	0.3	338	3.8	50	281	110	0.1	97	<0.71	-	<0.3				
CCR-B-03D	Shallow	Shallow	5.6	0.3	655	0.2543	2.5	0.7	421	1.6	740	285	66	<0.1	321	-	-	1.7				
GW-A-29D	Deep	Deep	5.7	<0.1	<50	0.167	0.9	0.3	150	1.6	103	10.3	9	0.1	319	2.947	<0.0005	-	<0.3			
GW-A-32D	Deep	Deep	6.0	0.1	128	<0.097	<0.5	0.1	124	1.6	10	11	2	<0.1	66	1.368	<0.0005	<0.3				
IB-06D	Deep	Deep	7.0	0.1	2090	0.028	0.6	2.8	858	12.2	289	209	51	<0.1	253	4.930	0.0001	<0.3				
CCR-B-07D	Bedrock	Bedrock	6.7	0.7	50	0.028	2.0	1.3	350	5.7	196	126	11	<0.1	221	-	-	0.5				
GW-A-11BR	Bedrock	Bedrock	7.5	0.4	<50	<0.025	0.7	0.8	4.6	2750	21.6	970	813	<0.1	222	37.833	0.0002	0.4				
GW-A-11BLR	Bedrock	Bedrock	8.3	-	207	<0.025	<0.5	0.8	46	7.2	84	67	-	<0.1	322	1.980	0.0016	0.9				
GW-A-29BRA	Bedrock	Bedrock	7.7	1.8	<50	0.067	0.7	0.2	153	0.4	29	213	11	<0.1	146	-	-	-				

Notes:

- 1) Background threshold values were calculated using data from background groundwater samples collected June 2015 to September 2017.
- 2) Background threshold values were calculated using data from background groundwater samples collected March 2011 to December 2018.
- 3) Statistical mean, geometric mean, or median calculated from data ranging from January 2018 to June 2019. Ash pore water results are not compared to groundwater standards or criteria.

Mean or median results were used based on the central tendency of the data set.

For wells with data sets containing fewer than four valid results, the most recent valid sample data was used.

Means were calculated for wells with four or more valid sample results. Sample results were excluded from calculations.

1) turbidity > 10 NTU (or 50% above than base)

2) unless data (RL) greater than the normal laboratory RL

Bold text = Constituent concentration exceeds applicable comparison criteria.

Yellow box = Constituent indicates value is greater than or equal to the regulatory standard

Blue box = Constituent indicates value is greater than or equal to the greatest background threshold value where there is no regulatory standard

Green box = Constituent indicates value either within range of background threshold values to constituents where there is no regulatory standard or within range of background threshold values and the regulatory standard

< - concentration not detected at or above the adjusted reporting limit.

Value not available

NE = not established
m/L = milligrams per liter
pC/L = picocuries per liter
pCi/L = microcuries per liter
S.L. = standard unit

Prepared by TTS Checked by TAW

TABLE 6-21
COT MANAGEMENT MATRIX
FORMER UNITS 1-4 ASH BASIN
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO

Prepared by: 115 Checked by: 115

TABLE 6-22
SUMMARY TREND ANALYSIS RESULTS
FOR MONITORING WELLS
FORMER UNITS 1-4 ASH BASIN
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

Wells Between Waste Boundary and Compliance Boundary				
Well ID	Boron	Lithium	Sulfate	Total Dissolved Solids
Shallow Flow Zone				
GWA-10S	D	NT	D	D
GWA-12S	ND	NT	S	I
Deep Flow Zone				
GWA-10D	ND	D	I	D
GWA-12BRU	ND	S	S	I

Wells Downgradient of the Source Area Near Compliance Boundary						
	Well ID	Boron	Lithium	Sulfate	Total Dissolved Solids	
Deep Flow Zone						
	CCR-1B-01S	D	NT	NT	NT	I (292)
	CCR-1B-03S	I	NT	NT	NT	S
	GWA-11S	S	NT	D	D	D
Bedrock Flow Zone						
	CCR-IB-01D	ND	S	S	S	I
	CCR-IB-03D	D	NT	D	D	S
	GWA-11BRU	S	I (23,3)	D	D	D
	GWA-29D	ND	NT	D	D	S
Bedrock Flow Zone						
	CCR-IB-03BR	S	S	S	S	S
	GWA-29BRA	ND	D	D	D	S

Mann-Kendall trend analysis and results prepared by Arcadis U.S. Inc.

Notes:

- Summary of results and trends are presented for samples collected from 2015 - 2019.
- Trend results are presented when at least four samples were available and frequency of detection was >50%. Statistically significant trends are reported at the 90% confidence level.
- Variability Index (V_1) is calculated as the (maximum - minimum) / median concentration and is calculated using detected concentrations only. Values less than 1 indicate low variability in the dataset.
- For pH, statistically significant, increasing trend with a maximum recent result (2018 - 2019) less than the lower end of the standard range or greater than the upper end of the standard range. Maximum detected result for 2018 and 2019 time period shown in parentheses.
- Wells that had insufficient samples collected ($n < 4$) for all four constituents were removed from table. See designation 'NE'.

ND	= Greater than 50 percent of constituent concentrations were non-detect
D	= Statistically significant, decreasing concentration trend
S	= Stable. No significant trend and variability is low ($V_1 \leq 1$)
NT	= No significant trend and variability is high ($V_1 > 1$)
I	= Statistically significant, increasing concentration trend.
NE	= Insufficient number of samples to evaluate trend ($n < 4$)

Prepared by: MAE Checked by: HES

TABLE 6-23
SEEP CORRECTIVE ACTION STRATEGY
FORMER UNITS 1-4 ASH BASIN
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

Seep ID	Regulatory Program	General Location	Approximate Average Present Flow (cfs)	Anticipated Seep Corrective Action Strategy
S-03	SOC	North of U1-4 AB	0.1	Corrective action at this location may consist of capturing and treating the seep or other remedial actions. Final corrective action plans for seeps that are not dispositioned after completion of decanting will be proposed in an amendment to the CAP Update and submitted based on the schedule outlined in the SOC.

Notes:

cfs- cubic feet per second

NPDES – National Pollution Discharge Elimination System

SOC – Special Order by Consent

Prepared by: SAS Checked by: TG

TABLE 6-24
REMEDIAL TECHNOLOGY SCREENING SUMMARY
FORMER UNITS 1-4 ASH BASIN
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

Summary of Remedial Technology Screening		Retain Technology for Further Consideration	
Technology	Yes/No	Rationale	
Monitored Natural Attenuation (MNA)	Yes	COIs pose no unacceptable risk to human health or the environment under conservative exposure scenarios. MNA could be implemented in conjunction with source control measures.	
In-Situ Technologies			
Low Permeability Barriers (LPB)	No	Technically challenging and costly.	
Groundwater Flushing	No	The source of COIs has been excavated and the concentrations of COIs appear to be stable.	
Encapsulation	No	No area where COIs are concentrated.	
Permeable Reactive Barrier (PRB)	No	Boron is not amenable to treatment in a PRB.	
Groundwater Extraction Technologies			
Vertical Extraction Wells	No	The source of COIs has been excavated and the concentrations of COIs appear to be stable.	
Horizontal or Angular Extraction Wells	No	The source of COIs has been excavated and the concentrations of COIs appear to be stable.	
Extraction Trenches	No	The source of COIs has been excavated and the concentrations of COIs appear to be stable.	
Hydraulic Fracturing	No	Not warranted based upon the limited extent of COIs in bedrock.	
Phytoremediation	Yes	Groundwater extraction by TreeWells™ could act as a barrier to mitigate COIs to the Broad River.	
Groundwater Treatment Technologies			
pH Adjustment	No	No extraction of groundwater is anticipated for Former Units 1-4 Ash Basin.	
Precipitation	No	No extraction of groundwater is anticipated for Former Units 1-4 Ash Basin.	

TABLE 6-24
REMEDIAL TECHNOLOGY SCREENING SUMMARY
FORMER UNITS 1-4 ASH BASIN
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

Summary of Remedial Technology Screening		Retain Technology for Further Consideration	
Technology	Yes/No	Rationale	
Ion Exchange	No	No extraction of groundwater is anticipated for Former Units 1-4 Ash Basin.	
Membrane Filtration	No	No extraction of groundwater is anticipated for Former Units 1-4 Ash Basin.	
Management of Extracted Groundwater			
NPDES Permitted Discharge	No	Groundwater extraction is not retained	
Publicly Owned Treatment Works (POTW)	No	Groundwater extraction is not retained	
Non-Discharge Permit/Infiltration Gallery	No	Groundwater extraction is not retained	
Non-Discharge Permit/Land Application	No	Groundwater extraction is not retained	
Beneficial Reuse			
Fire Protection	No	Groundwater extraction is not retained	
Non-Contact Cooling Water	No	Groundwater extraction is not retained	
Dust Suppression and Truck Wash	No	Groundwater extraction is not retained	

Prepared by: TJG Checked by: JEC

TABLE 6-25
REMEDIAL ALTERNATIVE 2 TREEWELL SUMMARY
FORMER UNITS 1-4 ASH BASIN
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

Phytoremediation and TreeWell Technology System		
Number of TreeWells	Flow Zone	Total Depth (ft bgs)
286	Saprolite/Transition Zone	30-40
Groundwater removal projections for TreeWell system: Groundwater removal rate of the system will be approximately 3.1 million gallons per year upon reaching maturity		

Prepared by: VT Checked by: GTC

Notes:

ft bgs – feet below ground surface

gpm – gallons per minute

TABLE 6-26
ENVIRONMENTAL SUSTAINABILITY COMPARISONS FOR REMEDIATION ALTERNATIVES
FORMER UNITS 1-4 ASH BASIN
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS LLC, MOORESBORO, NC

Remedial Alternative		Remedial Alternative 1 – Groundwater Remediation by MNA	Remedial Alternative 2 – Groundwater Remediation by TreeWells™
Emissions	Units		
CO ₂ Emissions	metric ton	2.07E+01	-1.74E+02
Onsite NO _x emissions	metric ton	2.43E-02	1.54E-01
Onsite SO _x Emissions	metric ton	2.48E-03	1.58E-02
Onsite PM ₁₀ Emissions	metric ton	2.19E-03	1.39E-02
Total NO _x emissions	metric ton	4.25E-02	1.81E-01
Total SO _x Emissions	metric ton	1.34E-02	3.27E-02
Total PM ₁₀ Emissions	metric ton	3.88E-03	1.70E-02
Total Energy Used	MMBTU	3.88E+03	4.06E+03
Total Emissions	metric ton	2.08E+01	-1.73E+02

Prepared by: GTC Checked by: SJB

Notes:

CO₂ - Airborne emissions of carbon dioxide

MMBTU - Million British Thermal Units

NO_x - Airborne emissions of nitrogen oxides (combination of nitrogen monoxide and nitrogen dioxide)

SO_x - Airborne emissions of sulfur oxides (combination of sulfur monoxide, sulfur dioxide, sulfur trioxide, and others)

PM₁₀ - Airborne emissions of particulate matter that is 10 micrometers or less in diameter

TABLE 6-27
EFFECTIVENESS MONITORING PLAN ELEMENTS
FORMER UNITS 1-4 ASH BASIN
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

Effectiveness Monitoring Plan (EMP) Implemented 30 days after CAP Approval	Post-Closure Monitoring Plan (PCMP) Implemented after completion of ash basin closure activities																					
EMP Groundwater Well Monitoring Network <small>(background, downgradient of source areas)</small>	PCMP Groundwater Well Monitoring Network <small>(background, downgradient of source areas)</small>																					
Performance Monitoring Network <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 33%;">CCR-IB-1S</td><td style="width: 33%;">GWA-10S</td><td style="width: 33%;">IB-6S</td></tr> <tr> <td>CCR-IB-1D</td><td>GWA-10D</td><td>IB-6D</td></tr> <tr> <td>CCR-IB-3S</td><td>GWA-11S</td><td>IB-6BR*</td></tr> <tr> <td>CCR-IB-3D</td><td>GWA-11BRU</td><td>IB-7S</td></tr> <tr> <td>CCR-IB-3BR</td><td>GWA-11BR</td><td>IB-7D</td></tr> </table>	CCR-IB-1S	GWA-10S	IB-6S	CCR-IB-1D	GWA-10D	IB-6D	CCR-IB-3S	GWA-11S	IB-6BR*	CCR-IB-3D	GWA-11BRU	IB-7S	CCR-IB-3BR	GWA-11BR	IB-7D	<p>A PCMP will be implemented at the Site in accordance with G.S. 130A-309.214(a)(4)k.2 after completion of ash basin closure activities.</p>						
CCR-IB-1S	GWA-10S	IB-6S																				
CCR-IB-1D	GWA-10D	IB-6D																				
CCR-IB-3S	GWA-11S	IB-6BR*																				
CCR-IB-3D	GWA-11BRU	IB-7S																				
CCR-IB-3BR	GWA-11BR	IB-7D																				
Background Monitoring Wells¹ <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 33%;">GWA-30S</td><td style="width: 33%;">MW-30DA</td><td style="width: 33%;">MW-32D</td></tr> <tr> <td>GWA-30BR</td><td>MW-32S</td><td>MW-32BR</td></tr> <tr> <td>MW-30S</td><td></td><td></td></tr> </table>	GWA-30S	MW-30DA	MW-32D	GWA-30BR	MW-32S	MW-32BR	MW-30S															
GWA-30S	MW-30DA	MW-32D																				
GWA-30BR	MW-32S	MW-32BR																				
MW-30S																						
EMP Groundwater Quality^{3, 4} <small>(Semi-Annual Sampling Frequency)</small> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 33%;">Alkalinity</td><td style="width: 33%;">Ferrous Iron</td><td style="width: 33%;">Sodium</td></tr> <tr> <td>Aluminum</td><td>Iron²</td><td>Strontium²</td></tr> <tr> <td>Arsenic²</td><td>Lithium²</td><td>Sulfate²</td></tr> <tr> <td>Bicarbonate Alkalinity</td><td>Magnesium</td><td>Total Dissolved Solids²</td></tr> <tr> <td>Boron²</td><td>Manganese²</td><td>Total Organic Carbon</td></tr> <tr> <td>Calcium</td><td>Nitrate + Nitrite</td><td>Total Radium²</td></tr> <tr> <td>Cobalt²</td><td>Potassium</td><td>Vanadium²</td></tr> </table>	Alkalinity	Ferrous Iron	Sodium	Aluminum	Iron ²	Strontium ²	Arsenic ²	Lithium ²	Sulfate ²	Bicarbonate Alkalinity	Magnesium	Total Dissolved Solids ²	Boron ²	Manganese ²	Total Organic Carbon	Calcium	Nitrate + Nitrite	Total Radium ²	Cobalt ²	Potassium	Vanadium ²	PCMP Groundwater Quality <small>(Sampling frequency to be determined)</small> <p>Parameters and sampling frequency to be included in the PCMP in accordance with G.S. 130A-309.214(a)(4)k.2 when submitted.</p>
Alkalinity	Ferrous Iron	Sodium																				
Aluminum	Iron ²	Strontium ²																				
Arsenic ²	Lithium ²	Sulfate ²																				
Bicarbonate Alkalinity	Magnesium	Total Dissolved Solids ²																				
Boron ²	Manganese ²	Total Organic Carbon																				
Calcium	Nitrate + Nitrite	Total Radium ²																				
Cobalt ²	Potassium	Vanadium ²																				
CMP and PCMP Groundwater Field Parameters <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 33%;">Water Level</td><td style="width: 33%;">Specific Conductivity</td><td style="width: 33%;">Temperature</td></tr> <tr> <td>PH</td><td>Oxidation Reduction Potential</td><td>Dissolved Oxygen</td></tr> </table>	Water Level	Specific Conductivity	Temperature	PH	Oxidation Reduction Potential	Dissolved Oxygen																
Water Level	Specific Conductivity	Temperature																				
PH	Oxidation Reduction Potential	Dissolved Oxygen																				
EMP Review <ul style="list-style-type: none"> <u>Annual Effectiveness Monitoring Evaluation and Reporting:</u> <ol style="list-style-type: none"> 1) Summary of annual groundwater monitoring results 2) Evaluate statistical concentration trends 2) Comparison of observed concentrations to model predictions 3) Evaluation of compliance with applicable Standards 4) Evaluation of system performance and effectiveness 4) Recommend plan adjustments, if applicable, to optimize the remedial action <u>5-Year Performance Review Reporting:</u> <ol style="list-style-type: none"> 1) Update background analysis 2) Confirm Risk Assessment assumptions remain valid 3) Re-evaluate effectiveness of technology 4) Verify modeling results, update model if needed 5) Modify corrective action approach, as needed, to achieve compliance goal established 	PCMP Review <ul style="list-style-type: none"> <u>Annual Evaluation and Reporting:</u> <ol style="list-style-type: none"> 1) Summary of annual groundwater monitoring results 2) Evaluate statistical concentration trends 2) Comparison of observed concentrations to model predictions 3) Evaluation O2L compliance 4) Recommend plan adjustments, if applicable <u>At a frequency no greater than 5 years:</u> <ol style="list-style-type: none"> 1) Update background analysis 2) Confirm Risk Assessment assumptions remain valid 3) Verify model results, update if needed 																					
EMP Duration <p>30 days after CAP approval, the EMP will be implemented at the Site and will continue until there is a total of three years of data confirming COIs are below applicable Standards at or beyond the compliance boundary, at which time a request for completion of active remediation will be filed with NCDEQ.</p> <p>If applicable standards are not met, the EMP will continue and transition to post-closure monitoring if necessary.</p>	PCMP Duration <p>After ash basin closure and following ash basin closure certification, a PCMP will be implemented at the Site for a minimum of 30 years in accordance with G. S. 130A-309.214(4)(k)(2).</p> <p>Early termination: If groundwater monitoring results are below applicable Standards at the compliance boundary for three years, Duke Energy will request completion of corrective action in accordance with G.S. 130A-309.214(a)(3)b. If groundwater monitoring results are above applicable Standards, the PCMP will continue.</p>																					

¹ Approved background groundwater monitoring locations

² Corrective action COIs to monitor plume stability and physical attenuation either from active remedy or natural dilution/dispersion

³ The number of monitoring wells and parameters may be adjusted based on additional data and the effects of corrective action.

⁴ Groundwater standards may be modified over time in accordance with O2L .0106(k)

* Proposed new well

Italicized parameters - parameters for general water quality to evaluate monitoring data quality

Wells indicated in red will have geochemical sondes placed to monitor geochemical conditions

Source Area 3 (Unit 5 Inactive Ash Basin)

TABLE 6-28
BORON CONCENTRATIONS IN GROUNDWATER BELOW SOURCE AREA
UNIT 5 INACTIVE ASH BASIN
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

Well Beneath Ash (Flow Zone)	Number of Sample Events	Time Period of Record	Boron Concentration Range in Groundwater (µg/l)	Boron Concentration Range in Overlying Pore Water (µg/l)
U5-2BR (Bedrock)	13	03/2016 – 01/2019	58.3 – 140	192 – 470 (~10' saturated ash)
U5-2D (Deep)	16	06/2015 – 01/2019	109 – 286	
U5-7D (Deep)	6	06/2015 – 06/2016	103 – 160	170 – 190 (~50' saturated ash)

Prepared by: TJG

Checked by: SAS

TABLE 6-29
SUMMARY OF UNSATURATED SOIL ANALYTICAL RESULTS
UNIT 5 INACTIVE ASH BASIN
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

Analytical Parameters		pH	Arsenic	Boron	Chromium	Cobalt	Iron	Manganese	Strontium	Sulfate	Thallium	Vanadium	
Reporting Units		S.U.	mg/kg	mg/kg	mg/kg	mg/kg	mg/kg	mg/kg	mg/kg	mg/kg	mg/kg	mg/kg	
PSRG Protection of Groundwater	NE	5.8	45	3.8	0.9	150	65	1,500	1,438	0.28	350		
Background Threshold Values	4.0-6.8	7.8	31	142	48	74,362	672	9.9	13	1.1	161		
Sample ID	Sample Collection Date	Analytical Results											
Background													
BG-02D (3.5 - 5)	02/23/2015	5.5 j	<3.5	<69.4	84	15.2	61,500	234	1.1	<353	<1.4	110	
BG-02D (8.5 - 10)	02/23/2015	5.2 j	3.3 j	18.4 j-	85.5	22	39,100	591 j	<3.2	<310	<3.2	75.7	
BG-02D (18.5 - 20)	02/23/2015	5.5 j	3.4 j	21.7	109	19.3	22,000	415	<0.83	<400	<4.2	60.1	
BG-02D (28.5 - 30)	02/23/2015	5.7 j	3.5	<16.9	71.2	25.6	16,600	517	0.9	<330	<1.4	52.9	
BGSB-MW-30 (6-7)	10/17/2017	5.2	4.3 B	<9.6 M	120	6.2	73,000 M	160	16	<13	0.39	180 B	
BGSB-MW-30 (14-15)	10/17/2017	5.2	2.7 B	<5.9	91	30	49,000	190	0.89 j	<13	0.32	130 B	
BGSB-MW-30 (24-25)	10/17/2017	5.6	0.73 B	<15	94	12	38,000	390	<6.2	<13 M	0.41	83 B	
BGSB-MW-32 (2-3)	10/19/2017	4.8	12	<14	69	2.4	44,000 B	40	6.9	35	0.31	89	
BGSB-MW-32 (14-15)	10/19/2017	4.4	6.4	<4.8	41	2.6	40,000 B	130	0.6 j	<12	0.15	71	
MW-30D (3.5 - 5.5)	02/23/2015	5.9 j	3.2 j	<3.9	79.9	7.3	48,500	145	1.1	<394	<1.6	97.8	
MW-30D (8.5 - 10)	02/23/2015	6.0 j	2.4 j	<4.1	48.1	3.3 j	27,300	89	1.6	<396	<4.1	70.3	
MW-30D (18.5 - 20)	02/23/2015	5.0 j	3.5 j	<4.7	80.6	2.4 j	60,600	215	<0.94	<488	<1.9	125	
MW-30D (28.5 - 30)	02/23/2015	6.1 j	3.6 j	27.3 j	88.6	36.1	38,700	979	<7.7	<380	1 j	93.8	
MW-32D (3.5 - 5)	02/23/2015	5.2 j	3.8	<30.1	79.8	5.7	48,700	148	1.4	204 j	<1.2	96.7	
MW-32D (8.5 - 10)	02/25/2015	6 j	1.9 j	<30.6	50.5	6.7	44,800	107	2	<309	<1.2	74.5	
MW-32D (18.5 - 20)	02/25/2015	5.9 j	1.7	<3.3	3.7	3.2	2,760	62	13.3	<321	<1.3	3	
MW-32S (22.5 - 24)	03/12/2015	6.3 j	7.9	<38.9	116	33.8	46,400	910	1.4 j+	<387	<3.9	90.1	
MW-42D (28.5 - 30)	02/23/2015	6.6 j	1.8	<4	85.4	13.1	21,600	321	7.1	<423	0.89 j	50.9	
Beyond Ash Basin Waste Boundary													
GWA-03D (48.5 - 50)	04/16/2015	6.5 j	3.9 j-	<17.9	144	17.9	42,800	463	4.5	<355	<7.2	105	
GWA-05BRU (13.5 - 15)	02/23/2015	5.7 j	2.6 j	<19.7	129	25.2	26,700	498	2.7	<386	0.84 j	85.8	
GWA-05S (13.5 - 15)	03/06/2015	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	
GWA-06D (28.5 - 30)	05/08/2015	6.0 j	<9.7	<24.2	130	20.7	32,800	601	10.1	<466	<9.7	78.8	
GWA-31BR (4 - 4)	04/21/2015	7.1 j	7.7	31.3	98.8	17.5	35,200	401	5.5	<317	<6.6	79.9	
GWA-31D (7 - 7)	04/23/2015	10.7 j	<5	20.9	69.2	5.8	22,900	266	2 j	135 j	<5	61.5	
GWA-31D (8.7 - 8.7)	04/23/2015	11.5 j	4.5 j	41.6	43	7.1	15,500	403	115	162 j	<5.3	37.1	
GWA-32D (11.7 - 11.7)	06/05/2015	5.8 j	<5.3	<13.2	<1.3	<5.3	1,720	13.2	<2.6	<264	<5.3	<5.3	
MW-38D (33.5 - 35)	03/02/2015	6.0 j	3	<3	16.3	43.7	15,100	317	4.1	<298	<1.2	31.7	
MW-38S (33.5 - 35)	03/04/2015	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	
MW-40BRU (3.5 - 5)	03/30/2015	7.1 j	<6.1	<15.2	89.2	22.2	31,100	411	3.9	<295	<6.1	71.6	

Prepared by: TJG Checked by: VJH

Notes:

- Bold highlighted concentration indicates exceedance of the Inactive Hazardous Sites Branch PSRG Table (May 2019) for Protection of Groundwater or the Background Threshold Value (BT), whichever is higher.

- Concentration not detected at or above the adjusted reporting limit.

B - Target analyte detected in method blank at or above the reporting limit. Target analyte concentration in sample is less than 10X the concentration in the method blank. Analyte concentration in sample could be due to blank contamination.

j - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

j- - Estimated concentration, biased low.

j+ - Estimated concentration, biased high.

M - Matrix spike / matrix spike dup failure.

mg/kg - milligrams per kilogram

NA - not analyzed

NE - not established

PSRG - preliminary soil remediation goals

S.U. - standard units

TABLE 6-30
SOURCE AREA INTERIM ACTIONS
UNIT 5 INACTIVE ASH BASIN
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

Groundwater Remedy Component	Rationale
Source Area Stabilization	U5 AB main dam modifications including the installation of a new spillway.

Prepared by: SAS Checked by: TJG

**TABLE 6-31
MEANS OF GROUNDWATER COIS - JANUARY 2018 TO JUNE 2019
UNIT 5 INACTIVE ASH BASIN
CORRECTIVE ACTIVE PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC**

Analytical Parameter		pH	Arsenic	Boron	Chromium (VI)	Cobalt	Iron	Lithium	Manganese	Strontron	Sulfate	Thallium	Total Dissolved Solids	Total Radium	Total Uranium	Vanadium			
Reporting Units	\$,U.	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	PC/L	µg/L	µg/L	µg/L			
15A NCAC 02L Standard	6.5 - 8.5	10	700	NE	10	300	NE	50	NE	500	NE	500	NE	NE	0.3*				
2017 Background Threshold Values (Shallow Flow Zone) ²	4.0 - 6.1	1	0.5	4	11	684	NE	169	37	1	0.1	75	3	0.0005	1				
2019 Background Threshold Values (Shallow Flow Zone) ²	4.0 - 6.0	0.2	50	4	26	1700	3	969	34	4	57	2	0.0005	1	0.3				
2017 Background Dataset Range (Shallow Flow Zone) ²	2.3 - 6.1	<0.1 - 0.73	<50	<0.025 - 4.8	<0.5 - 26.2	0.16 - 22.9	<50 - 5750	<0.5 - 4.6	6.7 - 1000	6.8 - 103	<0.1 - 0.3	<75 - 10700	0.0976 - 1.061	<0.0002 - <0.0005	<0.3 - 1.9				
2019 Background Dataset Range (Shallow Flow Zone) ²	1.8 - 6.1	1	50	0.2	2	5	515	NE	78	56	10	0.1	71	2	0.0005	1			
2019 Background Threshold Values (Deep Flow Zone) ²	3.9 - 7.2	2	50	0.6	2	12	1840	12	260	69	15	0.2	107	2	0.0005	11			
2019 Background Dataset Range (Deep Flow Zone) ²	3.8 - 7.3	<0.1 - 2	<50 - 150	<0.025 - 1.2	<0.5 - 9.9	<0.1 - 6.1	<50 - 3200	1.5 - 13.4	5.2 - 408	6.3 - 70.5	<1 - 18.5	<0.1 - <0.2	<25 - 407	0.017 - 2.323	<0.0005	<0.3 - 12.2			
2017 Background Threshold Values (Bedrock Flow Zone) ²	1.4 - 7.4	1	50	0.1	4	1	6220	NE	89	107	15	0.2	120	3	0.0005	0.4			
2019 Background Threshold Values (Bedrock Flow Zone) ²	1.5 - 7.5	1	50	0.7	3	2	7680	11	113	93	17	0.2	120	3	0.0005	1			
2019 Background Dataset Range (Bedrock Flow Zone) ²	1.8 - 7.6	<0.1 - 1.2	<50 - 83	<0.025 - 0.8	<0.5 - 10.5	<0.1 - 2.6	<50 - 11000	1.1 - 7.3	5 - 134	16.6 - 116	1.1 - 17.6	<0.1 - 0.5	<25 - 330	0 - 346	<0.0005	<0.3 - 1.5			
Sample ID		Mean, Geometric, or Median Result³																	
Background Locations		Flow Zone																	
GWA-30S		Shallow	5.7	0.1	<50	0.041	1.3	5.0	264	1.1	269	24	<1	0.2	43	-			
MW-30S		Shallow	5.3	0.1	<50	0.120	3.0	0.4	159	1.2	8	10	33	0.490	<0.0005	<0.3			
MW-32S		Shallow	5.0	0.1	<50	0.177	0.6	1.1	73	2.5	37	<1	<0.1	59	1.208	<0.0005	<0.3		
CCPMW-01S		Deep	5.3	<0.1	0.324	0.8	2.2	53	2.0	42	<5	<1	<0.1	<25	2.13	0.0003	10.0		
MW-30DA		Deep	6.7	0.2	<50	0.076	<0.5	53	11.1	8	65	16	<0.1	116	0.420	<0.0005	0.3		
MW-32D		Deep	6.7	0.2	<50	0.025	0.6	0.8	241	10.2	219	68	3	0.1	326	<0.0005	<0.3		
CCPMW-01D		Bedrock	5.9	0.1	<50	0.034	0.6	1.8	<50	2.8	40	7	<0.1	73	0.593	<0.0005	<0.2		
GWA-31BR		Bedrock	6.3	<0.1	<50	0.056	<0.5	0.3	<50	1.1	22	1	<0.1	40	0.0	<0.0005	<0.3		
MW-32BR		Bedrock	7.0	0.1	<50	<0.025	0.8	<0.1	5305	6.1	33	57	14	<0.1	103	<0.249	<0.0005	<0.3	
Within the Waste Boundary Locations																			
U5-02S-SEB		Ash Pan Water	6.6	5775.0	267	<0.025	0.6	11.9	67950	54.9	643	1665	145	1.3	429	0.145	0.0110	0.6	
U5-02S		Shallow	6.2	4.2	<50	<0.025	0.7	7.5	51348	<0.5	4594	138	5	<0.1	217	-	0.5	-	
U5-02S		Shallow	5.4	0.2	135	0.2640	3.8	1.5	553	1.4	253	22	-	-	-	0.4	-		
U5-02S		Shallow	4.2	0.6	158	<0.025	2.1	21	107	4010	8.8	374	167	0.5	301	-	1.0	-	
U5-02S		Shallow	6.5	12.0	<50	<0.025	1.1	1.1	6580	<0.5	2980	150	221	<1	211	-	<0.3	-	
U5-02D		Deep	6.5	0.5	<50	0.034	<0.5	1.1	2322	20.7	2211	68	3	0.1	129	-	1.6	-	
U5-02D		Deep	6.7	4170	125	0.034	0.6	3.1	36740	16.7	872	1440	113	65	<1	338	1.5	<0.0005	-
U5-02D		Deep	7.3	1.4	<50	0.105	1.7	0.3	456	9.6	28	113	65	<0.1	183	-	<0.3	-	
U5-02D		Deep	6.3	1.4	331	0.035	3.1	19.2	16332	28.7	3222	186	163	<0.1	422	3.3	0.0119	0.5	
U5-02D		Deep	5.7	1.0	162	0.029	1.1	2.0	14182	21.4	1442	408	163	0.1	319	-	1.2	-	
U5-02D		Deep	6.0	164	120	0.50	1.068	1.3	2.0	25.1	6266	1.3	5910	396	2	0.3	195	-	0.7
U5-02BR		Bedrock	10.6	2.0	<50	0.580	0.5	0.3	59	113	-	9	18	<0.1	108	-	0.4	-	
U5-04RA		Bedrock	8.9	11.7	447	0.057	2.0	2.1	59	67.1	31	1342	555	1	1424	-	1.4	-	
U5-08BR		Bedrock	10.0	3.9	<50	0.680	1.4	0.0	47	11.3	<5	33	13	<0.1	124	-	2.6	-	
Between Waste Boundary and Compliance Boundary																			
CCH-15-US		Shallow	5.0	<0.1	4	2.5	1.7	-	1.2	1.9	-	113	53.2	0.4	52	54	-	-	
CCH-15-ID		Shallow	5.2	0.4	<50	3.2	2.8	-	122	0.9	-	207	5.3	<0.1	433	0.277	-	-	
CCH-15-10D		Shallow	5.5	<0.1	10	1.3	0.8	-	172	8.4	195	-	-	-	-	-	0.4	-	
Downgradient of the Ash Basin																			
CCR-15-03S		Shallow	5.9	<0.1	94	0.579	1.5	0.2	102	0.4	290	165	50	<0.1	169	-	0.3	-	
CCR-15-04S		Shallow	5.4	1.2	563	1.200	1.9	33.7	683	5.2	1830	550	182	0.5	338	0.366	-	0.6	
CCR-15-05S		Shallow	4.0	0.3	139	<0.5	33.3	2.6	251	1.0	-	150	0.6	289	1.4	-	-		
CCR-15-06S		Shallow	5.6	0.4	52	0.1	124	0.6	52	-	14	218	0.2	372	0.459	-	-		
CCR-15-07S		Shallow	5.2	<0.1	129	0.202	0.6	0.2	203	0.5	206	129	0.1	61	0.327	-	-		
CCR-15-08S		Shallow	5.5	<0.1	129	0.025	<0.5	0.2	59.4	18160	5.8	2014	537	194	1.3	313	<0.0005	<0.3	-
GW-03S		Shallow	4.3	0.8	159	<0.025	0.5	0.5	51.6	1851	7.5	1048	234	109	0.6	205	0.613	<0.0005	<0.3
GW-03S		Shallow	5.3	1.2	79	<0.1	0.7	0.2	4.7	1.1	-	52	<0.1	115	-	-	-		
CCR-15-09D		Deep	5.2	0.1	80	0.153	0.6	0.7	2.8	297	0.9	293	75	0.2	226	-	0.3	-	
CCR-15-09D		Deep	5.2	0.6	999	<0.025	0.5	0.6	61.3	107	16105	6.8	3640	555	341	0.9	59	0.4	-
CCR-15-09D		Deep	4.6	0.1	73	-	-	1.8	179	-	-	178	-	401	0.21	-	-		
CCR-15-09D		Deep	4.6	1.1	189	-	-	1.8	431	0.5	10.7	115	1.1	981	1.7	-	-		
GW-04BR		Deep	6.2	0.2	400	0.382	2.0	3.3	1.74	4.7	1444	233	449	233	1.6	269	-	0.0005	0.6
GWA-03D		Deep	5.7	0.4	165	<0.025	0.7	0.7	93.9	16.000	7.4	4320	6	461	381	0.7	874	<0.3	-
GWA-16D		Deep	6.7	0.4	165	0.214	0.7	0.7	91	37.4	5.6	4436	323	308	2.1	572	0.707	<0.0005	0.4
GWA-16D		Bedrock	6.8	0.5	114	<0.025	0.9	0.1	7120	9.0	0.1	598	281	2.7	-	577	0.0003	0.4	

**TABLE 6-31
MEANS OF GROUNDWATER COIS - JANUARY 2018 TO JUNE 2019
UNIT 5 INACTIVE ASH BASIN
CORRECTIVE ACTIVE PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC**

DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC															
Analytical Parameter	Reporting Units	pH	Arsenic	Boron	Chromium (VI)	Cobalt	Iron	Lithium	Manganese	Strontron	Sulfate	Thallium	Total Dissolved Solids	Total Uranium	Vanadium
Sample ID	Flow Zone	\$,U.	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	
CCR-15-02D	Bedrock	6.9	1.1	384	-	0.7	5.4	-	4.5	-	151	<0.1	452	<0.599	
GWA-02BRA	Bedrock	8.2	0.6	885	<0.025	1.0	0.1	852	5.4	125	43	<0.1	209	-	
GWA-31BRA	Bedrock	7.8	1.7	<50	0.031	0.2	<0.1	278	35.3	35	52	<0.1	302	<0.518	
GWA-67BR	Bedrock	11.8	-	<50	-	-	-	-	-	-	-	-	-	-	
GWA-68BRL	Bedrock	7.4	0.2	133	<0.025	0.5	0.1	1825	8.8	197	174	<0.1	241	3.7	
Near or Beyond Compliance Boundary	Flow Zone	\$,U.	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	
MW-42S	Shallow	5.6	0.2	<50	0.850	2.6	0.3	178	0.5	11	45	7	<0.1	67	
MW-45D	Deep	8.2	0.9	<50	<0.025	1.2	0.1	118	0.2	24	136	27	<0.1	201	
MW-47-DA	Deep	7.2	0.7	<50	0.079	0.8	0.3	152	36.5	43	116	112	<0.1	302	
Downgradient of the Ash Basin	Flow Zone	\$,U.	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	µg/L	
GWA-24S	Shallow	5.9	0.1	50	0.047	<0.5	16.9	160240	0.7	65	50	41	<0.1	53	
GWA-37S	Shallow	5.8	0.9	80	<0.025	1.3	92.7	15860	0.6	74	7866	74	<0.1	131	
GWA-34S	Shallow	6.1	0.2	<50	0.383	1.8	2.1	820	1.3	146	66	138	<0.1	182	
MW-36S	Shallow	5.2	<0.1	<50	0.063	<0.5	1.2	130	1.2	25	5	<1	<0.1	314	
MW-38S	Shallow	5.7	0.1	57	0.200	0.6	<0.1	261	0.4	41	10	<0.1	57	<0.25	
MW-40S	Shallow	5.3	0.1	126	0.540	1.5	3.7	377	1.1	366	81	153	<0.1	247	
GWA-01BD	Deep	7.1	0.5	<50	0.694	1.2	0.6	356	0.6	28	113	<0.1	247	-	
GWA-37D	Deep	6.0	0.1	<50	0.067	0.6	0.2	795	3.0	59	45	8	<0.1	95	
GWA-34D	Deep	6.4	0.1	128	<0.025	0.5	0.1	124	0.6	10	11	2	<0.1	27	
GWA-37D	Deep	5.3	0.2	62	0.665	11.1	1.3	4578	10.5	119	112	63	<0.1	189	
GWA-56D	Deep	6.5	0.2	<50	<0.025	1.4	0.6	1547	9.25	116	290	541	<0.1	3.0	
MW-34BRU	Deep	7.4	0.1	<50	0.028	<0.5	<0.1	783	1.3	40	64	12	<0.1	312	
MW-36BRU	Deep	6.9	<0.1	<50	0.076	<0.1	216	2.9	67	71	11	118	<0.1	121	
MW-38D	Deep	5.3	0.2	233	0.109	1.1	2.6	196	7.8	398	211	232	<0.1	424	
GWA-10BRU	Deep	7.7	0.5	<50	0.082	<0.5	<0.1	159	2.9	201	98	<0.1	268	4.6	
GWA-34BR	Bedrock	8.0	0.1	<50	<0.025	0.5	0.1	1057	1.5	30	66	<0.1	153	<0.3	
GWA-36BR	Bedrock	6.6	0.8	53	<0.025	1.0	0.9	2358	16.1	252	378	509	<0.1	3.3	<0.2

Notes:

1 - Background threshold values were calculated using data from background groundwater samples collected June 2015 to September 2017.

2 - Background threshold values were calculated using data from background groundwater samples collected March 2011 to December 2018.

3 - Statistical mean, geometric, or median calculated from data arising from January 2015 to June 2019. Ash pore water results are not compared to groundwater standards or criteria.

Meas were calculated for wells that have valid sample results, the most recent valid sample data was used.

Means were calculated for wells with four or more valid sample results. Sample results were excluded from calculations:

1) if turbidity >10 NTU (for COIs other than boron)

2) for unusable data (COI qualified)

3) if a result was non-detected at a reporting limit (RL) greater than the normal laboratory RL

Rule Text - Constituent concentration exceeds analytical comparison criteria

b1 - bold highlighted concentration value is greater than the 15A NCAC 02L .0202 Standard or the 15A NCAC 02L .0232 Standard and IMAc is April 1, 2013

b2 - bold highlighted concentration value is greater than the greatest background threshold value where there is no regulatory standard

b3 - highlighted concentration indicates value either within range of background threshold values or greater than regulatory standard or within range of background threshold value and the regulatory standard

< = concentration not detected at or above the adjusted reporting limit.

-- = value not available

NE = not established

mg/L = milligrams per liter

pCi/L = picocuries per liter

µg/L = micrograms per liter

S.U. = standard unit

Prepared by: TANX Checked by: TANX

TABLE 6-33
SUMMARY TREND ANALYSIS RESULTS
FOR MONITORING WELLS
UNIT 5 INACTIVE ASH BASIN
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

Wells Within the Waste Boundary								Wells Between Waste Boundary and Compliance Boundary				Wells Downgradient of the Source Area Near or Beyond Compliance Boundary			
Well ID	Boron	Lithium	Sulfate	Total Dissolved Solids	Well ID	Boron	Lithium	Sulfate	Well ID	Boron	Lithium	Sulfate	Total Dissolved Solids		
Shallow Flow Zone															
U5-01S	ND	ND	D	NT	CCR-U5-03S	S	D	D	GWA-34S	ND	NE	NT	NT	NT	NT
U5-08S	S	S	D	D	CCR-U5-04S	S	NT	S	GWA-35S	S	NE	S	S	S	S
Deep Flow Zone															
U5-01D	ND	NT	D	D	CCR-U5-06S	D	D	D	GWA-37S	S	S	D	S	S	S
U5-02D	D	S	S	D	CCR-U5-08S	NT	D	NT	GWA-38S	I (538)	D	S	S	S	S
U5-03D	D	S	D	NT	CCR-U5-09S	S	NT	NT	MW-34S	ND	NE	ND	ND	ND	ND
Bedrock Flow Zone															
U5-02BR	I	S	1	I	CCR-U5-10S	ND	NT	NT	MW-36S	S	NE	NT	D	D	D
U5-08BR	S	NE	NE	NE	GWA-02S	S	S	D	MW-38S	S	NT	S	S	S	S
Deep Flow Zone															
U5-04S	NT	S	NT	NT	GWA-04S	D	S	S	MW-40S	S	S	I	I (292)	I	I
U5-08S	S	S	D	D	GWA-05S	ND	S	NT	NW-01BRU	ND	NT	S	S	S	S
Bedrock Flow Zone															
CCR-U5-01D	ND	NT	I	NT	CCR-U5-02D	S	D	S	GWA-34D	S	NE	D	D	D	D
CCR-U5-03D	S	NT	D	S	CCR-U5-04D	S	S	S	GWA-35D	I	S	D	I (559)	S	S
CCR-U5-05D	D	NT	S	S	CCR-U5-06DA	S	D	D	GW-A-36D	ND	NE	S	S	S	S
CCR-U5-07D	D	NT	S	S	CCR-U5-08D	D	D	S	GW-A-37D	I	S	D	D	D	D
Bedrock Flow Zone															
CCR-U5-01D	I	S	S	I (275)	CCR-U5-02D	S	D	S	GWA-38D	ND	NE	S	S	S	S
CCR-U5-03D	S	NT	D	S	CCR-U5-04D	S	S	S	MW-34BRU	ND	NE	S	S	S	S
CCR-U5-05D	D	NT	S	S	CCR-U5-06DA	S	D	D	MW-36BRU	ND	NE	D	D	D	D
CCR-U5-07D	D	NT	S	S	CCR-U5-08D	D	D	I (660)	MW-38BRU	ND	D	I (332)	I	I	I
Notes:															
1.	Summary of results and trends are presented for samples collected from 2015 - 2019.														
2.	Trend results are presented when at least four samples were available and frequency of detection was >50%. Statistically significant trends are reported at the 90% confidence level.														
3.	Variability index (VI) is calculated as the (maximum - minimum) / median concentration and is calculated using detected concentrations only. Values less than 1 indicate low variability in the dataset.														
4.	For pH, statistically significant, increasing trend with a maximum recent result (2018 - 2019) less than the lower end of the standard range or greater than the upper end of the standard range. Maximum detected result for 2018 and 2019 time period shown in parentheses.														
5.	Wells that had insufficient samples collected (<4) for all four constituents were removed from table. See designation 'NE'.														
ND	= Greater than 50 percent of constituent concentrations were non-detect														
D	= Statistically significant, decreasing concentration trend														
S	= Stable, No significant trend and variability is low ($V1 \leq 1$)														
NE	= Insufficient number of samples to evaluate trend ($n < 4$)														

Prepared by: AECOM U.S., Inc.
 Checked by: HES

TABLE 6-34
SEEP CORRECTIVE ACTION STRATEGY
UNIT 5 INACTIVE ASH BASIN
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

Seep ID	Regulatory Program	General Location	Approximate Average Present Flow (cfs)	Seep Corrective Action Strategy
S-02	SOC	North of U5 AB	0.1	Corrective action at this location may consist of capturing and treating the seep or other remedial actions. Final corrective action plans for seeps that are not dispositioned after completion of decanting will be proposed in an amendment to the CAP Update and submitted based on the schedule outlined in the SOC.

Notes:

cfs- cubic feet per second
NPDES – National Pollution Discharge Elimination System
SOC – Special Order by Consent

Prepared by: SAS Checked by: TG

TABLE 6-35
NPDES PERMIT LIMITS AND ANTICIPATED GROUNDWATER REMEDIATION
PARAMETER LEVELS
UNIT 5 INACTIVE ASH BASIN
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

NPDES Outfalls	Outfall 002 ¹		Outfall 005		Maximum Detected Concentrations by Flow Zone²		
	Effluent Limitations and Monitoring Requirements						
Parameter	Monthly Average	Daily Maximum	Monthly Average	Daily Maximum	Saprolite	Transition Zone	Bedrock
Flow (MGD)	NS	1 MGD	NS	NS	NA	NA	NA
Oil & Grease	15.0 mg/L	20.0 mg/L	15.0 mg/L	20.0 mg/L	NA	NA	NA
TSS	30.0 mg/L	50.0 mg/L	30.0 mg/L	50.0 mg/L	9.2 mg/L	12.7 mg/L	6 mg/L
Total Chromium	0.2 mg/L	0.20 mg/L	0.2 mg/L	0.2 mg/L	0.003 mg/L	0.02 mg/L	0.002 mg/L
Total Zinc	1.0 mg/L	1.0 mg/L	1.0 mg/L	1.0 mg/L	0.05 mg/L	0.25 mg/L	0.008 mg/L
pH	From 6.0 to 9.0 S.U.		From 6.0 to 9.0 S.U.		3.7 – 6.4 S.U.	3.0 – 6.1 S.U.	6.4 – 6.9 S.U.
Total Copper ³	NA	NA	251 µg/L	272 µg/L	9.6 µg/L	2.8 µg/L	0.72 µg/L
Chronic Toxicity	NA	NA	Note 4		NA	NA	NA
Total Iron ³	NA	NA	1.0 mg/L	1.0 mg/L	20.9 mg/L	23.4 mg/L	2.95 mg/L
Total Residual Chlorine	NA	NA	NS	28 µg/L	NA	NA	NA
5-day BOD; 20° C	NA	NA	30.0 mg/L	45.0 mg/L	NA	NA	NA
Fecal Coliform (geo. Mean)	NA	NA	200/100 mL	400/100 mL	NA	NA	NA
Temperature	NA	NA	NS	100° F	NA	NA	NA

Prepared by: VTV Checked by TJG

Notes:

- 1 - Effective beginning on the commencement of the dewatering operation and lasting until permit expiration.
- 2 - Downgradient groundwater monitoring wells in area of groundwater remediation; Q1 2018 through Q2 2019 data.
- 3 - Monitoring shall be per occurrence of chemical metal cleaning and sample from a representative discharge.
- 4 - Chronic Toxicity (Ceriodaphnia) P/F at 3.14%; March, June, September, and December.

MGD - million gallons per day

NS - not specified

NA - not analyzed

TSS - total suspended solids

S.U. - standard units

BOD - biological oxygen demand

mg/L - milligrams per liter

µg - micrograms per liter

mL - milliliters

TABLE 6-36
REMEDIAL TECHNOLOGY SCREENING SUMMARY
UNIT 5 INACTIVE ASH BASIN
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

Summary of Remedial Technology Screening		Retain Technology for Further Consideration	
Technology	Yes/No	Rationale	
Monitored Natural Attenuation (MNA)	Yes	COIs pose no unacceptable risk to human health or the environment under conservative exposure scenarios. MNA could be implemented in conjunction with source control measures.	
In-Situ Technologies			
Low Permeability Barriers (LPB)	No	Technically challenging and costly.	
Groundwater Flushing	No	Mobile COIs are not the major concern. Modeling indicates that extraction will exert hydraulic control.	
Encapsulation	No	No area where COIs are concentrated.	
Permeable Reactive Barrier (PRB)	Yes	Potentially applicable for mitigation of low pH water.	
Groundwater Extraction Technologies			
Vertical Extraction Wells	Yes	Commonly used technology for groundwater extraction.	
Horizontal or Angular Extraction Wells	No	Modeling indicates that vertical extraction wells are sufficient.	
Extraction Trenches	Yes	A shallow trench could capture and control of the acidic groundwater near the saddle dam.	
Hydraulic Fracturing	No	Not warranted based upon the limited extent of COIs in bedrock.	
Phytoremediation	No	Limited additional mass removal.	
Groundwater Treatment Technologies			
pH Adjustment	Yes	Retained for remedial alternatives that include groundwater extraction.	
Precipitation	Yes	Part of the treatment in the WWTP associated with Outfall 005.	
Ion Exchange	No	Expensive and not expected to be needed to meet discharge requirements.	
Membrane Filtration	No	Expensive and not expected to be needed to meet discharge requirements.	

TABLE 6-36
REMEDIAL TECHNOLOGY SCREENING SUMMARY
UNIT 5 INACTIVE ASH BASIN
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

Summary of Remedial Technology Screening		Retain Technology for Further Consideration	
Technology	Yes/No	Rationale	
Management of Extracted Groundwater			
NPDES Permitted Discharge	Yes	Potential to discharge at Outfall 002 or 005; must modify permit to include discharge of extracted groundwater	
Publicly Owned Treatment Works (POTW)	No	Would require installation of infrastructure; NPDES is a better option.	
Non-Discharge Permit/Infiltration Gallery	No	Site soils have limited capacity to transmit water.	
Non-Discharge Permit/Land Application	No	Will not be considered as long as disposal via NPDES permitted outfall is a viable option.	
Beneficial Reuse			
Fire Protection	No	Limited application. Storage is problematic	
Non-Contact Cooling Water	No	Limited application.	
Dust Suppression and Truck Wash	No	Limited application.	

Prepared by: TJG Checked by: JEC

TABLE 6-37
REMEDIAL ALTERNATIVE 3 EXTRACTION WELL AND SOURCE
CONTROL TRENCH SUMMARY
UNIT 5 INACTIVE ASH BASIN
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

Groundwater Extraction System		
Number of Wells	Flow Zone	Total Depth (ft bgs)
12	Saprolite/Transition Zone	98 - 122
1 (Source Control Trench)	Saprolite	17 - 19
Total Extraction Well Count: 13		
Groundwater extraction system flow and operation assumptions: Modeled groundwater extraction rate: 0.6 to 2.7 gpm per well; average 1.8 gpm per well. Estimated total system groundwater extraction rate: 21.6 gpm. Groundwater extraction wells operate to maintain water level near top of the submersible pump.		

Prepared by: VTV Checked by: RAG

Notes:

ft bgs – feet below ground surface

gpm – gallons per minute

TABLE 6-38
ENVIRONMENTAL SUSTAINABILITY COMPARISONS FOR REMEDIATION ALTERNATIVES
UNIT 5 INACTIVE ASH BASIN
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS LLC, MOORESBORO, NC

Remedial Alternative		Remedial Alternative 1 – Groundwater Remediation by MNA	Remedial Alternative 2 – Groundwater Remediation by pH Adjustment Gallery	Remedial Alternative 3 – Groundwater Remediation by Extraction Wells and Source Control Trench
Emissions	Units			
CO ₂ Emissions	metric ton	1.14E+00	1.51E+03	5.09E+02
Onsite NO _x emissions	metric ton	0.00E+00	2.50E-01	4.02E-01
Onsite SO _x Emissions	metric ton	0.00E+00	1.61E-02	2.04E-02
Onsite PM ₁₀ Emissions	metric ton	0.00E+00	1.25E-02	1.43E-02
Total NO _x emissions	metric ton	4.23E-04	3.78E+00	1.89E+00
Total SO _x Emissions	metric ton	1.49E-05	5.29E+00	1.18E+00
Total PM ₁₀ Emissions	metric ton	8.58E-05	1.07E+00	2.47E-01
Total Energy Used	MMBTU	1.44E+01	4.55E+05	4.48E+05
Total Emissions	metric ton	1.14E+00	1.52E+03	5.12E+02

Prepared by: GTC Checked by: SJB

Notes:

CO₂ - Airborne emissions of carbon dioxide

MMBTU - Million British Thermal Units

NO_x - Airborne emissions of nitrogen oxides (combination of nitrogen monoxide and nitrogen dioxide)

SO_x - Airborne emissions of sulfur oxides (combination of sulfur monoxide, sulfur dioxide, sulfur trioxide, and others)

PM₁₀ - Airborne emissions of particulate matter that is 10 micrometers or less in diameter

TABLE 6-39
MODELED GROUNDWATER EXTRACTION WELL DETAILS
UNIT 5 INACTIVE ASH BASIN
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

Well ID	Easting	Northing	Approximate Ground Surface Elevation (feet)	Operational DTW Maintained In Well (ft BGS)	Well Depth (ft BGS)	Targeted Flow Zones	Total Simulated Flow (gpm)
							Vertical Extraction Wells
EX-U5-1	1174126.90	545805.10	709	14	98	Saprolite/Transition Zone	2.5
EX-U5-2	1174180.80	545752.90	711	17	98	Saprolite/Transition Zone	2.5
EX-U5-3	1174241.40	545707.50	711	17	106	Saprolite/Transition Zone	2.7
EX-U5-4	1174000.70	545764.70	710	13	98	Saprolite/Transition Zone	2.4
EX-U5-5	1173854.20	545720.90	707	12	106	Saprolite/Transition Zone	2.4
EX-U5-6	1173945.10	545512.20	714	19	90	Saprolite/Transition Zone	0.6
EX-U5-7	1174014.10	545517.20	714	21	98	Saprolite/Transition Zone	1.1
EX-U5-8	1174093.30	545524.00	715	23	114	Saprolite/Transition Zone	1.8
EX-U5-9	1174201.00	545547.50	711	22	114	Saprolite/Transition Zone	2.0
EX-U5-10	1174148.80	545466.70	715	24	122	Saprolite/Transition Zone	0.7
EX-U5-11	1174249.80	545401.00	708	29	122	Saprolite/Transition Zone	1.4
EX-U5-12	1174259.90	545337.10	709	27	122	Saprolite/Transition Zone	1.4

Notes:

All depths are approximated and may change depending on site conditions.
Flowrates are approximate and may change depending on site conditions.

DTW - depth to water

ft - feet

ft BGS - feet below ground surface

gpm - gallons per minute

NA - Not applicable

Prepared by: GTC

Checked by: RAG

TABLE 6-40
EFFECTIVENESS MONITORING PLAN ELEMENTS
UNIT 5 INACTIVE ASH BASIN
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
DUKE ENERGY CAROLINAS, LLC, MOORESBORO, NC

Effectiveness Monitoring Plan (EMP) Implemented 30 days after CAP Approval			Post-Closure Monitoring Plan (PCMP) Implemented after completion of ash basin closure activities																					
EMP Groundwater Well Monitoring Network (background, downgradient of source areas)			PCMP Groundwater Well Monitoring Network (background, downgradient of source areas)																					
Performance Monitoring Network <table> <tr><td>CCR-U5-6S</td><td>GWA-36S</td><td>GWA-37BR*</td></tr> <tr><td>CCR-U5-6DA</td><td>GWA-36D</td><td>MW-38S</td></tr> <tr><td><i>GWA-4S</i></td><td>GWA-36BR*</td><td>MW-38D</td></tr> <tr><td><i>GWA-4D</i></td><td>GWA-37S</td><td>MW-38BR</td></tr> <tr><td><i>GWA-4BR*</i></td><td>GWA-37D</td><td></td></tr> </table>			CCR-U5-6S	GWA-36S	GWA-37BR*	CCR-U5-6DA	GWA-36D	MW-38S	<i>GWA-4S</i>	GWA-36BR*	MW-38D	<i>GWA-4D</i>	GWA-37S	MW-38BR	<i>GWA-4BR*</i>	GWA-37D								
CCR-U5-6S	GWA-36S	GWA-37BR*																						
CCR-U5-6DA	GWA-36D	MW-38S																						
<i>GWA-4S</i>	GWA-36BR*	MW-38D																						
<i>GWA-4D</i>	GWA-37S	MW-38BR																						
<i>GWA-4BR*</i>	GWA-37D																							
Continued Monitoring Network <table> <tr><td>CCR-U5-3S</td><td>GWA-2S</td><td>GWA-35D</td></tr> <tr><td>CCR-U5-3D</td><td>GWA-2BRU</td><td>GWA-35BR*</td></tr> <tr><td>CCR-U5-4S</td><td>GWA-2BRA</td><td>GWA-67BR</td></tr> <tr><td>CCR-U5-4D</td><td>GWA-3D</td><td>MW-36S</td></tr> <tr><td>CCR-U5-4BR</td><td>GWA-3BR*</td><td>MW-36BRU</td></tr> <tr><td>CCR-U5-5D</td><td>GWA-35S</td><td>MW-36BR*</td></tr> </table>			CCR-U5-3S	GWA-2S	GWA-35D	CCR-U5-3D	GWA-2BRU	GWA-35BR*	CCR-U5-4S	GWA-2BRA	GWA-67BR	CCR-U5-4D	GWA-3D	MW-36S	CCR-U5-4BR	GWA-3BR*	MW-36BRU	CCR-U5-5D	GWA-35S	MW-36BR*	A PCMP will be implemented at the Site in accordance with G.S. 130A-309.214(a)(4)k.2 after completion of ash basin closure activities.			
CCR-U5-3S	GWA-2S	GWA-35D																						
CCR-U5-3D	GWA-2BRU	GWA-35BR*																						
CCR-U5-4S	GWA-2BRA	GWA-67BR																						
CCR-U5-4D	GWA-3D	MW-36S																						
CCR-U5-4BR	GWA-3BR*	MW-36BRU																						
CCR-U5-5D	GWA-35S	MW-36BR*																						
Background Monitoring Wells¹ <table> <tr><td>GWA-30S</td><td>MW-30DA</td><td>MW-32D</td></tr> <tr><td>GWA-30BR</td><td>MW-32S</td><td>MW-32BR</td></tr> <tr><td>MW-30S</td><td></td><td></td></tr> </table>			GWA-30S	MW-30DA	MW-32D	GWA-30BR	MW-32S	MW-32BR	MW-30S															
GWA-30S	MW-30DA	MW-32D																						
GWA-30BR	MW-32S	MW-32BR																						
MW-30S																								
EMP Groundwater Quality^{3, 4} (Semi-Annual Sampling Frequency) <table> <tr><td>Alkalinity</td><td>Cobalt²</td><td>Potassium</td></tr> <tr><td>Aluminum</td><td>Ferrous Iron</td><td>Sodium</td></tr> <tr><td>Bicarbonate Alkalinity</td><td>Iron²</td><td>Strontium²</td></tr> <tr><td>Boron²</td><td>Lithium²</td><td>Sulfate²</td></tr> <tr><td>Calcium</td><td>Magnesium</td><td>Total Dissolved Solids²</td></tr> <tr><td>Chromium (Total)²</td><td>Manganese²</td><td>Total Organic Carbon</td></tr> <tr><td>Chromium (VI)²</td><td>Nitrate + Nitrite</td><td>Total Radium²</td></tr> </table>			Alkalinity	Cobalt ²	Potassium	Aluminum	Ferrous Iron	Sodium	Bicarbonate Alkalinity	Iron ²	Strontium ²	Boron ²	Lithium ²	Sulfate ²	Calcium	Magnesium	Total Dissolved Solids ²	Chromium (Total) ²	Manganese ²	Total Organic Carbon	Chromium (VI) ²	Nitrate + Nitrite	Total Radium ²	PCMP Groundwater Quality (Sampling frequency to be determined)
Alkalinity	Cobalt ²	Potassium																						
Aluminum	Ferrous Iron	Sodium																						
Bicarbonate Alkalinity	Iron ²	Strontium ²																						
Boron ²	Lithium ²	Sulfate ²																						
Calcium	Magnesium	Total Dissolved Solids ²																						
Chromium (Total) ²	Manganese ²	Total Organic Carbon																						
Chromium (VI) ²	Nitrate + Nitrite	Total Radium ²																						
CMP and PCMP Groundwater Field Parameters <table> <tr><td>Water Level</td><td>Specific Conductivity</td><td>Temperature</td></tr> <tr><td>pH</td><td>Oxidation Reduction Potential</td><td>Dissolved Oxygen</td></tr> </table>			Water Level	Specific Conductivity	Temperature	pH	Oxidation Reduction Potential	Dissolved Oxygen	Parameters and sampling frequency to be included in the PCMP in accordance with G.S. 130A-309.214(a)(4)k.2 when submitted.															
Water Level	Specific Conductivity	Temperature																						
pH	Oxidation Reduction Potential	Dissolved Oxygen																						
EMP Review <ul style="list-style-type: none"> <u>Annual Effectiveness Monitoring Evaluation and Reporting</u> <ol style="list-style-type: none"> 1) Summary of annual groundwater monitoring results 2) Evaluate statistical concentration trends 3) Comparison of observed concentrations to model predictions 4) Evaluation of system performance and effectiveness 4) Recommend plan adjustments, if applicable, to optimize the remedial action <u>5-Year Performance Review Reporting</u> <ol style="list-style-type: none"> 1) Update background analysis 2) Confirm Risk Assessment assumptions remain valid 3) Re-evaluate effectiveness of technology 4) Verify modeling results, update model if needed 5) Modify corrective action approach, as needed, to achieve 			PCMP Review <ul style="list-style-type: none"> <u>Annual Evaluation and Reporting:</u> <ol style="list-style-type: none"> 1) Summary of annual groundwater monitoring results 2) Evaluate statistical concentration trends 2) Comparison of observed concentrations to model predictions 3) Evaluation O2L compliance 4) Recommend plan adjustments, if applicable <u>At a frequency no greater than 5 years:</u> <ol style="list-style-type: none"> 1) Update background analysis 2) Confirm Risk Assessment assumptions remain valid 3) Verify model results, update if needed 																					
EMP Duration <p>30 days after CAP approval, the EMP will be implemented at the Site and will continue until there is a total of three years of data confirming COIs are below applicable Standards at or beyond the compliance boundary, at which time a request for completion of active remediation will be filed with NCDEQ.</p> <p>If applicable standards are not met, the EMP will continue and transition to post-closure monitoring if necessary.</p>			PCMP Duration <p>After ash basin closure and following ash basin closure certification, a PCMP will be implemented at the Site for a minimum of 30 years in accordance with G.S. 130A-309.214(4)(k)(2).</p> <p><u>Early termination:</u> If groundwater monitoring results are below applicable Standards at the compliance boundary for three years, Duke Energy will request completion of corrective action in accordance with G.S. 130A-309.214(a)(3)b. If groundwater monitoring results are above applicable Standards, the PCMP will continue.</p>																					

¹ Approved background groundwater monitoring locations

² Corrective action COIs to monitor plume stability and physical attenuation either from active remedy or natural dilution/dispersion

³ The number of monitoring wells and parameters may be adjusted based on additional data and the effects of corrective action.

⁴ Groundwater standards may be modified over time in accordance with O2L .0106(k)

* Proposed new well

Italicized parameters - parameters for general water quality to evaluate monitoring data quality
Wells indicated in red will have geochemical sondes placed to monitor geochemical conditions

FIGURES

(*CAP Content Section 10*)




FIGURE ES-1
USGS LOCATION MAP
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
MOORESBORO, NORTH CAROLINA





www.synterracorp.com


DRAWN BY: J. KIRKZ
 REVISED BY: C. DAVIS
 CHECKED BY: T. GRANT
 APPROVED BY: T. GRANT
 PROJECT MANAGER: S. SPINNER


DATE: 06/12/2019
 DATE: 12/27/2019
 DATE: 12/27/2019
 DATE: 12/27/2019


GRAPHIC SCALE
 0 500 1,000 2,000 3,000
 (IN FEET)



















NOTES:

1. ALL BOUNDARIES ARE APPROXIMATE.
2. 2016 USGS TOPOGRAPHIC MAP, CHESNEE & BOILING SPRINGS SOUTH QUADRANGLE, OBTAINED FROM THE USGS STORE AT <https://store.usgs.gov/map-locator>.








FIGURE 1-3
1955 AERIAL PHOTOGRAPH
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
MOORESBORO, NORTH CAROLINA

SOURCE:
March 1955 Aerial Photograph obtained from the USGS EARTH EXPLORER website at
<http://earthexplorer.usgs.gov>

Graphic Scale
0 400 800
IN FEET

DUKE ENERGY CAROLINAS


synterra



www.synterracorp.com

DRAWN BY: J. CHRISTIAN I
DATE: 12/21/2019
REVIEWED BY: J. CHRISTIAN I
DATE: 12/21/2019
CHECKED BY: T. GRANT
DATE: 12/21/2019
APPROVED BY: T. GRANT
DATE: 12/21/2019
PROJECT MANAGER: S. SPINNER

Rogers Energy Complex Simplified
Process Flow Diagram Post Outfall 005
Operation



Not to Scale

Legend

→ = Process Flows
- - - - - → = Overflows



Duke
Energy
CAROLINAS



www.synterracorp.com

DATE: 12/17/2019

DRAWN BY: T. COLTON

REvised By:

T. GRANT

CHECKED BY:

T. GRANT


APPROVED BY:

T. SPINNER

PROJECT MANAGER:

www.synterracorp.com

FIGURE 1-4
SIMPLIFIED PROCESS FLOW DIAGRAM
POST OUTFALL 005 OPERATION
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STREAM STATION
MOORESBORO, NORTH CAROLINA






Figure 5-2
LeGrand Slope Aquifer System
Included in Section 5 text

Figure 5-3

Ash Basin Current Flow Conditions

Included in Section 5 text

Figure 5-4a

Water Level Map (East) – Shallow Flow Zone

Provided in separate electronic figure file as a large sheet size

Figure 5-4b

Water Level Map (East) – Deep Flow Zone

Provided in separate electronic figure file as a large sheet size

Figure 5-4c

Water Level Map (East) – Bedrock Flow Zone

Provided in separate electronic figure file as a large sheet size

Figure 5-5a

Water Level Map (West) – Shallow Flow Zone

Provided in separate electronic figure file as a large sheet size

Figure 5-5b

Water Level Map (West) – Deep Flow Zone


Provided in separate electronic figure file as a large sheet size

Figure 5-5c


Water Level Map (West) – Bedrock Flow Zone

Provided in separate electronic figure file as a large sheet size

**PORTION OF
CROSS SECTION K-K'**



FRACTURES CONCEPTUALLY DEPICTED ON THIS CROSS SECTION REPRESENT GENERALIZED ORIENTATIONS OF FRACTURES OBSERVED BASED ON VIEWER LOGGING THE DEFECT. FRACTURE ORIENTATIONS ACCOUNT FOR APPARENT DEPTH WITHIN THE PLANE OF THE CROSS SECTION, AND FRACTURE LENGTHS ARE EXAGGERATED. THE ACTUAL NUMBER OF FRACTURES IS FAR TOO NUMEROUS TO ILLUSTRATE AT THIS SCALE. IN ADDITION, THE DEPTHS AND LENGTHS OF FRACTURES VERSUS DEPTH ARE CONCEPTUAL ONLY.



1. DEPTH TO GROUNDWATER GAUGED IN MONITORING
WELLS ON APRIL 22, 2019.
2. SURFACE WATER ELEVATION ESTIMATED FROM SURVEY
DATA COLLECTED ON APRIL 22, 2019.
3. ALL VERTICAL ELEVATIONS ARE MEASURED
IN FEET, NORTH AMERICA VERTICAL
DATUM (NAVD of 1988).

LEGEND

- GWA-55S**: WELL IN SHALLOW LAYER
- GWA-55D**: WELL IN DEEP LAYER
- GWA-55B**: WELL IN BEDROCK LAYER
- GWA-55B2**: WELL IN BEDROCK LAYER
- GENERALIZED WATER TABLE
- GENERALIZED VERTICAL POTOMETERIC FLOW LINES

WATER LEVEL ELEVATION (NAMEF 88)
(LABEL COLORING BY FLOW ZONE)

GENERALIZED BEDROCK FRACTURE
ORIENTATION

WELL SCREEN


COMPLIANCE BOUNDARY


ASH
ASH PORE WATER
FILL
SAPROLITE
TRANSITION ZONE
BEDROCK


715.37
702.23


FIGURE 5-6
GROUNDWATER FLOW CROSS SECTION
AAB UPSTREAM DAM
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
MOORESBORO, NORTH CAROLINA


CROSS SECTION LOCATION



























Source Area 1


(Active Ash Basin and Ash Storage Area)


Figure 6-1


**Fly Ash and Bottom Ash Interbedded
Depiction**



Included in Section 6 text


















450 FRACTURES CONCEPTUALLY DEPICTED ON THIS CROSS SECTION REPRESENT GENERALIZED ORIENTATIONS OF FRACTURES OBSERVED BASED ON TELEVIEWER LOGGING. THE DEPICTED FRACTURE ORIENTATIONS ACCOUNT FOR APPARENT DIP WITHIN THE PLANE OF THE CROSS SECTION, AND VERTICAL EXAGGERATION. THE NUMBER OF FRACTURES IS FAR TOO NUMEROUS TO ILLUSTRATE AT THIS SCALE. IN ADDITION, THE DEPTHS AND LENGTHS OF FRACTURES VERSUS DEPTH ARE CONCEPTUAL ONLY.

LEGEND

- GWA-25S**: WELL IN SHALLOW FLOW LAYER
- GWA-25D**: WELL IN DEEP FLOW LAYER
- GWA-24ER**: WELL IN BEDROCK FLOW LAYER
- GE-6S**: WELL IN SHALLOW FLOW LAYER
- GENERALIZED WATER TABLE**: Dashed blue line with a blue arrow pointing up.
- GENERALIZED BEDROCK FRACTURE ORIENTATION**: A series of short black lines indicating fracture orientation.
- GENERALIZED GROUNDWATER FLOW DIRECTION**: A blue arrow pointing generally right.
- ASH**: A pattern of vertical lines.
- ASH PORE WATER**: A purple rectangle.
- FILL**: A white rectangle.
- SAPROLITE**: A grey rectangle.
- TRANSITION ZONE**: A white rectangle.
- BEDROCK**: A black rectangle.
- ALUMINUM**: A grey rectangle.



GENERAL CROSS SECTION A-A'

MEAN OF BORON, LITHIUM, SULFATE AND DISSOLVED SOLIDS (TDs)

ACTIVE ASH BASIN

CLIFFSIDE STEAM STATION

MOOREFIELD, NORTH CAROLINA

CORRECTIVE ACTION PLAN UPDATE

DRAWN BY: L. CHASTAIN
REMEDIED BY: D. KREBSFAM
CHECKED BY: T. GRANT
PROJECT MANAGER: B. SPRINGER

VERTICAL SCALE 1" = 400'
VERTICAL SCALE 1" = 40'


DATE: 10/22/2019
DATE: 10/29/2019
DATE: 10/29/2019


www.synterracop.com



2 DOCUMENTS AND INFORMATION CONCERNING THE USE OF ANGIOGENIC PROTEINS

LITERATURE (mg/L)	STANDARD (mg/L)	REPORTING LIMIT (mg/L)	DILUTION (mg/L)	NO. OF SAMPLES (n)	TOS
3. ANALYTICAL PARAMETER	B	Li	SO4	TO5	TO5
BACKGROUND THRESHOLD CONCENTRATIONS ARE IN MILLIGRAMS PER LITER (mg/L)					
3.1. BACKGROUND THRESHOLD CONCENTRATIONS ARE IN MILLIGRAMS PER LITER (mg/L)					
3.1.1. WHERE THE DATA SET IS FOR DIVIDED RESULTS, THE MOST RECENT VALID SAMPLE AT A DATE UP TO JUNE 2010 WAS USED.					
3.1.2. NO DATA AVAILABLE					
3.1.3. UPDATED BACKGROUND THRESHOLD VALUES ARE CALCULATED USING DATA FROM BACKGROUND GROUNDWATER SAMPLES COLLECTED FEBRUARY 2010 TO DECEMBER 2010 AND SEPTEMBER 2010 IN AME 2015.					
3.1.4. NOT ESTABLISHED					

CROSS SECTION LOCATION









CROSS SECTION LOCATION




www.synterracorp.com





SAYING YES TO
ORIENTATION.



CROSS SECTION LOCATION

FIGURE 6-Jb

GENERAL CROSS SECTION J-J'
NON-CONSERVATIVE GROUP
MEAN OF ARSENIC, STRONTIUM, TOTAL URANIUM
AND VANADIUM

ACTIVE ASH BASIN
CLIFFSIDE ACTION PLAN UPDATE
MOORESBORO, NORTH CAROLINA


DRAWN BY: C.A. ASTAIN
REVIEWED BY: D. KRIESEL
CHECKED BY: B.S. SPERL
PROJECT MANAGER: S. SCHAFFNER

DATE: 10/3/2019
DATE: 10/30/2019
DATE: 10/30/2019
DATE: 10/30/2019

5X VERTICAL EXAGGERATION
HORIZONTAL SCALE: 1" = 240'
VERTICAL SCALE: 1" = 48'

www.synteracorp.com

FIGURE 6-9B
GENERAL CROSS SECTION OF THE NON-CONSERVATIVE CORRECTIVE ACTION PLANS FOR ARSENIC, STRONTIUM, AND VANADIUM AT THE ACTIVE ASH BASIN, CLIFFSIDE STEAM STATION, MOORESBORO, NORTH CAROLINA






FIGURE 6.10b
GENERAL CROSS SECTION K-K'
NONCONDUCTIVE GROUP
MEAN OF ARSENIC, STRONTIUM, TOTAL URANIUM
AND VANADIUM

ACTIVE AS BASIN
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
MOORESBORO, NORTH CAROLINA

DUKE ENERGY
CAROLINAS



synterra

www.synterra.com

2013

2014

2015

2016

2017

2018

2019

2020

2021

2022

2023

2024

2025

2026

2027

2028

2029

2030

2031

2032

2033

2034

2035

2036

2037

2038

2039

2040

2041

2042

2043

2044

2045

2046

2047

2048

2049

2050

2051

2052

2053

2054

2055

2056

2057

2058

2059

2060

2061

2062

2063

2064

2065

2066

2067

2068

2069

2070

2071

2072

2073

2074

2075

2076

2077

2078

2079

2080

2081

2082

2083

2084

2085

2086

2087

2088

2089

2090

2091

2092

2093

2094

2095

2096

2097

2098

2099

2010

2011

2012

2013

2014

2015

2016

2017

2018

2019

2020

2021

2022

2023

2024

2025

2026

2027

2028

2029

2030

2031

2032

2033

2034

2035

2036

2037

2038

2039

2040

2041

2042

2043

2044

2045

2046

2047

2048

2049

2050

2051

2052

2053

2054

2055

2056

2057

2058

2059

2060

2061

2062

2063

2064

2065

2066

2067

2068

2069

2070

2071

2072

2073

2074

2075

2076

2077

2078

2079

2080

2081

2082

2083

2084

2085

2086

2087

2088

2089

2090

2091

2092

2093

2094

2095

2096

2097

2098

2099

2010

2011

2012

2013

2014

2015

2016

2017

2018

2019

2020

2021

2022

2023

2024

2025

2026

2027

2028

2029

2030

2031

2032

2033

2034

2035

2036

2037

2038

2039

2040

2041

2042

2043

2044

2045

2046

2047

2048

2049

2050

2051

2052

2053

2054

2055

2056

2057

2058

2059

2060

2061

2062

2063

2064

2065

2066

2067

2068

2069

2070

2071

2072

2073

2074

2075

2076

2077

2078

2079


2080


2081


2082


2083


<p











Note:
* sampling events prior
to 1/1/2018

Ash Pore Water Wells

AB-03MA15	□	AB-05S
AB-03S	○	AB-06S
AB-03SL	△	AB-07S
AB-04LA15	▽	AB-08S
AB-04S	◇	AB-09S
AB-04SL	×	AS-07S
AB-04UA15	*	AS-08S

AB-6BR

AB-6D

CCR-16D

CCR-16S*

GWA-47D




FIGURE 6-13a
ASH PORE WATER AND
GROUNDWATER PIPER DIAGRAMS
NORTH AND SOUTH TRANSECTS
ACTIVE ASH BASIN
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
MOORESBORO, NORTH CAROLINA

DRAWN BY: R. Badum REVISED BY: CHECKED BY: T. Grant APPROVED BY: T. Grant PROJECT MANAGER: S. Spinner	DATE: 12/4/2019
Duke Energy Carolinas	Synterra

AS-2S	AS-7BRB	AS-1SB	AS-2BR	AS-2D
AB-7BR	CCR-7D	CCR-7S	CLMW-3D	

Note:
* sampling events prior
to 1/1/2018

Ash Pore Water Wells

AB-03MA15	AB-05S
AB-03S	AB-06S
AB-03SL	AB-07S
AB-04LA15	AB-08S
AB-04S	AB-09S
AB-04SL	AS-07S
AB-04UA15	AS-08S

AB-2BRO AB-2D AB-2S

GWA-20D GWA-20S

GWA-2BR GWA-20R

GWA-3BRUA

GWA-3I GWA-58BR

GWA-58S GWA-58RRU

GWA-62BRU



CCR-8BR CCR-8D


CCR-8I


GWA-58S

GWA-62BRU

GWA-58RRU










FIGURE 6-15b
HYDROGRAPHS - GROUNDWATER
ACTIVE ASH BASIN
CORRECTIVE ACTION PLAN UPDATE
CLIFFSIDE STEAM STATION
MOORESBORO, NC