

System Name: **Blaney Farms** Well #: **2** System #: **409213***

PSI on: _____
PSI off: _____

DATE M/D/Y	TIME Arrived	Backwash Gallons Used	Master Meter	Meter Number	Gallons Since Last Visit	PSI	Chem. Added		Chem. Level		pH	Well House Residuals				Inlets	Comments & Adjustments
							CL2	PO4	CL2	PO4		CL2	PO4	Fe	Mn		
7/1/22	1:45			16738357		82	1.5		17/45	34		0.51	0.65			ADB	
7/5/22	9:20			16738367		90			30	28		0.73	0.53	0	0.012	ADB	
7/7/22	9:30			16738374		85	1		25/40	25/30		0.65	0.68			ADB	
7/11/22	10:30			16738392		82			32	27		0.52	0.61	0	0.019	ADB	
7/13/22	10:45			16738411		85			24	24		0.64	0.46			ADB	
7/15/22	10:30			16738431		84	2	1.5	15/45	20/46		0.53	0.37			ADB	
7/19/22	10:20			16738441		80			44	44		0.59	0.55			ADB	
7/20/22	8:58			16738461		82			33	40		0.61	0.73	0.01	0.022	ADB	Cl2 stroke 45 to 50
7/25/22	9:30			16738475		68	1		27/40	38		0.33	0.69				

Date M/D/Y	Time Arrived	MRT Residuals				Gals Flushed	Initials	MRT Address
		CL2	PO4	Fe	Mn			
7/1/22	1:45	0.35	0.77			ADB	3828 hickory manor	
7/7/22	9:30	0.42	0.8			ADB	2108 stillness pond	
	10:50	0.41	0.65			ADB	3828 hickory manor	
7/13/22	10:45	0.39	0.96			ADB	3828 hickory manor	
7/15/22	10:30	0.38	0.71			ADB	2108 stillness pond	
7/20/22	8:55	0.37	0.62	0.02	0.003	ADB	2212 serene lake drive	
7/21/22	9:00	0.51	0.64	0	0.005	ADB	2120 stillness pond	
7/25/22	9:30	0.41	0.67	0.01	0.06	ADB	4025 kaylor creek (blow off)	
	10	0.37	0.79	0.05	0.01	ADB	4008 kaylor creek 8.7 PH	

System Name Blaney Farms	Well # 2	System # 409213
-----------------------------	-------------	--------------------

PSI on: _____
PSI off: _____

DATE M/D/Y	TIME Arrived	Backwash Gallons Used	Master Meter	Meter Number	Gallons Since Last Visit	PSI	Chem. Added		Chem. Level		pH	Well House Residuals				Initials	Comments & Adjustments	Date M/D/Y	Time Arrived	MRT Residuals				Gals Flushed	Initials	MRT Address				
							Cl2	PO4	Cl2	PO4		CL2	PO4	Fe	Mn					CL2	PO4	Fe	Mn							
8/1/22	2		16,738,495			88			35	35		0.85	0.37	0.05	0.036	ADB	Cl2 was .47 and I adjusted cl2 stroke from 50 to 60 . Po stroke 30 to 35	8/3/22	9	0.23	1.41						ADB	2122 serene lake		
8/3/22	9						1		31/45			0.35						8/4/22	8:45	0.54	0.76	0.05	0.018			ADB	3828 hickory manor			
8/4/22	8:45		16,738,402			82	0.5		43	33		0.54	0.79			ADB		8/8/22	10:30	0.65	0.67	0.02	0.016	950	ADB	4016 cross timber				
8/8/22	9:00		16,738,424			92			35	29		0.78	0.59	0	0.033	ADB		8/10/22	11:	0.45	1.11	0	0			ADB	3828 hickory			
8/10/22	11																													
8/11/22	8:30		16738439			88			30	25		0.85	0.53			ADB		8/18/22	1:00	0.27	1.44	0	0			ADB	3724 hickory manor			
8/15/22	9:20		16738460			92			24	20		0.5	0.7			ADB		8/19/22	10:15	0.61	0.94	0.17	0	550	ADB	4025 kaylor creek blow off				
8/18/22	1:00		16738474			82			20/35	18		0.58	1.1			ADB														
8/19/22	10:15																													
8/22/22	10:20		16738487			80			31	15		0.35	0.71	0.11	0.021	ADB	Cl2 stroke 65 to 70	8/25/22	9:35	0.51	0.89			420	ADB	2200 serene lake blow off				
8/25/22	9:35		16738390			82	1		27	14/30		0.52	0.87			ADB			10:05	0.32	0.91	0	0.017			ADB	4008 kaylor creek			
8/29/22	12:20		16738405			80			23	28		0.59	0.79			ADB														

System Name Blaney Farms	Well # 2	System # 409113
-----------------------------	-------------	--------------------

PSI on: _____
PSI off: _____

DATE M/D/Y	TIME Arrived	Backwash Gallons Used	Master Meter	Meter Number	Gallons Since Last Visit	PSI	Chem. Added		Chem. Level		pH	Well House Residuals				Initials	Comments & Adjustments	
							CL2	PO4	CL2	PO4		CL2	PO4	Fe	Mn			
9/1/22	10					82	1.5		17.45	25								
9/2/22	9:50		16738422			90			43	26	0.47	0.87			ADB			
9/6/22	10:20		16,738,442			88			36	20	0.48	0.93			ADB			
9/8/22	10:00		16,738,452			90			33	18	0.45	0.79			ADB	PO stroke 40 to 35. Cl2 stroke 70 to 75		
9/12/22	1		16738463			85			30	15	0.49	0.79			ADB			
9/15/22	10:00		16738473			85	1	1	25/36	15/26	0.32	0.89			ADB			
9/19/22	9		16738485			77		1	34	24/40	0.37	0.82			ADB	Cl2 stroke 75 to 80		
9/22/22	10:00		33699			95	1		30/45	39	0.55	0.86			ADB	New meter		
9/26/22	8:40		61612	27,913		88			43	38	0.42	0.86			ADB			

Date M/D/Y	Time Arrived	MRT Residuals				Gals Flushed	Initials	MRT Address
		CL2	PO4	Fe	Mn			
9/1/22	9:30	0.53	1.09	0.21	0.031	1000	ADB	4016 cross timber
	10:00	0.28	1.14	0.22	0.031		ADB	3816 hickory manor
9/8/22	10:00	0.28	1.85				ADB	3816 hickory manor
	10:45	0.23	1.39				ADB	4008 kaylor creek
9/15/22	9:15	0.33	1.18	0.11	0.036		ADB	3800 hickory manor
	11:45	0.41	1.85				ADB	4008 kaylor creek
9/19/22	10:30	1.03	1.13	0.1	0.002	550	ADB	4025 kaylor creek
9/20/22	10:18	0.37	1.14				ADB	2209 serene lake