

System Name Senter	Well # 586	System # 4092134
-----------------------	---------------	---------------------

PSI on: _____
PSI off: _____

DATE M/D/Y	TIME Arrived	Backwash Gallons Used	Master Meter	Meter Number	Gallons Since Last Visit	PSI	Chem. Added		Chem. Level		Well House Residuals				Initials	Comments & Adjustments
							CL2	PO4	CL2	PO4	pH	CL2	PO4	Fe		
7/1/22	2:00		3,889,892	22,535		92	1		10/25	17	0.5	0.81			ADB	
			132,383	31												
7/5/22	9:45		3712640	22,948		92			22	16	0.25	0.88	0	0.015	ADB	CL2 line was split and needed replacing
			132402	19												
7/7/22	11		3,730,350	17,710		86			20	14	0.49	0.77			ADB	
			132,422	20												
7/11/22	11		3781987	31,617		90	1	1	15/30	14/30	0.44	0.79			ADB	
			132445	23												
7/15/22	11:00		3794884	32,717		95			26/30	30	0.79	0.89			ADB	
			132445	1												
7/19/22	8:15		3828090	33,406		80			26	28	0.65	0.81	0	0.017	ADB	
			132450	4												
7/21/22	9:20		3849303	21,213		92			24	28	0.37	0.75			ADB	
			132474	24												
7/25/22	11:00		3888190	38,887		90			18	25	0.33	0.55	0	0.019	ADB	
			132504	30												
7/28/22	10:15		3907543	19,353		86			16	25	0.38	0.86			ADB	
			132522	18												

Date M/D/Y	Time Arrived	MRT Residuals				Gals Flushed	Initials	MRT Address
		CL2	PO4	Fe	Mn			
7/7/22	11:15	0.42	0.76			ADB	2036 Braeburn	
7/18/22	11:00	0.94	0.86			ADB	3728 apple grove	
7/21/22	9:35	0.37	0.91	0.1	0.058	ADB	2125 orchard lake	
7/28/22	10:00	0.33	0.9			ADB	3728 apple grove	

System Name Senter	Well # 586	System # 409213
------------------------------	---------------	--------------------

PSI on: _____
PSI off: _____

DATE M/D/Y	TIME Arrived	Backwash Gallons Used	Master Meter	Meter Number	Gallons Since Last Visit	PSI	Chem. Added		Chem. Level		pH	Well House Residuals				Inittals	Comments & Adjustments
							CL2	PO4	CL2	PO4		CL2	PO4	Fe	Mn		
8/1/22	1:30		3,938,528	30,985		82	2		10/45	25	0.27	0.43	0.2		ADB	Cl2 stroke 30 to 35	
			132,553	170													
8/4/22	9:15		3958451	19,923					38/41	23	1.61	0.69			ADB		
			132326	-227													
8/8/22	9:46		3,996,205	37,764		84			36	20	0.88	0.71			ADB		
			132,367	41													
8/11/22	9:05		4023591	27,386		85			31	20	0.73	0.69			ADB		
			132407	40													
8/15/22	9:35		4052068	28,477		81			28	18	0.69	0.65			ADB		
			132453	46													
8/18/22	12:40		4079052	28,984		82			21	16	0.65	0.79			ADB		
			132497	44													
8/22/22	10:55		4131422	52,370		82	1		14/30	13	0.89	0.79			ADB		
			132566	69													
8/25/22	8:45		4156683	25,261		86	1	2	27/43	10/45	0.61	0.21	0.14	0.023	ADB	Pa speed 30 to 40' po4 .55 after adjustment	
			132588	20													
8/29/22	11:00		4206673	49,190		82			35	35	0.68	0.59			ADB		
			132594	8													
8/31/22	1:00																

Date M/D/Y	Time Arrived	MRT Residuals				Gals Flushed	Inittals	MRT Address
		CL2	PO4	Fe	Mn			
8/4/22	9:15	1.45	1.71			ADB	3728 apple grove	
8/11/22	9:05	0.65	1.11			ADB	3728 apple grove	
8/18/22	12:50	0.58	0.49			ADB	3728 apple grove	
8/23/22	9:20	0.59	0.53	0.27	0.018	ADB	2105 orchard lake drive	
8/31/22	1:15	0.68	1.3			ADB	3728 apple grove	

System Name Senter	Well # 586	System # 409234
-----------------------	---------------	--------------------

PSI on: _____
PSI off: _____

DATE M/D/Y	TIME Arrived	Backwash Gallons Used	Master Meter	Meter Number	Gallons Since Last Visit	PSI	Chem. Added		Chem. Level		Well House Residuals				Initials	Comments & Adjustments
							CL2	PO4	Cl2	PO4	pH	CL2	PO4	Fe		
9/2/22	10		4,251,785	45,892		88			28	29	0.55	0.84			ADB	
			132,646	52												
9/8/22	10:0		4298993	47,228		90			20	21	0.74	0.91			ADB	
			132701	55												
9/8/22	10:30		4,315,129	16,136		85			17	18	0.72	0.89			ADB	
			132,725	24												
9/12/22	12:30		4376561	60,432		88	0.75		7/15	7	0.75	0.85			ADV	
			132797	62												
9/13/22	12:20						2	2.5	13/45	5/45					ADB	
9/16/22	9:40		4411524	35,963		88			40	43/50	1.05	2.5			ADB	Ps speed 30-28
			132750													
9/19/22	9:45		4473671	62,147		96	1		30/45	48	1.03	0.66			ADB	
			132795	45												
9/22/22	11:56		4523684	49,993		96			38	43	1.05	0.66			ADB	Fix cl2 line
			132824	28												
9/28/22	8:55		4589606	65,042		92			28	35	0.94	0.57			ADB	
			132878	64												

Date M/D/Y	Time Arrived	MRT Residuals				Gals Flushed	Initials	MRT Address
		CL2	PO4	Fe	Mn			
9/6/22	10:15	0.67	1.76				ADB	3728 apple grove
9/15/22	9:30	1.03	2.15	0.15	0.017		ADB	3728 apple grove
9/22/22	12:30	0.75	0.53					