

# Duke Energy Resource Mix to Meet 70% CO<sub>2</sub> Reduction by 2030 in NC

## REVIEW AND ANALYSIS OF DRAFT CARBON PLAN

**PREPARED BY**

**MICHAEL HAGERTY  
METIN CELEBI  
FREDERICK CORPUZ  
JADON GROVE  
JULIA OLSZEWSKI**

**JULY 15, 2022  
REVISED: AUGUST 16, 2022**

**PREPARED FOR**

**CLEAN POWER SUPPLIERS  
ASSOCIATION**



OFFICIAL COPY

Aug 17 2022

# Disclaimer

---

## PLEASE NOTE

- This report was prepared for Clean Power Suppliers Association, in accordance with The Brattle Group's engagement terms, and is intended to be read and used as a whole and not in parts.
- The report reflects the analyses and opinions of the authors and does not necessarily reflect those of The Brattle Group's clients or other consultants.
- The projections provided in this presentation are necessarily based on assumptions with respect to conditions or events which may or may not arise or occur in the future. While we believe these assumptions to be reasonable for purposes of preparing our analysis, they are dependent upon future events that are not within our control or the control of any other person. Actual future outcomes can and will differ, perhaps materially, from those evaluated in these projections. No one can give any assurance that the assumptions and methodologies used will prove to be correct or that the projections will match actual results of operations. We do not make any representation with respect to the likelihood of any specific future outcome, and cannot and do not accept liability for losses suffered.
- While the analyses presented may assist Clean Power Suppliers Association in rendering informed decisions, it is not meant to be a substitute for the exercise of Clean Power Suppliers Association's own business judgment. Neither we nor Brattle will accept any liability under any theory for losses suffered, whether direct or consequential, arising from the reliance on the analyses presented, and cannot be held responsible if any conclusions drawn from this presentation should prove to be inaccurate.
- There are no third party beneficiaries with respect to this report, and The Brattle Group does not accept any liability to any third party in respect of the contents of this report or any actions taken or decisions made as a consequence of the information set forth herein.

# Contents

---

- Review of Duke Carbon Plan Portfolios
- Alternative Portfolios to Achieve 70% CO<sub>2</sub> Reduction
- Benefits of Proactive Transmission Planning

---

# Review of Draft Carbon Plan

# Duke Draft Carbon Plan Proposed Portfolios

In its draft Carbon Plan, Duke proposed four portfolios to achieve 70% CO<sub>2</sub> reductions for North Carolina generation facilities in the 2030 to 2034 timeframe

- Proposed portfolios rely on coal plant retirements and a mix of new resources to reduce emissions
- New resources added across portfolios include gas, solar, offshore wind, onshore wind and nuclear generation as well as battery storage and pumped hydro storage
- Portfolios differ depending on which resources are selected and when they achieve compliance



Note 1: Gray blocks denote coal retirements, which are dependent on addition of resources shown.

Note 2: Remaining coal planned to be retired by year end 2035.

Note 3: New Solar includes solar + storage, excludes projects related to pre-existing programs such as HB 589 and Green Source Advantage.

Note 4: Capacities as of beginning of the target year of 70% reduction.

Note 5: IVVC = Integrated Volt/VAr Control.


Note 6: CPP = Critical Peak Pricing.

Note 7: Battery includes batteries paired with solar.

# Carbon Plan Generation Mix to Achieve 70% Reduction

Duke will need to add new clean energy resources that can produce about **20-27 TWh per year** by the compliance year to serve its electricity demand and achieve the Carbon Plan goals:

- Fossil resources are limited to about **52 TWh per year** to remain below the CO<sub>2</sub> cap
- Existing nuclear already operates as baseload, generating about **73 TWh per year**
- Existing clean resources are mostly fixed output, generating about **16 TWh per year**



OFFICIAL COPY

Aug 17 2022

# Selected New Clean Generation Resources


To fill the need for clean energy, all of Duke’s portfolios rely on significant solar generation capacity as the primary clean energy resource to reduce CO<sub>2</sub> emissions

However, Duke limits how much solar generation can be built each year

Differences in solar generation across portfolios are driven by the assumed solar annual capacity limits and the amount of non-solar clean energy resources selected by Duke to fill the remaining gap

- Onshore Wind: added in all portfolios
- Offshore Wind: added in P1, P2 and P4
- Nuclear SMRs: added in P3 and P4 portfolios


New Clean Generation  
in Year 70% Reduction Achieved



# Carbon Plan Solar Capacity Limits

Draft Carbon Plan limits incremental solar additions on an annual basis, such that 5,400 MW of cumulative solar capacity can be built by 2030 in P1 and 7,200 MW can be built by 2032 in P2-P4\*

- Solar capacity limits push back the timeline over which 70% CO<sub>2</sub> reductions are achievable given limited alternatives
- Even if Duke could hit the 2030 CO<sub>2</sub> target with other resources, it would do so at higher cost to ratepayers



OFFICIAL COPY

Aug 17 2022

\* Assumes the Duke system will have 6.7 GW of solar capacity on its system by 2030 following the completion of resource additions required under H589 before the incremental solar additions to achieve the Carbon Plan goals shown above.



# Unclear Basis for Solar Capacity Limit

---

Duke has provided the following reasons for capping solar additions in the Carbon Plan:

- Time to construct new infrastructure to accommodate increasing levels of renewables
- Increasingly complex interconnections as solar facilities are located farther from existing infrastructure
- Unknown future solar project size and impacts on interconnection
- Finite interconnection resources
- Land availability and community acceptance

However, Duke has not provided technical analysis to support their proposed solar limit based on network upgrades, which will depend on multiple factors that require detailed analysis, or analysis of limits imposed by land availability and community acceptance

# Proactive Planning Would Reduce Network Upgrades

---

Concerns about future network upgrades for solar are caused by the existing transmission planning process, which takes a piecemeal and just-in-time approach to identifying and constructing transmission upgrades via the generation interconnection process

Completing system-wide proactive transmission planning in parallel to the recently reformed generation interconnection process would:

- Identify no-regrets system-level upgrades that can provide multiple benefits regardless of exact locations and types of resources that interconnect
- Reduce costs, complexity, and time required for interconnecting new resources
- Debottleneck the process for the least-cost resources entering the system

Duke could further reduce the challenges to interconnecting sufficient solar capacity by 2030 by adopting a proactive long-term transmission planning process that studies potential resource mixes and the necessary transmission infrastructure to meet future system needs

We provide more insights into the benefits of proactive transmission planning in Section III

# Carbon Plan Projects Lower Demand Compared to 2020 IRP

2030 demand included in Duke's Carbon Plan modeling is 1,200 GWh lower than the 2020 IRP

Carbon Plan forecast is primarily lower due to:

- 1,775 GWh lower gross retail sales, based on projections of economic activity in their service territory
- 822 GWh lower due to additional utility EE programs

The lower demand is offset by the following factors that increase demand:

- 902 GWh of less rooftop solar
- 878 GWh of additional EV demand (assuming 5.5% of vehicles on the road are electric by 2035)

**Components of Duke 2030 Demand Forecast (GWh)**

|                   | Gross Retail Sales | Energy Efficiency | NEM Rooftop Solar | EVs        | IVVC        | CPP/PTR    | Net Retail Sales at Meter |
|-------------------|--------------------|-------------------|-------------------|------------|-------------|------------|---------------------------|
| Duke Carbon Plan  | 132,200            | -5,477            | -697              | 1,965      | -804        | -22        | 127,164                   |
| Duke 2020 IRP     | 133,975            | -4,655            | -1,599            | 1,087      | -389        | 0          | 128,418                   |
| <b>Difference</b> | <b>-1,775</b>      | <b>-822</b>       | <b>902</b>        | <b>878</b> | <b>-415</b> | <b>-22</b> | <b>-1,254</b>             |

# Carbon Plan Assumes Conservative Forecast for EV Demand

Duke assumes a conservative outlook for future electric vehicle (EV) sales for 2030-2035


- Duke assumes 310,000 light-duty and nearly 12,000 medium- and heavy-duty vehicles will electrify by 2030
- Duke’s EV forecast implies that EVs will make up about 20% of new vehicle sales by 2030
- Their 2030 EV sales outlook is well below recent forecasts and policy goals (30 – 50% of sales by 2030)

Carbon Plan underestimates EV demand by at least 1,050 GWh in 2030 and 3,220 GWh in 2035 based on the conservative BNEF forecast (30% sales in 2030)

- We relied on similar assumptions as Duke for demand per EV and overall vehicle fleet size (see table)

Higher EV demand will need to be matched by additional solar or other clean energy resources to achieve the Carbon Plan CO<sub>2</sub> goals

EV Market Share Forecast



2030 Total EV Electricity Demand



| Utility           | Estimated Vehicle Fleet | % of Fleet  | Total EVs on Road | EV Demand (MWh/EV) | EV Demand (GWh) |
|-------------------|-------------------------|-------------|-------------------|--------------------|-----------------|
| DEC               | 7,410,000               | 2.5%        | 188,000           | 6.4                | 1,210           |
| DEP               | 4,580,000               | 2.9%        | 134,000           | 5.6                | 760             |
| <b>Duke Total</b> | <b>12,990,000</b>       | <b>2.7%</b> | <b>322,000</b>    | <b>6.1</b>         | <b>1,970</b>    |
| <b>BNEF Total</b> | <b>12,990,000</b>       | <b>4.1%</b> | <b>494,000</b>    | <b>6.1</b>         | <b>3,020</b>    |

# P1 Achieves Lower Cumulative CO<sub>2</sub> Emissions through 2050

Duke set CO<sub>2</sub> limits in the compliance year for each portfolio (2030 to 2034) to achieve the 70% reduction in CO<sub>2</sub> emission and then decreased CO<sub>2</sub> emissions to achieve it 2050 net zero goal

This approach results in significantly lower cumulative CO<sub>2</sub> emissions in the P1 scenario through 2050


- Cumulative P1 CO<sub>2</sub> emission of 533 million short tons are 7% lower than P2 (569 million short tons), 12% lower than P3 (601 million short tons), and 11% lower than P4 (599 million short tons)



# Carbon Plan Overstates the P1 Cost Premium Over P2

Duke’s estimate of \$2.3 billion higher PVRR in P1 relative to P2 is overstated in part because of greater CO<sub>2</sub> emissions reductions in P1 relative to P2

- We estimate that nearly half of the incremental costs of P1 are due to the long-term differences in CO<sub>2</sub> limits
- A more apples-to-apples comparison between P1 and P2 costs would require aligning long-term CO<sub>2</sub> limits beyond the compliance dates
- Accelerating addition of clean energy resources should result in lower long-term costs past the compliance date given the new clean energy assets have already begun depreciating



OFFICIAL COPY

Aug 17 2022

# Key Takeaways from Review of Duke Carbon Plan

---

- **Duke assumes new solar additions will be limited due to their claimed challenges to building and coordinating network upgrades to support interconnection**
  - The limit on solar capacity additions require Duke to select other clean energy resources to achieve Carbon Plan goals, including higher cost and higher risk offshore wind and nuclear SMRs
  - Replacing lower-cost solar with higher cost resources increases costs to achieve CO<sub>2</sub> goals and challenges timely compliance with the goals given limited availability of other new clean energy resources in Duke's territory through the early 2030s
- **Duke understates future demand due to an overly conservative estimate of EV adoption**
  - Higher electricity demand will increase need for clean energy resources to achieve Carbon Plan goals
- **Duke applies lower CO<sub>2</sub> limits over the long-term in the 2030 compliance scenario (P1)**
  - Results in 7 – 12% less cumulative CO<sub>2</sub> emissions than other scenarios
  - Long-term difference in CO<sub>2</sub> limits accounts for about 50% of the difference in costs across scenarios

---

# Analyzing Alternative Carbon Plan Portfolios



# Analysis of Resource Portfolios to Achieve 70% CO<sub>2</sub> Reduction

---

**Objective:** Analyze a more complete set of resource portfolios that achieve a 70% reduction of CO<sub>2</sub> emissions from Duke Energy's North Carolina power generation by 2030 or 2032 to inform the Carolinas Carbon Plan

**Scope:** Model Duke Energy system in North Carolina and South Carolina through 2035 using our internal capacity expansion model, GridSIM

## Approach:


- Incorporate updated assumptions for the Duke Energy system into GridSIM
- Identify the least-cost resource mix to meet 2030 or 2032 CO<sub>2</sub> goals
- Estimate annual resource additions to achieve the CO<sub>2</sub> goals

# Modeling Approach

Analyzed the combined Duke Energy system using Brattle's internal capacity expansion model GridSIM

- Simulates the dispatch of generation and storage resources to serve demand and the expansion of the resource mix to meet the planning reserve margin and CO<sub>2</sub> emissions goals
- Captures chronological dynamics of a future power system that relies more heavily on renewable resources by analyzing 49 representative days (4 days in each month plus the peak demand day)

Modeled the Duke service territory as an island with limited transactions with neighboring markets, similar to the approach in Duke Carbon Plan



Source: Duke Carbon Plan, Appendix E, p. 8.

# GridSIM Overview

## INPUTS

### Supply

- Existing resources
- Planned builds and retirements
- Fuel prices
- Investment/fixed costs
- Variable costs (inc. emissions costs)

### Demand

- Representative day hourly demand
- Forecasts of annual and peak demand
- Planning reserve margins

### Transmission

- Zonal limits
- Intertie limits


### Regulations and Policies

- State energy policies and procurement mandates

## GridSIM OPTIMIZATION ENGINE

### Objective Function

- Minimize NPV of Investment & Operational Costs



### Constraints

- Planning Reserve Margin
- Hourly Energy Balance
- Regulatory & Policy Constraints
- Resource Operational Constraints
- Transmission Constraints
- GHG Emissions Constraints

## OUTPUTS

**Builds/Retirements**

**Carbon Emissions**

**Market Prices  
(Energy, Capacity, REC)**

**Total Resource Costs**

**Customer Costs**

**Generator Revenues**

OFFICIAL COPY

Aug 17 2022

# GridSIM vs EnCompass

Similar to GridSIM, EnCompass identifies the least-cost portfolio of resources to maintain system reliability, meet 2030 CO<sub>2</sub> limits, and meet hourly demand

- Encompass uses a different modeling approach that optimizes unit commitment decisions and also can simulate dispatch of resources chronologically throughout the year

|  | GridSIM                        | EnCompass             |
|--|--------------------------------|-----------------------|
| <b>Network Representation</b>                      | Zonal                          | Zonal                 |
| <b>Optimized Capacity Expansion and Retirement</b> | Yes                            | Yes                   |
| <b>Resource Adequacy Requirements</b>              | Yes                            | Yes                   |
| <b>CO<sub>2</sub> Emissions Limit</b>              | Yes                            | Yes                   |
| <b>Production Cost Simulation</b>                  | Hourly, 49 representative days | Hourly, chronological |
| <b>Optimized Unit Commitment</b>                   | No                             | Yes                   |



OFFICIAL COPY

Aug 17 2022

# NC and SC CO<sub>2</sub> Emissions Caps

---

To achieve the Carbon Plan goal, we limit Duke's NC generation plants to 22.6 million short tons in the year of compliance, a 70% reduction from 2005 emissions (75.4 million short tons)

- Estimate 2035 CO<sub>2</sub> limit of 16.9 million short tons by linearly reducing emissions to achieve net zero by 2050, which we apply to all cases

To limit CO<sub>2</sub> emissions leakage into SC, we limited Duke South Carolina generation plant emissions based on the SC plant emissions reported by Duke in its Carbon Plan modeling


# Coal Plant Retirement and Conversion Date Assumptions

We assume that Duke’s coal plants retire based on timing in the Carbon Plan

- Belews Creek 1-2 and Cliffside 6 are converted to operate on natural gas
- Marshal 3-4 remains available to burn coal through its 2033 retirement

## Coal Plant Retirement/Conversion Dates

| Plant                   | Owner      | Capacity        | Modeled Retirement      |
|-------------------------|------------|-----------------|-------------------------|
| Allen 2-4               | DEC        |                 | 2022                    |
| Allen 1,5               | DEC        |                 | 2024                    |
| Cliffside 5             | DEC        | 546 MW          | 2026                    |
| Roxboro 3-4             | DEP        | 1,409 MW        | 2028                    |
| Mayo 1                  | DEP        | 746 MW          | 2029                    |
| Marshall 1-2            | DEC        | 760 MW          | 2029                    |
| Roxboro 1-2             | DEP        | 1,053 MW        | 2029                    |
| Marshall 3-4            | DEC        | 1,318 MW        | 2033                    |
| <b>Belews Creek 1-2</b> | <b>DEC</b> | <b>2,200 MW</b> | <b>Gas-Only in 2030</b> |
| <b>Cliffside 6</b>      | <b>DEC</b> | <b>849 MW</b>   | <b>Gas-Only in 2030</b> |




Aug 17 2022

OFFICIAL COPY

# Resource Adequacy

## Estimated capacity shortfall for both DEC and DEP to meet the 25% reserve margin achieved in the Carbon Plan

- Started with Carbon Plan winter capacity balance and adjusted reserve margin based on assumed coal plant retirements and new resource additions
- New gas, renewable and battery storage resources added to fill capacity needs



Aug 17 2022

# Available New Generation and Storage Resources

GridSIM identifies new resource additions necessary to meet capacity & energy demand and CO<sub>2</sub> targets at least cost to ratepayers

| Resource Type | Capacity Factor | RA Credit (% ICAP) | 2032 Capacity Limit   | Assumed Life |
|---------------|-----------------|--------------------|-----------------------|--------------|
| Gas CC        | n.a.            | 100%               | 2,400 MW              | 20 years     |
| Gas CT        | n.a.            | 100%               | n.a.                  | 25 years     |
| Solar         | 28%             | 2%                 | <i>Varies by Case</i> | 30 years     |
| Onshore Wind  | 30%             | 40%                | 600 MW                | 30 years     |
| Offshore Wind | 42%             | 67%                | 1,600 MW              | 30 years     |
| 4-Hour BESS   | n.a.            | 95%                | n.a.                  | 15 years     |
| 4-Hour BESS   | n.a.            | 41%                | n.a.                  | 15 years     |

We did not consider Gas CC with CCS or Nuclear SMR as being feasible to be built by 2030-2032



# Solar+Storage Configurations

---

GridSIM may select solar paired with battery storage (S+S) in the following four configurations:

- 4-hr BESS at 50% of the solar capacity (60% ELCC)
- 2-hr BESS at 50% of the solar capacity (26% ELCC)
- 4-hr BESS at 25% of the solar capacity (30% ELCC)
- 2-hr BESS at 25% of the solar capacity (13% ELCC)

We estimated BESS costs using ATB projections, similar to standalone BESS, with the following changes:

- We assumed BESS in S+S will be able to receive the same ITC as the solar facility
- We removed network upgrade costs for the BESS as they will share a point of interconnection with the solar generation, similar to Duke's assumption
- We reduced BESS capital costs by 5% to account for lower development costs for hybrid facilities versus two standalone facilities

# Capital Costs for New Generation and Storage Resources

## Capital cost assumptions based on 2022 ATB cost projections

- We used the Conservative case for solar, onshore wind, and gas CCs and the Moderate case for offshore wind and battery storage
- Based on feedback from Duke, we adopted lower capital costs for Gas CT using recent PJM Cost of New Entry (CONE) study
- For new Gas CC, we added \$125/kW for the costs of new gas lateral based on EPA analysis of NC plants


## We added estimated transmission upgrades for each resource:

- Offshore wind: \$441/kW in 2030 based on NCTPC study
- All other resources: \$100/kW
- BESS paired with solar does not incur incremental network upgrade costs

## Assume ITC and PTC phase out:

- 30% ITC for solar & storage online by Jan 1, 2023; phased down to 10% for projects online by Jan 1, 2026 or thereafter
- 30% ITC for offshore wind commencing construction by Jan 1, 2026 with ten years to complete (available for 2030 and 2032)
- PTC phases out for onshore wind resources entering after 2025

## Overnight Capital Cost Projections




OFFICIAL COPY

Aug 17 2022

# Comparison of Levelized Costs of Renewable Energy

The estimated 2030 LCOE for solar and onshore wind are similar (\$60-70/MWh), while offshore wind is nearly 2x higher (\$125/MWh)


- We estimated the LCOE assuming the levelized costs remain constant in nominal terms over its economic life and assuming Duke’s most recent cost of capital of about 6.5% ATWACC
- LCOE values shown here are higher than ATB due to use of nominal 2030 dollars (instead of real 2019 dollars), assumption that levelized costs are constant in nominal terms (instead of real terms), and higher cost of capital



# Delivered Fuel Price Projections

- Gas price forecast based on Duke’s projected prices for Transco Zone 5
  - Monthly shapes based on average historical shape from 2018-2020 to account for commodity price and variable delivery charges
  - Add firm transportation costs based on Duke’s assumptions for new and existing units
- Coal price by plant based on delivered coal prices in 2020 and escalated based on AEO2021 forecast for delivered cost of coal into SRCA region

**Coal and Natural Gas Cost Assumptions**



# Summary of Differences in Assumptions with Duke

---

- **Capacity Expansion Model:** Use our internal capacity expansion model GridSIM
- **Timeframe:** Run through 2035
- **New Resource Costs:** Rely primarily on NREL 2022 Annual Technology Baseline
- **Solar Capacity Limits:** Model cases without and with solar limits included in Duke's analysis
- **CO<sub>2</sub> Emissions Limits:** Assume 2035 CO<sub>2</sub> emissions are consistent across all cases

# Alternative Portfolios to Achieve 70% CO<sub>2</sub> Reductions


We analyzed 5 scenarios to identify the least-cost resource mix to achieve Duke’s CO<sub>2</sub> reduction goals

- Note that we used middle of the year (MOY) capacity limits equivalent to Duke’s beginning of year (BOY) limits because GridSIM assumes a constant capacity throughout the year

CPSA Carbon Plan Scenarios

| Portfolio | Compliance Year | Solar Cap    |
|-----------|-----------------|--------------|
| CPSA1     | 2030            | No Cap       |
| CPSA2     | 2030            | Duke Low Cap |
| CPSA3     | 2030            | CPSA Cap     |
| CPSA4     | 2032            | Duke Low Cap |
| CPSA5     | 2032            | CPSA Cap     |

Modeled Solar Capacity Limits  
(MOY MW)




# CPSA1 Generation and Storage Resource Mix



- 2030 Compliance Year with No Solar Cap

**Duke Energy Capacity Additions/Retirements**



Note: Paired storage is implicitly accounted for by the paired solar capacity additions and not shown above.

## Total New Resources by 2030

### Utility-Scale Solar: +9,500 MW

- Standalone Solar: +2,100 MW
- Paired with 50% 4-hr BESS: +5,700 MW
- Paired with 25% 4-hr BESS: +1,700 MW

### 4-hr BESS: +3,300 MW

- Paired with 50% Solar: +2,900 MW
- Paired with 25% Solar: +400 MW

### Onshore Wind: +600 MW

### Gas CC: +2,000 MW


Aug 17 2022

# CPSA2 Generation and Storage Resource Mix

OFFICIAL COPY

• **2030 Compliance Year with Low Solar Cap**

## Duke Energy Capacity Additions/Retirements



Note: Paired storage is implicitly accounted for by the paired solar capacity additions and not shown above.

## Total New Resources by 2030

### Utility-Scale Solar: +5,200 MW

- Standalone Solar: +2,100 MW
- Paired with 50% 4-hr BESS: +3,100 MW

### 4-hr BESS: +1,800 MW

- Standalone: +200 MW
- Paired with 50% Solar: +1,600 MW

### Onshore Wind: +600 MW

### Offshore Wind: +800 MW

### Gas CC: +2,400 MW

### Gas CT: +900 MW


Aug 17 2022



# CPSA3 Generation and Storage Resource Mix

- 2030 Compliance Year with CPSA Solar Cap

## Duke Energy Capacity Additions/Retirements



Note: Paired storage is implicitly accounted for by the paired solar capacity additions and not shown above.

## Total New Resources by 2030

**Utility-Scale Solar: +7,500 MW**

- Standalone Solar: +2,100 MW
- Paired with 50% 4-hr BESS: +5,400 MW

**4-hr BESS: +2,700 MW**

- Paired with 50% Solar: +2,700 MW

**Onshore Wind: +600 MW**

**Offshore Wind: +400 MW**

**Gas CC: +2,400 MW**

OFFICIAL COPY


Aug 17 2022

# CPSA4 Generation and Storage Resource Mix

OFFICIAL COPY

• **2032 Compliance Year with Low Solar Cap**

Total New Resources by 2032\*



**Utility-Scale Solar: +7,900 MW**

- Standalone Solar: +3,600 MW
- Paired with 50% 4-hr BESS: +3,200 MW
- Paired with 25% 4-hr BESS: +1,100 MW

**4-hr BESS: +2,300 MW**

- Standalone BESS: +500 MW
- Paired with 50% Solar: +1,600 MW
- Paired with 25% Solar: +300 MW

**Onshore Wind: +600 MW**

**Offshore Wind: +1,100 MW**

**Gas CC: +2,400 MW**

**Gas CT: +1,100 MW**

Note: Paired storage is implicitly accounted for by the paired solar capacity additions and not shown above.


\* Individual capacity components may not add up to totals due to rounding.

Aug 17 2022

# CPSA5 Generation and Storage Resource Mix

- 2032 Compliance Year with CPSA Solar Cap

## Duke Energy Capacity Additions/Retirements



Note: Paired storage is implicitly accounted for by the paired solar capacity additions and not shown above.

## Total New Resources by 2032

**Utility-Scale Solar: +10,700 MW**

- Standalone Solar: +2,100 MW
- Paired with 50% 4-hr BESS: +5,200 MW
- Paired with 25% 4-hr BESS: +3,500 MW

**4-hr BESS: +3,500 MW**


- Paired with 50% Solar: +2,600 MW
- Paired with 25% Solar: +900 MW

**Onshore Wind: +600 MW**

**Gas CC: +2,400 MW**

**Gas CT: +500 MW**

# System Costs of Alternative Carbon Plan Portfolios



Aug 17 2022

---

# Benefits of Proactive Transmission Planning

# Carbon Plan Should Identify Least-Cost Resource Mix

---

Identifying the least-cost resource mix to achieve the Carbon Plan must account for both generation and transmission (G&T) costs

The least-cost G&T resource plan can be identified either through:

- A model that can roughly co-optimize generation and transmission expansion
- Or, through running multiple scenarios that consider different transmission expansion options

After potential resource portfolios are identified, Duke should analyze the tradeoffs of each, including a more detailed analysis of transmission system impacts

- Transmission studies will identify upgrades for each portfolio and potential impacts of outages
- Proactively building system-level upgrades will mitigate interconnection challenges

Only if the optimal resource mix either cannot be achieved through transmission planning and interconnection processes or requires significant incremental costs not considered in the capacity expansion modeling, should Duke deviate from the least-cost resource mix

# PacifiCorp Integrated Resource Planning

In its 2021 IRP, PacifiCorp accounted for transmission upgrades and costs in two ways:

- Allows model to endogenously select transmission upgrades to achieve optimal resource mix
- Modeled alternative scenarios with and without several major transmission upgrades

IRP identified 14 transmission upgrades necessary to access and integrate resources through 2040

Figure 1.3 – 2021 IRP Preferred Portfolio (All Resources)




Table 1.1 – Transmission Projects Included in the 2021 IRP Preferred Portfolio<sup>1,2,\*</sup>

| Year  | Resource(s)   | From  | To                | Description   |
|-------|---|---|-------------------|---|
| 2025  | 1,641 MW RFP Wind (2025)  | Aeolus WY                                     | Clover            | Enables 1,930 MW of interconnection with 1700 MW of TTC: Energy Gateway South   |
| 2026  | 615 MW Wind (2026)  | Within Willamette Valley OR Transmission Area |                   | Enables 615 MW of interconnection: Albany OR area reinforcement   |
| 2026  | 130 MW Wind (2026)<br>450 MW Wind (2032)<br>650 MW Battery (2037) | Portland North Coast                          | Willamette Valley | Enables 2080 MW of interconnection with 1950 MW TTC: Portland Coast area reinforcement, Willamette Valley and Southern Oregon |
|       |   |   | Southern Oregon   |   |
| 2026  | 600 MW Solar+Storage (2026)                                       | Borah-Populous                                | Hemingway         | Enables 600 MW of interconnection with 600 MW of TTC: B2H Boardman-Hemingway  |
| 2028  | 41 MW Solar+Storage (2028)<br>377 MW Solar+Storage (2030)         | Within Southern OR Transmission Area          |                   | Enables 460 MW of interconnection: Medford area reinforcement   |
| 2030  | 160 MW Solar+Wind+Storage (2030)<br>20 MW Solar+Storage (2030)    | Yakima WA Transmission Area                   |                   | Enables 180 MW of interconnection: Yakima local area reinforcement  |
| 2031  | 820 MW Solar+Storage (2031)<br>206 MW Non-Emitting Peaker (2033)  | Northern UT Transmission Area                 |                   | Enables 1040 MW of interconnection: Northern UT 345 kV reinforcement  |
| 2033  | 400 MW Non-Emitting Peaker (2033)<br>1100 MW Solar+Storage (2033) | Southern UT                                   | Northern UT       | Enables 1500 MW of interconnection with 800 MW TTC: Spanish Fork - Mercer 345 kV; New Emery - Clover 345 kV                   |
| 2040  | 156 MW Solar+Storage (2040)<br>500 MW Pumped Storage (2040)       | Central OR                                    | Willamette Valley | Enables 980 MW of interconnection with 1500 MW of TTC   |
| 2028* | 500 MW Adv Nuclear (2028)   | Southwest Wyoming Transmission Area           |                   | Reclaimed transmission upon retirement of Naughton 1 & 2  |
| 2029* | 549 MW Battery (2029)   | Eastern Wyoming Transmission Area             |                   | Reclaimed transmission upon retirement of Dave Johnston Plant   |
| 2037  | 909 MW Solar+Storage (2037)                                       | Southern Utah Transmission Area               |                   | Reclaimed transmission upon retirement of Huntington 1 & 2  |
| 2038  | 412 MW Non-Emitting Peaker (2038)<br>1000 MW Adv Nuclear (2038)   | Bridger WY Transmission Area                  |                   | Reclaimed transmission upon retirement of Jim Bridger Plant   |
| 2040  | 206 MW Non-Emitting Peaker (2040)<br>60 MW Wind (2040)            | Eastern Wyoming Transmission Area             |                   | Reclaimed transmission upon retirement of Wyodak  |


# California IRP and Transmission Planning Process

During each IRP cycle, CPUC identifies optimal resource portfolios needed to meet state policy goals over next 10 years, including resource type and zone

- Capacity expansion model accounts for transmission limits, total resource potential, and estimated transmission costs of alternative resources
- Identify substations within each renewable zone for placing new resources for transmission planning studies

CAISO then studies whether there are reliability, economic, and/or policy needs for new transmission under each portfolio

- 2021-22 process identified 23 reliability, policy, and economic projects, estimated to cost \$2,964 million
- Stakeholders play a key role in reviewing assumptions and preliminary results, and submitting transmission upgrades for CAISO to study



| Resource Category              | Unit      | 2031          |               |               |
|--------------------------------|-----------|---------------|---------------|---------------|
|                                |           | 46 MMT        | 38 MMT        | OSW           |
| Gas                            | MW        | -             | -             | -             |
| Biomass                        | MW        | -             | -             | -             |
| Geothermal                     | MW        | 651           | -             | -             |
| Hydro (Small)                  | MW        | -             | -             | -             |
| Wind                           | MW        | 2,943         | 4,955         | 4,689         |
| Wind OOS New Tx                | MW        | 1,062         | 3,000         | 3,000         |
| Offshore Wind                  | MW        | -             | -             | 8,351         |
| Solar                          | MW        | 13,043        | 13,816        | 9,807         |
| Customer Solar                 | MW        | -             | -             | -             |
| Battery Storage                | MW        | 9,368         | 9,447         | 7,604         |
| Pumped Storage                 | MW        | 627           | 1,843         | 1,613         |
| Shed DR                        | MW        | 608           | 222           | 222           |
| Gas Capacity Not Retained      | MW        | -             | (1,319)       | (1,718)       |
| <b>In-State Renewables</b>     | <b>MW</b> | <b>16,638</b> | <b>18,876</b> | <b>22,847</b> |
| <b>Out-Of-State Renewables</b> | <b>MW</b> | <b>1,062</b>  | <b>3,000</b>  | <b>3,000</b>  |



Table 8.2-2: New Policy-driven Transmission Projects Found to be needed

| No. | Project Name   | Service Area | Expected In-Service Date | Project Cost      |
|-----|--|--------------|--------------------------|-------------------|
| 1   | Laguna Bell-Mesa No. 1 230 kV Line Rating Increase Project | SCE          | 2023                     | \$17.3M           |
| 2   | Reconductor Delevan-Cortina 230kV line                     | PG&E         | 2028                     | \$17.7M-\$35.4 M  |
| 3   | New Collinsville 500 kV substation                         | PG&E         | 2028                     | \$475M-\$675M     |
| 4   | Reconductor Rio Oso-SPI Jct-Lincoln 115kV line             | PG&E         | 2028                     | \$10.6M - \$21.2M |
| 5   | New Manning 500 kV substation                              | PG&E         | 2028                     | \$325M - \$485M   |
| 6   | GLWVEA area upgrades                                       | GLWVEA       | TBD                      | \$278M            |

Table 8.2-3: New Economic-driven Transmission Projects Found to be needed

| No. | Project Name  | Service Area | Expected In-Service Date | Project Cost |
|-----|---|--------------|--------------------------|--------------|
| 1   | Installing 10 ohms series reactors on the PG&E's Moss Landing - Las Aguilas 230 kV line | PG&E         | 2026                     | \$30-40M     |




# CPUC IRP Transmission Capacity and Cost Assumptions

OFFICIAL COPY

Aug 17 2022

## In-State Transmission Zones



- Norcal\_Z3\_SacramentoRiver
- Norcal\_Z2\_Humboldt
- Norcal\_Z4\_Solano
- Norcal\_Z4\_Solano\_subzone
- SPGE\_Z4\_CentralValleyAndLosBanos
- SPGE\_Z1\_Westlands
- SPGE\_Z2\_KernAndGreaterCarrizo
- SPGE\_Z3\_Carrizo
- GK\_Z1\_GreaterKramer
- GK\_Z3\_NorthOfVictor
- GK\_Z4\_Pisgah
- GK\_Z2\_InyokernAndNorthOfKramer
- SCADSNV\_Z5\_SCADSNV
- SCADSNV\_Z3\_GreaterImperial
- SCADSNV\_Z4\_RiversideAndPalmSprings
- SCADSNV\_Z1\_EldoradoAndMtnPass
- SCADSNV\_Z2\_GLW\_VEA
- Tehachapi
- NorCalOutsideTxConstraintZones
- WestlandsOutsideTxConstraintZones
- GreaterImpOutsideTxConstraintZones
- TehachapiOutsideTxConstraintZones
- KramerInyoOutsideTxConstraintZones
- SCADOutsideTxConstraintZones
- <all other values>

## Available Capacity and Incremental Deliverability Costs by Transmission Zone

| Transmission Zone or Subzone   | Incremental Deliverability Cost (\$/kW-yr) | FCDS Availability on Existing Transmission, Net of Post-2018 COD Baseline Capacity (MW) | Energy-Only Availability on Existing Transmission (MW, Default) *** | Energy-Only Availability (MW, Sensitivity) **** |
|--------------------------------|--|---|---|---|
| Carrizo                        | \$10                                       | 187   | 0   | 700   |
| Central_Valley_North_Los_Banos | \$36                                       | 791   | 0   | 500   |
| GLW_VEA                        | \$14                                       | 596   | 0   | 1470  |
| Greater_Imperial               | \$221                                      | 919   | 1900  | 1900  |
| Greater_Kramer                 | \$48                                       | 597   | 0   | 0   |
| Humboldt                       | \$999**                                    | 0   | 100   | 100   |
| Inyokern_North_Kramer          | \$161                                      | 97  | 0   | 0   |
| Kern_Greater_Carrizo           | \$21                                       | 784   | 700   | 3680  |
| Kramer_Inyokern_Ex*            | \$999**                                    | 0   | 0   | 0   |
| Mountain_Pass_El_Dorado        | \$7  | 250   | 2150  | 3790  |
| None                           | \$0  | 0   | 0   | 0   |
| North_Victor                   | \$161                                      | 300   | 0   | 0   |
| Northern_California_Ex*        | \$999**                                    | 866   | 0   | 0   |
| Riverside_Palm_Springs         | \$88                                       | 2665  | 2550  | 3100  |
| OffshoreWind_UnknownCost       | \$999**                                    | 0   | 0   | 0   |
| Sacramento_River               | \$19                                       | 1995  | 2600  | 2600  |
| SCADSNV                        | \$102                                      | 2434  | 6600  | 10260   |
| Solano                         | \$21                                       | 599   | 700   | 700   |
| Solano_subzone                 | \$999**                                    | 0   | 0   | 0   |
| Southern_California_Desert_Ex* | \$999**                                    | 862   | 0   | 0   |
| SPGE                           | \$7  | 675   | 700   | 4080  |
| Tehachapi                      | \$13                                       | 3677  | 800   | 1800  |
| Tehachapi_Ex*                  | \$999**                                    | 0   | 0   | 0   |
| Westlands_Ex*                  | \$999**                                    | 1779  | 0   | 0   |

Source: [CPUC IRP Assumptions](#).

\* Resources that end in "Ex" refers to areas outside of the CAISO transmission cost and availability estimates


# ERCOT Long-Term System Assessment of Transmission Needs

ERCOT develops 10-year forward projections of the resource mix under alternative scenarios and then studies the transmission system needs for each scenario

- ERCOT will adjust capacity expansion analysis if new transmission system limits identified
- LTSA results inform nearer-term needs for upgrades through the Regional Transmission Plan

Currently analyzing need for West Texas upgrades to support growing solar development based on identification of need in previous LTSA studies

## ERCOT’s Iterative Transmission Planning Process



# Industry Experience in Implementing Proactive Transmission Planning

---

Resource planning is a proactive generation planning effort that needs to be combined with proactive transmission planning to be the most effective


RTOs and utilities across the country have implemented proactive transmission planning approaches that identify cost effective upgrades for their changing resource mix

- Duke Energy can take advantage of this broad experience to identify an effective approach to planning for the future needs of its system
- Transmission planning will not identify all the upgrades necessary for new resources seeking interconnection, but will identify more cost-effective system upgrades in advance of the needs

Regional projects from proactive planning will speed up the generation interconnection process because fewer deep network upgrades will be triggered by GI requests

The parallel proactive transmission planning process can also identify upgrades that provide a wider range of benefits and address unexpected emerging network needs, such as rising congestion and curtailments

# Current U.S. Transmission Planning Processes for...



**These solely reliability-driven processes account for > 90% of all transmission investments**

- None involve any assessments of economic benefits (i.e., cost savings offered by the new transmission)
- Which also means these investments are not made with the objective to find the most cost-effective solutions
- Will yield higher system-wide costs and electricity rates

**Planning for economic and public-policy projects: less than 10% of all transmission investments**

**Interregional planning processes are largely ineffective**

- Essentially no major interregional transmission projects have been planned and built in the last decade

# Duke Can Look to Other Regions for Planning Best Practices

Available experience points to proven planning practices that reduce total system costs and risks:

1. **Proactively plan for future generation and load** by incorporating realistic projections of the anticipated generation mix, policy mandates, load levels, and load profiles over lifespan of the transmission investment
2. **Account for the full range of transmission projects' benefits and use multi-value planning** to comprehensively identify investments that cost-effectively address all categories of needs and benefits
3. **Address uncertainties and high-stress grid conditions explicitly through scenario-based planning** that takes into account a broad range of plausible long-term futures as well as real-world system conditions, including challenging and extreme events
4. **Use comprehensive transmission network portfolios** to address system needs and **cost allocation** more efficiently and less contentiously than a project-by-project approach
5. **Jointly plan inter-regionally across neighboring systems** to recognize regional interdependence, increase system resilience, and take full advantage of interregional scale economics and geographic diversification benefits

# Experience with Proactive Transmission Planning Processes

Significant experience exists with successful proactive, multi-value, scenario- and portfolio-based transmission planning efforts:


|   | Proactive Planning | Multi-Benefit | Scenario-Based | Portfolio-Based | Interregional Transmission |
|---|--------------------|---------------|----------------|-----------------|----------------------------|
| CAISO TEAM (2004) <sup>146</sup>                      | ✓                  | ✓             | ✓              |                 |                            |
| ATC Paddock-Rockdale (2007) <sup>147</sup>            | ✓                  | ✓             | ✓              |                 |                            |
| ERCOT CREZ (2008) <sup>148</sup>                      | ✓                  |               |                | ✓               |                            |
| MISO RGOS (2010) <sup>149</sup>                       | ✓                  | ✓             |                | ✓               |                            |
| EIPC (2010-2013) <sup>150</sup>                       | ✓                  |               | ✓              | ✓               | ✓                          |
| PJM renewable integration study (2014) <sup>151</sup> | ✓                  |               | ✓              | ✓               |                            |
| NYISO PPTPP (2019) <sup>152</sup>                     | ✓                  | ✓             | ✓              | ✓               |                            |
| ERCOT LTSA (2020) <sup>153</sup>                      | ✓                  |               | ✓              |                 |                            |
| SPP ITP Process (2020) <sup>154</sup>                 |                    | ✓             |                | ✓               |                            |
| PJM Offshore Tx Study (2021) <sup>155</sup>           | ✓                  |               | ✓              | ✓               |                            |
| MISO RIIA (2021) <sup>156</sup>                       | ✓                  | ✓             | ✓              | ✓               |                            |
| Australian Examples:                                  |                    |               |                |                 |                            |
| - AEMO ISP (2020) <sup>157</sup>                      | ✓                  | ✓             | ✓              | ✓               | ✓                          |
| - Transgrid Energy Vision (2021) <sup>158</sup>       | ✓                  | ✓             | ✓              | ✓               | ✓                          |



# MISO Renewable Generation Outlet Study (RGOS) and MVP Projects


OFFICIAL COPY

## G&T Cost of Local vs Regional Generation




MISO and its stakeholders identified total capital costs associated with generation capacity and indicative transmission to deliver the energy to the system

## RGOS Energy Zones



MISO sought input from regulatory bodies and various state agencies to identify energy zones; zone selection was based on a number of potential locations developed by MISO using NREL wind data

## MVP Transmission Projects



Transmission upgrades were identified by MISO and its stakeholders over a series of planning studies that resulted in the MVP portfolio

Aug 17 2022

# Decade of Experience with Identifying and Quantifying Benefits

## SPP 2016 RCAR, 2013 MTF

### Quantified

1. **production cost savings\***
  - value of reduced emissions
  - reduced ancillary service costs
2. avoided transmission project costs
3. reduced transmission losses\*
  - capacity benefit
  - energy cost benefit
4. lower transmission outage costs
5. value of reliability projects
6. value of mtg public policy goals
7. Increased wheeling revenues

### Not quantified

8. reduced cost of extreme events
9. reduced reserve margin
10. reduced loss of load probability
11. increased competition/liquidity
12. improved congestion hedging
13. mitigation of uncertainty
14. reduced plant cycling costs
15. societal economic benefits

(SPP Regional Cost Allocation Review [Report](#) for RCAR II, July 11, 2016. SPP Metrics Task Force, [Benefits for the 2013 Regional Cost Allocation Review](#), July, 5 2012.)

## MISO MVP Analysis

### Quantified

1. **production cost savings \***
2. reduced operating reserves
3. reduced planning reserves
4. reduced transmission losses\*
5. reduced renewable generation investment costs
6. reduced future transmission investment costs

### Not quantified

7. enhanced generation policy flexibility
8. increased system robustness
9. decreased natural gas price risk
10. decreased CO<sub>2</sub> emissions output
11. decreased wind generation volatility
12. increased local investment and job creation

(Proposed Multi Value Project Portfolio, Technical Study Task Force and Business Case Workshop August 22, 2011)

## CAISO TEAM Analysis

(DPV2 example)

### Quantified

1. **production cost savings\*** and reduced energy prices from both a societal and customer perspective
2. mitigation of market power
3. insurance value for high-impact low-probability events
4. capacity benefits due to reduced generation investment costs
5. operational benefits (RMR)
6. reduced transmission losses\*
7. emissions benefit

### Not quantified

8. facilitation of the retirement of aging power plants
9. encouraging fuel diversity
10. improved reserve sharing
11. increased voltage support

(CPUC Decision 07-01-040, January 25, 2007, Opinion Granting a Certificate of Public Convenience and Necessity)

## NYISO PPTN Analysis

(AC Upgrades)

### Quantified

1. **production cost savings\*** (includes savings not captured by normalized simulations)
2. capacity resource cost savings
3. reduced refurbishment costs for aging transmission
4. reduced costs of achieving renewable and climate policy goals

### Not quantified

5. protection against extreme market conditions
6. increased competition and liquidity
7. storm hardening and resilience
8. expandability benefits

(Newell, et al., [Benefit-Cost Analysis of Proposed New York AC Transmission Upgrades](#), September 15, 2015)


\* Fairly consistent across RTOs



# Quantifying Benefits Beyond “Production Cost” Savings

Relying on solely on traditionally-quantified Adjusted Production Cost (APC) Savings results in the rejection of beneficial transmission projects:

FIGURE 5. BENEFIT-COST RATIOS OF TRANSMISSION PROJECTS WITH AND WITHOUT A BROAD SCOPE OF BENEFITS



Source: [Transmission Planning for the 21st Century: Proven Practices that Increase Value and Reduce Costs \(brattle.com\)](https://www.brattle.com/resources/publications/Transmission-Planning-for-the-21st-Century-Proven-Practices-that-Increase-Value-and-Reduce-Costs)

# Proactive Transmission Planning for Changing Resource Mix

---

- **ERCOT:** CREZ lines unlocked over 11 GW of wind and solar capacity based on detailed review of ideal locations; currently considering additional upgrades to expand West Texas capacity
- **SPP:** Priority Projects developed to access 3 GW of wind; later replaced by Integrated Transmission Planning process for identifying upgrades to provide broad range of benefits
- **MISO:** Identified least-cost mix of regional & local renewable resources through RGOS that resulted in market-wide Multi-Value Project upgrades to access 14 GW of wind resources
- **PJM:** In recent study, identified much lower cost portfolio of upgrades to interconnect 75 GW of renewable resources across its system compared to doing so through GI process
- **PacifiCorp:** Gateway West projects proposed to access 1,500 MW of low-cost wind in WY
- **NV Energy:** Building Greenlink projects to access 4,000 MW of low-cost solar resources in NV

# Proactive Planning Will Improve Interconnection Process

---

Proactive planning efforts will provide the roadmap to the most cost-effective solutions for interconnection-related and other transmission needs over the next 10-20 years

These planning efforts usually run in parallel with the regular interconnection process

- Each planning study may take 1-2 years to complete and be done only every few years, but that does not hold up anything else

At the same time, Duke should consider approaches to continuing to improve the interconnection process:

- Identify network upgrades based on a level of output that more closely reflects its ELCC instead of its nameplate capacity
- Allow solar resources to request non-firm/energy-only service
- Allow solar to begin operating as an energy-only resource after building its attachment facilities and then become a full network resource once network upgrades completed

# Substantial Differences in Generation Interconnection Processes

Interconnection processes and study criteria differ substantially across the regions:

- ERCOT's generation interconnection process is generally seen as more effective
  - Efficient handoff of study roles by ERCOT and Transmission Owners limits restudy needs
  - Projects can be developed and interconnected within 2-3 years; in other regions, the interconnection study process itself takes longer than that
  - Upgrades focused more on local needs (similar to ERIS) and are recovered through postage stamp
  - Network constraints managed through market dispatch – which imposes higher congestion and curtailment risks on interconnecting generators but yields more efficient outcomes and risk sharing
  - See [working-paper.pdf \(enelgreenpower.com\)](#) [Note: Brattle was not involved]
- Attractive: UK “Connect and Manage” (replaced prior “Invest and Connect”)
  - Similar to ERIS; reduced lead times by 5 years; network constraints addressed later (e.g., with congestion management) <https://www.gov.uk/guidance/electricity-network-delivery-and-access#connect-and-manage>
- Generation interconnection study criteria matter, yet differ substantially across RTOs
  - For example, PJM's stringent study criteria tend to trigger more “deep network” upgrades, which increases churn and restudy requirements; will often be less cost effective than congestion management

# Recommendations for Carbon Plan

---

- Develop least-cost resource mixes to achieve 70% CO<sub>2</sub> reductions without the proposed limit on incremental solar additions
- Instead, either include estimates of transmission costs in the simulations (which may increase with additions) or simulate alternative transmission buildout scenarios
- Identify likely locations of new resources in least-cost resource mix, including input from stakeholders on renewable energy zones, transmission constraints, and costs
- Perform proactive transmission planning studies for identified resource mixes that consider a broad range of system benefits
- Review generation interconnection process to identify opportunities to align with best practices across the industry

# Prepared By

---



**Michael Hagerty**

SENIOR ASSOCIATE | WASHINGTON, DC

[Michael.Hagerty@brattle.com](mailto:Michael.Hagerty@brattle.com)

+1.202.419.33223



**Metin Celebi**

PRINCIPAL | BOSTON

[Metin.Celebi@brattle.com](mailto:Metin.Celebi@brattle.com)

+1.617.234.5610

# Appendix

# About Brattle

---

The Brattle Group answers complex economic, finance, and regulatory questions for corporations, law firms, and governments around the world. We are distinguished by the clarity of our insights and the credibility of our experts, which include leading international academics and industry specialists. Brattle has over 400 talented professionals across three continents. For more information, please visit **brattle.com**.

## Our Services

Research and Consulting  
Litigation and Support  
Expert Testimony

---

## Our People

Renowned Experts  
Global Teams  
Intellectual Rigor

---

## Our Insights

Thoughtful Analysis  
Exceptional Quality  
Clear Communication

---



# Our Practices and Industries

---

## TOP 25 PRACTICES

- Accounting
- Alternative Investments
- Antitrust & Competition
- Bankruptcy & Restructuring
- Broker-Dealers & Financial Services
- Consumer Protection & Product Liability
- Credit, Derivatives & Structured Products
- Cryptocurrency & Digital Assets
- Electricity Litigation & Regulatory Disputes
- Electricity Wholesale Markets & Planning
- Environment & Natural Resources
- Financial Institutions
- Healthcare & Life Sciences
- Infrastructure
- Intellectual Property
- International Arbitration
- M&A Litigation
- Oil & Gas
- Regulatory Economics, Finance & Rates
- Regulatory Investigations & Enforcement
- Securities Class Actions
- Tax Controversy & Transfer Pricing
- Technology
- Telecommunications, Internet, Media & Entertainment
- White Collar Investigations & Litigation

# Our Offices

OFFICIAL COPY  
Aug 17 2022



# Clarity in the face of complexity

---

That's the Power of Economics™



OFFICIAL COPY  
Aug 17 2022