

System Name		Well #	System #	PSI on:	PSI off:
Blaney Farms		2	409213		

DATE M/D/Y	TIME Arrived	Backwash Gallons Used	Master Meter	Meter Number	Gallons Since Last Visit	PSI	Chem. Added		Chem. Level		Well House Residuals				Initials	Comments & Adjustments	Date M/D/Y	Time Arrived	MRT Residuals				Gals Flushed	Initials	MRT Address	
							CL2	PO4	CL2	PO4	pH	CL2	PO4	Fe					Mn	CL2	PO4	Fe				Mn
4/4/22	10:00		16737881			85	2.5		0/45		0.61	0.58	0.07		ADB	Cleaned c/2 tank. 1 gallon of c/2 to 16.8 gallons of water	4/5/22	10:35	0.54	0.77	0	0.025		ADB	Serene lake dr	
4/5/22	10:38																4/5/22	11:15	0.56	0.69				ADB	Cross timber lane	
4/7/22	11:05		16738000	19	19	75			39 29		0.89	0.48	0.08	0.053	ADB											
4/11/22	11		16738013	13		80			30 26		0.62	0.52			ADB											
4/14/22	9:30																4/14/22	9:30	0.47	0.51	0.07		100	ADB	Serene lake dr	
4/16/22	11:25		16738005			85			23 24		0.64	0.52			ADB		4/14/22	10:56	0.46	0.61	0.09	0.028		ADB	Kaylor creek	
4/18/22	10:30		16738050			88			16 21		0.95	0.49			ADB											
4/19/22	12:00						2		14/45	21					ADB	Po stroke 40 to 50										
4/20/22	9:50																4/20/22	9:50	0.45	0.76					ADB	3816 hickory manor drive
4/22/22	10:50		18738120			80			39 17		0.75	0.56			ADB											
4/26/22	10:30		18738090			84			2 28 13/45		0.56	0.55	0.05	0.044	ADB		4/28/22	1:40	0.44	0.67					ADB	3816 hickory manor
4/28/22	1:40																4/28/22	2:10	0.58	0.77					ADB	2100 stillness pond
4/28/22	10:48		18738112			92			18 43		0.48	0.48			ADB											
master meter broken, New meter ordered																										

OFFICIAL COPY
Jul 01 2022

System Name		Well #		System #		PSI on:		PSI off:																			
Senter		586		408213																							
DATE M/D/Y	TIME Arrived	Backwash Gallons Used	Master Meter	Meter Number	Gallons Since Last Visit	PSI	Chem. Added CL2	Chem. Added PO4	Chem. Level CL2	Chem. Level PO4	pH	Well House Residuals CL2	Well House Residuals PO4	Fe	Mn	Initials	Comments & Adjustments	Date M/D/Y	Time Arrived	MRT Residuals CL2	MRT Residuals PO4	Fe	Mn	Gals Pushed	Initials	MRT Address	
4/4/22	10:45		3,333,271		11,131	94			38	32		0.79	0.45			ADB											
			131,267		67																						
4/5/22	10:55																										
4/7/22	1:15		3345203		11,932	85			31	31		0.86	0.42	0.1	0.01	ADB											
			131,269		2																						
4/11/22	11:30		3,357,444		12,241	92			29	30		0.58	0.52			ADB											
			131325		56																						
4/14/22	10:20																										
4/15/22	11:45		3379626		16,482	89			28	30		0.73	0.79			ADB											
			131383		58																						
4/19/22	10:58		3383268		9,342	90			25	29		0.45	0.42			ADB											
			131435		52																						
4/19/22	11:55																										
4/21/22	1:45																										
4/22/22	11:05		3395960		12,722	85			25	29		0.61	0.42			ADB											
			131488		63																						
4/25/22	11:10		3407192		11,142	90			25	28		0.7	0.44			ADB											
			131643		45																						
4/28/22	1:50								24	28		0.65	0.55			ADB											
4/29/22	11:00		3417903		10,771	85																					
			131601		58																						

OFFICIAL COPY

Jul 01 2022

System Name			Well #	System #		PSI on: _____ PSI off: _____																														
Blaney Farms			2			DATE	TIME	Backwash	Master	Meter	Gallons Since	PSI	Chem. Added	Chem. Level	Well House Residuals					Initials	Comments & Adjustments	Date	Time	MRT Residuals				Gals	Initials	MRT						
						MDY	Arrived	Gallons Used	Meter	Number	Last Visit		CL2	PO4	CL2	PO4	pH	CL2	PO4	Fe	Mn			MDY	Arrived	CL2	PO4	Fe	Mn	Flushed		Address				
5/1/22	10		16,738,126			14	02	2				0940	39					0.55	0.42	0	0.021	ADB		5/5/22	9:15											
5/6/22	11:45		16,738,148			22	85					31	36					0.55	0.45			ADB		5/6/22	9:16	0.44	0.85	0.07	0.021		ADB	3816 Hickory Manor drive				
5/10/22	9:35		16738170			22	96					21	31					6.69	0.45			ADB		5/6/22	10:10	0.71	0.57	0	0.01		ADB	2100 stillness pond				
5/12/22	10:05											15/30	29											5/12/22	10:05	0.64	0.73				ADB	2100 stillness pond				
5/13/22	11:40		15738183			13	95					29	28					0.72	0.55			ADB				0.55	0.72				ADB	3816 Hickory Manor				
5/17/22	10:15		16738201			18	86	1				19/35	24					0.57	0.49			ADB														
5/18/22	9:30											30	2140									ADB		5/18/22	8:30	0.47	0.88				ADB	3800 Hickory Manor				
5/19/22	9:30											1	30	2140								ADB		5/19/22	9:20	0.25	2.01				ADB	2100 stillness pond				
5/20/22	10:50		15738219			12	85					28	39					0.55	0.49			ADB														
5/23/22	2:30		16738225			12	90					21	36					0.51	0.51			ADB														
5/25/22	10:15																							5/25/22	10:15	0.48	0.63				ADB	2100 stillness pond				
5/26/22	2:00		16738235			10	80	0.5				14/23	34					0.55	0.52			ADB														
5/31/22	10:25		16738252			17	81					13	30					0.55	0.45			ADB														
				Master meter broken Meter ordered																																

16		System Name		Well #		System #		Prelim		Prel on		Prel off											
DATE	TIME	Backwash Gallons Used	Master Water	Master Number	Gallons Sipped Last Visit	PSI	Chem. Added Cl2 PCl	Chem. Level Cl2 PCl	pH	Well House Residuals Cl2 PCl	Fe	Mn	Initials	Comments & Adjustments	Date MO/Y	Time Arrived	Cl2	MRT Residuals PCL	Fe	Mn	Gain Residual	Initials	MRT Address
5/17/22	11:15		3427148	9246		88		28	28	0.52	1.11		ADB		5/17/22	9:30	0.57	0.75	0	0.017		ADB	3728 apple grove
5/17/22	9:25		1316951	50											5/17/22	9:30	0.57	0.75	0	0.017		ADB	3728 apple grove
5/17/22	11:50		3439341	12192		85		24	28	0.55	1.15		ADB		5/17/22	9:30	0.57	0.75	0	0.017		ADB	3728 apple grove
5/17/22	9:30		1317196	57		91		23	25	0.63	1.11		ADB		5/17/22	11:30	0.56	0.73				ADB	3728 apple grove
5/17/22	11:35		3452285	11970		81		21	25	0.55	0.85		ADB		5/17/22	11:30	0.56	0.73				ADB	3728 apple grove
5/17/22	11:50		1319495	47		82		19	24	0.63	0.79		ADB		5/17/22	11:30	0.56	0.73				ADB	3728 apple grove
5/17/22	10:30		3471714	12348		82		18	24	0.68	0.74		ADB		5/17/22	11:30	0.56	0.73				ADB	3728 apple grove
5/17/22	11:30		3488538	10825		92		16	24	0.65	0.77		ADB		5/17/22	11:30	0.56	0.73				ADB	3728 apple grove
5/17/22	2:45		1318606	43		88		16	24	0.65	0.77		ADB		5/17/22	10:45	0.51	0.73				ADB	3728 apple grove
5/17/22	2:45		3488105	5565		88		16	24	0.65	0.77		ADB		5/17/22	10:45	0.51	0.73				ADB	3728 apple grove
5/17/22	10:45		131850	44		88		16	24	0.65	0.77		ADB		5/17/22	10:45	0.51	0.73				ADB	3728 apple grove
5/17/22	2:05		3480370	785		82		15	24	0.65	0.71		ADB		5/17/22	10:45	0.51	0.73				ADB	3728 apple grove
5/17/22	2:05		131850	40		82		15	24	0.65	0.71		ADB		5/17/22	10:45	0.51	0.73				ADB	3728 apple grove
5/17/22	10:35		3421330	18200		86		30	23	1.15	1.41	0.01	ADB		5/17/22	10:35						ADB	
5/17/22	10:35		132058	18		86		30	23	1.15	1.41	0.01	ADB		5/17/22	10:35						ADB	

System Name			Well #		System #												PSI on: _____		PSI off: _____								
Blaney Farms			2		4092134																						
DATE M/D/Y	TIME Arrived	Backwash Gallons Used	Master Meter	Meter Number	Gallons Since Last Visit	PSI	Chem. Added		Chem. Level		Well House Residuals				Initials	Comments & Adjustments	Date M/D/Y	Time Arrived	MRT Residuals				Gale Flushed	Initials	MRT Address		
							CL2	PO4	CL2	PO4	pH	CL2	PO4	Fe					Mn	CL2	PO4	Fe				Mn	
6/2/22	9:15		16738259			90	2.6		7/46			0.57	0.55			ADB		6/2/22	9:15	0.29	0.88	0.03	0.006		ADB	2100 stillness pond	
6/3/22	10:30		16738272			88			42	26		1.46	0.75			ADB	CL2 stroke 45 to 40	6/3/22	9:45	0.39	0.75				ADB	3816 hickory manor	
6/6/22	12		16738270			88			33	24		0.62	1.13			ADB											
6/9/22	2:20																	6/9/22	2:25	0.31	0.62				ADB	3816 hickory manor	
6/10/22	11:20		16738283			82			24	17		0.45	0.58			ADB		6/9/22	2:45	0.35	0.73				ADB	2100 stillness pond	
6/13/22	2		16738293			88	2		14/45	14		0.55	0.51			ADB											
6/15/22	9:05																	6/15/22	9:05	0.4	0.61				ADB	3800 hickory manor	
6/17/22	11:40		16738304			80		2	34	9/45		0.52	0.55			ADB		6/17/22	12:15	0.35	0.73				ADB	2100 stillness pond	
6/20/22	11:45		16738315			82			25	44		0.35	0.75	0	0.025	ADB	CL2 stroke 35 to 45	6/20/22	11:45	0.22	0.85	0.1	0.067		ADB	2224 stillness pond	
6/21/22	8:25						1.5		24/45	43								6/21/22	8:50	0.38	0.75	0.13	0.021		ADB	4015 cross timber lane	
																			8:15	0.26	1.1	0	0.015		ADB	2204 stillness pond outside facet	
6/22/22	9:30																	6/22/22	9:3	0.19	1.11	0.06	0.002		ADB	2204 stillness pond inside facet	
6/24/22	10:20		16738331			84			38	42		0.55	0.55			ADB									ADB	Kaylor creek	
6/28/22	2:20		16738346			82			25	37		0.55	0.61			ADB											

OFFICIAL COPY
Jul 01 2022

System Name		Well #		System #		PSI on		PSI off		Date		Time		MRT Residuals				Gals		Initials		MRT					
Senter		5&6		409213						M/D/Y		Arrived		CL2		PO4		Fe		Mn		Flushed		Address			
DATE	TIME	Backwash Gallons Used	Master Meter	Meter Number	Gallons Since Last Visit	PSI	Chem. Added CL2	Chem. Added PO4	Chem. Level CL2	Chem. Level PO4	pH	Well House Residuals CL2	Well House Residuals PO4	Well House Residuals Fe	Well House Residuals Mn	Initials	Comments & Adjustments	Date	Time	CL2	PO4	Fe	Mn	Flushed	Initials	MRT	
6/2/22	10:30		3,528,777	7,447		88			29	23		0.55	0.51	0	0	ADB		6/2/22	10:30	0.41	0.51				ADB	3728 apple grove	
			132,061	25																							
6/6/22	12:10		3542163	13,386		94			28	23		0.52	0.58			ADB											
			132116	55																							
6/10/22	11:30		3,556,484	15,028		94			28	22		0.55	0.51			ADB	Cl2 line needed replacing . Reason for low cl2	6/10/22	11:30	0.21	0.55				ADB	3728 apple grove	
			132,147	31																							
6/13/22	9:30		3571512	15,028		92			26	21		0.45	0.68			ADB											
			132179	32																							
6/14/22	11:55		3595887	24,175		88			23	20		0.51	0.6			ADB		6/14/22	11:55	0.45	0.52				ADB	3728 apple grove	
6/17/22	12		132227	48																							
6/20/22	12:30		3613674	18,287		95			20	19		0.55	0.75	0.01	0.029	ADB		6/20/22	12:30	0.25	1.04	0.1	0.022		ADB	3728 apple grove	
			132252	35																							
6/24/22	10:30		3641571	27,387		92			17	16		0.51	0.69			ADB											
			132307	45																							
6/28/22	2:40		3657157	25,786		92			14	15		0.55	0.7			ADB											
			132352	45																							

OFFICIAL COPY
Jul 01 2022