

BEFORE THE NORTH CAROLINA UTILITIES COMMISSION

DOCKET NO. E-7, SUB 1250

**IN THE MATTER OF)
APPLICATION OF DUKE ENERGY)
CAROLINAS, LLC PURSUANT TO)
N.C.G.S. § 62-133.2 AND)
COMMISSION RULE R8-5)
RELATING TO FUEL AND FUEL-)
RELATED CHARGE ADJUSTMENTS)
FOR ELECTRIC UTILITIES)**

**DIRECT TESTIMONY OF
DEVI GLICK ON BEHALF OF
THE SIERRA CLUB**

TABLE OF CONTENTS

LIST OF TABLES	2
1. Introduction and purpose of testimony	3
2. Findings and recommendations	8
3. DEC controls and coordinates the commitment and dispatch of its coal-fired generating units.	12
4. DEC’s coal fleet operated at an average cost that exceeded the marginal system cost for nearly all of 2020.....	18
5. DEC excluded over 40 percent of the fuel and variable costs incurred at its coal units from its unit commitment and dispatch decision-making process	24
6. DEC incurred \$8.5 million in avoidable unit costs at its coal plants as a result of uneconomic unit commitment decisions.....	31
7. Recommendations for the Commission	41

LIST OF TABLES

Table 1: 2020 Annual Capacity Factors for DEC Coal Units.....	19
Table 2: CONFIDENTIAL Average Cost of Generation relative to Average System Lambda (\$/MWh).....	21
Table 3: DEC's coal unit costs relative to other solid-fuel plants in the U.S. in 2020.....	24
Table 4: Total Production Costs incurred by DEC's Coal Fleet in 2020 (\$Million).....	27
Table 5: Operational costs in excess of system lambda (\$Million).....	39

1 **1. INTRODUCTION AND PURPOSE OF TESTIMONY**

2 **Q Please state your name and occupation.**

3 **A My name is Devi Glick. I am a Senior Associate at Synapse Energy Economics,**
4 **Inc. (“Synapse”). My business address is 485 Massachusetts Avenue, Suite 3,**
5 **Cambridge, Massachusetts 02139.**

6 **Q Please describe Synapse Energy Economics.**

7 **A Synapse is a research and consulting firm specializing in energy and**
8 **environmental issues, including electric generation, transmission and distribution**
9 **system reliability, ratemaking and rate design, electric industry restructuring and**
10 **market power, electricity market prices, stranded costs, efficiency, renewable**
11 **energy, environmental quality, and nuclear power.**

12 **Synapse’s clients include state consumer advocates, public utilities**
13 **commission staff, attorneys general, environmental organizations, federal**
14 **government agencies, and utilities.**

15 **Q Please summarize your work experience and educational background.**

16 **At Synapse, I conduct economic analysis and write testimony and publications**
17 **that focus on a variety of issues related to electric utilities. These issues include**
18 **power plant economics, utility resource planning practices, valuation of**
19 **distributed energy resources, and utility handling of coal combustion residuals**
20 **waste. I have submitted expert testimony on unit-commitment practices, plant**

1 economics, utility resource needs, and solar valuation before state utility
2 regulators in North Carolina, Arizona, Connecticut, Florida, Indiana, Michigan,
3 New Mexico, South Carolina, Texas, Wisconsin, and Virginia. In the course of
4 my work, I develop in-house electricity system models and perform analysis using
5 industry-standard electricity system models.

6 Before joining Synapse, I worked at Rocky Mountain Institute, focusing
7 on a wide range of energy and electricity issues. I have a master's degree in public
8 policy and a master's degree in environmental science from the University of
9 Michigan, as well as a bachelor's degree in environmental studies from
10 Middlebury College. I have more than eight years of professional experience as a
11 consultant, researcher, and analyst. A copy of my current resume is attached as
12 Exhibit DG-1.

13 **Q On whose behalf are you testifying in this case?**

14 **A** I am testifying on behalf of the Sierra Club.

15 **Q Have you testified previously before the North Carolina Utilities Commission**
16 **(“Commission”)?**

17 Yes, I submitted testimony in Docket No. E-100, Sub 158, the 2018 biennial
18 proceeding regarding avoided cost rates.

1 **Q What is the purpose of your testimony in this proceeding?**

2 My testimony addresses the analysis and decision-making processes Duke Energy
3 Carolinas’ (“DEC” or the “Company”) uses to commit (turn on, keep on, or turn
4 off) and dispatch (turn up or down once a unit is committed) its coal-fired power
5 plants. In particular, I evaluate the production costs that DEC reported and used to
6 make its unit commitment decisions in 2020 (the marginal production cost) and
7 compare those to the fuel costs the Company seeks to recover from ratepayers in
8 this docket (the average or full cost of production). I explain how the significant
9 discrepancy between the marginal and average cost of production is driving
10 DEC’s uneconomic commitment of its coal plants and evaluate the impact DEC’s
11 underrepresentation of unit costs had on ratepayers in 2020. Finally, I outline
12 recommendations for improving the transparency and functioning of the
13 Company’s unit commitment process to better serve ratepayers.

14 **Q Why is the issue of unit commitment relevant to this fuel clause adjustment**
15 **proceeding?**

16 North Carolina law says that the utility can recover the “reasonable costs of fuel
17 and fuel-related costs prudently incurred during the test period.”¹ DEC’s incurred
18 fuel costs are directly tied to the operation of each of its units, and thus its unit-

¹ N.C. Gen. Stat. § 133-2(d).

1 commitment decisions and practices inform the Commission's determination
2 whether those costs were reasonable and prudently incurred.

3 While in the past utilities operated their coal-fired plants as baseload
4 resources with little thought given to whether the plants should be turned on or
5 off, in recent years low gas prices and nearly zero-variable cost renewables have
6 pushed coal generation to become marginal and uncompetitive during many hours
7 of the year. The practice of committing coal plants to run when it is not economic
8 to do so saddles ratepayers with avoidable fuel costs, recovered in this docket, and
9 thereby allows utilities to continue operating aging and costly coal plants when
10 there are lower cost alternatives that can meet customers' needs.

11 **Q You've addressed the full 'production' cost of DEC's generating units, which**
12 **includes variable operations and maintenance costs. Why is the full**
13 **production cost relevant to a proceeding that only seeks recovery of fuel**
14 **costs?**

15 The operation of the Company's generation units is governed by the full
16 production cost of those units, which includes both fuel and non-fuel variable
17 costs. While the Company only seeks recovery of its incurred fuel costs in this
18 docket, whether or not the Company prudently incurred those fuel costs can only
19 be assessed by evaluating how the Company operated its generating units.

20 **Q How is the remainder of your testimony structured?**

21 In Section 2, I summarize my findings and recommendations for the Commission.

1 In Section 3, I define the terms “unit commitment” and “dispatch” and
2 describe how electric utilities make daily operational decisions at coal-fired power
3 plants.

4 In Section 4, I evaluate the fuel and other production costs incurred by
5 DEC (which, if determined to be reasonable and prudently incurred, would
6 normally be passed on to ratepayers) to operate its coal-fired power plants in the
7 2020 test year. I compare the production cost of DEC units to those of other coal
8 units around the country.

9 In Section 5, I review the marginal production costs the Company uses to
10 make its unit commitment decisions at its coal units and evaluate the significant
11 deviation between the average production cost incurred at each unit over the
12 course of the test year, and the marginal cost of production used for the purposes
13 of making unit commitment and dispatch decisions.

14 In Section 6, I explain the practice of uneconomic unit commitment,
15 outline reasons why utilities may utilize this practice, and discuss the impacts this
16 practice has on DEC’s ratepayers. I evaluate the economic performance of DEC’s
17 coal units during the 2020 test year. I discuss the costs that uneconomic
18 commitment practices will impose on ratepayers if approved for recovery in this
19 proceeding. I quantify the customer net revenue losses resulting from the
20 Company’s decisions to “must-run” each of its coal plants during the test year.

1 In Section 7, I outline recommended reporting requirements for future fuel
2 charge adjustment dockets that will allow the Commission to evaluate whether the
3 Company's unit-commitment practices are causing the Company to incur fuel
4 costs unreasonably or imprudently.

5 **2. FINDINGS AND RECOMMENDATIONS**

6 **Q Please summarize your findings.**

7 **A** My primary findings are:

- 8 1. During the 2020 test year, DEC's coal units had some of the highest fuel
9 costs among all coal units in the country, yet DEC continued to incur costs
10 in operating and maintaining the units. As explained in Section 4, Allen,
11 Marshall, Cliffside and Belews Creek ranked in the top 75th – 90th
12 percentile for most expensive fuel costs in 2020 among all United States
13 coal-fired power plants.
- 14 2. During the 2020 test year, DEC's reported average cost of generation at
15 each of its four coal plants exceeded the system lambda (marginal cost of
16 energy) during nearly every month, with only two exceptions – Allen and
17 Cliffside in the month of December 2020. Other than these two instances,
18 the average cost of generation exceeded the system lambda for all plants in
19 all months, as explained in Section 4. In total, DEC's units incurred ~~\$194~~
20 \$233 million in variable costs above system lambda. This means that

1 during the test year, many of DEC's coal plants failed to pass the lowest
2 bar of economic performance a large portion of the time.

3 3. DEC omitted from its unit commitment decisions approximately ~~\$225~~
4 ~~\$263~~ million worth of fuel and variable costs (approximately ~~\$214~~ ~~\$250~~
5 million of which is fuel costs), representing over 40 percent of those costs
6 at its coal units, thus allowing the units to commit and dispatch
7 significantly more than they would if the units' full variable production
8 cost was reflected.

9 4. DEC regularly committed its coal units at times when its marginal
10 production costs exceeded the system lambda, even when it would have
11 been less costly to serve captive retail customer load with other resources.
12 This means that those unit commitments were uneconomic, yet DEC seeks
13 to pass those excess costs on to ratepayers in this docket.

14 5. During the 2020 test year, DEC's unit-commitment practices at its coal
15 plants caused the Company to incur avoidable excess costs of \$8.5 million
16 at Allen, Marshall, Cliffside, and Belews Creek based on the Company's
17 reported marginal variable production costs for those units.

18 6. DEC did not adequately report and describe its fuel cost accounting and
19 unit-commitment practices in its fuel charge adjustment application. The
20 Company should have included documentation of its daily decision-
21 making process and its reasoning for frequent uneconomic commitment.

1 **Q Please summarize your recommendations.**

2 **A Based on my findings, I offer the following chief recommendations:**

3 1. I recommend that the Commission examine DEC's production cost
4 accounting, its unit commitment process that relies on its production costs,
5 and the operational decisions and incurred costs that result, and scrutinize
6 such costs carefully for potential disallowance in future proceedings.

7 2. DEC's should be required to provide full transparency into the Company's
8 marginal and average production costs. Specifically, DEC should provide
9 a full breakdown of the following, accompanied by a detailed explanation
10 of each and full work papers that show how each component was
11 calculated:

12 a. Full production cost of each unit that will be passed on to
13 ratepayers in this docket, broken down by the following categories:

14 i. Fixed costs

15 ii. Variable costs

16 1. Fuel

17 2. Reagents/ by products

18 3. Emissions

19 4. Variable O&M

20 b. Marginal production cost of each unit used for making unit

21 commitment and dispatch decisions, broken down by the same

Direct Testimony of Devi Glick – Sierra Club
NCUC Docket E-7, Sub 1250

1 components listed directly above. For any production costs
2 Excluded from DEC marginal production costs, the Company
3 should provide a detailed justification for why these costs are not
4 relevant for making unit commitment decisions.

- 5 3. The Commission should require DEC to provide a detailed report
6 describing its daily unit-commitment decisions and practices as part of
7 future fuel charge adjustment proceedings. DEC should provide the
8 following information as part of each fuel charge adjustment filing, to
9 inform the Commission's review of its unit-commitment practices and
10 determination whether DEC's fuel- and fuel-related costs for those units
11 were reasonably and prudently incurred:
- 12 a. All 7-day forecast sheets used to develop the Company's daily
13 unit-commitment decisions and marginal cost.
 - 14 b. The reason for any deviation between the commitment decision
15 suggested by the Company's forward-looking price-based analysis
16 and the Company's actual commitment decision (e.g., where the
17 Company's analysis suggests that a unit has a production cost
18 above the marginal system cost during a given day, and the
19 Company self-commits the unit anyway).
 - 20 c. Hourly data sufficient for the Commission to calculate the net
21 revenues that each plant actually incurred in each test year period,

1 including total unit generation, delivered fuel cost, marginal or
2 “replacement” fuel cost, total variable operations and maintenance
3 (“O&M”) cost, system lambdas, day-ahead commitment status,
4 and actual outages.

- 5 4. Given the low capacity factor at which DEC’s coal fleet operated in
6 2020—extremely low, in the case of some units—the Company should
7 evaluate moving some of its plants to seasonal operation and retiring some
8 of its units.

9 **3. DEC CONTROLS AND COORDINATES THE COMMITMENT AND DISPATCH OF ITS**
10 **COAL-FIRED GENERATING UNITS.**

11 **Q Please summarize this section.**

12 **A** In this section, I define the concepts of unit commitment and dispatch and explain
13 how dispatchable power plants operate in DEC’s system. I define the practice of
14 uneconomic unit commitment by regulated, vertically integrated utilities like DEC
15 and discuss the impacts this practice can have on ratepayers, if utilities are
16 permitted to pass along the avoidable excess costs that result.

17 **Q Please explain the terms “unit commitment” and “dispatch.”**

18 **A** Unit commitment is the process by which a utility decides if a long-lead time
19 generating unit, generally steam boilers, should be operational for the following
20 day. Commitment is the decision to either keep the unit online, bring a unit online
21 that is not currently generating, or bring offline (“de-commit”) a unit that is

1 currently online. Unit commitment decisions are distinct from “dispatch”
2 decisions, which are the decisions to incrementally increase or decrease a unit’s
3 generation. Fast-start units like combustion turbines or battery storage can
4 generally be dispatched from idle (or “blackstart”) and do not need to be
5 committed ahead of time. However, large steam boilers require a clear
6 commitment, and once committed to operate, must run at a minimum level of
7 output.

8 **Q How does the process of unit-commitment occur?**

9 **A** The process of unit commitment requires that the operator look forward to
10 determine if a long-lead time unit is likely to operate economically over the next
11 few days. To make this determination, the operator will compare the costs of
12 starting and operating a particular unit with the costs of all other units on its
13 system to determine whether that unit should be online the next day. When a unit
14 is committed economically, the unit is reasonably expected to be lower cost than
15 the marginal cost of energy, called “system lambda,” over the next day or days.
16 When a unit is committed uneconomically, the operator has decided to operate
17 that unit at its economic minimum, which is the lowest MW output that a unit can
18 safely and efficiently maintain, even though that unit’s marginal costs of
19 production are projected to be higher than the system lambda.

20 **Q In this testimony, you refer to “average costs” of production and DEC’s**
21 **reported “marginal cost” of production. Can you briefly explain what you**

1 mean by these two terms, which variable costs are included in each, and why
2 they are relevant to this proceeding?

3 A Each of DEC's coal-fired power plants has a specific set of costs incurred to
4 operate the unit. The cost of production is composed of fixed costs, which are
5 incurred regardless of whether and how a unit is operated, and variable costs,
6 which are incurred based on usage. Variable costs include fuel,
7 reagents/byproducts emissions, and variable O&M.

8 When making a unit commitment decision, DEC utilizes the marginal cost
9 of production. The marginal cost of production is calculated based on the
10 replacement cost of fuel, which is the "market price of fuel plus variable
11 transportation costs,"² and the cost of reagents/byproducts, emission, and variable
12 O&M. This cost represents the incremental cost of operating the unit.

13 But the marginal cost of production does not represent the actual
14 production costs passed on to ratepayers. The average production cost represents
15 the cost to operate each unit (that is actually passed on to ratepayers) spread out
16 over the unit's MW output. This includes the cost of the fuel that was actually
17 burned (or paid out) and all associated transportation costs, regardless of contract
18 structure. Reagent / byproduct, emissions, and variable O&M costs are also
19 included.

² Duke Energy Carolinas Response to Sierra Club Request 1-8.

1 **Q** **Please describe how dispatchable power plants are generally committed and**
2 **operated by electric utilities like DEC that operate outside of organized**
3 **wholesale markets.**

4 **A** In a non-centralized market, the unit commitment process is completely dictated
5 by the utility. The utility is responsible for internally committing and dispatching
6 its units, and procuring energy through bilateral trades when needed, and
7 generally does so on a variable cost basis within operational constraints. These
8 utilities generally use internal systems that project the marginal production cost to
9 operate each unit and calculates the cost of the marginal unit in the system, called
10 “system lambda.” Resources are committed based on cost, with the lowest-cost
11 resources coming online first, and progressively more expensive units being
12 turned on until system load is met. Both the unit-commitment and dispatch
13 processes should be based on economics and should generally ensure customers
14 are served by the lowest-cost resources while maintaining reliability.

15 **Q** **In practice, are all power plants actually committed by electric utilities in**
16 **that way?**

17 **A** No. Utilities may ignore marginal cost when making operational decisions or
18 simply consider only a portion of the unit’s actual cost in making commitment
19 and dispatch decisions. The result is that utilities keep units online and operating
20 when it otherwise would not operate. Some utilities do adhere closely to efficient
21 dispatch and commitment, but others do not, and can exhibit a wide discrepancy
22 between the cost of operation and operational decision, as is seen with DEC.

1 There are a variety of reasons why utilities ignore or underrepresent unit costs,
2 and the practice varies widely

3 First, for inflexible units with long start-up and shut-down times, such as
4 coal-fired power plants, utilities regularly force units to stay online in order to
5 avoid unit cycling costs. Utilities have historically tried to avoid cycling of coal
6 plants because it can result in wear-and-tear that increases maintenance costs.³

7 But, while continuous operation of coal units can reduce cycling costs, it
8 generally results in the incursion of unnecessary operational costs well in excess
9 of the cycling costs being avoided. Cycling times and costs can be incorporated
10 into multi-day unit commitment decision-making processes.

11 Second, in order to address fuel over-supply issues, utilities sometimes
12 explicitly adjust how fuel costs are accounted for in their dispatch. Specifically,
13 they may lower the marginal cost of a unit for the purposes of keeping a unit
14 online to burn excess fuel. This is generally done when it is cheaper to burn the
15 coal at a loss than to store the coal or cancel a fuel contract. Duke Energy Indiana
16 refers to this process as a ‘coal price decrement.’⁴

17 Third, there are structural and company decisions relating to fuel
18 contracts, transportation contracts, and operations and maintenance (“O&M”) that

³ See Recent Changes to U.S. Coal Plant Operations and Current Compensation Practices. NARUC, January 2020. Accessible at <https://pubs.naruc.org/pub/7B762FE1-A71B-E947-04FB-D2154DE77D45>.

⁴ Direct Testimony of John Swez, IURC Cause No. 38707-FAC 125.

1 drive the utility’s categorization of costs. Specifically, utilities that sign coal
2 contracts with fixed tonnage requirements or must-take provisions of fuel
3 contracts often categorize some of their fuel costs as fixed, and therefore exclude
4 them from unit dispatch and commitment decisions. This practice effectively
5 locks ratepayers into paying a portion of fuel costs, often without any formal
6 approval from the regulatory commission. Utility treatment of O&M costs—
7 specifically, utility judgement of what costs are truly variable and predictable
8 based on unit operations, and which are truly fixed—also varies widely.

9 **Q Are there any reasons why a utility might be incentivized to operate a unit**
10 **more often than it should be from a cost perspective?**

11 **A** Yes. A utility that receives a return of and on assets in the rate base may have an
12 incentive to show that aging units are still “used and useful” despite the
13 substantial capital and fixed expense required to keep them online. A unit that is
14 neither economic over the long-run (i.e. relative to replacement options) and does
15 not provide economic service on a short-term basis may be perceived as not used
16 or useful and at risk for disallowance. As noted by the Energy Information
17 administration, coal units that move to very low utilizations are often retired
18 shortly thereafter,⁵ because the justification for their operational costs evaporates.

⁵ As U.S. coal-fired capacity and utilization decline, operators consider seasonal operation. September 1, 2020. Accessible at <https://www.eia.gov/todayinenergy/detail.php?id=44976>

1 **4. DEC'S COAL FLEET OPERATED AT AN AVERAGE PRODUCTION COST THAT**
2 **EXCEEDED THE MARGINAL SYSTEM COST FOR NEARLY ALL OF 2020.**

3 **Q Please summarize this section.**

4 **A** In this section, I review the actual generation costs that were passed on to
5 ratepayers as a result of DEC's operation of its coal-fired units in the test year
6 2020. I find that the Company's four coal-fired power plants all operated at an
7 average production cost that exceeded the marginal system cost during nearly
8 every month in 2020 (the exception was one month at each Allen and Cliffside).

9 **Q Describe DEC's coal-fired power stations.**

10 **A** The Company has four coal-fired power stations: Allen, Marshall, Cliffside, and
11 Belews Creek. Allen consists of five units (Units 1-5) and has a total capacity
12 rating of 1,130 MW. Marshall consists of four units and has a total capacity rating
13 of 2,078 MW. Cliffside consists of two units, Units 5 and 6, which have capacity
14 ratings of 546 and 849 MW respectively. Belews Creek consists of two units,
15 Units 1 and 2, which each have a capacity rating of 1,100 MW.⁶

⁶ Duke Energy Carolinas, Application in the Fuel Charge Adjustment Proceeding. Exhibit 6, Schedule 10.

1 **Q Describe Duke's utilization of its coal-fired fleet in 2020.**

2 **A** In 2020, each of Duke's coal-fired power plants was minimally utilized.

3 Specifically, every unit with the exception of Cliffside 6 (56.6 percent) had an

4 annual capacity factor below 39 percent, as shown in Table 1. The five Allen units

5 had the worst performance, operating at between a 1.1 percent and 10.8 percent

6 capacity factor.⁷

7 **Table 1: 2020 Annual Capacity Factors for DEC Coal Units**

Unit	2020 Capacity Factor (%)
Allen 1	1.1%
Allen 2	1.2%
Allen 3	2.8%
Allen 4	10.8%
Allen 5	9.4%
Belews Creek 1	28.1%
Belews Creek 2	27.5%
Cliffside 5	22.8%
Cliffside 6	56.6%
Marshall 1	25.9%
Marshall 2	28.9%
Marshall 3	36.1%
Marshall 4	38.2%

8 **Source:** DEC Response to Sierra Club Request 1-3(a), CONFIDENTIAL
 9 Attachment; DEC Application in the Fuel Charge Adjustment Proceeding
 10 (Exhibit 6, Schedule 10)

⁷ Duke Energy Carolinas Response to Sierra Club 1-3a, CONFIDENTIAL 2021 SCDR 1.3a_d_e_j DEC Coal Unit Fuel Detail; Duke Energy Carolinas, Application in the Fuel Charge Adjustment Proceeding. Exhibit 6, Schedule 10. Disclosed publicly with agreement of DEC counsel.

1 **Q** **Please summarize your analysis of the economic performance of DEC’s units**
2 **in 2020 based on the Company’s actual cost data.**

3 **A** I reviewed data reported by DEC on the average cost of generation for each plant
4 by month and the hourly system lambdas. I compared the monthly average system
5 lambda⁸ to the monthly average cost of generation at each plant.⁹ As shown in
6 Table 2, I found that during the test year of 2020 the average cost of generation at
7 each coal station was higher than the average system lambda, with the exception
8 of one month each at Allen and Cliffside. That means that in every month of
9 2020, nearly all of DEC’s coal-fired power plants were operating at an average
10 cost above the marginal cost of electricity on its system, when there were lower
11 cost resources available to serve load. DEC did this by underrepresenting the
12 marginal production cost used for the purposes of making unit commitment
13 decision. In total, DEC total production costs were ~~\$194~~ \$233 million more than
14 the cost of serving load met by the coal units at the system lambda (as discussed
15 in section 5).

⁸ Duke Energy Carolinas Response to Sierra Club 1-3b, CONFIDENTIAL 2021 SCDR 1.3b DEC INCDEC.

⁹ Duke Energy Carolinas Response to Sierra Club 1-3 1-3f&j, CONFIDENTIAL Attachment.

1
2[illegible]3
4
56
7
8

1 **A** It is reasonable to expect there will be a small difference between marginal unit
2 costs and average unit costs based on (1) the delta between fuel and market prices
3 at the time contracts were signed and the present, as well as truly unavoidable
4 fixed/ sunk production costs. But a responsible utility manager should seek to
5 minimize the portion of average costs that falls into these categories and are
6 therefore omitted from the unit commitment process. Specifically, this can be
7 done by (1) securing fuel and transportation contracts that are flexible and have
8 minimal locked-in or must-take provisions; (2) carefully reviewing the costs of
9 fuel contracts relative to alternatives, including reduced operation and retirement
10 of the plant, prior to signing any new fuel contracts; and (3) carefully reviewing
11 O&M costs to break-out the variable costs associated with predictive and
12 preventative maintenance from those that are truly fixed.

13 **Q** **Does the analysis reflected in Table 2 represent the total costs incurred by**
14 **ratepayers as a result of DEC operating and maintaining its coal plants?**

15 **A** No. The monthly Average Cost of Generation displayed in Table 2 was provided
16 by the Company and is composed of actual fuel and variable operating expenses,
17 and excludes from consideration any of the large fixed costs of maintaining those
18 units which are passed on to customers. These costs are not the same as those used
19 by the Company for the purpose of making unit commitment decisions. As I will
20 discuss in depth in section 5, there is a significant and unexplained discrepancy
21 between the average production costs DEC seeks to pass on to ratepayers in this

1 docket and the marginal production costs DEC uses to make unit commitment and
2 dispatch decisions.

3 The data in Table 2 simply show whether the units pass the lowest bar of
4 providing value to ratepayers on an hourly basis. It says nothing about whether
5 the plant is the lowest-cost resource available to serve customer load (relative to
6 alternatives) based on the full forward-going costs (both fixed and variable)
7 required to keep the plant operational. A full unit economic analysis of this type
8 was presented by my colleague Rachel Wilson in Docket No. E-7, Sub 1214.

9 **Q Do the coal units “pass the lowest bar of providing value to ratepayers on an**
10 **hourly basis”?**

11 **A** According to the values reported by the Company, no.

12 **Q How do the fuel costs at DEC’s coal units compare to those of other coal**
13 **plants across the country?**

14 **A** Allen, Marshall, Cliffside and Belews Creek have some of the highest fuel costs
15 among coal plants in the country.¹⁰ Specifically, as shown in Table 3, the coal used
16 at Allen, Belews Creek, Marshall and Cliffside cost between \$2.38/MMBtu and
17 \$2.81/MMBtu during the 2020. This puts these plants in the 75th to 90th percentile
18 of most expensive solid fuel in the country. Allen, for example, has a fuel cost

¹⁰ Author’s calculation from EIA Form 923, 2020.

higher than 90 percent of comparable coal plants nationwide. Even the DEC coal plant with the lowest fuel cost in this analysis, Cliffside, is more expensive than 75 percent of comparable plants nationwide.¹¹

Table 3: DEC's coal unit costs relative to other solid-fuel plants in the U.S. in 2020

Plant	Fuel Cost (\$/MMBtu)	Percentile of most expensive solid-fuel plants
Allen	\$2.81	90%
Belews Creek	\$2.68	86%
Marshall	\$2.52	81%
Cliffside	\$2.38	75%

Source: EIA Form 923 for 2020.

5. DEC EXCLUDED OVER 40 PERCENT OF THE PRODUCTION COSTS INCURRED AT ITS COAL UNITS FROM ITS UNIT COMMITMENT AND DISPATCH DECISION-MAKING PROCESS

Q Please summarize this section.

A In this section I review the production costs that DEC seeks to pass on to ratepayers, the marginal production costs DEC models in making its daily unit commitment and dispatch decisions, and DEC's marginal system cost. I find that DEC excluded a significant portion of its production costs from its unit commitment decisions, and the justifications provided by the Company only explain a small portion of the omitted costs.

¹¹ EIA Form 923, 2020.

1 **Q Do you have any concerns with the unit-commitment data DEC has**
2 **provided?**

3 **A** Yes, DEC appears to be excluding a significant portion of its actual fuel and
4 variable operating costs from the marginal cost of production that it uses to make
5 its unit-commitment decisions. Specifically, the Company's reported marginal
6 cost of production omits over 40 percent of actual production costs incurred at its
7 coal plants.¹²

8 The Company's marginal fuel costs represent the cost DEC would pay
9 today to replace the fuel that it burns. DEC calculates the replacement cost of coal
10 based on "[REDACTED]"

11 [REDACTED]
12 [REDACTED] 13

13 Actual fuel costs, however, represent the cost of the fuel that DEC actually uses
14 for generation at each plant. The Company seeks to recover actual fuel expenses
15 from ratepayers in this docket.

16 As shown in Table 4 below, in 2020 DEC incurred ~~\$558~~ \$597 million in
17 fuel and other production costs operating its coal fleet. But only \$333 million in

¹² Analysis based on data from Duke Energy Carolinas Response to Sierra Club Request 1-3(a) CONFIDENTIAL 2021 SCDR 1.3a_d_e_j DEC Coal Unit Fuel Detail; Duke Energy Carolinas Response to Sierra Club request 1-3(b), CONFIDENTIAL 2021 SCDR 1.3b DEC INCDEC Prices; and Duke Energy Carolinas Response to Sierra Club Request 1-3(f) CONFIDENTIAL 2021 SCDR 1.3f_j.

¹³ Duke Energy Carolinas Response to Sierra Club Request CONFIDENTIAL 1-17.

1 variable fuel and other operating costs were included in the Company's unit
2 commitment and dispatch modeling. This means that a full 40 percent of the
3 Company's production costs, equaling ~~\$225~~ \$263 million, were excluded from
4 DEC's unit commitment and dispatch decision-making processes. As a result,
5 Duke's unit commitment modeling showed that its fleet provided a value of
6 almost \$31 million in production costs to its ratepayers in 2020, but in fact the
7 Company actually incurred ~~\$194~~ \$233 million in excess production costs relative
8 to system lambda in 2020. Of that total, approximately 95 percent, or ~~\$184.5~~ \$221
9 million, represents fuel costs.

Table 4: Total Production Costs incurred by DEC's Coal Fleet in 2020
(\$Million)

Cost Description	(\$Million)	Source
a. Production costs passed on to ratepayers	\$558 <u>\$597</u>	Average Cost of Generation from DEC in SC 1.3(f)&(j)
b. Unit variable costs used by DEC for the purpose of making unit commitment and dispatch decisions	\$333	Modeled unit variable costs from DEC in SC 1.3(a)
c. Total cost of serving load met by coal units at System Lambda	\$364	System lambda from DEC in SC 1.3(b) x generation from SC 1.3(a)
e. Cost of generation omitted from DEC's unit commitment and dispatch decision-making process	(\$225) <u>(\$263)</u>	(b) - (a)
d. Difference between system lambda and DEC's incomplete modeled unit production costs	\$31	(c) - (b)
f. Actual operational losses incurred by DEC and passed on to ratepayers from operating its coal fleet in 2020	(\$194) <u>(\$233)</u>	(c) - (a)

Source: DEC Response to Sierra Club Request 1-3(a), CONFIDENTIAL 2021 SCDR 1.3a_d_e_j DEC Coal Unit Fuel Detail; DEC Response to Sierra Club request 1-3(b), CONFIDENTIAL 2021 SCDR 1.3b DEC INCDEC Prices; DEC Response to Sierra Club Request 1-3(f) CONFIDENTIAL 2021 SCDR 1.3f_j. Disclosed publicly with agreement of DEC counsel.

Q How does this discrepancy in reported fuel costs impact the Company's unit-commitment decision-making?

A As discussed above, DEC makes unit commitment decisions based on each unit's marginal production cost, also known as the incremental operating costs. Lower operating costs therefore put the unit lower on the supply curve and make it more likely that a unit will be committed. If the marginal production costs used for making unit-commitment decisions and market offer curves represent only a

1 portion of the actual cost of fuel, then a unit will appear more economic than it
2 actually is, and the unit will be over-committed and over-dispatched as a result.

3 Full (actual) fuel costs are still typically passed on to ratepayers either
4 through the fuel charge adjustment process or through base rates (for the non-fuel
5 variable component), regardless of what cost is used to make unit-commitment
6 decisions. But these costs will be higher than if the plant was committed and
7 operated based on its actual fuel cost. For this reason, the Commission should be
8 concerned about which fuel costs the Company is using for different purposes and
9 how those costs are calculated.

10 **Q What accounts for the difference between DEC marginal and actual fuel**
11 **costs at its coal plants?**

12 **A** DEC provided several explanations for why certain of its operational costs are
13 considered fixed and therefore excluded from its unit commitment decision-
14 making process. But none of the Company's explanations account for the sheer
15 magnitude of costs \$225 million in costs excluded from its commitment
16 modeling.

17 First, DEC indicated that its current rail transportation contracts include
18 both fixed and variable costs. The fixed cost component is considered by DEC to

1 be sunk and therefore excluded from its unit commitment decisions.¹⁴ But, fixed
2 transportation costs accounted for only 0.2 percent of total fuel costs incurred in
3 December 2020, according to the Company's December 2020 fuel report.¹⁵ The
4 Company indicated that in the contract it is about to sign, these rail costs will
5 instead be fully variable. While in theory, accounting for these rail costs as
6 variable will increase the marginal production cost of DEC's units slightly, closing
7 the gap between the units marginal and actual production costs, and making
8 alternatives even more attractive, in reality these costs have only a small impact
9 on total production cost.

10 Second, the incremental cost of fuel DEC models represents the
11 replacement cost of fuel, not the cost the Company has paid for its current fuel
12 supply. But, because DEC utilized a fuel procurement strategy that relied on
13 relatively flexible and short-term coal purchases this delta should be minimized.
14 Indeed, in 2020, just over [REDACTED] of DEC's coal supply came from contracts
15 of two years or fewer.¹⁶ With short-term and spot contracts, the coal price in the
16 contract and the replacement price the Company would pay on the spot market
17 should not differ significantly. Additionally, with short-term and spot contracts,

¹⁴ Duke Energy Carolinas Response to Sierra Club Request 1-22.

¹⁵ Exhibit 6, Schedule 7 to Duke Energy Carolinas Application in Docket No. E-7, Sub 1250.

¹⁶ Duke Energy Carolinas Response to Sierra Club Request 1-18, CONFIDENTIAL Coal Supply Summary attachment.

1 the Company has more flexibility to adjust its purchase based on need (compared
2 with long-term contracts that tend to contain a minimum annual take). Short-term
3 contracts should not lock ratepayers into significant fixed costs.

4 Third, DEC selected a buy-out option for some of its coal contracts instead
5 of accepting delivery of the fuel and running the units for the purpose of burning
6 off the coal. The Company's own analysis indicated that this option was projected
7 to save ratepayers \$22 million in 2020.¹⁷ The \$24.8 million in costs associated
8 with this buy-out are also included in the fuel costs passed on to ratepayers.^{18,19}

9 **Q How would DEC's system be impacted if the Company updated its marginal**
10 **production costs to include underrepresented costs?**

11 **A** If DEC updated its marginal costs to represent a larger portion of the production
12 cost of each unit, its coal units would shift higher on the supply stack. This would
13 make alternative resources more cost-competitive on an operational basis. As a
14 result, the output of DEC's coal-fired units would be expected to decrease
15 substantially. System lambdas would also likely increase, to more accurately
16 reflect the true system lambda. This increase in system lambdas may lead to an
17 increase in the valuation of alternative new resources.

¹⁷ Direct Testimony of J. Verderame, Page 6.

¹⁸ Duke Energy Carolinas Response to Sierra Club Request 1-21, 2021 DEC PS DR 3-1d
CONFIDENTIAL Carolinas Decrement Analysis Documents.

¹⁹ Direct Testimony of J. Verderame, Page 5.

1 **6. DEC INCURRED \$8.5 MILLION IN AVOIDABLE UNIT COSTS AT ITS COAL PLANTS AS A**
2 **RESULT OF UNECONOMIC UNIT COMMITMENT DECISIONS.**

3 **Q Please summarize this section.**

4 **A** In this section I review the marginal cost of production that DEC uses for the
5 purposes of making unit commitment and dispatch decisions. I find that, even
6 with DEC modeling marginal costs that omit over 40 percent of its actual variable
7 production costs, DEC still incurred nearly \$8.5 million in avoidable operational
8 costs at its coal plants during these months as a result of these uneconomic unit
9 commitment practices.

10 **Q How does the analysis in this section differ from the analysis presented in**
11 **section 4 above?**

12 **A** In Section 4, I present analysis on how DEC's units *actually* performed during the
13 test year period using data available after the fact (*i.e.*, the average cost of
14 generation²⁰ that DEC incurred by operating its coal units uneconomically rather
15 than turning them off). I show the total excess costs that DEC seeks to pass on to
16 ratepayers during the months where the units average production costs exceeded
17 the average system lambda.²¹

²⁰ This number is slightly higher than the [REDACTED] million contract-buy out cost calculated by DEC on Duke Energy Carolinas Response to Sierra Club 1-3 1-3f&j CONFIDENTIAL Attachment.

²¹ Duke Energy Carolinas Response to Sierra Club 1-3b, CONFIDENTIAL 2021 SCDR 1.3b DEC INCDEC.

1 In contrast, in this section, I evaluate the hourly data, projections, and
2 analysis that DEC modeled to inform its unit commitment decisions.²² I identify
3 the periods of time when the Company projected it would incur operational costs
4 in excess of the system marginal cost²³ by operating its units, but yet still opted to
5 operate its coal units and then predictably incurred significant net losses. I then
6 calculate the excess costs that DEC seeks to pass on to ratepayers.

7 In this section I am relying on DEC's characterization of its marginal cost
8 of production at its coal plants, which as I note above are far lower than—its
9 average costs of production. Even relying on the company's characterization of
10 marginal costs of production, I still find that the Company self-commits its coal
11 units out of merit on a regular basis.

12 **Q What does it mean to operate a unit “out of merit” or “uneconomically”?**

13 **A** When a utility operates a unit without regard for the unit's marginal cost, the unit
14 is said to be committed “out of merit” order. This is generally done by the utility
15 applying a “must-run” status to the unit, thereby forcing the unit to operate with a
16 power output no less than its minimum operating level—no matter how the unit's
17 operating economics compare to that of other units on the utility's system.

²² DEC Response to Sierra Club Request 1-3(a), CONFIDENTIAL 2021 SCDR 1.3a_d_e_j DEC Coal Unit Fuel Detail; DEC Response to Sierra Club request 1-3(b), CONFIDENTIAL 2021 SCDR 1.3b DEC INCDEC Prices.

²³ DEC Response to Sierra Club request 1-3(b), CONFIDENTIAL 2021 SCDR 1.3b DEC INCDEC Prices.

1 Ratepayers incur the fuel and variable costs to operate the unit, regardless of
2 whether there were lower cost resource options available to meet system needs.

3 This practice is common among investor-owned utilities, such as DEC,
4 that are able to pass fuel costs directly on to ratepayers. It is much less common
5 among merchant plants / independent power producers that operate within
6 organized wholesale markets.²⁴ These operators rely entirely on market revenues
7 to cover their units' operating and fixed costs. This provides a strong incentive to
8 them to only commit their units when the market will cover the unit's operating
9 costs.

10 **Q How does DEC operate its system?**

11 **A** DEC operates its system with Duke Energy Progress based on the terms of a Joint
12 Dispatch Agreement.²⁵ The Fuels and Systems Optimization Portfolio
13 Management group (Unit Commitment) is responsible for developing a unit
14 commitment plan (that is deciding which units to turn on or keep online). The
15 Energy Control Center (ECC) is responsible for operating and economically

²⁴ See, for example, *Playing with Other People's Money*. Sierra Club, October 2019.
Accessible at
<https://www.sierraclub.org/sites/www.sierraclub.org/files/Other%20Peoples%20Money%20Non-Economic%20Dispatch%20Paper%20Oct%202019.pdf>.

²⁵ Duke Energy Carolinas Response to Sierra Club Request 1-28, Attachment SC 1.28.

1 dispatching the Company's generation resources.²⁶ In deciding which units to
2 commit and dispatch, the Company calculates the marginal production cost for
3 each unit based on the market replacement cost of fuel, reagents/byproduct costs,
4 emissions, and other variable O&M costs incurred at that particular unit.²⁷

5 **Q What tools does DEC have to inform its unit-commitment decisions?**

6 **A** DEC conducts cost-based forward-looking analysis everyday using a unit
7 commitment modeling software called GenTrader.²⁸ Forecasted customer
8 demand, fuel and emission market prices, contractual obligations, unit costs and
9 parameters, and planned unit outage information are all input into the model. The
10 model outputs "a unit commitment plan that is utilized to dispatch the generation
11 fleet to minimize production costs while ensuring reliability over the 7-day
12 forecast period."²⁹ The Company adjusts the analysis throughout the day as
13 needed. I will refer to this analysis as the "7-day forecast."³⁰

²⁶ Duke Energy Carolinas Response to Sierra Club Request 1-5.

²⁷ Duke Energy Carolinas Response to Sierra Club Request 1-8.

²⁸ *Id.*

²⁹ Duke Energy Carolinas Response to Sierra Club Request 1-9.

³⁰ In Indiana, Duke Energy produces a 7-day forecast known as the P&L or Profit and Loss Analysis.

1 **Q** **How should DEC be using the results of its cost-based analysis to inform**
2 **unit-commitment decisions?**

3 **A** Except in the case of unit testing or other extenuating circumstances, DEC should
4 elect to commit its units only if it expects the unit to operate at below system
5 lambda over a reasonable near-term time period (the Company's 7-day forecast
6 period would be a reasonable time-period), incorporating consideration of
7 reliability, start-up and shut-down costs and times. Conversely, the Company
8 should take a unit offline if the Company projects it will operate at a cost that
9 exceeds system lambda. Operating the units otherwise would predictably result in
10 higher costs that could have been avoided. Therefore, the Company should
11 document any deviations between its final commitment decision and the decision
12 based on its 7-day forecast.

13 **Q** **Should a utility always commit its units to minimize costs to ratepayers based**
14 **purely on the basis of marginal costs?**

15 **A** Not necessarily. There are certainly circumstances, although limited, in which a
16 unit needs to be operated out of merit. For example, units sometimes need to be
17 brought or kept online for testing purposes or in anticipation of a reliability need.
18 These decisions may be made regardless of costs. Aside from these exceptions,
19 utilities are expected to use accurate cost information and robust processes to
20 make commitment decisions, but they are not expected to never operate a unit
21 uneconomically or to always be right based on perfect hindsight.

1 First, given the inflexibility of coal units, it can sometimes make sense to
2 leave a unit online for short periods of time, even when there are lower cost
3 resources available, in order to be available to provide electricity during hours of
4 high demand. But even so, the unit must be projected to be economic overall
5 across a multi-day or week period of time.

6 Second, if system demand or the availability (or cost) of alternative energy
7 opportunities differs significantly from what the utility projected, the utility's
8 commitment decisions may not minimize costs to ratepayers during a multi-day
9 period. If the utility's own contemporaneous analysis indicated that operating the
10 unit would minimize costs, it is not necessarily an imprudent decision. But, if the
11 high costs are part of a pattern in which the utility is consistently and
12 systematically wrong and has neglected to modify its decision-making process,
13 the entire process may not be robust or prudent. The accuracy of the utility's daily
14 unit-commitment decision-making process should itself be a feedback into its
15 decision-making process, with modifications incorporated when the current
16 process is falling short.

17 **Q Why is it concerning that DEC is self-committing its coal units out of merit**
18 **order so frequently?**

19 **A** Operating units out of merit order incurs unnecessary fuel and variable
20 operational costs that are passed on to ratepayers. These costs are likely avoidable
21 if the units were instead committed and dispatched based on economics.

1 In addition, when a unit is committed out of merit, it shows up on the
2 supply curve as a zero- or low-cost resource, but ratepayers still incur the full cost
3 to operate the resources. By artificially cutting the line, and showing up as a zero-
4 or low-cost resource, these out of merit coal units displace lower cost resources
5 that were previously below the margin. This has a price suppressive effect, and
6 results in a system lambda that is below the marginal cost of energy on DEC's
7 system. The coal unit is still operating above system lambda and those full unit
8 costs are being passed on to ratepayers. Beyond the direct ratepayer impact, this
9 has important implications for how avoided costs are calculated.

10 **Q Why is it notable that DEC incurred costs in excess of system lambda at**
11 **many of its units over many months during the test year period?**

12 **A** As discussed above, it is understandable that DEC may incur operational costs in
13 excess of system marginal costs on a daily or even weekly basis as a result of the
14 longer start-up and shut-down costs associated with coal units. These units may
15 accept a "loss" in a few hours of the day or week in order to be online during peak
16 hours. But it is not reasonable or prudent for DEC to operate a unit at a cost that
17 exceeds the system marginal cost over a sustained period of time. Excess costs
18 incurred as a result of this operational decision are avoidable through better unit-
19 commitment decisions and indicate that DEC is either (1) not using robust and
20 complete input data to inform its unit-commitment decisions, or (2) ignoring the
21 results of its unit-commitment analysis.

1 **Q Did you identify avoidable losses based on your analysis?**

2 **A Yes, as shown in Table 5, I find that in 2020, DEC could have avoided at least**
3 \$8.5 million in operational costs at its coal plants if the Company had made better
4 unit-commitment decisions. Specifically, these are the costs that are avoidable if
5 DEC had turned its coal units off in the months when each unit’s production costs
6 exceeded the system’s marginal cost and instead used its lower cost resources to
7 meet system needs.

Table 5: Operational costs in excess of system lambda (\$Million)

Plant	Avoidable Operational Costs (\$000)
Allen 1	
Allen 2	
Allen 3	
Allen 4	
Allen 5	
Belews Creek 1	
Belews Creek 2	
Cliffside 5	
Cliffside 6	
Marshall 1	
Marshall 2	
Marshall 3	
Marshall 4	
Total	\$(8,463)

Source: DEC Response to Sierra Club Request 1-3(a), CONFIDENTIAL 2021 SCDR 1.3a_d_e_j DEC Coal Unit Fuel Detail; DEC Response to Sierra Club request 1-3(b), CONFIDENTIAL 2021 SCDR 1.3b DEC INCDEC Prices.

Confidential Exhibit DG-2 shows the monthly break-down, by unit, of monthly production costs relative to system lambda. In the months where the values are positive, the unit on net has a lower production cost than the marginal system cost. In months where the values are negative, the unit on net has a higher production cost than the system marginal cost.

1 **Q** **What evidence do you have that the costs incurred during the months in 2020**
2 **when unit costs exceeded system marginal costs are avoidable?**

3 **A** DEC provided hourly data with “modeled” unit costs and load and actual system
4 lambdas. Although the modeling occurs after the fact,³¹ the modeled costs
5 represent the cost information that the Company had at the time it made its units
6 commitment and dispatch decisions. Any time the unit costs were projected to
7 exceed system lambda (inclusive of start-up cost considerations) over a multi-day
8 stretch, a responsible utility manager would reduce costs to ratepayers if the units
9 were shut down.

10 We asked multiple times for the contemporaneous documentation that
11 DEC produced at the time that they made their daily unit commitment decisions,
12 but they only provided the loading reports, not their 7-day forecast sheets.³²
13 Without the contemporaneous documentation, the Commission will lack critical
14 information to assess the reasonableness and prudence of the Company’s daily
15 unit commitment decisions.

³¹ Duke Energy Carolinas Response to Sierra Club Request 3-2.

³² Duke Energy Carolinas Response to Sierra Club 1-9(b); Duke Energy Carolinas Response to Sierra Club Request 3-1.

1 **7. RECOMMENDATIONS FOR THE COMMISSION**

2 **Q Please summarize your recommendations.**

3 **A I recommend that the Commission examine closely DEC's production cost**
4 accounting, its unit commitment process that relies on its production costs, and
5 the operational decisions and incurred costs that result, and carefully scrutinize
6 these costs for potential disallowance in future proceedings.

7 **Q What do you recommend to address the discrepancy in production costs used**
8 **to make unit commitment decision and the actual costs passed on to**
9 **ratepayers?**

10 **A DEC's should be required to provide full transparency into the Company's**
11 marginal and average production costs. Specifically, DEC should provide a full
12 breakdown of the following, accompanied by a detailed explanation of each and
13 full work papers that show how each component was calculated:

- 14 1. Full production cost of each unit that will be passed on to ratepayers in
15 this docket, broken down by the following categories:
- 16 a. Fixed costs
 - 17 b. Variable costs
 - 18 i. Fuel
 - 19 ii. Reagents/ by products
 - 20 iii. Emissions
 - 21 iv. Variable O&M.

1 2. Marginal production cost of each unit used for making unit commitment
2 and dispatch decisions, broken down by the same components listed
3 directly above. For any items not included in DEC marginal production
4 costs, the Company should provide a detailed justification for why these
5 costs are not relevant for making unit commitment decisions.

6 **Q What information do you specifically recommend that DEC provide in each**
7 **fuel cost adjustment filing to allow a review of the prudence of its unit-**
8 **commitment practices?**

9 **A The utility filings in this docket are insufficient and do not meet the filing**
10 requirements for this proceeding outlined in Commission Rule R8-55(e).³³ I
11 recommend that DEC compile and file as workpapers with its annual fuel cost
12 adjustment application a detailed report describing its daily unit-commitment
13 decisions and practices as part of future fuel charge adjustment proceedings. DEC
14 should provide the following information as part of each annual fuel charge
15 adjustment application, to inform the Commission's review of its unit-
16 commitment practices and determination whether DEC's fuel- and fuel-related
17 costs for those units were reasonably and prudently incurred:

18 a. All 7-day forecast sheets used to develop the Company's daily
19 unit-commitment decisions and marginal cost.

³³ NCUC Rule R8-55(e).

- 1 b. The reason for any deviation between the commitment decision
2 suggested by the Company’s forward-looking price-based analysis
3 and the Company’s actual commitment decision (e.g., where the
4 Company’s analysis suggests that a unit has a production cost
5 above the marginal system cost during a given day, and the
6 Company self-commits the unit anyway).
- 7 c. Hourly data sufficient for the Commission to calculate the net
8 value or excess costs that each plant actually incurred in each test
9 year period, including total unit generation, delivered fuel cost,
10 marginal or “replacement” fuel cost, total variable operations and
11 maintenance (“O&M”) cost, system lambdas, day-ahead
12 commitment status, and actual outages.

13 **Q What other recommendations do you have for the Commission?**

14 **A**I recommend that the Commission direct DEC to conduct a new retirement study
15 of each unit in the Company’s fleet. I acknowledge that the Company conducted
16 retirement analyses for its 2020 Integrated Resource Plans at the direction of the
17 Commission. However, DEC should be required to evaluate the continued
18 operation of each of its coal units based on economics, from both a short-term
19 operational, and long-term planning perspective.

1 **Q** **Are you recommending a disallowance in this docket relating to DEC's**
2 **uneconomic commitment practices at any of its coal units?**

3 **A** Not at this time. As discussed in Section 6, \$8.5 million represents the net
4 operational losses that DEC incurred at its coal units as a result of sustained
5 uneconomic operations during specific months. These losses could have been
6 avoided, had the Company economically committed its coal units. While I am not
7 recommending a disallowance at this time, I do recommend that the Commission
8 direct DEC to evaluate the economics of continuing to maintain and operate the
9 units relative to alternative resources to meet system capacity and energy needs
10 while maintaining reliability.

11 **Q** **Does this conclude your testimony?**

12 **A** Yes.

CERTIFICATE OF SERVICE

I certify that the parties of record on the service list who have signed a confidentiality agreement have been served with the Direct Testimony of Devi Glick –*Confidential Version* on behalf of the Sierra Club either by electronic mail or by deposit in the U.S. Mail, postage prepaid.

This the 1st day of June, 2021.

s/ Gudrun Thompson

Direct Testimony of Devi Glick – Sierra Club
NCUC Docket E-7, Sub 1250