Duke Energy Carolinas, LLC Docket No. E-7, Sub 1276 Guyton Direct Exhibit 6 Distribution Program Summaries

Table of Contents

Capacity	3
Distribution Automation	7
Distribution Hardening & Resiliency: Laterals	12
Distribution Hardening & Resiliency: Public Interference	15
Distribution Hardening & Resiliency: Storm	18
Energy Storage	22
Hazard Tree Removal Program	25
Infrastructure Integrity	28
Integrated Volt VAR Control (IVVC)	31
Long Duration Interruption	35
Self-Optimizing Grid	38
Targeted Undergrounding	44
Voltage Regulation & Management	47

Capacity

Program purpose

Capacity upgrades and improvements enhance reliability of service for our new and existing customers, and support load growth from traditional loads. Additionally, the upgrades support transportation electrification and integration of distributed energy resources (DERs), such as rooftop solar and battery storage.

Timeline for construction

Refer to the MYRP Project List for project-specific timelines. At the program level, construction is planned from December 2020 to December 2026.

Estimated in-service date

Refer to the MYRP Project List for project-specific dates. At the program level, individual location inservice dates range from January 2024 to December 2026.

Program description

Capacity work is driven by customer load growth, including the expansion of electric vehicles and other distributed technologies.

Retail substation upgrades focus on work needed within the retail substations that serve distribution customers. Work includes installation of transformers, substation upgrades, and extension of transmission lines to new substation property. Improvements like transformer upgrades increase the capacity available at that substation to meet current and future customer demand for electricity.

Distribution system capacity upgrades focus on work needed to add capacity on distribution lines. Improvements include new distribution lines and equipment (e.g., regulators, reclosers) or upgrades to existing equipment to increase the maximum current that can be delivered. The use of advanced data analysis, like Morecast and the Advanced Distribution Planning (ADP) toolsets, help to forecast locations where capacity upgrades are most needed. As demand for electricity increases, either from customer growth or installation of large quantities of distributed energy resources, it increases pressure on the system from the points of use upstream to the substation. Upgrading the lines to a larger conductor by replacing conductors, adding a new circuit, or transferring some load to an adjacent circuit, can help better distribute electricity and provide a reliable experience for all customer needs. This improvement program will drive planners to choose the best and most cost-effective solution for targeted line upgrades to enable sustainable customer load growth and expansion of distributed resources.

The picture below represents an actual retail substation. It acts as the interconnection between the transmission and distribution systems.





The picture above represents an actual distribution line. These lines take the power from the substations and deliver it to our customers as well as enable two-way power flow to support DERs.

Projected costs (including capital and O&M expenditure)

DEC NC	Jan '24-Dec '24	Jan '25-Dec '25	Jan '26-Dec '26	Total
Capital Costs	\$157.4M	\$205.9M	\$164.5M	\$527.8M
O&M Costs (installation	\$3.1M	\$2.6M	\$2.5M	\$8.2M
only)				

Grid capabilities enabled		Н	3951 Poli	cy Considerations	addressed
Address changing custome equipping circuits with the meet increasing load Promote DER adoption by power flow	capacity needed	•	and sto Encourse Encourse includire Promote electrice Mainta	ages DERs ages beneficial ele ng electric vehicles es resilience and s	ectrification, s security of the

Capacity

Customer Benefits

Is the Program required by law?

No.

Explanation of need for proposed expenditure

As customer growth expands and becomes concentrated in some areas, it is important that we ensure our system is ready to support that growth. In addition, the expansion of distributed technologies like battery storage and electric vehicle charging will add increased demands on lines and equipment that are nearing capacity or that were not built with these technologies in mind. Expanding the capacity of the lines and substations, and in some cases, distributing load to other lines can help support growth and expand distributed technologies while maintaining high reliability for new and existing customers.

Benefits created for customers	
Benefit	Description
Improved reliability	Reduce potential outages due to overloaded conductors and equipment associated with DER penetration and customer load growth. Upgrades will also help improve resiliency by allowing for additional switching scenarios to address outages and high demand scenarios.
Improved resiliency	Higher capacity lines improve voltage quality and make it easier to troubleshoot outages and restore service. Additional capacity and connectivity can also support self-healing networks in the area to lessen the duration and impact of outages on the system.
Expand solar and renewables	Strategically upgrading capacity supports more efficient DER connections.

Distribution Automation

Program purpose

The Distribution Automation program focuses on modernizing single use fuses with devices capable of intelligently resetting themselves for reuse, restoring power faster for customers and eliminating unnecessary use of resources (labor, fuel, inventory, etc.) to reset them. The program seeks to improve reliability and minimize customer interruption when an outage occurs, turning what would have been a sustained outage into a momentary blink.

Timeline for construction

Refer to the MYRP Project List for project-specific timelines. At the program level, construction is planned from December 2020 to December 2026.

Estimated in-service date

Refer to the MYRP Project List for project-specific dates. At the program level, individual location inservice dates range from January 2024 to December 2026.

Program description

The Distribution Automation program replaces single use fuses on a distribution line with automated lateral devices, which effectively operate comparable to small reclosers. Currently, distribution line fuses are designed to open in the event of a fault, resulting in a sustained outage. Line fuses are one-operation devices, meaning that once a fuse interrupts a fault, the fuse melts and must be manually replaced. Most interruptions on the distribution grid are temporary, such as a tree limb falling on a power line before falling to the ground. But due to the use of fuses, those temporary faults often become sustained outages.

The new, automated lateral device (ALD) will open during the temporary fault, but then resets and attempts to close and restore power after a short period of time. If the fault source is cleared, power is restored without manual intervention. The ALD is capable of attempting self-restoration multiple times. If the fault source is sustained, the ALD opens to protect the circuit until a manual repair can be completed to the line.

Larger reclosing devices on our lines can sense faults downstream of line fuses and typically open and reclose in an attempt to clear faults without a sustained outage. In these instances, a large portion of customers will still experience a momentary outage. By introducing the ALD, in most cases, the remaining customers on the circuit will not see a momentary outage like they typically do today. Historically, lateral devices designed to de-energize and re-energize the line to clear faults without an outage were only available in sizes designed to serve larger load segments of our distribution system. With the availability of ALDs, however, reclosing capability can be applied to smaller segments of the circuit traditionally protected by fuses.


The Fuse Replacement program focuses on segments of the distribution system where line protection is less robust and where it is likely that even a temporary fault will result in a fuse melting and a sustained outage. These upgrades will provide benefits to help reduce both sustained and momentary outages.

Figure 1: The pictures below respresent two possible ALDs that can be used in this program.



Figure 2: The schematic below represents a pre- and post-program example. Currently, when a fault occurs beyond a fuse, it's possible that the upstream reclosing device blinks affecting many customers plus the fuse melts with a sustained outage. Future state with an automated lateral device, the fault is isolated, affecting only the customers on the lateral/tap with a momentary blink in most cases.

MYRP Distribution Project Summaries Page 9 of 51



Projected costs (including capital and O&M expenditure)

DEC NC	Jan '24-Dec '24	Jan '25-Dec '25	Jan '26-Dec '26	Total
Capital costs	\$15.0M	\$8.1M	\$5.3M	\$28.4M
O&M costs	\$.3M	\$.1M	\$.1M	\$.5M
(installation only)				

Capital costs	\$15.0M	\$8.1M		\$5.3M	\$28.4M
O&M costs	\$.3M	\$.1M		\$.1M	\$.5M
(installation only)					
Grid capabilities enabl	ed		HB951 P	olicy Considerations	addressed
Reliability Improve resiliency and ability to rapid Promote DER adop consistent power fl	ly restore power tion by providing	strength	Encount include Main custo Prom	urages DERS urages beneficial ele ding electric vehicles tains adequate level mer service otes resilience and s ric grid	s of reliability and

Distribution Automation

Cost Benefit Analysis

Is the Program required by law?

No.

Explanation of need for proposed expenditure

When a fault occurs on a distribution line equipped with traditional fuse protection, the fuse activation typically results in an extended outage for customers until the fuse is manually replaced. The Fuse Replacement program modernizes single-use fuses with devices capable of intelligently resetting themselves for reuse, helping turn a sustained outage into a momentary blink. This smart technology also helps to eliminate unnecessary use of resources (labor, fuel, inventory, etc.) to reset the fuse, helping improve operational efficiency.

Financial Cost-Benefit Analy	rsis	
Total NPV Costs		\$24.9M
Total NPV Benefits		\$67.0M
Net value of Program		\$42.1M
Benefit to Cost Ratio (BCR)		2.7
Description of Benefits		
Benefit Category	Description	
Improve reliability and resiliency	Reduction in customer interruptions benefits all customers where applied, including potential critical need customers. Instead of an extended outage, customers now experience	

only a momentary outage when clearing a temporary fault.

Distribution Hardening & Resiliency: Laterals

Program purpose

This distribution work improves reliability by targeting lateral sections of an overhead power line, also known as tap lines, identified as a risk for failure, which could lead to a disruptive, unplanned outage. Identifying improvement opportunities in advance of an outage provides the opportunity to engage with customers to complete the work in a way that minimizes disruptions and strengthens the grid against unplanned interruptions of service.

Timeline for construction

Refer to the MYRP Project List for project-specific timelines. At the program level, construction is planned from December 2023 to December 2026.

Estimated in-service date

Refer to the MYRP Project List for project-specific dates. At the program level, individual location inservice dates range from January 2024 to December 2026.

Program description

This work is focused on the lateral sections, also known as tap lines, which branch from the main feeder lines and feed neighborhoods, businesses, and commercial/industrial customers. Targeted work is identified through a data-driven approach based on factors such as historical data and observed condition of the line. Risk factors that are considered when identifying candidates for this program are power lines that have a history of prior outages due to deteriorated wire, evidence of prior damage (fraying, multiple splices, pitting etc.), and small wire that has been identified with a steel core that presents a risk of deterioration.

This work includes replacing at-risk steel core conductor with new all-aluminum segments of conductor, which is extremely corrosion resistant, and increasing the size in some cases, to accommodate more load. These improvements will help to improve reliability on the line, deliver a better experience for customers and support the high level of performance needed to grow distributed technologies in the area.

Projected costs (including capital and O&M expenditure)

DEC NC	Jan '24-Dec '24	Jan '25-Dec '25	Jan '26-Dec '26	Total
Capital costs	\$70.0M	\$135.6M	\$230.9M	\$436.5M
O&M costs	\$1.3M	\$2.5M	\$4.2M	\$8.0M
(installation only)				

Grid capabilities enabled	HB951 Policy Considerations addressed	
Reliability	Maintains adequate levels of reliability and	
 Improved resiliency by increasing grid 	customer service	
strength and ability to rapidly restore power	Encourages DER	
Promote DER adoption by providing	Encourages beneficial electrification,	
consistent power flow	including electric vehicles.	

Distribution Hardening & Resiliency: (Laterals)

Cost Benefit Analysis

Is the program required by law?

No.

Explanation of need for proposed expenditure

Duke Energy has an obligation to provide reliable service to customers in every community that we serve. Proactively replacing and upgrading damaged, deteriorated, or at-risk lateral distribution lines that can lead to unplanned outages is essential for providing safe and reliable service to customers and supports the reliable expansion of distributed resources.

Financial Cost-Benefit Ana	lysis		
Total NPV Costs		\$361.5M	
Total NPV Benefits		\$898.5M	
Net value of Program		\$536.9M	
Benefit to Cost Ratio (BCR)		2.5	
Description of Benefits			
Benefit Category	Description		
Improved reliability	the size and quality of the wire. Th	Eliminate the risk of overhead conductor failures by upgrading the size and quality of the wire. This improvement will help increase reliability for customers served by the line.	
Improved resiliency	avoid outages, but also help crews these areas. Upgrades that help shor up line and tree crews sooner to help	More robust design and construction standards can help to avoid outages, but also help crews restore power faster in these areas. Upgrades that help shorten outages can also free up line and tree crews sooner to help with outage restoration in other areas. Provides a consistent power flow to support DER adoption.	
Outage cost avoidance	Fewer and shorter outages resulting work help avoid recurring trips to the power after severe weather and car crews available faster to assist with p areas.	same locations to restore a also make line and tree	
Improved customer experience	Improving the overall reliability of resiliency of the line, and decre improves the overall customer expensional environment that is more conducive to distributed technologies.	rasing restoration times rience and establishes an nore resilient and more	

Distribution Hardening & Resiliency: Public Interference

Program purpose

This distribution work improves reliability by targeting the company's most outage-prone overhead backbone power line sections that are statistically impacted most by outages and damage from vehicle accidents and other public interference events. Using advanced data analytics, design teams will identify the appropriate hardening and resiliency solution to reduce the number of outages experienced by customers.

Timeline for construction

Refer to the MYRP Project List for project-specific timelines. At the program level, construction is planned from June 2022 to December 2026.

Estimated in-service date

Refer to the MYRP Project List for project-specific dates. At the program level, individual location inservice dates range from February 2024 to December 2026.

Program description

Public interference outages, typically cars hitting overhead power line poles, are outside of the company's control. When these accidents occur, it often results in a long-duration outage due to the severity of the damage caused by the incident. Historical outage data is used to identify the locations where vehicles have been prone to strike poles.

Criteria for consideration in the selection of targeted communities include:

- Service location (i.e., lines must be located on three-phase portions of the circuit)
- Frequency of outages from vehicle accidents

Lines targeted will receive a custom solution which may include undergrounding of the overhead line, relocating the line, or changing the design of the infrastructure at the location of the repeat occurrences.

Projected costs (including capital and O&M expenditure)

DEC NC	Jan '24-Dec '24	Jan '25-Dec '25	Jan '26-Dec '26	Total
Capital costs	\$11.8M	\$39.7M	\$44.6M	\$96.1M
O&M costs	\$.2M	\$.7M	\$.8M	\$1.7M
(installation only)				

Grid capabilities enabled

consistent power flow

Improved resiliency by increasing grid

Promote DER adoption by providing

strength and ability to rapidly restore power

Reliability:

•	Maintains adequate levels of reliability and
	customer service
•	Encourages DER
•	Encourages beneficial electrification,
	including electric vehicles.
•	

HB951 Policy Considerations addressed

Distribution Hardening & Resiliency: Public Interference

Cost Benefit Analysis

Is the program required by law?

No.

Explanation of need for proposed expenditure

Duke Energy has experienced an increasing number of public interference outages in recent years in many parts of its service area. This Distribution Hardening and Resiliency program will improve overall reliability in locations proven to be vulnerable to outages caused by public interference. Addressing areas with outlier outage performance improves reliability, increases public safety, and lowers maintenance and restoration costs for all customers.

Financial Cost-Benefit Analysi	s		
Total NPV Costs		\$80.3M	
Total NPV Benefits		\$99.9M	
Net value of Program		\$19.6M	
Benefit to Cost Ratio (BCR)		1.2	
Description of Benefits			
Benefit Category	Description		
Improved reliability	A stronger grid is more resistant	to outages from public	
	interference. Reducing the risk of ou	utages on overhead lines	
	improves reliability and provides a	a better experience for	
	customers.		
Improved resiliency	More robust design and construction standards helps avoid		
	outages and reduces the need for crews to return to the same		
	outage-prone areas. Provides stable power flow to support		
	DER adoption.		
Outage cost avoidance	Fewer and shorter outages resulting from grid strengthening		
	work helps avoid recurring trips to the same locations to		
	restore power.		
Improved customer	Improving the overall reliability of	the line, increasing the	
experience	resiliency of the line, and decreasing restoration times		
	improves the overall customer exper		
	operational environment that is more	conducive to distributed	
	technologies in that area.		

Distribution Hardening & Resiliency: Storm

Program purpose

These distribution improvements strengthen the grid in areas vulnerable to severe weather, and in other high-impact areas. Assets will be engineered to better withstand high winds and impacts from snow and ice to help reduce outages and restoration time in areas prone to physical damage during severe storms. Strengthening the grid in these areas improves reliability and can also help free up resources faster to assist with outage restoration in other areas.

Timeline for construction

Refer to the MYRP Project List for project-specific timelines. At the program level, construction is planned from June 2022 to December 2026.

Estimated in-service date

Refer to the MYRP Project List for project-specific dates. At the program level, individual location in-service dates range from January 2024 to December 2026.

Program description

The distribution grid across North Carolina was historically built to withstand the typical weather types that are most commonly experienced in the state (e.g., winter storms, an occasional tropical system, summer afternoon thunderstorms). Increasingly, though, we are seeing a rise in frequency and severity of outages in many parts of the state. This trend can become even more pronounced in areas that are more exposed to these extreme conditions.

Distribution hardening and resiliency improvements are targeted to locations of the distribution grid that have been identified, through analysis of historical outage data, as being more vulnerable to outage impacts from extreme weather events. Examples are poles and wires in heavily vegetated areas that experience impacts from downed trees, or areas where an outage could potentially impact essential services or large numbers of customers for an extended period of time.

Poles and wires in these areas are being replaced with an upgraded, more robust standard that includes larger poles, shorter spans, and additional guy wiring which helps provide a hardened, more reliable grid during extreme weather events. A construction comparable to Grade B & NESC 250B-D loading for solutioning will be applied to the targeted circuit segments. The grades of construction (B/C/N) determine the different safety factors for design, with Grade B providing the highest margin of safety. For example, Grade B is required for spans crossing limited access highways, railroads, and waterways. NESC 250B-D defines required wind and ice loading for design.

DEC NC	Jan '24-Dec	Jan '25-Dec	Jan '26-Dec '26	Total
	'24	'25		
Capital costs	\$3.4M	\$16.3M	\$31.6M	\$51.3M
O&M costs	\$.06M	\$.3M	\$.6M	\$.9M
(installation only)				

Grid capabilities enabled	HB951 Policy Considerations addressed
Reliability	Promotes resilience and security of the
 Improved resiliency by increasing grid 	electric grid
strength and ability to rapidly restore	Maintains adequate levels of reliability
power	and customer service
 Promote DER adoption by providing 	Encourages DERs
consistent power flow	Encourages beneficial electrification,
	including electric vehicles

Distribution Hardening & Resiliency: Storm

Cost Benefit Analysis

Is the program required by law?

No.

Explanation of need for proposed expenditure

Storms have increased in frequency and severity over the last decade. Historical data demonstrates that some areas are more vulnerable to the impacts of outages from severe weather than others. Smart, targeted investments in these areas can help to reduce outage impacts on communities and customers in areas prone to extreme weather and keep essential services available when customers depend on them most.

Financial Cost-Benefit Analysis	
Total NPV Costs	\$41.8M
Total NPV Benefits	\$167.9M
Net value of Program	\$126.1M
Benefit to Cost Ratio (BCR)	4.0

Delient to Cost Ratio (BCR)		4.0	
Description of Benefits			
Benefit Category	Description		
Improved reliability		A stronger grid is more resistant to power outages from severe weather. This helps reduce the frequency of long-duration power outages caused by storms.	
Improved resiliency	More robust design and constructivulnerable areas can help to avoid out restore power faster in these areas. Upoutages can also free up line and tree outage restoration in other areas. Proflow to support DER adoption.	tages, but also help crews pgrades that help shorten crews sooner to help with	
Outage cost avoidance	Fewer and shorter outages resulting work helps avoid recurring trips to the power after severe weather and can crews available faster to assist with pareas.	same locations to restore also make line and tree	
Improved customer experience	Improving the overall reliability of resiliency of the line, and decreasing rethe overall customer experience and e	estoration times improves	

environment that is more resilient	and	more	conducive	to
distributed technologies in that area.				

MYRP Distribution Project Summaries

Page 21 of 51

Energy Storage

Program purpose

The Energy Storage program expands Duke Energy's fleet of flexible battery storage systems to enable cleaner energy options. It addresses existing reliability challenges on the distribution system, improving reliability and resiliency by avoiding outages and speeding restoration for groups of distribution customers or single community-critical customers. The program does so while providing benefits to the bulk electric system as it transitions from legacy generation types to more renewable resources in support of the Carbon Plan.

Timeline for construction

Refer to MYRP Project List for project-specific timelines. At the program level, construction is planned from late 2023 through September 2025.

Estimated in-service date

Refer to MYRP Project List for project-specific dates. Initial in-service is expected to occur between June 2024 and September 2025.

Program description

Projected costs (including capital and O&M expenditure)

Note: Timing for costs based on in-service dates for associated projects; capital includes contingency and AFUDC

DEC NC	Jan '24-Dec '24	Jan '25-Dec '25	Jan '26-Dec '26	Total
Reliability	\$21M	\$55M	\$0M	\$76M
Critical Customer	\$7.5M	\$0M	\$0M	\$7.5M
Total Capital costs	\$28.5M	\$55M	\$0M	\$83.5M
O&M Costs (installation	\$0M	\$0M	\$0M	\$0M
only)				

Grid capabilities enabled

Reliability

 Promote DER adoption by providing consistent power flow

Capacity

- Promote DER adoption by enabling 2-way power flow capability in more circuits
- Address changing demand by outfitting circuits with capacity to meet increasing load

Automation & Communication

 Promote DER adoption by enabling more efficient resource management

HB951 Policy Considerations addressed

- Encourages utility-scale renewable energy and storage
- Encourages DERs
- Maintains adequate levels of reliability and customer service

Energy Storage

Customer Benefits

Is the Program required by law?

Financial Cost-Renefit Analysis

No. However, standalone battery energy storage is included in the Carbon Plan's near-term action plan, as filed in compliance with the Energy Solutions for North Carolina Act.

Explanation of need for proposed expenditure

The Energy Storage program addresses long-standing reliability challenges with cost-effective applications of a maturing technology, while providing benefits to the bulk electric system without construction of new carbon-emitting resources.

Financial Cost-Benefit Analys	IS	
Total NPV Costs		\$66.8M
Total NPV Benefits \$6		
Net value of Program		(\$3.9M)
Benefit to Cost Ratio		0.94
Other Qualitative Benefits		
Benefit	Description	
Improved Reliability and Resiliency	Reliability microgrids improve service reliability, resulting in saved customer expenses such as spoiled food, lost home office productivity, lost business revenue and backup generator fuel purchase which are a direct result of unplanned utility interruptions caused by vegetation, wildlife, and vehicle accidents.	
Basic Services	Reliability microgrids include volunteer fire departments, TV broadcasting stations, cell towers, gas stations, medical practice, schools, and grocery sales. Improving reliability for these customers and reducing service outages increases the safety of the communities they serve.	
Solution Scaling	Deployment of multiple reliability microgrid projects builds confidence in microgrids as available "tools in the toolbox" for solving other/future operational and engineering challenges.	
Community Safety	Critical customer microgrids help ensure that the continuation of fundamental community services provided by organizations such as hospitals. As such, the benefits created by electric service reliability improvements are enjoyed by a	

dayton birect Exhibit o	large variety and number of customers in the utility service territory.
New Customer Solutions	By deploying early critical customer projects, Duke Energy can continue offering innovative solutions, like microgrids, as options for customers with needs for high electric service reliability and ability to share project costs and benefits.
Sustainability	Benefits to the bulk electric system such as capacity, regulation and contingency reserves have traditionally been performed by carbon-emitting generation resources. Replacing carbon-emitting resources with assets that have nearly zero direct emissions helps reduce emissions and deliver positive environmental benefits to the state.
Interconnection Study Process Improvements	Engineering assessments of the projects' impacts to the existing transmission and distribution systems are constantly being improved across the Carolinas. Challenges solved during execution of these initial projects will enable faster, more efficient, more predictable outcomes when studies are performed for future projects.
Organizational Experience (Design/Ops)	Duke Energy teams in the Carolinas have not yet operated battery energy storage projects at this scale. Battery use cases explored in the DEC MYRP energy storage portfolio will refine future ideation/construction/operation processes and enable more effective designs and more efficient operations when repeated for future similar projects.
Cost-effective implementation	Sourcing of materials and labor for battery engineering, procurement, and construction is more effective when a group of projects can be solicited rather than individual/single projects. A programmatic approach will likely result in better outcomes in terms of cost, material certainty, and schedule predictability. These outcomes can help improve service and deliver cost savings to customers.

Hazard Tree Removal Program

Program purpose

The Vegetation Management Capital Hazard Tree program identifies and takes down dead, structurally unsound, dying, diseased, leaning, or otherwise defective trees from outside the maintained right-of-way that could strike electrical lines or equipment on the distribution system. Reliability is maintained or improved by minimizing interruptions from tree-caused outages.

Timeline for construction

Refer to the MYRP Project List for project-specific timelines. At the program level, work is planned throughout the MYRP period from July 2023 to December 2026.

Estimated in-service date

Refer to the MYRP Project List for project-specific dates. At the program level, individual location inservice dates range from August 2023 to December 2026. This is based on the understanding that vegetation capital blankets are placed in service monthly.

Program description

All hazard trees are identified by a qualified Duke Energy representative per industry best management practices. Any tree found to present an *extreme risk to infrastructure and failure is imminent* is designated for immediate mitigation. A Duke Energy program manager assigns remaining identified trees to a supplier for property owner/customer notification and consent for pending work (for trees in unmaintained areas, tree mitigation may proceed if supplier made a good faith effort to contact owner but was unsuccessful). As schedule and mobilization allows, suppliers cut down trees following property owner/customer notification.

Projected costs (including capital and O&M expenditure)

DEC NC	Aug '23-Dec '24	Jan '25-Dec '25	Jan '26-Dec '26	Total
Capital costs	\$35.8M	\$21.5M	\$19.5M	\$76.8M
O&M costs	\$0	\$0	\$0	\$0
(installation only)				

Grid capabilities enabled	HB951 Policy Considerations addressed
Reliability & Resiliency	Encourages DERs
Improved reliability through a better	 Encourages beneficial electrification,
protected grid that can better resist	including electric vehicles
vegetation-based outages	 Promotes resilience and security of the
 Improved resiliency by removal of hazard 	electric grid
trees that can cause extensive damage to	Maintains adequate levels of reliability and
distribution infrastructure and result in	customer service
longer outage restorations	
Improved power flow consistency and	
efficiency through fewer vegetation-related	
outages, which supports the level of	
reliability needed to promote greater	
adoption of distributed energy resources	

Hazard Tree Removal Program

Customer Benefits

Is the Program required by law?

No.

Explanation of need for proposed expenditure

Trees are one of the leading causes of power outages, and damage to the grid from trees outside of the right-of-way can cause more frequent and longer power outages due to damage these trees can cause. The purpose of the program is to improve reliability by identifying and taking down dead, structurally unsound, dying, diseased, leaning, or otherwise defective trees from outside the maintained right-of-way that could strike electrical lines or equipment of the distribution system. Reliability is improved by minimizing interruptions from tree-caused outages.

Description of Benefits		
Benefit Category	Description	
Improve reliability and resiliency	Managing trees and other vegetation to improve reliability and make the grid more resistant to vegetation-related outages.	

Infrastructure Integrity

Program purpose

The Infrastructure Integrity program seeks to continually improve and ensure a safe and reliable electrical energy delivery system through identification and mitigation of risk factors such as end-of-service equipment, technology obsolescence, and removal of damaged inservice distribution equipment such as capacitors, regulators, reclosers, and other line equipment. Proactively identifying and planning these improvement opportunities can minimize impacts to customers, turn potential emergency outage response into a planned replacement, strengthen the overall grid against unplanned interruptions of service, and support the increased grid capabilities being implemented to promote DER adoption.

Timeline for construction

Refer to the MYRP Project List for project-specific timelines. At the program level, construction is planned from December 2020 to December 2026.

Estimated in-service date

Refer to the MYRP Project List for project-specific dates. At the program level, individual location in-service dates range from January 2024 to December 2026.

Program description

As more automation is added to the system from grid improvements to improve reliability and support DER, the historical system integrity norms are changing to consider the dependency of distribution customer reliability on two-way power flow. Programs that were historically in place to address known risk factors are now evolving to support more devices on the system, changes in device operations due to power intermittency, and newer technologies that deliver new capabilities and challenges for the grid. Examples of infrastructure integrity work include:

- Asset replacement Inspection-based programs including poles.
- Oil mitigation hydraulic-to-solid dielectric replacement, and replacement of livefront/end-of-life transformers.
- Greenhouse gas mitigation replacement of SF6 switchgear with solid dielectric.
- Technological obsolescence replacement of recloser control panels nearing end of
- System operability to serve dynamic power flows replacing non-communicating hydraulic reclosers with new remote-accessible solid dielectric units.
- Major outage root cause studies.

This work coincides with other distribution improvement work scheduled at the substation or circuit to optimize crew travel, maximize switching procedure utilization, and improve traffic control zone utilization.

Projected costs (including capital and O&M expenditure)

DEC NC	Jan '24-Dec '24	Jan '25-Dec '25	Jan '26-Dec '26	Total
Capital costs	222.9M	\$121.5M	\$103M	\$447.4M
O&M costs	\$4M	\$2.2M	\$1.9M	\$8.1M
(installation only)				

Grid capabilities enabled	HB951 Policy Considerations addressed
Reliability Improve resiliency by increasing grid strends and ability to rapidly restore power Promote DER adoption by providing consistent power flow	Encourages DERs

Infrastructure Integrity

Customer Benefits

Is the program required by law?

No.

Explanation of need for proposed expenditure

Equipment that is damaged or nearing its end of service is at a higher risk of failure that could lead to an extended power outage. Proactively upgrading or replacing at-risk distribution equipment is a key step to delivering the power quality and service that customers expect. These infrastructure integrity improvements also support changing customer expectations and will ultimately enhance access to cleaner renewable energy resources on the grid.

Benefits created for customers		
Benefit	Description	
Improved reliability	Sustaining the integrity of the infrastructure through data-informed replacements will lead to a more reliable power quality experience for customers.	
Improved resiliency	Sustaining infrastructure integrity makes it easier to troubleshoot outages and restore service quicker.	
Improve the customer experience	Coordinating infrastructure improvements with other planned work helps optimize crew travel, maximizes planned outage and switching procedures, and improves traffic control zone utilization on substation projects.	

Integrated Volt VAR Control (IVVC)

Program purpose

Integrated Volt-Var Control (IVVC) establishes control of distribution equipment in substations and on distribution lines to optimize delivery voltages and power factors on the distribution grid. DEC will dynamically operate IVVC in the form of Conservation Voltage Reduction (CVR) which reduces energy (MWh's) and saves fuel, while reducing Duke Energy's carbon footprint. By installing modern sensing and control devices, as well as integrating them into the Distribution Management System, IVVC helps improve distribution system operational efficiency.

Timeline for construction

Refer to the MYRP Project List for project-specific timelines.

At the program level, construction is planned from February 2024 to December 2026.

Estimated in-service date

Refer to MYRP Project List for project-specific dates.

At the program level, individual location in-service dates range from August 2024 to December 2026

Program description

Integrated Voltage/VAR Control (IVVC) is the coordinated control of distribution equipment in substations and on distribution lines to optimize voltages and power factors on the distribution grid. This allows the distribution system to operate as efficiently as possible without violating load and voltage constraints, while supporting the reactive power needs of the bulk power system. Historically, communication with and control of substation voltage regulation, substation capacitors, and distribution line voltage regulators on the DEC system is minimal. Additionally, distribution line capacitors have had communications, but not remote-control capabilities. The IVVC program installs communications and control infrastructure including substation voltage regulator control replacement, substation capacitor control replacement, distribution line voltage regulator control replacement, distribution line capacitor replacement, medium voltage sensors, and two-way communications implementation into these substation and distribution line devices. New distribution line voltage regulator and capacitor additions are installed where necessary. A conceptual view of IVVC is presented below in Figure 1.




Figure 1: Conceptual View of Integrated Volt/VAR Control (IVVC).

IVVC can dynamically optimize the control of substation and distribution devices, resulting in a flattening of the voltage profile across an entire circuit, starting at the substation and continuing out to the farthest endpoint on that circuit. This flattening of the voltage profile is accomplished by circuit conditioning, such as phase balancing, and by integrating substation and distribution line voltage regulators and capacitors into the Distribution Management System (DMS), with two-way communications, automating their operation. The DMS continuously monitors the conditions on the controlled circuits and maintains the desired voltage profile. Once the system is operating with a relatively flat voltage profile across an entire circuit, the resulting circuit voltage at the substation can then be operated at a lower overall level. Lowering the circuit voltage, through conservation voltage reduction (CVR), at the substation results in a reduction of system loading, creating the benefit of decreased generation. CVR supports voltage reduction and energy conservation. This provides fuel savings to customers and reduced emissions from the avoided generation.

IVVC provides increased visibility into the status and condition of substation and field devices such as capacitor banks, voltage regulators, and transformer load-tap changers. This added visibility and enhanced voltage control will help manage the integration of distributed energy resources (i.e., solar) by providing foundational capability to respond to intermittency.

DEC's 2024-2026 MYRP includes circuits that will receive both VRM and IVVC improvements. Technologies implemented in VRM further enhance IVVC by extending optimized Volt/VAR control into supporting greater DER integration. When developing IVVC/VRM scopes, DEC will make sure that IVVC and VRM circuit work is truly complementary and-not redundant. This will be accomplished by conducting the IVVC and VRM analysis sequentially and combining the implementation scopes at the circuit level.

Projected costs (including capital and O&M expenditure)

DEC NC	Jan '24-Dec '24	Jan '25-Dec '25	Jan '26-Dec '26	Total
Capital costs	\$25.5M	\$37.2M	\$33.6M	\$96.3M
O&M costs	\$.5M	\$.7M	\$.6M	\$1.8M
(installation only)				

(installation only)	
Grid capabilities enabled	HB951 Policy Considerations addressed
 More efficient grid due to lower line losses and reduced reactive power Less generation fuel consumed and lower emissions due to grid efficiencies Integrated control of capacitor banks provides greater ability to reduce reactive power, resulting in less apparent load on the system Optimized control of volt/VAR devices provides foundational capability to respond to intermittency 	 Encourages peak load reduction or efficient use of the system Encourages utility-scale renewable energy and storage Encourages DERs Encourages beneficial electrification, including electric vehicles Promotes resilience and updated security of the electric grid Maintains adequate levels of reliability and customer service

Integrated Voltage Var Control

Cost Benefit Analysis

Is the Program required by law?

No.

Explanation of need for proposed expenditure

Conservation Voltage Reduction (CVR) supports voltage reduction and energy conservation. IVVC can dynamically optimize the control of substation and distribution devices, enabling distribution system to operate in CVR mode, that results in a reduction of system loading, creating the benefit of decreased generation. This provides fuel savings to customers and reduced emissions from the avoided generation.

The IVVC program deploys technology that enables CVR mode, and installs devices that improve power quality to all customers by helping maintain voltage levels within acceptable ANSI standard voltage limitations as the load changes with future increased penetrations of DER.

Financial Cost-Benefit Analysis	
Total NPV Costs	\$540.2M
Total NPV Benefits	\$842.6M
Net value of Program	\$302.4M
Benefit to Cost Ratio (BCR)	1.6

Description of Benefits		
Benefit Category	Description	
Fuel Savings	IVVC reduces energy (MWh's) consumptions and	
	saves fuel. Fuel savings are passed directly to	
	customers.	
Carbon reduction	Lower carbon emissions from reduced generation due	
	to reduced energy (MWh's) consumption and	
	improved grid efficiencies.	
Improves voltage experience for	Integrated Volt/VAR Control maintains proper voltage	
customers	levels to customers by keeping voltages in the proper	
	range.	
Expands solar and renewables	Optimized control of Volt/VAR devices improves the	
	grid's ability to respond to intermittency	
Improve Grid Efficiency	More efficient grid due to lower line losses and	
	reduced reactive power.	
	Integrated sensing and control deployed in IVVC helps	
	improve distribution system operation efficiency.	

Long Duration Interruption

Program purpose

This distribution work relocates segments of main overhead feeder lines in hard-to-access areas to improve accessibility for utility trucks. Improving crew accessibility reduces restoration time for outages in difficult to reach areas and increases worker safety. Moving these line segments to road-accessible locations that are more easily maintained can also help reduce the risk of an outage, improving overall reliability for customers in these areas and can also help free up resources faster to assist with outage restoration in other areas.

Timeline for construction

Refer to the MYRP Project List for project-specific timelines. At the program level, construction is planned from July 2022 to December 2026.

Estimated in-service date

Refer to the MYRP Project List for project-specific dates. At the program level, individual location inservice dates range from January 2024 to December 2026.

Program description

Targeted areas for this program are radial distribution lines that serve entire communities or large groups of customers, as well as inaccessible line segments (i.e., off road, swamps, mountain gorges, extreme terrain, etc.). The areas targeted for improvement experience consistently higher-than-average outage durations and reduced power reliability and customer satisfaction. During extreme weather events, vegetation, erosion, and flooding can create challenges and potentially unsafe conditions for restoration crews trying to restore power, resulting in longer outage times. Addressing these challenges typically involves relocating the lines to road fronts which may require more line miles. Road accessibility helps improve the customer experience and provides positive benefits to the overall power restoration process as it allows more efficient access to lines and equipment from the road right of way.

Projected costs (including capital and O&M expenditure)

DEC NC	Jan '24-Dec '24	Jan '25-Dec '25	Jan '26-Dec '26	Total
Capital costs	\$6.4M	\$5.0M	\$11.7M	\$23.1M
O&M costs	\$.2M	\$.2M	\$.4M	\$.8M
(installation only)				

Grid capabilities enabled	HB951 Policy Considerations addressed
Reliability	Promotes resilience and security of the
 Improved resiliency by increasing grid 	electric grid
strength and ability to rapidly restore power	Maintains high levels of reliability and
Promote DER adoption by providing	improves customer service
consistent power flow	Encourages DERs
	Encourages beneficial electrification,
	including electric vehicles.

Long Duration Interruption

Cost Benefit Analysis

Is the program required by law?

No.

Explanation of need for proposed expenditure

Power restoration is more challenging in hard-to-reach areas when outages occur, creating a potential for longer restorations and increased outage time. Long-duration outages have a negative impact on overall system reliability and customer satisfaction. This challenge is increasingly true as more customers work and attend school remotely and rely on electricity for daily functional and productivity needs. The lines targeted for this long-duration interruption improvement are experiencing above-average outage durations that would benefit from relocating the line to an area more accessible by utility trucks and crews.

Financial Cost-Benefit Analysis		
Total NPV Costs	\$19.7M	
Total NPV Benefits		\$320.2M
Net value of Program		\$300.5M
Benefit to Cost Ratio (BCR)		16.3
Description of Benefits		
Benefit Category	Description	
Improved reliability	Strategically relocating outage-prone	e line segments to more
	accessible and maintainable locations helps reduce outage r	
Improved resilience	Relocating the feeder segment to	a more accessible and
	maintainable right of way helps impro	ove resiliency by reducing
	outages and promoting faster responses when outages	
	occur.	
Reduced outage costs	Relocating these feeder segments from hard-to-reach	
	locations to more maintainable areas	helps reduce outages and
	avoids the need for more specialized	
	and crew labor needed to repair outages.	
Improved customer Improving the overall reliability of the line, increasing the		the line, increasing the
experience resiliency of the line, and decreasing restoration times impro		•
	the overall customer experience	e and establishes an
	operational environment that is m	nore resilient and more
	conducive to distributed technologies	s in that area.

Self-Optimizing Grid

Program purpose

The Self-Optimizing Grid (SOG) program, also known as the smart-thinking grid, redesigns key portions of the distribution system and transforms it into a dynamic self-healing network to improve system reliability and resiliency, restore outages faster, and manage the dynamic two-way power flows that expansion of distributed energy resources (DER) will bring.

Timeline for construction

Refer to the MYRP Project List for project-specific timelines. At the program level, construction is planned from December 2020 to December 2026.

Estimated in-service date

Refer to the MYRP Project List for project-specific dates. At the program level, individual location inservice dates range from January 2024 to December 2026.

Program description

SOG uses self-healing technology to improve grid reliability and resiliency. To detect potential faults in real time, the system uses sensors, switches, and controls. The self-healing system can automatically detect power outages, quickly isolate the problem, and reroute power to restore service to customers as quickly as possible. This smart, self-healing technology can reduce the number of customers affected by an outage by up to 75% and can often restore power in less than a minute. This system can even detect issues before a customer reports a power outage. The SOG work executed during the three-year MYRP is expected to save annually, 127,000 customer interruptions (CI) and over 25 million customer minutes interrupted (CMI).

The SOG program converts circuits into switchable segments in order to minimize the number of customers affected by sustained outages, expands the capacity to support an integrated grid, and ensures the necessary connectivity to allow for rerouting options. The added capacity, smart switching capability, and connectivity necessary for SOG also enables the two-way power flow needed to support more rooftop solar, battery storage, electric vehicles, and microgrids technologies that will increasingly power the lives of customers and move the state of North Carolina towards a cleaner energy future for all customers.

The SOG program consists of three (3) major components: capacity, connectivity, and automation. SOG Capacity focuses on expanding substation and distribution line capacity to allow for two-way power flow. Increased line capacity through the SOG program reduces line losses and enables DER hosting capabilities. SOG Connectivity creates tie points between circuits to allow two-way power flow for automatic reconfiguration. SOG Automation provides intelligence and control for the Self-Optimizing Grid. Automation projects enable the grid to dynamically reconfigure around trouble and better manage local DER.

OFFICIAL COPY

Figure 1

Figure 1 shows a Smart Grid system that is composed of intelligent equipment, advanced communication equipment, and distributed energy resources. The figure shows two distribution circuits which are fully optimized that allow power to be fully rerouted in the event of an outage.




Figure 2


Figure 2 demonstrates how most current state circuits have line segments with a high customer count and do not have two-way power flow capabilities. Therefore, a system fault that results in an outage can impact many customers.



OFFICIAL COPY

Figure 3

Figure 3 demonstrates the future state under the SOG program in which a circuit with additional segmentation devices and interconnectivity to adjacent circuits allows the system to isolate faults to a small portion of the circuit while all other customers do not experience an outage.



Duke Energy Carolinas, LLC Docket No. E-7, Sub 1276 Guyton Direct Exhibit 6

Projected costs (including capital and O&M expenditure)

Note: Timing for costs based on in-service dates for associated projects; capital includes contingency and AFUDC

DEC NC	Jan '24-Dec '24	Jan '25-Dec '25	Jan '26-Dec '26	Total
Capital costs	\$127.8M	\$58.4M	\$84.6M	\$270.8M
O&M costs	\$1.8M	\$.8M	\$1.2M	\$3.8M
(installation only)				

(installation only)	
Grid capabilities enabled	HB951 Policy Considerations addressed
Reliability	Encourages DERs
Improve resiliency to increase grid strength	Encourages beneficial electrification,
and ability to rapidly restore power	including electric vehicles
Capacity	Promotes resilience and security of the
 Promote DER adoption by enabling 2-way 	electric grid
power flow capability in more circuits	Maintains adequate levels of reliability and
 Address changing demand by outfitting 	customer service
circuits with capacity to meet increasing load	
Automation & Communication	
Improve resiliency by detecting faults and	
rerouting power to self-heal, reducing impact	
from outages	
Promote DER adoption by enabling more	
efficient resource management	

Self-Optimizing Grid

Cost Benefit Analysis

Is the Program required by law?

No.

Explanation of need for proposed expenditure

The current grid has limited ability to reroute or rapidly restore power, and limited ability to optimize for the growing penetrations of distributed energy resources (DER). The SOG program was established to foundationally address both issues.

This smart-thinking grid technology functions as an integrated network with increased capacity, automated switching capabilities and support for two-way power flow. SOG can help to reduce outage impacts, improve reliability and resiliency, and enhance the customer experience. The deployment of SOG brings additional benefits including improved line efficiency along with DER and EV readiness.

Financial Cost-Benefit Analysis	
Total NPV Costs	\$238.4M
Total NPV Benefits	\$1,348.5M
Net value of Program	\$1,110.1M
Benefit to Cost Ratio (BCR)	5.7

Description of Benefits	
Benefit Category	Description
Improve reliability and resiliency	SOG creates a network of interconnected circuits that are split into smaller automatically switchable segments that can isolate faults and reconfigure to greatly reduce the number of customers affected by sustained outages. The program also reduces the number of outages, decreases the duration of outages when they do occur, and helps restore power in a matter of minutes.
Expand solar and renewables	SOG creates a network of interconnected circuits with more capacity and support for two-way power flow which accommodates more renewable energy resources.

Targeted Undergrounding

Program purpose

The Targeted Undergrounding (TUG) program improves reliability by strategically identifying the company's most outage prone overhead power line sections and relocating them underground to reduce the number of outages experienced by customers.

Timeline for construction

Refer to the MYRP Project List for project-specific timelines. At the program level, construction is planned from October 2021 to December 2026.

Estimated in-service date

Refer to the MYRP Project List for project-specific dates. At the program level, individual location inservice dates range from January 2024 to December 2026.

Program description

This program uses data analytics to identify overhead line segments with an unusually high frequency of historical outages and places those segments underground.

Criteria for consideration and selection of targeted communities includes:

- Performance of overhead lines
- Age of assets
- Service location (e.g., lines located in backyard where accessibility is limited)
- Vegetation impacts (e.g., heavily vegetated lines are often costly and difficult to trim)

Projected costs (including capital and O&M expenditure)

Note: Timing for costs based on in-service dates for associated projects; capital includes contingency and AFUDC

DEC NC	Jan '24-Dec '24	Jan '25-Dec '25	Jan '26-Dec '26	Total
Capital costs	\$38.4M	\$67.1M	\$88.2M	193.7M
O&M costs	\$.02M	\$.05M	\$.06M	\$.1M
(installation only)				

Grid capabilities enabled

Reliability

- Improved resiliency by increasing grid strength and ability to rapidly restore power
- Promote DER adoption by providing consistent power flow

HB951 Policy Considerations addressed

- Encourages DERs
- Encourages beneficial electrification, including electric vehicles
- Promotes resilience and security of the electric grid
- Maintains adequate levels of reliability and customer service

Targeted Undergrounding

Cost Benefit Analysis

Is the program required by law?

No.

Explanation of need for proposed expenditure

While the overall electric grid is very reliable, some segments of overhead power lines experience an unusually high number of outages, resulting in decreased customer satisfaction. When these segments of lines fail, they cause problems for customers directly served by them as well as customers upstream. Lines targeted to be moved underground are typically the most resource-intensive parts of the grid to repair after a major storm. Due to the frequent interruptions, equipment on these line segments can experience shortened equipment life and additional equipment-related service interruptions by being exposed to the frequent overcurrent from the faults.

The TUG program eliminates exposure to the elements that commonly cause outage events on the overhead portion of the grid. Converting overhead outage prone parts of the system to underground enables us to restore service more quickly and cost effectively for all customers. Addressing areas with outlier outage performance improves service while lowering maintenance and restoration costs for all customers.

Financial cost-benefit analysis	
Total NPV Costs	\$159.1M
Total NPV Benefits	\$487.0M
Net value of Program	\$327.9M
Benefit to Cost Ratio (BCR)	3.1

Description of Benefits	
Benefit Category	Description
Improved reliability	By undergrounding the overhead wires, the exposure to failures above ground will be eliminated and will lead to an improved reliability experience for customers on that line.
Improved resiliency	Improved system resiliency by reducing repeated trips to the same line segments during storms and outage events, freeing up resources faster to restore power to other customers. Provides stable flow for DER adoption.
Reduced outage costs	Overhead conductor that is converted to underground will not require vegetation maintenance costs to maintain the right of way.

Duke Energy Carolinas, LLC Docket No. E-7, Sub 1276 Guyton Direct Exhibit 6 MYRP Distribution Project Summaries Page 46 of 51

Improved customer	Improving the overall reliability of the line, increasing the
experience	resiliency of the line, and decreasing restoration times
	improves the overall customer experience and establishes an
	operational environment that is more resilient and more
	conducive to distributed technologies in that area.

Voltage Regulation & Management

Program purpose

The Voltage Regulation and Management (VRM) improvement program will modernize the grid by installing devices that will improve voltage management and power quality for all customers, while supporting the growth of distributed energy resources (DER).

Timeline for construction

Refer to the MYRP Project List for project-specific timelines.

At the program level, construction is planned from February 2024 to December 2026.

Estimated in-service date

Refer to MYRP Project List for project-specific dates.

At the program level, individual location in-service dates range from August 2024 to December 2026.

Program description

Currently, the electrical distribution systems are designed and operated based on the assumption of centralized generation, with one-way power flow from the distribution substation to end-use customers. With the increasing penetration of DERs, reverse power flow could occur through the distribution system. Significant reverse power flow may cause operational issues for the distribution system, including over-voltage on the distribution feeder.

This program establishes control of equipment on the distribution grid to optimize delivery voltages to customers and to prepare for two-way power flows on the grid. The Voltage Regulation Management (VRM) program will improve the grid's ability to address intermittency and fluctuations caused by DERs and to enable DER adoption and improve power quality to customers.

There are three levels of the VRM program that will be applied to circuits depending on the projected level of DER penetration (informed by Integrated System Operations Planning (ISOP) and Morecast data) on the circuit. These projects range from minor equipment for circuits with light forecasted DER penetration to major equipment for circuits with heavier forecasted DER penetration.

The first level will install voltage regulators on circuits, which help maintain a constant voltage level to create more "regulation zones". These zones improve the voltage management on the circuit by addressing high-end voltage conditions and reducing intermittency caused by solar DER sites. This also improves power quality for customers by maintaining voltage levels within ANSI standard voltage limits. These regulators will have new modernized microprocessor-based controls capable of two-way power flow and communications for remote monitoring, control, and data acquisition, as well as integration to the centralized Distribution Management System. The number of regulators being installed on a circuit will be proportional to the forecasted DER enablement on the circuit. For example, in Figure 1 below, two new line voltage regulators (the yellow dots) are installed to create three voltage regulation zones.




Figure 1: Illustration of voltage "Regulation Zones" on an example circuit (for conceptual purposes only).

The second level of the VRM program will install new distribution line capacitors on circuits. The capacitors will help improve voltage management and allow electricity to be distributed more efficiently across the distribution circuits by automatically adjusting the reactive power on the circuits. Capacitors complement the voltage regulators and help maintain the proper voltage levels for customers in each regulation zone. The capacitors will also be equipped with digital microprocessor-based controls capable of two-way communications to the centralized Distribution Management System. Real time communications to the capacitors will ensure the devices are operating properly under all load conditions. The controls will provide remote operation and monitoring functionality that will improve power quality to customers. Sensors will be installed at each new capacitor bank to continuously monitor the flow of power. The sensors can also provide real-time fault detection and location information.

Level 3 includes higher levels of DER penetration will require more specialized equipment like power electronic devices to handle the large and rapid voltage fluctuations that come with intermittent sunshine caused by cloud movement. These devices better equip the distribution system to manage power quality issues associated with increasing DER penetration. Power electronics devices also reduce voltage regulator and capacitor operations on a distribution circuit with high levels of DER.

The current system is limited in its ability to manage and integrate DERs. Investments in VRM will help transition the current grid to the grid of the future with two-way power flow capabilities. As distributed energy resources, such as rooftop solar and electric vehicles, reach deeper levels of penetration, it is essential to automatically manage and maintain proper voltage levels for customers. The implementation of modern, advanced voltage regulators, capacitors, and power electronic technologies based on ISOP modeling of customer DER growth enables effective voltage management under dynamic conditions and keeps pace with customer expectations.

In DEC, MYRP 2024-2026 includes circuits that will receive both VRM and IVVC improvements. Technologies implemented in VRM further enhance IVVC by extending optimized Volt/VAR control into supporting greater DER integration. When developing IVVC/VRM scopes, Duke Energy will make sure that IVVC and VRM circuit work is truly complementary and not redundant. This will be

accomplished by doing the IVVC and VRM analysis sequentially and combining the implementation scopes at the circuit level.

Projected costs (including capital and O&M expenditure)

Note: Timing for costs based on in-service dates for associated projects; capital includes contingency and AFUDC

DEC NC	Jan '24-Dec '24	Jan '25-Dec '25	Jan '26-Dec '26	Total
Capital costs	\$26.2M	\$40.6M	\$32.9M	\$99.7M
O&M costs	\$.5M	\$.8M	\$.6M	\$1.9M
(installation only)				

(moralitation of the property)	
Grid capabilities enabled	HB951 Policy Considerations addressed
 Voltage Regulation Promote DER adoption by regulating and stabilizing voltage levels to protect customers from disruptive supply spikes or sags Improve resiliency by reducing intermittency / fluctuations from DER power supply 	 Encourages peak load reduction or efficient use of the system Encourages utility-scale renewable energy and storage Encourages DERs Encourages beneficial electrification, including electric vehicles Promotes resilience and updated security of the electric grid Maintains adequate levels of reliability and customer service

Voltage Regulation & Management

Customer Benefits

Is the Program required by law?

No.

Explanation of need for proposed expenditure

Distributed Energy Resources (DER) and electric vehicles (EV) are expected to have a significant impact on the distribution system around voltage and reactive power (VAR) support. The distribution system is rapidly becoming more dynamic with two-way power flows driving the need for additional VAR and voltage management capabilities, compared to the current state.

The Voltage Regulation and Management Program will modernize the grid and improve voltage management to customers based on the predicted DER penetration for each circuit, with the goal of being proactive instead of reactive. A programmatic approach to place devices will be effective for voltage and Var support. Optimized control of Volt/Var devices improves the grid's ability to respond to intermittency. The devices installed in this program will improve power quality to all customers by helping maintain voltage levels within acceptable ANSI standard voltage limitations as the load changes with future increased penetrations of DER.

penetrations of BEIG		
Benefits created for customers		
Benefit	Description	
Improves voltage experience for	Advanced technologies help maintain proper voltage	
customers	levels to customers by keeping voltages in the proper	
	range. Additionally, integrating advanced equipment	
	on the grid helps reduce power quality issues	
	associated with increasing DER penetration.	
Expands solar and renewables	Increasing the level of distributed energy resources	
	that can be accommodated on the distribution grid	
	reduces the need to curtail or issue moratoriums on	
	customer-owned interconnections.	
Gives customers more options and	Increasing the grid's ability to integrate more	
control	renewables and electric vehicles provides customers	
	more options to meet their individual needs.	
Transforms the grid to prepare for a	Technologies that enable two-way power flows for	
cleaner, lower-carbon future	increased DER on the grid will allow more customers	
	to interconnect clean forms of renewable generation.	
	This capability helps North Carolina continue to be	

Duke Energy Carolinas, LLC Docket No. E-7, Sub 1276 Guyton Direct Exhibit 6 MYRP Distribution Project Summaries Page 51 of 51

attractive to businesses with environmental
commitments.

GUYTON DIRECT EXHIBIT 7 - OTHER PROGRAM SUMMARIES DOCKET NO. E-7, SUB 1276 Page 1 of 24



Distribution Program Summaries

Duke Energy Carolinas, LLC

Docket No. E-7, Sub 1276

GUYTON DIRECT EXHIBIT 7 - OTHER PROGRAM SUMMARIES DOCKET NO. E-7, SUB 1276 Page 2 of 24



Table of Contents

Advanced Distribution Management System (ADMS)	3
Land Mobile Radio (LMR)	7
Towers, Shelters & Power Supplies (TSPS)	10
Mission Critical Transport (MCT)	14
Corporate Facilities	<u>1</u> 7
Electrification Charging Infrastructure	22

GUYTON DIRECT EXHIBIT 7 - OTHER PROGRAM SUMMARIES DOCKET NO. E-7, SUB 1276 Page 3 of 24



Advanced Distribution Management System (ADMS)

Project purpose

The Advanced Distribution Management System (ADMS) program is deploying a single software platform that will consolidate the existing Outage Management System (OMS), Distribution Management System (DMS) and Supervisory Control and Data Acquisition (SCADA) System. The platform allows grid operators to perform control room functions from a single application rather than multiple applications from different vendors, allowing operators to monitor grid performance and manage outages from a single pane. Operators will also be able to use the consolidated platform to perform switching operations, manage Integrated Volt/Var Control (IVVC) and troubleshoot field devices. The ADMS will also provide a smart foundation that can support advanced capabilities such as Closed Loop Fault Isolation and Service Restoration (CLFISR), Advanced Fault Location (AFL), Conservation Voltage Reduction (CVR), and Distributed Energy Resources (DER) dispatch.

Timeline for construction

<u>Refer to MYRP Project List for project-specific timelines.</u> At the program level, construction is planned from July 2022 to March of 2024.

Estimated in-service date

Refer to MYRP Project List for project-specific dates. At the program level, individual location inservice dates range from December 2024 to March 2026.

Project description

The Advanced Distribution Management System (ADMS) is the centralized distribution monitoring and control system that harnesses information from across the grid to increase automation, optimize system performance and improve reliability for customers. This smart system orchestrates and manages technologies such as Self-Optimizing Grid (SOG) automation projects, smart switches, and distributed energy resources. The ADMS project consolidates existing SCADA, DMS and OMS systems into a single platform to improve operational efficiency and flexibility by standardizing grid operations, increasing situational awareness and control through real-time data from thousands of points across the grid, providing improved IT system reliability, and reducing human performance risk.


The ADMS system also provides the ability to manage voltage in near real time to optimize the grid and support the two-way power flows needed to enable more renewables and distributed resources. ADMS supports a variety of current and future capabilities, including:

Closed Loop Fault Isolation and Service Restoration (CLFISR) minimizes outage impacts by automatically identifying a fault and selecting a switching plan to isolate the fault and restore power to as many customers as possible in moments. Like other advanced applications, this self-healing

GUYTON DIRECT EXHIBIT 7 - OTHER PROGRAM SUMMARIES DOCKET NO. E-7, SUB 1276 Page 4 of 24



system relies on an accurate digital model of the grid to support analyses and quickly evaluate solutions to restore service to customers.



Distribution System Demand Response (DSDR) conversion to Continuous Voltage Reduction (CVR) mode -

In 2014, Duke Energy Progress implemented Distribution System Demand Response (DSDR) to achieve peak voltage reduction across the utility's distribution system. Because the substation, distribution, telecommunications, and IT infrastructure were put in place as part of the original DSDR implementation, the current project focuses on the distribution management upgrades required to support various operational modes, including the current DSDR mode and CVR mode, as well as Self-optimizing Grid and other distribution automation capabilities. Through this project, the company will enable an approximate 2% distribution system voltage reduction resulting in energy conservation that translates into an approximate 400,000 Mwh annual reduction.

Automatic Fault Location (AFL) uses smart devices on the grid to more precisely locate faults, such as a tree or tree limb, on a line. The project will upgrade distribution management capabilities to analyze grid device data in real time and provide more accurate fault locations to direct crews and restore power faster.

GUYTON DIRECT EXHIBIT 7 - OTHER PROGRAM SUMMARIES DOCKET NO. E-7, SUB 1276 Page 5 of 24



The DER Dispatch project will deliver new software and processes to help operators monitor and manage transmission and distribution-connected distributed resources such as solar and battery storage. Current processes and tools only provide operators with a rudimentary ability to shed large blocks of solar generation in emergency conditions to meet power control reliability standards. The proposed solution will account for energy delivered by each DER location, track curtailments, and balance energy management from these resources based on economic, contractual, and other considerations. Improving the way these resources are managed will help support more distributed resources at both the distribution and bulk power level, provide better communications to suppliers, and deliver cleaner options and lower carbon solutions to customers.

Projected costs (including capital and O&M expenditure)

Note: Timing for costs based on in-service dates for associated projects; capital includes contingency and AFUDC

DEC NC	Jan '24 - Dec '24	Jan '25 - Dec ' 25	Jan '26 - Dec '26	Total
Capital costs	\$82.6M	\$21.1M		\$103.7M
O&M costs (installation only)	\$.4M	\$.2M	-	\$.6M

Grid capabilities enabled

Reliability:

 Promote DER adoption by providing consistent power flow

Automation & Communication

- Improve resiliency by detecting faults and rerouting power to self-heal, reducing impact from outages
- Promote DER adoption by enabling more efficient resource management

Voltage Regulation

- Promote DER adoption by optimizing voltage levels to protect customers from disruptive supply spikes or sags
- Improve resiliency by reducing intermittency / fluctuations from DER power supply

Capacity

 Promote DER adoption by enabling two-way power flow capability in more circuits

HB951 Policy Considerations addressed

- Encourages peak load reduction or efficient use of the system
- Encourages utility-scale renewable energy and storage
- Encourages DERs
- Encourages beneficial electrification, including electric vehicles
- Promotes resilience and security of the electric grid
- Maintains adequate levels of reliability and customer service
- Promotes rate designs that yield peak load reduction or beneficial load-shaping

GUYTON DIRECT EXHIBIT 7 - OTHER PROGRAM SUMMARIES DOCKET NO. E-7, SUB 1276 Page 6 of 24



Advanced Distribution Management System (ADMS) Customer Benefits

Is the project / program required by law?

No

Explanation of need for proposed expenditure

Resiliency improvements and infrastructure support for cleaner energy options and distributed technology will depend heavily on smart monitoring and control technologies to support his dynamic and increasingly automated grid. The ADMS system can manage data from 1.2 million data points, analyze that data and control devices in the field to support self-healing outage restoration, manage battery storage and distributed technologies, and actively manage renewable energy systems on the grid.

The increased situational awareness and automation capabilities the ADMS brings will help to avoid or shorten outage time; locate faults and power quality issues on the system faster; better protect the grid from potential threats and suspicious activity; and enable faster responses to incidents like animal interference, cars hitting poles and other public activities.

Benefits created for customers [Describe benefits in the context of the overall filing narrative, which could include the followina]

Benefit	Description		
Improved reliability	Standardization and consolidation of the ADMS platform will drive a more consistent customer experience, improved monitoring and communications during outage events, and enable advanced capabilities like fault location and self-healing capabilities to reduce customer outage impacts.		
Voltage optimization and efficiency	DSDR/CVR Project will improve distribution voltage efficiencies and reduce overall energy consumption by customers and support better voltage quality and reliability.		
Affordability	DSDR/CVR will create power delivery efficiencies by regulating voltage at the lower end of the reliable range, which helps reduce overall consumption without sacrificing voltage quality. Reduced consumption helps lower fuel costs, which can generate savings for customers.		
Sustainable growth of renewables and distributed resources	DER dispatch tools support the increased integration of renewables and battery storage on the transmission and distribution grid, which also helps provide cleaner energy options to customers and achieve carbon reduction goals.		

GUYTON DIRECT EXHIBIT 7 - OTHER PROGRAM SUMMARIES DOCKET NO. E-7, SUB 1276 Page 7 of 24



Land Mobile Radio (LMR)

Project purpose

management and increase customer satisfaction through reliable service and restoration of power Energy region with a common enhanced, reliable, and interoperable communications system. The LMR network is a key component of Duke Energy's private communication infrastructure used by This work upgrades the existing, end-of-service Land Mobile Radio (LMR) systems in each Duke transmission and distribution teams to more effectively dispatch field resources; improve grid in a variety of operating conditions.

Timeline for construction

Refer to MYRP Project List for project-specific timelines. At the program level, construction is planned from

March 2022 - March 2025.

Estimated in-service date


Refer to MYRP Project List for project-specific dates. At the program level, individual location inservice dates range from January 2024 – December 2024.

Project description

able to control and dispatch from any location to any resource at any time during emergency type Distribution Management System (ADMS) and Distribution Control Center's (DCC) vision of being services) for field, dispatch center and grid management resources. LMR enables the Advanced The LMR network architecture provides higher resiliency and availability when other forms of communication services are challenged (e.g., commercial cellular networks and other leased of events.

GUYTON DIRECT EXHIBIT 7 - OTHER PROGRAM SUMMARIES DOCKET NO. E-7, SUB 1276 Page 8 of 24





Projected costs (including capital and O&M expenditure)

Note: Timing for costs based on in-service dates for associated projects; capital includes contingency and AFUDC

DEC NC	Jan '24 – Dec '24	Jan '25 – Dec '25	Jan '26 – Dec '26	Total
Capital costs	\$80M	-	-	\$80M
O&M costs (installation only)	-	-	-	=

Grid capabilities enabled

Reliability:

 Improved reliability and resiliency by providing a common platform and critical private communication infrastructure to dispatch crews and manage the grid to restore power faster when outages occur.

Automation & Communication

 Advanced communication capabilities to power grid improvements and system that enable and promote efficient management of distributed energy resources.

HB951 Policy Considerations addressed

- Promotes resilience and security of the electric grid
- Maintains adequate levels of reliability and customer service

GUYTON DIRECT EXHIBIT 7 - OTHER PROGRAM SUMMARIES DOCKET NO. E-7, SUB 1276 Page 9 of 24



Land Mobile Radio (LMR) Customer Benefits

Is the project / program required by law?

No

Explanation of need for proposed expenditure

Duke Energy requires a reliable internal communication solution that is available for mission critical operational purposes 24/7. A mission-critical communication system managed and maintained by Duke Energy ensures that the assets receive the highest priority to maintain mission critical voice communications. Upgrading the existing system moves Duke Energy to an industry standard P25 communication protocol and ensures OEM support and security patching.

Benefits created for customers [Describe benefits in the context of the overall filing narrative, which could include the following]

Benefit	Description Redundancy within the core communications network is a critical part of delivering the reliable service quality that customers expect during normal operations and during storm restoration to ensure the safety of equipment, personnel, and the public.		
Improved reliability			
Improved personnel safety	The company can respond more quickly to emergency alerts received from LMR radio user personnel in distress, or those unable to communicate through other communications channels.		
Improved resiliency	Interoperability between regions for both field and dispatch center resources enables dispatch from any location to any resource at any time during emergency type events. Additionally, the LMR network supports disaster recovery and business continuity plans by using utility-grade standards and is available when other forms of communication are not available (e.g., commercial cellular networks).		
Improved public safety	A communication system managed and maintained by Duke Energy ensures that our crews receive the highest priority mission critical communications to support public safety in the event of a natural disaster, including events associated with normal and high-water power plant operations.		
Sustained growth of renewables and distributed resources	Renewable resources are dispatched utilizing LMR which helps provide cleaner energy options to customers and achieve carbon reduction goals		

GUYTON DIRECT EXHIBIT 7 - OTHER PROGRAM SUMMARIES DOCKET NO. E-7, SUB 1276 Page 10 of 24



Towers, Shelters & Power Supplies (TSPS)

Program purpose

The Towers, Shelters & Power Supplies (TSPS) improvement program evaluates opportunities to address infrastructure nearing end of service and to construct new communications towers for microwave (MW) transport, Land Mobile Radio (LMR) systems and other strategic high-capacity edge wireless technologies. The program helps reduce operations and maintenance costs at sites where Duke Energy currently leases tower space by evaluating continued lease costs vs. ownership costs.

Duke Energy owns and leases communication towers in each region for its microwave transport network and various private wireless systems for mission critical voice communications, and communications to field devices for monitoring, control and/or data collection. In addition, each tower site incorporates a backup power supply system consisting of batteries and generators that allow communications to continue through challenging operating periods such as ice storms and hurricanes.

Timeline for construction

Refer to MYRP Project List for project-specific timelines. At the program level, construction is planned from December 2023 – September 2026

Estimated in-service date

Refer to the MYRP Project List for project-specific dates. At the program level, individual location inservice dates range from December 2023 -September 2026

GUYTON DIRECT EXHIBIT 7 - OTHER PROGRAM SUMMARIES DOCKET NO. E-7, SUB 1276 Page 11 of 24



Program description

Each component of TSPS is continually evaluated to create a prioritized upgrade and replacement schedule, based on key characteristics such as age, condition, maintenance history, risk, capacity to support growth, impact to grid operations, and potential to offset costs for sites where Duke Energy leases tower space. Approximately 14 TSPS sites are planned to be completed between 2023 and 2026.

Newly constructed towers are designed and built to meet the latest ANSI/TIA tower structure standards for existing wireless infrastructure while providing added capacity for future growth. Backup power systems are also evaluated for age and capacity to ensure they can meet the resiliency requirements for a utility communications network.

Power supplies are located at all tower/shelter and strategic telecom locations to provide the operational availability and resiliency required for a utility communications network. Battery systems provide the primary source of power to operate the telecom hardware housed in the shelter at the site. Batteries are charged by the electric service to the site. The electric service is backed up by a generator with automatic transfer capabilities. Generally, batteries will supply a minimum of 8 hours of standby time in the event electric service is interrupted and a generator fails to run. A generator's fuel supply will support a minimum run time of 7 days.

Projected costs (including capital and O&M expenditure)

Note: Timing for costs based on in-service dates for associated projects; capital includes contingency and AFUDC

DEC NC	Jan ' 24 – Dec '24	Jan '25 – Dec '25	Jan '26 – Dec '26	Total
Capital costs	\$7.7M	\$9.2M	\$8.7M	\$25.6M
O&M costs (installation only)			-	-

Grid capabilities enabled

Reliability and resiliency

- Improved reliability by improving communication capabilities to better manage the grid and ensure efficient operations.
- Improved resiliency through improved communication resilience to coordinate essential restoration

HB951 Policy Considerations addressed

- Encourages peak load reduction or efficient use of the system
- Encourages DERs
- Encourages beneficial electrification, including electric vehicles
- Promotes resilience and security of the electric grid
- Maintains adequate levels of reliability and customer service

GUYTON DIRECT EXHIBIT 7 - OTHER PROGRAM SUMMARIES DOCKET NO. E-7, SUB 1276 Page 12 of 24



- activities, helping restore power faster after outage events.
- Upgraded communication technologies to support improved grid management and efficiency.

Automation & Communication

- Improved resiliency by detecting faults and rerouting power to selfheal, reducing impact from outages
- Provided advanced communication and control technologies to support the two-way power flow needed to expand distributed energy resources.

Voltage Regulation

- Optimized voltage levels to encourage the adoption of DER while protecting customers from disruptive supply spikes or sags
- Improved resiliency by reducing intermittency / fluctuations from DER power supply

Capacity

 Expanded capacity to support the two-way power flow needed to sustainably enable expanded DER adoption.

GUYTON DIRECT EXHIBIT 7 - OTHER PROGRAM SUMMARIES DOCKET NO. E-7, SUB 1276 Page 13 of 24



Towers, Shelters & Power Supplies (TSPS) Customer Benefits

Is the program required by law?

No

Explanation of need for proposed expenditure

TSPS are key Duke Energy communications assets that enable highly reliable private wireless communications systems to support mission critical operations 24/7. Private mission-critical communications infrastructure managed and maintained by Duke Energy ensures that grid control systems and field assets receive the highest priority to support grid integrity, and reliability.

Benefits created for customers [Describe benefits in the context of the overall filing narrative, which could include the following]

Benefit	Description		
Duke Energy tower designs align to ANSI/TIA tower structural standards	Ensures maximum survivability for structures based on critical guidance regarding load requirements and design criteria. Designed with margin to support future growth in the use of wireless technologies.		
Improved Reliability	Ensures proper level of tower structural integrity, shelter that provide a protected environment for electronics, an availability of standby power during challenging operating periods such as ice storms and hurricanes		
Provide reliable communications for normal and event operations	Communications infrastructure managed and maintained by Duke Energy helps ensure that we operate at the highest levels of availability to maintain mission critical communications 24/7.		

GUYTON DIRECT EXHIBIT 7 - OTHER PROGRAM SUMMARIES DOCKET NO. E-7, SUB 1276 Page 14 of 24



Mission Critical Transport (MCT)

Program purpose

Mission Critical Transport (MCT) strategically upgrades and incorporates the backbone infrastructure needed for high-speed, reliable, sustainable, interoperable communications for grid devices and personnel including the use of high-capacity private fiber routes.

Timeline for construction

Refer to Master Project List for project-specific timelines. At the program level, construction is planned from December 2023 – September 2026

Estimated in-service date

Refer to Master Project List for project-specific dates. At the program level, individual location inservice dates range from December 2023 - September 2026

Program description

MCT strategically evaluates and upgrades communications high-capacity fiber infrastructure required for high-speed, reliable, sustainable, and interoperable communications for grid devices and personnel.

Current fiber routes are continually evaluated and identified to create a prioritized replacement schedule for potentially at-risk routes, based on key characteristics such as age, condition, maintenance history, risk, and capacity to support growth, and impact to grid operations.

The scope of MCT also includes strategic fiber construction for new private routes to replace leased circuits, increase capacity, and/or improve security, reliability, and resiliency leveraging transmission line rebuild projects where and when possible.

Projected costs (including capital and O&M expenditure)

Note: Timing for costs based on in-service dates for associated projects; capital includes contingency and AFUDC

DEC NC	Jan '24 - Dec 24	Jan '25 - Dec '25	Jan '26 – Dec '26	Total
Capital costs	-	\$21.1M	\$8.7M	\$29.8M
O&M costs (Installation only)	-	•		-

Grid capabilities enabled	HB951 Policy Considerations addressed		
Reliability and resiliency Improved reliability by improving communication capabilities to better manage the grid and	 Encourages peak load reduction or efficient use of the system Encourages DERs 		
 ensure efficient operations. Improved resiliency through improved communication resilience to coordinate essential restoration activities, helping 	 Encourages beneficial electrification, including electric vehicles Promotes resilience and security of the electric grid 		

GUYTON DIRECT EXHIBIT 7 - OTHER PROGRAM SUMMARIES DOCKET NO. E-7, SUB 1276 Page 15 of 24



restore power faster after outage events.

 Upgraded communication technologies to support improved grid management and efficiency.

Automation & Communication

- Improved resiliency by detecting faults and rerouting power to self-heal, reducing impact from outages
- Provided advanced communication and control technologies to support the twoway power flow needed to expand distributed energy resources.

Maintains adequate levels of reliability and customer service

GUYTON DIRECT EXHIBIT 7 - OTHER PROGRAM SUMMARIES DOCKET NO. E-7, SUB 1276 Page 16 of 24



Mission Critical Transport (MCT) Customer Benefits

Program required by law?

No

Explanation of need for proposed expenditure

Mission Critical Transport (MCT) is a key Duke Energy communications asset that enables very reliable high speed and high-capacity private communications to support mission critical operations 24/7. Mission Critical Transport infrastructure managed and maintained by Duke Energy ensures that grid control systems and field

assets receive the highest priority to support grid integrity and reliability.

Benefits created for customers			
Benefit	Description Ensures maximum capacity based on grid control and customer system needs regarding bandwidth and latency requirements. Designed with margin to support future growth.		
Duke Energy fiber designs align to Telecommunications Industry standards			
Improved Reliability	Ensures reliable high capacity and secure core infrastructure to enable high speed, low latency grid operations during normal, as well as challenging operating periods such as ice storms and hurricanes		
Provide reliable communications for normal and event operations	Communications infrastructure managed and maintained by Duke Energy ensures that we operate at the highest levels of availability to maintain mission critical communications 24/7.		
Supports remote operations of renewable energy assets	Mission Critical Transport infrastructure provides a platform for wireless technologies that enables resilient communications for renewable energy control and management		

GUYTON DIRECT EXHIBIT 7 - OTHER PROGRAM SUMMARIES DOCKET NO. E-7, SUB 1276 Page 17 of 22



Corporate Facilities

Program purpose

Operations centers are the workplace for customer delivery, transmission, lighting, and fleet staff that support the electric grid's construction and maintenance. They are also hubs for material storage, service vehicles and even crew staging and operations during storms. These facilities are being updated to meet the needs of growing towns and cities, as well as support the significant grid improvements taking place to better serve customers and achieve Duke Energy's cleaner energy and carbon goals.

Timeline for construction

Planning and design for the projects within this program started in the first quarter of 2022. Construction of these facility updates will occur through the summer/fall of 2026, with individual operation centers completing construction and entering service throughout this period.

Estimated in-service date

Refer to Master Project List for project-specific in-service dates. At the program level, individual location in-service dates range from October 2023 to June 2026

Program description

DEC-NC

Matthews New Ops Center

A new operations center in Matthews will replace an existing facility that has reached its end of service. The existing facility has storm damage, and the team has outgrown the space. With grid improvement work underway in the area, the building space and acreage is not sufficient to support needs. The new facility, located at a different location, will better serve operational needs in the area going forward.

Little Rock Ops Center Land

The purpose of this land purchase is to secure the location for the new Charlotte operations center that will support the southern region of the city.

Little Rock Operations Center-New Center

Although this new facility is not due to force from the airport, their continued growth has long hindered the operation at this center. The airport has future plans that may include expansion in our space, so this replacement will well position our teams for success whenever that challenge occurs.

Hickory Ops Center Renovation

This work will improve the space for the betterment of employees that support grid maintenance activities that help to ensure continued reliability of service to customers in the area.

GUYTON DIRECT EXHIBIT 7 - OTHER PROGRAM SUMMARIES DOCKET NO. E-7, SUB 1276 Page 18 of 24



Elkin Ops Renovation

This work will improve the space for the betterment of employees that support grid maintenance activities that help to ensure continued reliability of service to customers in the area.

Lewisville Ops Center Renovation

Operations Centers are the workplace for customer delivery, transmission, lighting, and fleet staff that support the grid's maintenance and expansion, but they are also the hubs for material storage and service vehicle placement. As the towns and cities throughout the DEC region have grown and transformed, the operations centers must be well positioned to provide the needs of the workforce that directly support customers.

Fairfax Garage Renovation

Operations Centers are the workplace for customer delivery, transmission, lighting, and fleet staff that support the grid's maintenance and expansion, but they are also the hubs for material storage and service vehicle placement. As the towns and cities throughout the DEC region have grown and transformed, the operations centers must be well positioned to provide the needs of the workforce that directly support customers.

Burlington Ops Center Renovation

Operations Centers are the workplace for customer delivery, transmission, lighting, and fleet staff that support the grid's maintenance and expansion, but they are also the hubs for material storage and service vehicle placement. As the towns and cities throughout the DEC region have grown and transformed, the operations centers must be well positioned to provide the needs of the workforce that directly support customers.

Fairfax Ops Roof Replacement

Replacing the roof of this facility will greatly extend the life of the building and protect the health and well being of occupants.

Hendersonville Ops Center Renovation

Operations Centers are the workplace for customer delivery, transmission, lighting, and fleet staff that support the grid's maintenance and expansion, but they are also the hubs for material storage and service vehicle placement. As the towns and cities throughout the DEC region have grown and transformed, the operations centers must be well positioned to provide the needs of the workforce that directly support customers.

Spindale Ops Center Renovation

Operations Centers are the workplace for customer delivery, transmission, lighting, and fleet staff that support the grid's maintenance and expansion, but they are also the hubs for material storage and service vehicle placement. As the towns and cities throughout the DEC region have grown and transformed, the operations centers must be well positioned to provide the needs of the workforce that directly support customers.

GUYTON DIRECT EXHIBIT 7 - OTHER PROGRAM SUMMARIES DOCKET NO. E-7, SUB 1276 Page 19 of 24



Wentworth New Ops Center

Operations Centers are the workplace for customer delivery, transmission, lighting, and fleet staff that support the grid's maintenance and expansion, but they are also the hubs for material storage and service vehicle placement. As the towns and cities throughout the DEC region have grown and transformed, the operations centers must be well positioned to provide the needs of the workforce that directly support customers.

Rural Hall Ops Center Renovation

Operations Centers are the workplace for customer delivery, transmission, lighting, and fleet staff that support the grid's maintenance and expansion, but they are also the hubs for material storage and service vehicle placement. As the towns and cities throughout the DEC region have grown and transformed, the operations centers must be well positioned to provide the needs of the workforce that directly support customers.

Mooresville Ops Center Renovation

Operations Centers are the workplace for customer delivery, transmission, lighting, and fleet staff that support the grid's maintenance and expansion, but they are also the hubs for material storage and service vehicle placement. As the towns and cities throughout the DEC region have grown and transformed, the operations centers must be well positioned to provide the needs of the workforce that directly support customers.

Salisbury Ops Center Renovation

Operations Centers are the workplace for customer delivery, transmission, lighting, and fleet staff that support the grid's maintenance and expansion, but they are also the hubs for material storage and service vehicle placement. As the towns and cities throughout the DEC region have grown and transformed, the operations centers must be well positioned to provide the needs of the workforce that directly support customers.

Fairfax Bldg Renovation

Operations Centers are the workplace for customer delivery, transmission, lighting, and fleet staff that support the grid's maintenance and expansion, but they are also the hubs for material storage and service vehicle placement. As the towns and cities throughout the DEC region have grown and transformed, the operations centers must be well positioned to provide the needs of the workforce that directly support customers.

	ncluding capital and Costs based on in-servi		ed projects	
DEC NC	Jan '24 – Dec '24	Jan '25 – Dec '25	Jan '26 – Dec '26	Total
Capital costs	\$56.4M	\$22.8M	\$45.6M	\$124.8M
O&M costs	\$.42K	\$.23K	\$0.38K	\$1.03M

GUYTON DIRECT EXHIBIT 7 - OTHER PROGRAM SUMMARIES DOCKET NO. E-7, SUB 1276 Page 20 of 24



Grid capabilities enabled	HB951 Policy Considerations addressed
• N/A	 Promotes resilience and security of the electric grid Maintains adequate levels of reliability and customer service

GUYTON DIRECT EXHIBIT 7 - OTHER PROGRAM SUMMARIES DOCKET NO. E-7, SUB 1276 Page 21 of 24



Corporate Facilities Customer Benefits

Is the project / program required by law?

No

Explanation of need for proposed expenditure

As towns and cities throughout the Duke Energy Progress region continue to grow, the operations centers that serve them must be updated or constructed to meet workforce and supply needs in the service of customers.

Benefits created for customers [Describe benefits in the context of the overall filing narrative, which could include the following]

Benefit	Description
Improved recovery times	By improving the location and capabilities of its operations centers, the company can more efficiently respond to outages and restore power faster to customers.
Readiness for grid modernization	Operations centers must have sufficient indoor and outdoor spaces to support crews and materials working to improve the electric grid, increase reliability and resiliency, and ready the grid for cleaner energy options and a lower carbon future.

GUYTON DIRECT EXHIBIT 7 - OTHER PROGRAM SUMMARIES DOCKET NO. E-7, SUB 1276 Page 22 of 24



Electrification Charging Infrastructure

Program purpose

This project will provide necessary charging stations for both Duke Energy facilities and as required for home charging for Duke Energy vehicles. These charging stations are essential to achieve our 2030 corporate goal of converting 100% of light duty vehicles to electric and 50% of the combined fleet of medium-duty, heavy-duty, and off-road vehicles to EVs, plug in hybrids or other zero-carbon alternatives by 2030.

Timeline for construction

Refer to Master Project List for project-specific timelines. At the program level, construction is planned from August 2023 to August 2026.

Estimated in-service date


Refer to Master Project List for project-specific dates. At the program level, individual location inservice dates range from October 2023 to September 2026.

Program description

- Scope of project: Installation of Level 2 and Level 3 charging stations distributed across Duke Energy facilities and home charging locations as required in support of electrification of internal Fleet assets
- Project / program justification: Charging stations are required to meet enterprise electrification goal for 2030
- Technology details (how it works): Charging stations will be a mix of network and non-network chargers as well as varying Levels (see below) as needed to gather necessary data in support of carbon-reduction goals and reporting.

GUYTON DIRECT EXHIBIT 7 - OTHER PROGRAM SUMMARIES DOCKET NO. E-7, SUB 1276 Page 23 of 24





Projected costs (including capital and O&M expenditure) Note: Note: Timing for costs based on in-service dates for associated projects; capital includes contingency and AFUDC

DEC NC	Jan '24 – Dec '24	Jan '25 - Dec '25	Jan '26 – Dec '26	Total
Capital costs	\$6.1M	\$6.8M	\$4.2M	\$17.1M
O&M costs (installation only)		9	-	•

Grid capabilities enabled

- Network chargers enable charging in off peak
- Identification of forecasted additional load requirements/load impact in support of electrification charging infrastructure

HB951 Policy Considerations addressed

- Encourages peak load reduction or efficient use of the system
- Encourages utility-scale renewable energy and storage
- Encourages energy efficiency
- Encourages beneficial electrification, including electric vehicles

GUYTON DIRECT EXHIBIT 7 - OTHER PROGRAM SUMMARIES DOCKET NO. E-7, SUB 1276 Page 24 of 24



Electrification Charging Infrastructure Customer Benefits

Is the Program required by law?

No

Explanation of need for proposed expenditure

This project will provide necessary charging stations for both Duke Energy facilities and as required for home charging for Duke Energy vehicles. These charging stations are essential to achieve our 2030 corporate goal of converting 100% of light duty vehicles to electric and 50% of the combined fleet of medium-duty, heavy-duty, and off-road vehicles to EVs, plug in hybrids or other zero-carbon alternatives by 2030.

Benefits created for customers [Describe benefits in the context of the overall filing narrative, which could include the following]

Benefit	Description
More control over consumption	Leveraging network chargers to charge in off peak
Carbon reduction	Support electrification of Fleet
Reduction in fuel costs	Overall reduction in fuel costs and fuel consumption

Page 1 of 31

AREA/PROJECT/PROGRAM	Fuse Replacement - 8									
PERIOD:	2024-2026									
REGULATORY JURISDICTION:	DEC									
STATE:	NC									
	NEW JOSEPHER									
	NPV of COST/BENEFIT STREAM									
	STREAM	2022	2023	2024	2025	2026	2027	2028	2029	2030
		0	1	2	3	4	5	6	7	8
200										
COSTS Program Copital Costs	\$ 22,006,794 \$	1,346,625 \$	9,630,976 \$	8,691,821 \$	3,516,405 \$	1,363,964 \$	- \$		- \$	
Program Capital Costs Program Capital Contingency Costs	\$ 2,239,140 \$	137,016 \$	979,929 \$	884,372 \$	357,786 \$	138,780 \$	- \$	- \$	- \$	
Total Program Capital Costs	\$ 24,245,934 \$	1,483,641 \$		9,576,193 \$	3,874,191 \$	1,502,744 \$	- \$			
Total Trogram capital costs	y Engages y	1,403,041 \$	10,010,303 \$	3,370,133 Q	3,074,131 \$	1,502,744 \$			Ÿ	
Program O&M Costs	\$ 485,707 \$	29,721 \$	212,563 \$	191,835 \$	77,610 \$	30,104 \$	- \$	- \$	- \$	
Total Program Costs	\$ 24,731,641 \$	1,513,362 \$	10,823,468 \$	9,768,029 \$	3,951,801 \$	1,532,847 \$	- \$	- \$	- \$	- 3
On-Going Maintenance	\$ 162,480 \$	- \$		- \$	6,552 \$	10,014 \$	12,275 \$	12,582 \$	12,896 \$	13,21
Total On-Going Costs	\$ 162,480 \$	- \$	- \$	- \$	6,552 \$	10,014 \$	12,275 \$	12,582 \$	12,896 \$	13,21
OPERATIONAL BENEFITS										
N/A	\$ - \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	2
Total Operational Benefit	ts \$ - \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	1-1
CUSTOMER REPORTED										
CUSTOMER BENEFITS Avoided Sustained Outage Benefits (Non-MED) - Residential Customers	\$ 377,946 \$	- \$	ė	- \$	14,546 \$	22,789 \$	28,632 \$	29,348 \$	30,082 \$	30,834
Avoided Sustained Outage Benefits (Non-MED) - Small C&I Customers	\$ 7,337,940 \$	- \$	- \$	- \$	282,407 \$	442,448 \$	555,902 \$	569,799 \$	584,044 \$	598,645
Avoided Sustained Outage Benefits (Non-MED) - Medium & Large C&I Customers	\$ - \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	-
A STATE OF THE STA										
Avoided Momentary Outage Benefits (Non-MED) - Residential Customers	\$ 8,675,255 \$	- \$	- \$	- \$	333,875 \$	523,082 \$	657,213 \$	673,643 \$	690,484 \$	707,74
Avoided Momentary Outage Benefits (Non-MED) - Small C&I Customers	\$ 50,587,528 \$	- \$	- \$	- \$	1,946,906 \$	3,050,221 \$	3,832,369 \$	3,928,179 \$	4,026,383 \$	4,127,043
Avoided Momentary Outage Benefits (Non-MED) - Medium & Large C&I Customers	\$ - \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	100
Total Customer Benefit	ts \$ 66,978,669 \$	- \$	- Ś	- \$	2,577,733 \$	4,038,539 \$	5,074,116 \$	5,200,969 \$	5,330,993 \$	5,464,26
Total customer benefit	3 00,578,005 3	,	,		2,311,133 9	4,030,333 3	3,074,110 \$	3,200,303 \$	3,330,933	3,404,200
COMBINED COSTS AND BENEFITS				4						
Total PV of Operational Benefits	\$ - \$	- \$	- \$ - \$	- \$	- \$	- \$	- \$	- \$	- \$	F 464 266
Total PV of Customer Benefits Total PV of Combined Benefits	\$ 66,978,669 \$ \$ 66,978,669 \$	- \$	- \$	- \$	2,577,733 \$ 2,577,733 \$	4,038,539 \$ 4,038,539 \$	5,074,116 \$ 5,074,116 \$	5,200,969 \$ 5,200,969 \$	5,330,993 \$ 5,330,993 \$	5,464,268
Total FY VI Combined benefits	\$ 600,576,009 \$	- ,	. ,	- 3	2,311,133 \$	4,050,555 \$	3,074,110 3	3,200,909 \$	3,330,333 \$	3,404,200
Total PV Program and On-Going Costs	\$ 24,894,120 \$	1,513,362 \$	10,823,468 \$	9,768,029 \$	3,958,352 \$	1,542,861 \$	12,275 \$	12,582 \$	12,896 \$	13,219
e de lance	4	44 540 0501 4	40 000 scal A	(a 750 ann). A	/4 200 540\ A	2 405 570 A	5.054.044 A	F 400 207 A	5 040 007 A	
Combined NPV of Program	\$ 42,084,548 \$	(1,513,362) \$	(10,823,468) \$	(9,768,029) \$	(1,380,619) \$	2,495,678 \$	5,061,841 \$	5,188,387 \$	5,318,097 \$	5,451,050
Ratio of NPV Benefits to NPV Costs	2.7									
Cumulative Net Benefits (Payback Period)	Ś	(1,513,362) \$	(12,336,831) \$	(22,104,859) \$	(23,485,478) \$	(20,989,801) \$	(15 927 959) è	(10,739,572) \$	(5,421,474) \$	29,575
Camalative Net Delicina (rayback relicu)	2	(1,513,502) \$	(12,030,031) \$	(22,104,033) \$	(23,403,470) \$	(20,303,001) \$	(10,027,000) \$	(10,133,312) \$	(2)457,414) 2	23,373

Distribution Automation:

Page 2 of 31

2 of 4

AREA/PROJECT/PROGRAM	Distribution Automation Fuse Replacement - 8
PERIOD:	2024-2026
REGULATORY JURISDICTION:	DEC
STATE:	NC

	NPV of COST/BENEFIT STREAM							YEAR		
	STREAM	2031	2032	2033	2034	2035	2036	2037	2038	2039
		9	10	11	12	13	14	15	16	17
OSTS										
Program Capital Costs	\$ 22,006,794	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	
Program Capital Contingency Costs	\$ 2,239,140 \$				- \$	- \$	- \$	- \$	- \$	
Total Program Capital Costs	\$ 24,245,934 \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	
Program O&M Costs	\$ 485,707 \$	- \$			- \$	- \$	- \$	- \$	- \$	
Total Program Costs	\$ 24,731,641 \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	
On-Going Maintenance	\$ 162,480 \$	13,549 \$	13,888 \$	14,235 \$	14,591 \$	14,956 \$	15,330 \$	15,713 \$	16,106 \$	16,50
Total On-Going Costs	\$ 162,480 \$	13,549 \$	13,888 \$	14,235 \$	14,591 \$	14,956 \$	15,330 \$	15,713 \$	16,106 \$	16,50
PERATIONAL BENEFITS										
N/A	\$ - \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	7
Total Operational Benefit	s <u>\$</u> \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	-
USTOMER BENEFITS										
Avoided Sustained Outage Benefits (Non-MED) - Residential Customers	\$ 377,946 \$	31,604 \$	32,395 \$	33,204 \$	34,035 \$	34,885 \$	35,758 \$	36,652 \$	37,568 \$	38,50
Avoided Sustained Outage Benefits (Non-MED) - Small C&I Customers	\$ 7,337,940 \$	0.444	628,952 \$	644,676 \$	660,793 \$	677,312 \$	694,245 \$	711,601 \$	729,391 \$	747,62
Avoided Sustained Outage Benefits (Non-MED) - Medium & Large C&I Customers	\$ - \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	-
Avoided Momentary Outage Benefits (Non-MED) - Residential Customers	\$ 8,675,255 \$	725,440 \$	743,576 \$	762,166 \$	781,220 \$	800,750 \$	820,769 \$	841,288 \$	862,320 \$	883,87
Avoided Momentary Outage Benefits (Non-MED) - Small C&I Customers	\$ 50,587,528 \$	4,230,219 \$	4,335,974 \$	4,444,374 \$	4,555,483 \$	4,669,370 \$	4,786,104 \$	4,905,757 \$	5,028,401 \$	5,154,11
Avoided Momentary Outage Benefits (Non-MED) - Medium & Large C&I Customers	\$ - \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	
Total Customer Benefit	s \$ 66,978,669 \$	5,600,875 \$	5,740,897 \$	5,884,419 \$	6,031,530 \$	6,182,318 \$	6,336,876 \$	6,495,298 \$	6,657,680 \$	6,824,12
OMBINED COSTS AND BENEFITS										
Total PV of Operational Benefits	\$ - \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	
Total PV of Customer Benefits	\$ 66,978,669 \$		5,740,897 \$	5,884,419 \$	6,031,530 \$	6,182,318 \$	6,336,876 \$	6,495,298 \$	6,657,680 \$	6,824,12
Total PV of Combined Benefits	\$ 66,978,669 \$		5,740,897 \$	5,884,419 \$	6,031,530 \$	6,182,318 \$	6,336,876 \$	6,495,298 \$	6,657,680 \$	6,824,12
Total PV Program and On-Going Costs	\$ 24,894,120 \$	13,549 \$	13,888 \$	14,235 \$	14,591 \$	14,956 \$	15,330 \$	15,713 \$	16,106 \$	16,50
Combined NPV of Program	\$ 42,084,548 \$	5,587,326 \$	5,727,009 \$	5,870,184 \$	6,016,939 \$	6,167,362 \$	6,321,546 \$	6,479,585 \$	6,641,575 \$	6,807,61
Ratio of NPV Benefits to NPV Costs	2.7									
The Control of the Co										

Page 3 of 31

AREA/PROJECT/PROGRAM	Fuse Replacement - 8													
PERIOD:	2024-2026													
REGULATORY JURISDICTION:	DEC													
STATE:	NC													
	NPV of COST/BENEFIT													
	STREAM													
	JAKEAIN .	2040	2041		2042	- 1	2043	2044	2045		2046	2047		2048
		18	19		20		21	22	23		24	25		26
COSTS														
Program Capital Costs	\$ 22,006,794	\$ -	\$	- \$	1.2	\$	- \$	1 27	\$.	\$	14	Ś	- \$	
Program Capital Contingency Costs				- \$	-	12	- \$			\$	-		- \$	
Total Program Capital Costs	\$ 24,245,934	\$ -	\$	- \$	-	\$	- \$	-	\$.	\$	12.0	\$	- \$	
Program O&M Costs	\$ 485,707	\$ -	\$	- \$	12.	Ś	- \$		\$.	\$		\$	- \$	
Total Program Costs	\$ 24,731,641	\$ -	\$	- \$		\$	- \$		\$	\$	- 2	\$	- \$	- 3
On-Going Maintenance	\$ 162,480	\$ 16,921	\$ 17,34	4 \$	17,778	\$	18,222 \$	18,678	\$ 19,145	5 \$	19,623	\$ 20,11	4 \$	20,617
Total On-Going Costs	\$ 162,480	\$ 16,921			17,778		18,222 \$	18,678			19,623			20,617
OPERATIONAL BENEFITS														
N/A	\$	\$ -	\$ -	\$		\$	- \$	- 3	-	\$	2	-	\$	1
Total Operational Benefi	ts \$ -	\$ -	\$ -	\$	*	\$	- \$	- 3	-	\$	-	-	\$	-
CUSTOMER BENEFITS														
Avoided Sustained Outage Benefits (Non-MED) - Residential Customers	\$ 377,946	\$ 39,470	\$ 40,45	6 \$	41,468	\$	42,505 \$	43,567	44,656	4	45,773	46,91	7 5	48,090
Avoided Sustained Outage Benefits (Non-MED) - Small C&I Customers	\$ 7,337,940				805,112		825,239 \$	845,870			888,693			933,683
Avoided Sustained Outage Benefits (Non-MED) - Medium & Large C&I Customers		\$ -	\$ -	\$		\$	- \$	-			-		-	
Avoided Momentary Outage Benefits (Non-MED) - Residential Customers	\$ 8,675,255	\$ 905,975	\$ 928,62	5 5	951,840	\$	975,636 \$	1,000,027	1,025,028	5	1,050,654	1,076,92	0 \$	1,103,843
Avoided Momentary Outage Benefits (Non-MED) - Small C&I Customers	\$ 50,587,528	\$ 5,282,964			5,550,414		5,689,174 \$	5,831,403			6,126,618			6,436,778
Avoided Momentary Outage Benefits (Non-MED) - Medium & Large C&I Customers		\$ -	\$ -	\$		\$	- \$	- 5		\$	-			-
Total Customer Benefit	ts \$ 66,978,669	\$ 6,994,725	\$ 7,169,59	4 \$	7,348,833	\$	7,532,554 \$	7,720,868	7,913,890	\$	8,111,737	\$ 8,314,53	3 \$	8,522,394
COMBINED COSTS AND BENEFITS														
Total PV of Operational Benefits	\$ -	\$	\$ -	\$	42	\$	- \$	- 5		\$	- 1	\$ -	\$	
Total PV of Customer Benefits	\$ 66,978,669				7,348,833		7,532,554 \$	7,720,868			8,111,737			8,522,394
Total PV of Combined Benefits	\$ 66,978,669				7,348,833		7,532,554 \$	7,720,868		_	8,111,737			8,522,394

16,921 \$

17,344 \$

17,778 \$

6,977,804 \$ 7,152,249 \$ 7,331,056 \$ 7,514,332 \$ 7,702,190 \$ 7,894,745 \$

18,222 \$

18,678 \$

62,626,520 \$ 69,778,769 \$ 77,109,825 \$ 84,624,157 \$ 92,326,348 \$ 100,221,093 \$ 108,313,207 \$ 116,607,623 \$ 125,109,400

19,145 \$

19,623 \$

8,092,114 \$ 8,294,417 \$

20,114 \$

20,617

8,501,777

Distribution Automation:

24,894,120 \$

42,084,548 \$

2.7

Total PV Program and On-Going Costs

Ratio of NPV Benefits to NPV Costs

Combined NPV of Program

AREA/PROJECT/PROGRAM	Distribution Automation: Fuse Replacement - 8
PERIOD:	2024-2026
REGULATORY JURISDICTION:	DEC
STATE:	NC

NP	V of COST/BENEFIT										
-	STREAM		2049		2050		2051		2052		TOTAL
			27		28		29		30		
Ŝ	22.006.794	1 5		Ś	- 2	\$	1.2	\$		\$	24,549,79
\$	2,239,140	\$		\$	- 4	\$		\$			2,497,88
\$	24,245,934	\$		\$		\$	-	\$		\$	27,047,67
\$	485,707	\$	+	\$	Q.	\$		\$	I-	\$	541,83
\$	24,731,641	\$	3-5	\$	-	\$		\$		\$	27,589,50
\$	162,480	\$						_			458,60
\$	162,480	\$	21,132	\$	21,660	\$	22,202	\$	22,757	\$	458,60
\$		\$	181	\$	-	\$	-	\$	4	\$	
its \$. \$	7	\$	-	\$	•	\$		\$	-
\$	377,946	\$	49,292	\$	50,525	\$	51,788	\$	53,082	\$	1,068,42
\$	7,337,940	\$	957,025	\$	980,950	\$	1,005,474	\$	1,030,611	\$	20,743,82
\$	-	\$	-	\$	-	\$	-	\$	-	\$	
\$	8,675,255	\$	1,131,439	\$	1,159,725	\$	1,188,718	\$	1,218,436	\$	24,524,32
\$	50,587,528	\$	6,597,698	\$	6,762,640	\$	6,931,706	\$			143,007,29
\$	-	\$	-	\$		\$		\$	-	\$	-
its \$	66,978,669	\$	8,735,454	\$	8,953,840	\$	9,177,686	\$	9,407,128	\$	189,343,86
									111		
\$		\$	140	\$	100.0	\$	1 +	\$	-	\$	-
\$		_		_				_	9,407,128	_	189,343,86
\$	66,978,669	\$	8,735,454	\$	8,953,840	\$	9,177,686	\$	9,407,128	\$	189,343,86
\$	24,894,120	\$	21,132	\$	21,660	\$	22,202	\$	22,757	\$	28,048,11
\$	42,084,548	\$	8,714,321	\$	8,932,180	\$	9,155,484	\$	9,384,371	\$	161,295,75
1	2.7										
										1	
	\$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$	\$ 22,006,794 \$ 2,239,140 \$ 24,245,934 \$ 485,707 \$ 24,731,641 \$ 162,480 \$ 162,480 \$ 162,480 \$ \$ \$ 377,946 \$ 7,337,940 \$ \$ 8,675,255 \$ 50,587,528 \$ 51,587,528 \$ 50,587,528 \$ 50,587,669 \$ 66,978,669 \$ 24,894,120 \$ 42,084,548	\$ 22,006,794 \$ 2,239,140 \$ 24,245,934 \$ 485,707 \$ 485,707 \$ 485,707 \$ 485,707 \$ 485,707 \$ 485,707 \$ 485,707 \$ 485,707 \$ 485,707,946 \$ 485,707 \$ 485,707,946	\$ 22,006,794 \$ - \$ 2,239,140 \$ - \$ 24,245,934 \$ - \$ \$ 24,731,641 \$ - \$ \$ 162,480 \$ 21,132 \$ \$ 162,480 \$ 21,132 \$ \$ 162,480 \$ 21,132 \$ \$ 162,480 \$ 21,132 \$ \$ 162,480 \$ 5 1,131,439 \$ 50,587,525 \$ 1,131,439 \$ 50,587,528 \$ 6,597,698 \$ 5 50,587,528 \$ 6,597,698 \$ 5 50,587,528 \$ 6,597,698 \$ 5 50,587,528 \$ 6,597,698 \$ 5 50,587,528 \$ 6,597,698 \$ 5 50,587,528 \$ 6,597,698 \$ 5 50,587,528 \$ 6,597,698 \$ 5 50,587,528 \$ 6,597,698 \$ 5 50,587,528 \$ 6,597,698 \$ 5 50,587,528 \$ 6,597,698 \$ 5 50,587,528 \$ 6,597,698 \$ 5 50,587,528 \$ 6,597,698 \$ 5 50,587,528 \$ 6,597,698 \$ 5 50,587,528 \$ 5 50,587,5454 \$ 5 50,587,669 \$ 8,735,454 \$ 5 50,587,67	\$ 22,006,794 \$ - \$ \$ 2,239,140 \$ - \$ \$ 24,245,934 \$ - \$ \$ 24,731,641 \$ - \$ \$ \$ 162,480 \$ 21,132 \$ \$ 162,480 \$ 21,132 \$ \$ 162,480 \$ 21,132 \$ \$ \$ 162,480 \$ 21,132 \$ \$ \$ 162,480 \$ 21,132 \$ \$ \$ \$ 162,480 \$ 21,132 \$ \$ \$ \$ 162,480 \$ 21,132 \$ \$ \$ \$ \$ 162,480 \$ \$ 21,132 \$ \$ \$ \$ \$ \$ 6,597,025 \$ \$ \$ - \$ \$ \$ \$ \$ 6,597,025 \$ \$ \$ \$ - \$ \$ \$ \$ \$ 66,978,669 \$ 8,735,454 \$ \$ \$ 66,978,669 \$ 8,735,454 \$ \$ \$ 66,978,669 \$ 8,735,454 \$ \$ \$ 66,978,669 \$ 8,735,454 \$ \$ \$ \$ 66,978,669 \$ 8,735,454 \$ \$ \$ \$ 66,978,669 \$ 8,735,454 \$ \$ \$ \$ 66,978,669 \$ 8,735,454 \$ \$ \$ \$ 66,978,669 \$ 8,735,454 \$ \$ \$ \$ \$ 66,978,669 \$ 8,735,454 \$ \$ \$ \$ \$ 66,978,669 \$ 8,735,454 \$ \$ \$ \$ \$ 66,978,669 \$ 8,735,454 \$ \$ \$ \$ \$ 66,978,669 \$ 8,735,454 \$ \$ \$ \$ \$ 66,978,669 \$ 8,735,454 \$ \$ \$ \$ \$ 66,978,669 \$ 8,735,454 \$ \$ \$ \$ \$ 66,978,669 \$ 8,735,454 \$ \$ \$ \$ \$ 66,978,669 \$ 8,735,454 \$ \$ \$ \$ \$ 66,978,669 \$ 8,735,454 \$ \$ \$ \$ \$ 66,978,669 \$ 8,735,454 \$ \$ \$ \$ \$ 66,978,669 \$ \$ 8,735,454 \$ \$ \$ \$ \$ 66,978,669 \$ \$ 8,735,454 \$ \$ \$ \$ \$ 66,978,669 \$ \$ 8,735,454 \$ \$ \$ \$ \$ 66,978,669 \$ \$ 8,735,454 \$ \$ \$ \$ \$ 66,978,669 \$ \$ 8,735,454 \$ \$ \$ \$ \$ 66,978,669 \$ \$ 8,735,454 \$ \$ \$ \$ \$ 66,978,669 \$ \$ 8,735,454 \$ \$ \$ \$ \$ \$ 66,978,669 \$ \$ 8,735,454 \$ \$ \$ \$ \$ 66,978,669 \$ \$ 8,735,454 \$ \$ \$ \$ \$ 66,978,669 \$ \$ 8,735,454 \$ \$ \$ \$ \$ 66,978,669 \$ \$ 8,735,454 \$ \$ \$ \$ \$ 66,978,669 \$ \$ 8,735,454 \$ \$ \$ \$ \$ 66,978,669 \$ \$ 8,735,454 \$ \$ \$ \$ \$ 66,978,669 \$ \$ 8,735,454 \$ \$ \$ \$ \$ 66,978,669 \$ \$ 8,735,454 \$ \$ \$ \$ \$ 66,978,669 \$ \$ 8,735,454 \$ \$ \$ \$ \$ 66,978,669 \$ \$ 8,735,454 \$ \$ \$ \$ \$ 66,978,669 \$ \$ 8,735,454 \$ \$ \$ \$ \$ 66,978,669 \$ \$ 8,735,454 \$ \$ \$ \$ \$ 66,978,669 \$ \$ 8,735,454 \$ \$ \$ \$ \$ \$ 66,978,669 \$ \$ 8,735,454 \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$	\$ 22,006,794 \$ - \$ - \$ - \$ - \$ \$ 24,245,934 \$ - \$ - \$ - \$ \$ - \$ \$ 162,480 \$ 21,132 \$ 21,660 \$ 162,480 \$ 21,132 \$ 21,660 \$ 162,480 \$ 21,132 \$ 21,660 \$ 162,480 \$ 21,132 \$ 21,660 \$ 162,480 \$ 21,132 \$ 21,660 \$ 162,480 \$ 21,132 \$ 21,660 \$ 162,480 \$ 21,132 \$ 21,660 \$ 162,480 \$ 21,132 \$ 21,660 \$ 162,480 \$ 21,132 \$ 21,660 \$ 162,480 \$ 21,132 \$ 21,660 \$ 162,480 \$ 21,132 \$ 21,660 \$ 163,480 \$ 21,132 \$ 21,660 \$ 163,480 \$ 163,	\$ 22,006,794 \$ - \$ - \$ \$ \$ \$ 2,239,140 \$ - \$ - \$ \$ \$ \$ \$ 24,245,934 \$ - \$ - \$ - \$ \$ \$ \$ \$ 24,731,641 \$ - \$ - \$ \$ \$ \$ \$ 162,480 \$ 21,132 \$ 21,660 \$ \$ \$ 162,480 \$ 21,132 \$ 21,660 \$ \$ \$ \$ 162,480 \$ 21,132 \$ 21,660 \$ \$ \$ \$ \$ 7,337,940 \$ 957,025 \$ 980,950 \$ \$ \$ \$ 7,337,940 \$ 957,025 \$ 980,950 \$ \$ \$ \$ \$ 50,587,528 \$ 6,597,698 \$ 6,762,640 \$ \$ \$ \$ \$ - \$ \$ - \$ \$ \$ \$ \$ \$ \$ \$ \$ \$	\$ 22,006,794 \$ - \$ - \$ - \$ - \$ - \$ - \$ - \$ - \$ - \$	STREAM	STREAM	STREAM

Duke Energy Carolinas, LLC
DOCKET NO. E-7, SUB 1276
Guyton Direct Exhibit 8 - MYRP Distribution CBA - Distribution Automation
4 of 4
Page 4 of 31

73,909,834 \$ 98,392,575 \$ 101,123,903 \$ 103,987,398 \$ 107,005,525 \$ 110,063,374 \$ 113,047,541 \$ 115,989,703 \$ 119,105,893 \$ 122,169,651 \$ 125,480,274 \$ 128,799,426 \$ 132,047,421 \$ 135,357,785

Sources

Total Benefits

\$ 1,348,548,964

		2040	19	2042	2043	2044	2045	2046	2047	2048	2049	2050	2051	2052	TOTAL
Benefits	Units	\$ 138,803,164		20	21 149,712,056 \$	22 153,541,608 \$	23 157,486,047 \$	24 161,375,788 \$	165,507,271 \$	26 169,704,931 \$	27 173,975,824 \$	28 178,191,030 \$	29 182,592,858 \$	30 187,128,852	
Costs Net		\$ 609,057 \$ 138,194,107		639,890 \$	655,888 \$ 149,056,168 \$	672,285 \$ 152,869,323 \$	689,092 \$ 156,796,955 \$	706,319 \$	723,977 \$ 164,783,294 \$	742,077 \$ 168,962,854 \$	760,629 \$	779,644 \$ 177,411,385 \$	799,135 \$ 181,793,722 \$	819,114 \$ 186,309,738 \$	
BCR															
COSTS															
PROGRAM COSTS (I Switch Automatic	Full & Partial So	D(-	224,53
Contingency	S													ŝ	
Implementation O&I Total Program Cos	M S	\$	s - s	- 5	- 5	- 5	. 5	- 5	- 5	- 5	- 5	. 5	- 5	- 5	247,38
ON-GOING COSTS (F	and the second	4		-			-								
On-going O&M	\$	\$ 609,057			655,888 \$	672,285 \$	689,092 \$	706,319 \$	723,977 \$	742,077 \$	760,629 \$	779,644 \$	799,135 \$	819,114 \$	
Total On-going O8	\$	\$ 609,057	\$ 624,283 \$	639,890 \$	655,888 \$	672,285 \$	689,092 \$	706,319 \$	723,977 \$	742,077 \$	760,629 \$	779,644 \$	799,135 \$	819,114 \$	16,83
TOTAL COSTS Program Costs	\$	S -	\$ - \$	- \$	- \$	- S	- \$	- \$	- S	- \$	- 5	- \$	- \$	- \$	251,00
On-going Costs	\$	\$ 609,057	\$ 624,283 \$	639,890 \$	655,888 \$	672,285 \$	689,092 \$	706,319 \$	723,977 \$	742,077 \$	760,629 \$	779,644 \$	799,135 \$	819,114 \$	16,83
Total Cost	\$	\$ 609,057	\$ 624,283 \$	639,890 \$	655,888 \$	672,285 \$	689,092 \$	706,319 \$	723,977 \$	742,077 \$	760,629 \$	779,644 \$	799,135 \$	819,114 \$	267,83
BENEFITS						_					_				
RELIABILITY	0.70				126373	20113								W-175	
CI Savings CMI Savings	outages min	126,987 25,793,033	126,987 25,793,033	126,987 25,793,033	126,987 25,793,033	126,987 25,793,033	126,987 25,793,033	126,987 25,793,033	126,987 25,793,033	126,987 25,793,033	126,987 25,793,033	126,987 25,793,033	126,987 25,793,033	126,987 25,793,033	
Typical Duration	hr	3.39	3 39	3.39	3.39	3.39	3.39	3 39	3.39	3 39	3.39	3 39	3.39	3.39	
Residential Custom Small C&I Custome	% %	86.4% 11.4%	11.4%	86.4% 11.4%	86.4% 11.4%	86.4% 11.4%	86.4% 11.4%	86.4% 11.4%	86.4% 11.4%	86.4% 11.4%	86.4% 11.4%	86.4% 11.4%	86.4% 11.4%	86.4% 11.4%	
Large C&I Custome Residential Outage	% \$/outage	\$ 22%		2 2%	2.2%	2 2%	2.2%	2.2%	2.2%	2.2%	2 2%	2.2%	2 2% 23 \$	2.2%	
Small C&I Outage \	\$/outage	\$ 3,228	\$ 3,309 \$	3,392 \$	3,477 \$	3,564 \$	3,653 \$	3,744 \$	3,838 \$	3,934 \$	4,032 \$	4,133 \$	4,236 \$	4,342	
Large C&I Outage \ Residential Moment	\$/outage \$/momentary	\$ 30,106 \$ 9	\$ 30,858 \$ \$ 10 \$		32,420 \$ 10 \$	33,231 \$ 10 \$	34,062 \$ 11 \$	34,913 \$ 11 \$	35,786 \$ 11 \$	36,681 \$ 11 \$	37,598 \$ 12 \$	38,538 \$ 12 \$	39,501 \$ 12 \$	40,489 13	
Small C&I Momenta Large C&I Momenta	\$/momentary \$/momentary	\$ 837 \$ 10,896			901 \$ 11,734 \$	923 \$ 12,027 \$	947 \$ 12,328 \$	970 \$ 12,636 \$	994 \$ 12,952 \$	1,019 \$ 13,276 \$	1,045 \$ 13,608 \$	1,071 \$ 13,948 \$	1,098 \$ 14,297 \$	1,125 14,654	
Momentary Outage:	momentaries	126,987	126,987	126,987	126,987	126,987	126,987	126,987	126,987	126,987	126,987	126,987	126,987	126,987	
Customer Avoided Customer Avoided	S	\$ 925,580 \$ 34,890,451		972,437 \$ 36,656,780 \$	996,748 \$ 37,573,199 \$	1,021,667 \$ 38,512,529 \$	1,047,208 \$ 39,475,343 \$	1,073,389 \$ 40,462,226 \$	1,100,223 \$ 41,473,782 \$	1,127,729 \$ 42,510,626 \$	1,155,922 \$ 43,573,392 \$	1,184,820 \$ 44,662,727 \$	1,214,441 \$ 45,779,295 \$	1,244,802 46,923,777	
Customer Avoided	s	\$ 54,645,623	\$ 56,011,764 \$	57,412,058 \$	58,847,359 \$	60,318,543 \$	61,826,507 \$	63,372,170 \$	64,956,474 \$	66,580,386 \$	68,244,895 \$	69,951,018 \$	71,699,793 \$	73,492,288	
Customer Avoided	\$	\$ 90,461,654 \$ 1,034,351			97,417,307 \$ 1,113,883 \$	99,852,740 \$ 1,141,730 \$	1,170,273 \$	1,199,530 \$	1,229,519 \$	110,218,741 \$ 1,260,256 \$	112,974,210 \$ 1,291,763 \$	115,798,565 \$ 1,324,057 \$	118,693,529 \$ 1,357,158 \$	121,660,867 1,391,087	_
Customer Avoided I Customer Avoided I	\$	\$ 12,063,108 \$ 30,562,120			12,990,648 \$ 32,912,060 \$	13,315,415 \$ 33,734,862 \$	13,648,300 \$ 34,578,233 \$	13,989,507 \$ 35,442,689 \$	14,339,245 \$ 36,328,756 \$	14,697,726 \$ 37,236,975 \$	15,065,169 \$ 38,167,900 \$	15,441,799 \$ 39,122,097 \$	15,827,844 \$ 40,100,149 \$	16,223,540 41,102,653	
Customer Avoided	S	\$ 43,659,579			47,016,592 \$	48,192,006 \$	49,396,807 \$	50,631,727 \$	51,897,520 \$	53,194,958 \$	54,524,832 \$	55,887,953 \$	57,285,151 \$	58,717,280	
CAPACITY SAVINGS		1													
Capacity Savings fr Capacity Value	MW S/kW	\$ 102		15 104 \$	15 105 \$	16 107 \$	16 110 \$	16 112 \$	16 115 \$	17 118 \$	17 121 \$	17 121 \$	17 121 \$	17 121	
Capacity Savings	\$	\$ 1,496,071		1,580,372 \$	1,608,603 \$	1,672,382 \$	1,734,574 \$	1,796,529 \$	1,892,930 \$	1,964,335 \$	2,024,867 \$	2,050,736 \$	2,067,142 \$	2,083,679 \$	40,19
ENERGY SAVINGS										-					
Capacity factor for e Energy Savings from	MWh	0.4% 515		0.4% 533	0.4% 539	0.4% 547	0.4% 554	0.4% 560	0.4% 577	0.4% 584	0.4% 588	0.4% 596	0.4% 601	0.4% 605	
Energy Value	S/MWh	\$ 26	\$ 28 \$	29 \$	31 \$	32 \$	33 \$	34 \$	35 \$	35 \$	36 \$	37 \$	38 \$	38	
Energy Savings (II	\$	\$ 13,530	\$ 14,630 \$	15,674 \$	16,633 \$	17,435 \$	18,363 \$	19,200 \$	20,033 \$	20,734 \$	21,301 \$	22,116 \$	22,575 \$	23,107 \$	37
Value: SOx	S/ton	\$	s - s	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- S		
Value: NOx	\$/ton	\$ -	\$ - \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- 5		
Value: CO2 Energy: SOx reduct	\$/ton ton/MWh	\$ 80	\$ 85 \$ 0.00	90 \$	95 \$ 0.00	0.00	105 \$ 0.00	110 \$	115 \$ 0.00	120 \$	125 \$ 0.00	130 \$	135 \$ 0.00	0.00	
Energy: NOx reduct Energy: CO2 reduct	ton/MWh ton/MWh	0.00	0 00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
Environmental Bene	\$	\$ 8,353	\$ 9,017 \$	9,658 \$	10,240 \$	10,993 \$	11,821 \$	11,717 \$	12,799 \$	13,591 \$	14,199 \$	14,064 \$	14,671 \$	15,439 \$	
Environmental Be	\$	\$ 8,353			10,240 \$	10,993 \$	11,821 \$	11,717 \$	12,799 \$	13,591 \$	14,199 \$	14,064 \$	14,671 \$	15,439 \$	21
Peak Shaving Ben	\$	\$ 1,517,954	\$ 1,577,865 \$	1,605,704 \$	1,635,476 \$	1,700,810 \$	1,764,758 \$	1,827,446 \$	1,925,763 \$	1,998,660 \$	2,060,368 \$	2,086,916 \$	2,104,388 \$	2,122,225 \$	40,79
DER ENABLEMENT				-				3,1			-		-		
Forecasted PV (Ani Forecasted PV (Cui	MW	45 901	45 946	45 992	46 1,038	46 1,084	47 1,131	49 1,180	49 1,229	49 1,278	51 1,329	51 1,380	53 1,433	55 1,488	
PV scaling factor (§	MW	20% 310		20% 310	20% 310	20% 310	20% 310	20% 310	20% 310	20% 310	20% 310	20% 310	20% 310	20% 310	
Limit (without SOG) Limit (with SOG)	MW	522	522	522	522	522	522	522	522	522	522	522	522	522	
PV derate factor for PV Enablement	MW	19% 43	19% 43	19% 43	19% 43	19% 43	19% 43	19% 43	19%	19% 43	19% 43	19% 43	19% 43	19% 43	
Energy Savings	MWh/MW	1,936	1,936	1,936	1,936	1,936	1,936	1,936	1,936	1,936	1,936	1,936	1,936	1,936	21.0
DER Enablement: (DER Enablement: E	S	\$ 499,381.57 \$ 1,313,286.17			513,637.82 \$ 1,544,424.54 \$	525,966 22 \$ 1,594,454.49 \$	538,592.31 \$ 1,657,992.53 \$	551,520 59 \$ 1,714,026 07 \$	564,759.19 \$ 1,738,040.45 \$	578,315.57 \$ 1,775,062.61 \$	592,197.36 \$ 1,811,584.47 \$	592,197.36 \$ 1,857,111.73 \$	592,197 36 \$ 1,880,625 80 \$	592,197.36 \$ 1,909,643.17 \$	
DER Enablement: E DER/PV Enableme	S	\$ 1,351,309 \$ 3,163,977	\$ 1,424,000 \$	1,510,653 \$	1,584,619 \$ 3,642,681 \$	1,675,630 \$ 3,796,051 \$	1,778,839 \$ 3,975,424 \$	1,743,284 \$ 4,008,831 \$	1,850,709 \$ 4,153,509 \$	1,939,194 \$ 4,292,572 \$	2,012,633 \$ 4,416,415 \$	1,968,288 \$ 4,417,597 \$	2,036,966 \$ 4,509,790 \$	2,126,639 \$ 4,628,479 \$	32,89
	3	a 3,103,977	+ 3,310,763 \$	3,491,001	J,042,001 \$	3,730,031	3,313,424	4,000,031	4,100,009	7,232,312	4,410,410	4,411,581	4,505,180 \$	4,020,479 \$	10,78
TOTAL BENEFITS Customer Avoide	S	\$ 90,461,654	\$ 92,723,195 \$	95,041,275 \$	97,417,307 \$	99,852,740 \$	102,349,058 \$	104,907,785 \$	107,530,479 S	110,218,741 \$	112,974,210 \$	115,798.565 S	118,693.529 S	121,660,867 \$	2,469 30
Customer Avoide	S	\$ 43,659,579	\$ 44,751,069 \$	45,869,846 \$	47,016,592 \$	48,192,006 \$	49,396,807 \$	50,631,727 \$	51,897,520 \$	53,194,958 \$	54,524,832 \$	55,887,953 \$	57,285,151 \$	58,717,280 \$	1,191,83
Peak Shaving Be DER/PV Enabler	\$	\$ 1,517,954 \$ 3,163,977			1,635,476 \$ 3,642,681 \$	1,700,810 \$ 3,796,051 \$	1,764,758 \$ 3,975,424 \$	1,827,446 \$ 4,008,831 \$	1,925,763 \$ 4,153,509 \$	1,998,660 \$ 4,292,572 \$	2,060,368 \$ 4,416,415 \$	2,086,916 \$ 4,417,597 \$	2,104,388 \$ 4,509,790 \$		
Total Benefits	Ś		\$ 142,368,914 \$		149,712,056 \$										

Page 7 of 31

AREA/PROJECT/PROGRAM	Distribution H&R Lateral - 7a									
PERIOD:	2024-2026									
REGULATORY JURISDICTION:	DEC									
STATE:	NC									
	NPV of COST/BENEFIT STREAM			A.A				7		
		2022	2023	2024	2025	2026	2027	2028	2029	2030
		0	1	2	3	4	5	6	7	8
COSTS										
Program Capital Costs	\$ 319,677,077	\$ 799,642	50,301,228 \$	134,260,745 \$	128,432,855 \$	60,878,918 \$	- \$	- \$	- \$	
Program Capital Contingency Costs		\$ 87,732				6,679,275 \$	- \$		- \$	
Total Program Capital Costs	\$ 354,750,158	\$ 887,374				67,558,193 \$	- \$	- \$		
Program O&M Costs	\$ 6,797,936	\$ 17,004 \$	1,069,656 \$	2,855,056 \$	2,731,126 \$	1,294,591 \$	- \$	- \$	- \$	
Total Program Costs	\$ 361,548,093	904,378				68,852,784 \$	- \$			
	İ\$ - 19		s - s			- \$	- \$	- \$	- \$	
Total On-Going Costs	\$ -	\$ -		- \$	- \$	- \$	- \$			
OPERATIONAL BENEFITS										
Avoided Outage Benefits	\$ 9,487,387	- 5	- \$	- \$	120,307 \$	353,080 \$	749,347 \$	768,080 \$	787,282 \$	806,
Total Operational Benefits	\$ 9,487,387	- 5	- \$	- \$	120,307 \$	353,080 \$	749,347 \$	768,080 \$	787,282 \$	806,9
CUSTOMER BENEFITS										
Avoided Sustained Outage Benefits (Non-MED) - Residential Customers	\$ 471,647	- 5	- \$	- \$	5,700 \$	17,145 \$	37,297 \$	38,230 \$	39,186 \$	40,1
Avoided Sustained Outage Benefits (Non-MED) - Small C&I Customers	\$ 11,134,278			- \$		404,754 \$	880,489 \$	902,501 \$	925,064 \$	948,
Avoided Sustained Outage Benefits (Non-MED) - Medium & Large C&I Customers	\$ -	- 5	.01	- \$		- \$	- \$	- \$	- \$	
Avoided Momentary Outage Benefits (Non-MED & MED) - Residential Customers	\$ 20,786,747	- \$	- \$	- \$	251,193 \$	755,641 \$	1,643,797 \$	1,684,892 \$	1,727,015 \$	1,770,
Avoided Momentary Outage Benefits (Non-MED & MED) - Small C&I Customers	\$ 242,425,193	- \$	- \$	- \$	2,929,537 \$	8,812,650 \$	19,170,768 \$	19,650,037 \$	20,141,288 \$	20,644,
Avoided Momentary Outage Benefits (Non-MED & MED) - Medium & Large C&I Cust	\$ 614,188,938	\$ - \$	- \$	- \$	7,422,040 \$	22,327,021 \$	48,569,514 \$	49,783,751 \$	51,028,345 \$	52,304,0
Total Customer Benefits	\$ \$ 889,006,803		- \$	- \$	10,743,020 \$	32,317,210 \$	70,301,865 \$	72,059,412 \$	73,860,897 \$	75,707,4
ONNING COCKS AND DENIFORM										
OMBINED COSTS AND BENEFITS Total PV of Operational Benefits	\$ 9,487,387	5 - 5	- \$	- \$	120,307 \$	353,080 \$	749,347 \$	768,080 \$	787,282 \$	806,9
Total PV of Customer Benefits	\$ 889,006,803			- \$		32,317,210 \$	70,301,865 \$	72,059,412 \$	73,860,897 \$	75,707,4
Total PV of Combined Benefits	\$ 898,494,190			- \$		32,670,291 \$	71,051,212 \$		74,648,180 \$	76,514,3
Total PV Program and On-Going Costs	\$ 361,548,093	904,378	56,889,638 \$	151,846,097 \$	145,254,875 \$	68,852,784 \$	- \$	- \$	- \$	
Combined NPV of Program	\$ 536,946,097	(904,378)	(56,889,638) \$	(151,846,097) \$	(134,391,548) \$	(36,182,493) \$	71,051,212 \$	72,827,492 \$	74,648,180 \$	76,514,
Ratio of NPV Benefits to NPV Costs	2.5									
Cumulative Net Benefits (Payback Period)		(904,378)	(57.794.016) \$	(209.640.113) \$	(344,031,661) \$	(380.214.154) \$	(309.162.942) \$	(236,335,450) \$	(161 687 270) \$	(85,172,8

age	8	of	31	
-----	---	----	----	--

PERIOD:	2024-2026									
REGULATORY JURISDICTION:	DEC									
STATE:	NC									
	NPV of COST/BENEFIT							YEAR		
	STREAM	2031	2032	2033	2034	2035	2036	2037	2038	2039
	<u> </u>	9	10	11	12	13	14	15	16	17
	_									
COSTS	4 240 577 677									
Program Capital Costs	\$ 319,677,077					- \$	- \$	- \$		
Program Capital Contingency Costs	\$ 35,073,081				- \$	- \$	- \$	- \$	- \$	
Total Program Capital Costs	\$ 354,750,158	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	
Program O&M Costs	\$ 6,797,936	- 5	- \$	- \$	- \$	- \$	- \$	- \$	- \$	
Total Program Costs	\$ 361,548,093	- \$				- \$	- \$	- \$		
21120140100	\$ - 5	- \$			- \$	- \$	- \$	- \$	- \$	
Total On-Going Costs	\$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	
OPERATIONAL BENEFITS										
Avoided Outage Benefits	\$ 9,487,387 \$	827,139 \$	847,817 \$	869,013 \$	890,738 \$	913,006 \$	935,831 \$	959,227 \$	983,208 \$	1,007,78
Total Operational Benefit	\$ 9,487,387 \$	827,139 \$	847,817 \$	869,013 \$	890,738 \$	913,006 \$	935,831 \$	959,227 \$	983,208 \$	1,007,78
CUSTOMER BENEFITS										
Avoided Sustained Outage Benefits (Non-MED) - Residential Customers	\$ 471,647 \$	41,169 \$	42,199 \$	43,254 \$	44,335 \$	45,443 \$	46,579 \$	47,744 \$	48,937 \$	50,16
Avoided Sustained Outage Benefits (Non-MED) - Small C&I Customers	\$ 11,134,278 \$	971,895 \$	The Part of the Pa	1,021,097 \$	1,046,624 \$	1,072,790 \$	1,099,610 \$	1,127,100 \$	1,155,278 \$	1,184,16
Avoided Sustained Outage Benefits (Non-MED) - Medium & Large C&I Customers	\$ - \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	-
Avoided Momentary Outage Benefits (Non-MED & MED) - Residential Customers	\$ 20,786,747 \$	1,814,445 \$	1,859,806 \$	1,906,301 \$	1,953,959 \$	2,002,808 \$	2,052,878 \$	2,104,200 \$	2,156,805 \$	2,210,72
Avoided Momentary Outage Benefits (Non-MED & MED) - Small C&I Customers	\$ 242,425,193 \$	21,160,941 \$		22,232,214 \$	22,788,019 \$	23,357,719 \$	23,941,662 \$	24,540,204 \$	25,153,709 \$	25,782,55
Avoided Momentary Outage Benefits (Non-MED & MED) - Medium & Large C&I Cus		53,611,655 \$		56,325,745 \$	57,733,889 \$	59,177,236 \$	60,656,667 \$	62,173,084 \$	63,727,411 \$	65,320,59
Total Customer Benefit	s \$ 889,006,803 \$	77,600,105 \$	79,540,108 \$	81,528,610 \$	83,566,826 \$	85,655,996 \$	87,797,396 \$	89,992,331 \$	92,242,139 \$	94,548,19
COMBINED COSTS AND BENEFITS										
Total PV of Operational Benefits	\$ 9,487,387 \$	827,139 \$	847,817 \$	869,013 \$	890,738 \$	913,006 \$	935,831 \$	959,227 \$	983,208 \$	1,007,78
Total PV of Customer Benefits	\$ 889,006,803 \$		The same of the sa	81,528,610 \$	83,566,826 \$	85,655,996 \$	87,797,396 \$	89,992,331 \$	92,242,139 \$	94,548,19
Total PV of Combined Benefits	\$ 898,494,190 \$			82,397,623 \$	84,457,564 \$	86,569,003 \$	88,733,228 \$	90,951,558 \$	93,225,347 \$	95,555,98
Total PV Program and On-Going Costs	\$ 361,548,093 _\$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	-
Combined NPV of Program	\$ 536,946,097 \$	78,427,244 \$	80,387,925 \$	82,397,623 \$	84,457,564 \$	86,569,003 \$	88,733,228 \$	90,951,558 \$	93,225,347 \$	95,555,98
Ratio of NPV Benefits to NPV Costs	2.5									
Cumulative Net Benefits (Payback Period)	\$	(6,745,642) \$	73,642,283 \$	156,039,906 \$	240,497,469 \$	327,066,472 \$	415,799,700 \$	506,751,258 \$	599,976,605 \$	695,532,58

Distribution H&R Lateral - 7a

AREA/PROJECT/PROGRAM

Page 9 of 31

AREA/PROJECT/PROGRAM	Distribution H&R Lateral - 7a									
PERIOD:	2024-2026									
REGULATORY JURISDICTION:	DEC									
STATE:	NC									
	NPV of COST/BENEFIT STREAM					- and		-, 6		
		2040	2041	2042	2043	2044	2045	2046	2047	2048
		18	19	20	21	22	23	24	25	26
COSTS										
Program Capital Costs	\$ 319,677,077	1 5 -	\$ -	\$ -	\$ - 5	- \$	- \$	\$ - \$	- \$	
Program Capital Contingency Costs	\$ 35,073,081	s .	\$ -		\$ - 5		- 5			
Total Program Capital Costs	\$ 354,750,158		\$ -		\$ - \$	- \$				
Program O&M Costs	\$ 6,797,936		\$ -	\$ -	s - s	- \$	- 5	s - \$	- \$	
Total Program Costs	\$ 361,548,093		\$ -		\$ - 5		- \$			
		1.								
Total On-Going Costs	\$ -	\$ -	\$ -	\$ -	\$ - \$	- \$	- \$		- \$	
PERATIONAL BENEFITS										
Avoided Outage Benefits	\$ 9,487,387	\$ 1,032,983	\$ 1,058,807	1,085,278	1,112,410 \$	1,140,220 \$	1,168,725 \$	1,197,943 \$	1,227,892 \$	1,258,58
Total Operational Benef	fits \$ 9,487,387	\$ 1,032,983	\$ 1,058,807	1,085,278	1,112,410 \$	1,140,220 \$	1,168,725 \$	1,197,943 \$	1,227,892 \$	1,258,589
CUSTOMER BENEFITS										
Avoided Sustained Outage Benefits (Non-MED) - Residential Customers	\$ 471,647	\$ 51,415	\$ 52,700 \$	54,018	55,368 \$	56,752 \$	58,171 \$	59,625 \$	61,116 \$	62,64
Avoided Sustained Outage Benefits (Non-MED) - Small C&I Customers	\$ 11,134,278	\$ 1,213,763				1,339,768 \$	1,373,262 \$	The state of the s		
Avoided Sustained Outage Benefits (Non-MED) - Medium & Large C&I Customers	\$ -	\$ -	\$ - 5			- \$	- \$	771000000000000000000000000000000000000	- \$	
Avoided Momentary Outage Benefits (Non-MED & MED) - Residential Customers	\$ 20,786,747	\$ 2,265,993	\$ 2,322,643	2,380,709	2,440,227 \$	2,501,232 \$	2,563,763 \$	2,627,857 \$	2,693,553 \$	2,760,89
Avoided Momentary Outage Benefits (Non-MED & MED) - Small C&I Customers	\$ 242,425,193		A STATE OF THE PARTY OF THE PAR			29,170,591 \$	29,899,856 \$			
Avoided Momentary Outage Benefits (Non-MED & MED) - Medium & Large C&I Co		\$ 66,953,611					75,751,865 \$			
Total Customer Benef	fits \$ 889,006,803	\$ 96,911,898	\$ 99,334,695	101,818,063	\$ 104,363,514 \$	106,972,602 \$	109,646,917 \$	112,388,090 \$	115,197,792 \$	118,077,73
COMBINED COSTS AND BENEFITS			G. Mariale V	a water to	L. Charles d	Same 2	4-74-5- 4	Automotive to		
Total PV of Operational Benefits	\$ 9,487,387					1,140,220 \$	1,168,725 \$			
Total PV of Customer Benefits	\$ 889,006,803		\$ 99,334,695						2017 THE RESIDENCE OF THE PROPERTY OF THE PROP	
Total PV of Combined Benefits	\$ 898,494,190	\$ 97,944,881	\$ 100,393,503	102,903,340	105,475,924 \$	108,112,822 \$	110,815,642 \$	113,586,033 \$	116,425,684 \$	119,336,32
Total PV Program and On-Going Costs	\$ 361,548,093	\$ -	\$ -	- 5	\$ - \$	- \$	- \$	- \$	- \$	

2.5

Combined NPV of Program

Ratio of NPV Benefits to NPV Costs

536,946,097 \$ 97,944,881 \$ 100,393,503 \$ 102,903,340 \$ 105,475,924 \$ 108,112,822 \$ 110,815,642 \$ 113,586,033 \$ 116,425,684 \$ 119,336,326

AREA/PROJECT/PROGRAM	Distribution H&R Lateral - 7a
PERIOD:	2024-2026
REGULATORY JURISDICTION:	DEC
STATE:	NC

	16	STREAM										TOTAL
				2049		2050		2051		2052		TOTAL
		- 0		27		28		29		30		
OSTS												
Program Capital Costs	\$	319,677,077	\$		\$	9	\$	1	\$		\$	374,673,38
Program Capital Contingency Costs	\$	35,073,081	\$		\$	-	\$		\$		\$	41,106,95
Total Program Capital Costs	\$	354,750,158	\$		\$		\$	-	\$		\$	415,780,3
Program O&M Costs	\$	6,797,936	\$	- Q	\$	1,0	\$	- 4	\$	- 2	\$	7,967,4
Total Program Costs	\$	361,548,093	\$		\$	*	\$	-	\$	7	\$	423,747,7
	\$		\$		\$		\$		\$		\$	
Total On-Going Costs	\$	2.0	\$	6	\$	Ť	\$	1	\$		\$	
PERATIONAL BENEFITS												
Avoided Outage Benefits	\$	9,487,387	\$	1,290,054	\$	1,322,305	\$	1,355,363	\$	1,389,247	\$	27,458,64
Total Operational Benefits	\$ \$	9,487,387	\$	1,290,054	\$	1,322,305	\$	1,355,363	\$	1,389,247	\$	27,458,64
NATIONAL DEPOSITS												
JSTOMER BENEFITS Avoided Sustained Outage Benefits (Non-MED) – Residential Customers	\$	471,647	\$	64,210	4	65,815	4	67,461	4	69,147	\$	1,365,98
Avoided Sustained Outage Benefits (Non-MED) - Small C&I Customers	Ś	11,134,278	\$	1,515,824		1,553,720		1,592,563		1,632,377	\$	32,247,20
Avoided Sustained Outage Benefits (Non-MED) - Medium & Large C&I Customers	\$		\$	-	\$	-	\$	-	\$	-	\$	1
Avoided Momentary Outage Benefits (Non-MED & MED) - Residential Customers	\$	20,786,747	\$	2,829,915	\$	2,900,663	\$	2,973,179	\$	3,047,509	\$	60,202,78
Avoided Momentary Outage Benefits (Non-MED & MED) - Small C&I Customers	\$	242,425,193	\$	33,003,846	\$	33,828,942	\$	34,674,666	\$	35,541,532	\$	702,114,29
Avoided Momentary Outage Benefits (Non-MED & MED) - Medium & Large C&I Cust	te \$	614,188,938	\$	83,615,885	\$	85,706,282	\$	87,848,939	\$	90,045,163	\$:	1,778,820,20
Total Customer Benefits	\$	889,006,803	\$	121,029,680	\$	124,055,422	\$	127,156,808	\$	130,335,728	\$ 2	2,574,750,47
DMBINED COSTS AND BENEFITS												
Total PV of Operational Benefits	\$	9,487,387	\$	1,290,054	\$	1,322,305	\$	1,355,363	\$	1,389,247	\$	27,458,64
Total PV of Customer Benefits	\$	889,006,803	\$	121,029,680	\$	124,055,422	\$	127,156,808	\$	130,335,728	\$ 2	2,574,750,47
Total PV of Combined Benefits	\$	898,494,190	\$	122,319,734	\$	125,377,728	\$	128,512,171	\$	131,724,975	\$ 2	2,602,209,12
Total PV Program and On-Going Costs	\$	361,548,093	\$	-	\$	-	\$	141	\$		\$	423,747,77
Combined NPV of Program	\$	536,946,097	\$	122,319,734	\$	125,377,728	\$	128,512,171	\$	131,724,975	\$ 2	2,178,461,34
Ratio of NPV Benefits to NPV Costs		2.5										
Cumulative Net Benefits (Payback Period)			\$:	1.792.846.475	Ś	1,918,224,203	\$	2.046.736.374	Ś	2.178.461.349	5	1 356 922 69

Duke Energy Carolinas, LLC
DOCKET NO. E-7, SUB 1276
Guyton Direct Exhibit 8 - MYRP Distribution - CBA - HR Laterals
4 of 4
Page 10 of 31

AREA/PROJECT/PROGRAM	Distribution H&R Public Int 7c
PERIOD:	2024-2026
REGULATORY JURISDICTION:	DEC
STATE:	NC

	NPV of COST/BENE STREAM	FIT										
			2022		2023	2024		2025		2026		2027
			0		1	2		3		4		5
OSTS												
Program Capital Costs	\$ 71,08	33,834 \$	431,505	\$	14,618,638	28,913,803	\$	29,479,475	\$	9,143,253	\$	
Program Capital Contingency Costs	\$ 7,7:	17,138 \$	46,846	\$	1,587,056 \$			3,200,406		992,627		
Total Program Capital Costs	\$ 78,80	00,972 \$	478,350	\$	16,205,695	32,052,798	\$	32,679,881	\$	10,135,880	\$	
Program O&M Costs	\$ 1,50	07,044 \$	9,148	\$	309,929	613,000	\$	624,993	\$	193,846	\$	
Total Program Costs	\$ 80,30	\$ \$	487,499	\$	16,515,623	32,665,798	\$	33,304,874		10,329,725	\$	-
	\$	- \$		\$	-	\$ -	\$		\$	4.	\$	
Total On-Going Costs	\$	- \$	-	\$	-	\$ -	\$	~	\$	7	\$	
PERATIONAL BENEFITS												
Avoided Outage Benefits	\$	- \$	-	\$	- \$	-	\$	+	\$		\$	-
Total Operational Benefits	\$	- \$		\$	- \$	(1) - 1) 4 -	\$	96	\$	*	\$	
CUSTOMER BENEFITS												
Avoided Sustained Outage Benefits (Non-MED) - Residential Customers	\$ 1,53	27,692 \$	+	\$	- \$	-	\$	14,190	\$	63,112	\$	120,61
Avoided Sustained Outage Benefits (Non-MED) - Small C&I Customers		32,625 \$		\$	- \$	4	\$	318,910		1,418,347		2,710,65
Avoided Sustained Outage Benefits (Non-MED) - Medium & Large C&I Customers	\$ 64,08	36,067 \$	-6	\$	- \$		\$	595,284	\$	2,647,519	\$	5,059,76
Total Customer Benefits	\$ 99,94	6,384 \$		\$	- \$		\$	928,384	\$	4,128,978	\$	7,891,03
OMBINED COSTS AND BENEFITS												
Total PV of Operational Benefits	\$	- \$		\$	- 0		\$		5		S	
Total PV of Customer Benefits		16,384 \$	-	Š	- \$	-	Ś	928,384	\$	4,128,978	\$	7,891,03
Total PV of Combined Benefits		16,384 \$		\$	- \$	-	\$	928,384	_	4,128,978	_	7,891,03
Total PV Program and On-Going Costs	\$ 80,30	8,016 \$	487,499	\$	16,515,623 \$	32,665,798	\$	33,304,874	\$	10,329,725	\$	
Combined NPV of Program	\$ 19,63	88,369 \$	(487,499)	\$	(16,515,623) \$	(32,665,798)	\$	(32,376,490)	\$	(6,200,748)	\$	7,891,03
Ratio of NPV Benefits to NPV Costs		1.2										

AREA/PROJECT/PROGRAM	Distribution H&R Public Int 7c
PERIOD:	2024-2026
REGULATORY JURISDICTION:	DEC
STATE:	NC

		_													
	NPV of COST/BENEFI STREAM	T			5.0-										
	JIRLAW		2028		2029		2030		2031		2032		2033		2034
			6		7		8		9		10		11		12
COSTS															
Program Capital Costs	\$ 71,083	,834	\$ -	\$	100	\$		\$	-	\$	- 2	\$	-	\$	
Program Capital Contingency Costs	\$ 7,717	,138	\$ -	\$	-	\$	-	\$	-	\$	-	\$	-	\$	
Total Program Capital Costs	\$ 78,800	,972	\$ -	\$	- 1	\$	9	\$	-	\$	-	\$	-	\$	
Program O&M Costs	\$ 1,507	,044	\$	\$	-	\$		\$	-	\$	-	\$	-	\$	
Total Program Costs	\$ 80,308	,016	\$ -	\$		\$		\$	-	\$	-	\$	-	\$	
	\$	- (\$ -	\$		\$		\$		\$		\$	-	\$	
Total On-Going Costs	\$	-	\$ -	\$	-	\$	7	\$		\$	9	\$	-	\$	
PERATIONAL BENEFITS															
Avoided Outage Benefits	\$	- \$	-	\$	- 4	\$	-	\$	9	\$	-	\$	(~	\$	
Total Operational Benefits	\$	\$		\$	*	\$	1.4	\$	7.	\$		\$	*	\$	
CUSTOMER BENEFITS															
Avoided Sustained Outage Benefits (Non-MED) - Residential Customers	\$ 1,527	,692 \$	123,631	\$	126,722	\$	129,890	\$	133,137	\$	136,465	\$	139,877	\$	143,37
Avoided Sustained Outage Benefits (Non-MED) - Small C&I Customers		,625 \$			2,847,881	\$	2,919,078		2,992,055		3,066,856		3,143,528		3,222,11
Avoided Sustained Outage Benefits (Non-MED) - Medium & Large C&I Customers	\$ 64,086	,067 \$	5,186,263	\$	5,315,920	\$	5,448,818	\$	5,585,038	\$	5,724,664	\$	5,867,781	\$	6,014,47
Total Customer Benefits	\$ 99,946	,384 \$	8,088,315	\$	8,290,523	\$	8,497,786	\$	8,710,230	\$	8,927,986	\$	9,151,186	\$	9,379,96
OMBINED COSTS AND BENEFITS															
Total PV of Operational Benefits	\$	- \$	-	5		\$		\$		5		\$	_	\$	_
Total PV of Customer Benefits		,384 \$		-	8,290,523		8,497,786		8,710,230	\$	8,927,986	100	9,151,186		9,379,96
Total PV of Combined Benefits		,384 \$		_	8,290,523	_	8,497,786	_	8,710,230		8,927,986		9,151,186	_	9,379,96
Total PV Program and On-Going Costs	\$ 80,308	,016 \$		\$		\$		\$		\$	- 4	\$	- 5	\$	-
Combined NPV of Program	\$ 19,638	,369 \$	8,088,315	\$	8,290,523	\$	8,497,786	\$	8,710,230	\$	8,927,986	\$	9,151,186	\$	9,379,96
Ratio of NPV Benefits to NPV Costs		1.2													

AREA/PROJECT/PROGRAM	Distribution H&R Public Int 7c
PERIOD:	2024-2026
REGULATORY JURISDICTION:	DEC
STATE:	NC

	NPV of COST/BENEFIT STREAM						YEAR					Service of	
			2035		2036		2037	2038		2039		2040	2041
			13		14		15	16		17		18	19
OSTS													
Program Capital Costs	\$ 71,083,834	\$		\$	14	\$		\$ -	\$		\$	-	\$
Program Capital Contingency Costs	\$ 7,717,138	\$	-	\$	14.	\$	6	\$ -	\$	-	\$	-	\$
Total Program Capital Costs	\$ 78,800,972	\$		\$	17	\$		\$ 	\$	4	\$	-	\$
Program O&M Costs	\$ 1,507,044	\$	- 5	\$	4	\$		\$ -	\$	-	\$	-	\$
Total Program Costs	\$ 80,308,016	\$		\$		\$		\$	\$		\$	-	\$
	\$ -	\$		\$		\$	_	\$ -	\$		\$	Y	\$
Total On-Going Costs	\$ -	\$	н	\$	-	\$,	\$ 	\$	191	\$	-	\$
PERATIONAL BENEFITS													
Avoided Outage Benefits	\$	\$	-	\$	-	\$	-	\$ 9	\$	-	\$	(~	\$
Total Operational Benefits	\$ -	- \$		\$		\$		\$ -	\$		\$	*	\$
USTOMER BENEFITS													
Avoided Sustained Outage Benefits (Non-MED) - Residential Customers	\$ 1,527,692	\$	146,958	\$	150,632	\$	154,398	\$ 158,258	\$	162,214	\$	166,270	\$ 170,42
Avoided Sustained Outage Benefits (Non-MED) - Small C&I Customers	\$ 34,332,625	\$	3,302,669	\$	3,385,235	\$	3,469,866	\$ 3,556,613	\$	3,645,528	\$	3,736,667	\$ 3,830,08
Avoided Sustained Outage Benefits (Non-MED) - Medium & Large C&I Customers	\$ 64,086,067		6,164,837	\$	6,318,958		6,476,932	6,638,856		6,804,827		6,974,948	7,149,32
Total Customer Benefits	\$ 99,946,384	\$	9,614,464	\$	9,854,826	\$	10,101,197	\$ 10,353,727	\$	10,612,570	\$	10,877,884	\$ 11,149,83
OMBINED COSTS AND BENEFITS													
Total PV of Operational Benefits	\$	\$		\$		\$		\$ _	S		5		\$
Total PV of Customer Benefits	\$ 99,946,384		9,614,464		9,854,826	\$	10,101,197	\$ 10,353,727	\$	10,612,570	\$	10,877,884	11,149,83
Total PV of Combined Benefits	\$ 99,946,384	_	9,614,464	_	9,854,826	_	10,101,197	\$ 10,353,727		10,612,570		10,877,884	 11,149,83
Total PV Program and On-Going Costs	\$ 80,308,016	\$		\$		\$	-	\$ 	\$		\$		\$
Combined NPV of Program	\$ 19,638,369	\$	9,614,464	\$	9,854,826	\$	10,101,197	\$ 10,353,727	\$	10,612,570	\$	10,877,884	\$ 11,149,83
Ratio of NPV Benefits to NPV Costs	1.2												

AREA/PROJECT/PROGRAM	Distribution H&R Public Int 7c
PERIOD:	2024-2026
REGULATORY JURISDICTION:	DEC
STATE:	NC

	NPV of COST/BENEFIT STREAM												
			2042		2043	2044		2045		2046		2047	2048
			20		21	22		23		24		25	26
OSTS													
Program Capital Costs	\$ 71,083,834	\$		\$	9.	\$ 1	\$	-	\$	-	\$	-	\$
Program Capital Contingency Costs	\$ 7,717,138	\$		\$	-	\$ -	\$	1.5	\$		\$	-	\$
Total Program Capital Costs	\$ 78,800,972	\$		\$	- 1	\$ 9	\$	-	\$	- 1	\$	-1	\$
Program O&M Costs	\$ 1,507,044	\$		\$	- 9	\$ 	\$	-	\$	-	\$	-	\$
Total Program Costs	\$ 80,308,016	\$		\$		\$ 	\$		\$		\$	-	\$
	\$ -	\$		\$		\$	\$	_	\$		\$	-	\$
Total On-Going Costs	\$ -	\$. 4	\$	-	\$	\$		\$	191	\$	-	\$
PERATIONAL BENEFITS	1												
Avoided Outage Benefits	\$	\$	-	\$	-	\$ -	\$	9	\$	-	\$	(+)	\$
Total Operational Benefits	\$ -	- \$		\$		\$ 	\$		\$		\$	*	\$
USTOMER BENEFITS													
Avoided Sustained Outage Benefits (Non-MED) - Residential Customers	\$ 1,527,692	\$	174,687	\$	179,054	\$ 183,531	\$	188,119	\$	192,822	\$	197,642	\$ 202,58
Avoided Sustained Outage Benefits (Non-MED) - Small C&I Customers	\$ 34,332,625	\$	3,925,835	\$	4,023,981	\$ 4,124,581	\$	4,227,695	\$	4,333,388	\$	4,441,722	\$ 4,552,76
Avoided Sustained Outage Benefits (Non-MED) - Medium & Large C&I Customers	\$ 64,086,067		7,328,054		7,511,256	\$ 7,699,037		7,891,513		8,088,801		8,291,021	\$ 8,498,29
Total Customer Benefits	\$ 99,946,384	\$	11,428,577	\$	11,714,291	\$ 12,007,149	\$	12,307,327	\$	12,615,010	\$	12,930,386	\$ 13,253,64
OMBINED COSTS AND BENEFITS													
Total PV of Operational Benefits	\$	Ś		\$		\$ -	\$		5		5		\$
Total PV of Customer Benefits	\$ 99,946,384		11,428,577		11,714,291	12,007,149		12,307,327	\$	12,615,010	Š	12,930,386	13,253,64
Total PV of Combined Benefits	\$ 99,946,384		11,428,577	_	11,714,291	12,007,149	_	12,307,327		12,615,010		12,930,386	13,253,64
Total PV Program and On-Going Costs	\$ 80,308,016	\$	-	\$		\$	\$		\$		\$		\$
Combined NPV of Program	\$ 19,638,369	\$	11,428,577	\$	11,714,291	\$ 12,007,149	\$	12,307,327	\$	12,615,010	\$	12,930,386	\$ 13,253,64
Ratio of NPV Benefits to NPV Costs	1.2												

AREA/PROJECT/PROGRAM	Distribution H&R Public Int 7c
PERIOD:	2024-2026
REGULATORY JURISDICTION:	DEC
STATE:	NC

	NPV of COST/BENEFIT STREAM								
			2049		2050		2051		2052
			27		28		29		30
OSTS		_							
Program Capital Costs	\$ 71,083,83			\$		\$		\$	
Program Capital Contingency Costs	\$ 7,717,13	_	- 1	\$	10	\$		\$	
Total Program Capital Costs	\$ 78,800,97	2 \$	- 3	\$	1	\$	9	\$	
Program O&M Costs	\$ 1,507,04	4 \$		\$	4	\$		\$	
Total Program Costs	\$ 80,308,01	6 \$		\$	7	\$		\$	-
	\$ -	\$		\$		\$	-	\$	
Total On-Going Costs	\$ -	\$		\$	-	\$	3	\$	
PERATIONAL BENEFITS	1								
Avoided Outage Benefits	\$	\$	-	\$		\$		\$	
Total Operational Benefit	s_\$ -	\$		\$		\$		3	-
USTOMER BENEFITS									
Avoided Sustained Outage Benefits (Non-MED) - Residential Customers	\$ 1,527,69		207,648	\$	212,839		218,160	\$	223,614
Avoided Sustained Outage Benefits (Non-MED) - Small C&I Customers	\$ 34,332,62	10.0	4,666,585		4,783,249		4,902,830		5,025,40
Avoided Sustained Outage Benefits (Non-MED) - Medium & Large C&I Customers	\$ 64,086,06	100	8,710,754		8,928,523		9,151,736		9,380,529
Total Customer Benefit	s \$ 99,946,38	4 \$	13,584,987	\$	13,924,611	\$	14,272,726	\$	14,629,54
OMBINED COSTS AND BENEFITS									
Total PV of Operational Benefits	\$ -	Ś		5		Ś		S	
Total PV of Customer Benefits	\$ 99,946,38	4 \$	13,584,987		13,924,611	\$	14,272,726	\$	14,629,545
Total PV of Combined Benefits	\$ 99,946,38		13,584,987	\$	13,924,611		14,272,726		14,629,54
Total PV Program and On-Going Costs	\$ 80,308,01	6 \$		\$		\$		\$	
Combined NPV of Program	\$ 19,638,36	9 \$	13,584,987	\$	13,924,611	\$	14,272,726	\$	14,629,54
Ratio of NPV Benefits to NPV Costs	1.	2							

AREA/PROJECT/PROGRAM	Distribution H&R Storm - 7b
PERIOD:	2024-2026
REGULATORY JURISDICTION:	DEC
STATE:	NC

	NPV of COST/BENEFIT											
	STREAM			_		_		200000	_			
			2022	-	2023	-	2024	2025		2026	2027	2028
			0		1		2	3		4	5	6
COSTS		_										
Program Capital Costs	\$ 36,974,775	100		- \$	4,002,757	\$	13,664,601 \$	15,077,677	\$	11,235,699 \$		\$
Program Capital Contingency Costs	\$ 4,067,225	_		- \$	440,303	\$	1,503,106 \$	1,658,544	\$	1,235,927 \$		\$
Total Program Capital Costs	\$ 41,042,000	\$		- \$	4,443,060	\$	15,167,707 \$	16,736,221	\$	12,471,626 \$		\$
Program O&M Costs	\$ 791,975	\$		- \$	85,736	\$	292,687 \$	322,954	\$	240,661 \$	-	\$
Total Program Costs	\$ 41,833,976	\$		- \$	4,528,797	\$	15,460,394 \$	17,059,175	\$	12,712,287 \$		\$
	\$	\$		\$		\$	- \$		\$	- \$		\$
Total On-Going Costs	\$	\$	-	- \$		\$	- \$		\$	- \$	-	\$
OPERATIONAL BENEFITS		_										
Avoided Outage Benefits	\$ 2,201,659			\$	+	\$	- \$	11,560		67,571 \$	175,923	
Total Operational Benefit	ts \$ 2,201,659	5	3	\$	-	Ş	- \$	11,560	\$	67,571 \$	175,923	180,32
CUSTOMER BENEFITS												
Avoided Sustained Outage Benefits (Non-MED) - Residential Customers	\$ 451,898	\$ \$		S	-	\$	- \$	2,260	5	13,542 \$	36,137	37,04
Avoided Sustained Outage Benefits (Non-MED) - Small C&I Customers	\$ 12,215,374			Ś	2	\$	- \$	61,095		366,046 \$	976,838	
Avoided Sustained Outage Benefits (Non-MED) - Medium & Large C&I Customer			5	\$	2	\$	- \$	104,669		627,115 \$	1,673,533	
Avoided Sustained Outage Benefits (MED) - Residential Customers	\$ 1,463,999	\$	2	\$	2	\$	- \$	7,322	\$	43,870 \$	117,073	120,00
Avoided Sustained Outage Benefits (MED) - Small C&I Customers	\$ 56,279,522	\$	-	\$	-	\$	- \$	281,482	\$	1,686,470 \$	4,500,555	4,613,06
Avoided Sustained Outage Benefits (MED) - Medium & Large C&I Customers	\$ 74,405,811	\$	4	\$	-	\$	- \$	372,141	\$	2,229,642 \$	5,950,076	6,098,82
Total Customer Benefit	ts \$ 165,744,170	\$		\$		\$	- \$	828,971	\$	4,966,685 \$	13,254,213	13,585,56
COMBINED COSTS AND BENEFITS												
Total PV of Operational Benefits	\$ 2,201,659	5	- 2	\$	5.7	\$	- \$	11,560	5	67,571 \$	175,923	180,32
Total PV of Customer Benefits	\$ 165,744,170			Ś		Ś	- \$	828,971		4,966,685 \$	13,254,213	
Total PV of Combined Benefits	\$ 167,945,829		-	\$		\$	- \$	840,530		5,034,255 \$	13,430,136	
Total PV Program and On-Going Costs	\$ 41,833,976	\$	- 3	\$	4,528,797	\$	15,460,394 \$	17,059,175	\$	12,712,287 \$		
Combined NPV of Program	\$ 126,111,853	\$ \$		\$	(4,528,797)	\$	(15,460,394) \$	(16,218,645)	\$	(7,678,032) \$	13,430,136	13,765,88
Ratio of NPV Benefits to NPV Costs	4.0											
Ratio of NPV Bellents to NPV Costs	4.0											
Cumulative Net Benefits (Payback Period)		\$	-	\$	(4,528,797)	\$	(19,989,191) \$	(36,207,835)	\$	(43,885,867) \$	(30,455,732)	(16,689,84

AREA/PROJECT/PROGRAM	Distribution H&R Storm - 7b
PERIOD:	2024-2026
REGULATORY JURISDICTION:	DEC
STATE:	NC

	NPV of COST/BENEFIT														
	STREAM		2020		020		2021		2022		2022		2024		2025
			7		8		9		2032 10		2033		2034 12		2035
OSTS		-				45								10	
Program Capital Costs	\$ 36,974,775	\$		\$	1-	\$	-	\$		\$	-	\$	-	\$	
Program Capital Contingency Costs	\$ 4,067,225	\$		\$	-	\$	-	\$		\$	-	\$		\$	
Total Program Capital Costs	\$ 41,042,000	\$	-	\$	-	\$	-	\$	-	\$	-	\$	-	\$	
Program O&M Costs	\$ 791,975	\$	-	\$	- 14	\$		\$		\$		\$		\$	
Total Program Costs	\$ 41,833,976	\$		\$	-	\$		\$	- 3	\$	-	\$	•	\$	
	\$ -	\$	2	\$		\$	-	\$	- 2	\$	1/2	\$		\$	
Total On-Going Costs	\$ -	\$	-	\$	~	\$	7	\$	757	\$	-	\$	-	\$	
PERATIONAL BENEFITS		_													
Avoided Outage Benefits	\$ 2,201,659		184,829		189,450		194,186		199,041	15	204,017	_	209,117		214,34
Total Operational Benefit	s \$ 2,201,659	- \$	184,829	Ş	189,450	\$	194,186	\$	199,041	Ş	204,017	\$	209,117	Ş	214,34
USTOMER BENEFITS															
Avoided Sustained Outage Benefits (Non-MED) - Residential Customers	\$ 451,898	15	37,967	Ś	38,916	\$	39,889	5	40,886	5	41,908	\$	42,956	\$	44,03
Avoided Sustained Outage Benefits (Non-MED) - Small C&I Customers	\$ 12,215,374	100	1,026,290		1,051,947		1,078,246		1,105,202	15	1,132,832		1,161,153		1,190,18
Avoided Sustained Outage Benefits (Non-MED) - Medium & Large C&I Customers			1,758,256		1,802,212		1,847,268		1,893,449		1,940,786		1,989,305		2,039,03
Avoided Sustained Outage Benefits (MED) - Residential Customers	\$ 1,463,999	\$	123,000	\$	126,075	\$	129,227	\$	132,457	\$	135,769	\$	139,163	\$	142,64
Avoided Sustained Outage Benefits (MED) - Small C&I Customers	\$ 56,279,522	\$	4,728,396	\$ 4	4,846,605	\$	4,967,771	\$	5,091,965	\$	5,219,264	\$	5,349,746	\$	5,483,48
Avoided Sustained Outage Benefits (MED) - Medium & Large C&I Customers	\$ 74,405,811	\$	6,251,299		5,407,581		6,567,771	\$	6,731,965	\$	6,900,264	\$	7,072,771	\$	7,249,59
Total Customer Benefit	s \$ 165,744,170	\$	13,925,207	\$ 14	1,273,337	\$	14,630,171	\$	14,995,925	\$	15,370,823	\$	15,755,094	\$	16,148,97
OMBINED COSTS AND BENEFITS															
Total PV of Operational Benefits	\$ 2,201,659	Ś	184,829	s	189,450	\$	194,186	5	199,041	5	204,017	\$	209,117	5	214,34
Total PV of Customer Benefits	\$ 165,744,170		13,925,207		4,273,337		14,630,171		14,995,925	S	15,370,823				16,148,97
Total PV of Combined Benefits	\$ 167,945,829		14,110,036		1,462,787		14,824,357	_	15,194,966	\$	15,574,840		15,964,211		16,363,31
Total PV Program and On-Going Costs	\$ 41,833,976	\$		\$		\$		\$		\$		\$		\$	-
Combined NPV of Program	\$ 126,111,853	\$	14,110,036	\$ 14	1,462,787	\$	14,824,357	\$	15,194,966	\$	15,574,840	\$	15,964,211	\$	16,363,31
Ratio of NPV Benefits to NPV Costs	4.0	Ū.													
Cumulative Net Benefits (Payback Period)		\$	(2,579,806)	\$ 11	1,882,981	\$	26,707,338	\$	41,902,303	\$	57,477,143	\$	73,441,354	\$	89,804,6

AREA/PROJECT/PROGRAM	Distribution H&R Storm - 7b
PERIOD:	2024-2026
REGULATORY JURISDICTION:	DEC
STATE:	NC

	NPV of COST/BENEFIT				YEAR										
	STREAM		2036		2037		2038		2039		2040		2041		2042
			14		15		16		17		18		19		20
OSTS															
Program Capital Costs	\$ 36,974,775	- 100	-	\$	1-	\$	-	\$	- 4	\$	-	\$	4	\$	
Program Capital Contingency Costs	\$ 4,067,22			\$	-	\$	-	\$		\$	-	\$		\$	
Total Program Capital Costs	\$ 41,042,000	\$	- (-)	\$	-	\$	-	\$	-	\$	-	\$		\$	
Program O&M Costs	\$ 791,97		-	\$		\$	-	\$	14	\$	[4	\$		\$	
Total Program Costs	\$ 41,833,970	\$		\$		\$		\$	-	\$	÷	\$	•	\$	
	\$ -	\$	- 5	\$		\$	- 4	\$	- 2	\$	- 42	\$		\$	
Total On-Going Costs	\$	\$	-	\$	~	\$	7	\$	7	\$	-	\$	-	\$	
PERATIONAL BENEFITS		_													
Avoided Outage Benefits	\$ 2,201,659		219,704	_	225,196		230,826		236,597		242,512		248,575		254,78
Total Operational Benefits	2,201,659	, ,	219,704	Þ	225,196	Þ	230,826	>	236,597	Þ	242,512	Þ	248,575	Þ	254,78
USTOMER BENEFITS															
Avoided Sustained Outage Benefits (Non-MED) - Residential Customers	\$ 451,898	3 \$	45,131	\$	46,259	\$	47,415	\$	48,601	\$	49,816	\$	51,061	\$	52,33
Avoided Sustained Outage Benefits (Non-MED) - Small C&I Customers	\$ 12,215,374		1,219,937	\$	1,250,435		1,281,696	\$	1,313,738		1,346,582	\$	1,380,246		1,414,7
Avoided Sustained Outage Benefits (Non-MED) - Medium & Large C&I Customers	\$ 20,927,560	5 \$	2,090,014	\$	2,142,264	\$	2,195,821	\$	2,250,716	\$	2,306,984	\$	2,364,659	\$	2,423,7
Avoided Sustained Outage Benefits (MED) - Residential Customers	\$ 1,463,999	\$	146,208	\$	149,863	\$	153,610	\$	157,450	\$	161,386	\$	165,421	\$	169,5
Avoided Sustained Outage Benefits (MED) - Small C&I Customers	\$ 56,279,522	2 \$	5,620,576	\$	5,761,091	\$	5,905,118	\$	6,052,746	\$	6,204,065	\$	6,359,166	\$	6,518,1
Avoided Sustained Outage Benefits (MED) - Medium & Large C&I Customers	\$ 74,405,81	1 \$	7,430,830	\$	7,616,601	\$	7,807,016	\$	8,002,191	\$	8,202,246	\$	8,407,302	\$	8,617,4
Total Customer Benefits	\$ 165,744,170	\$	16,552,695	\$	16,966,513	\$	17,390,676	\$	17,825,442	\$	18,271,079	\$	18,727,856	\$	19,196,0
OMBINED COSTS AND BENEFITS															
Total PV of Operational Benefits	\$ 2,201,659	9 5	219,704	\$	225,196	\$	230,826	\$	236,597	\$	242,512	\$	248,575	\$	254,78
Total PV of Customer Benefits	\$ 165,744,170		16,552,695		16,966,513		17,390,676		17,825,442		18,271,079		18,727,856		19,196,0
Total PV of Combined Benefits	\$ 167,945,829		16,772,399		17,191,709	_	17,621,502		18,062,039		18,513,590	-	18,976,430		19,450,8
Total PV Program and On-Going Costs	\$ 41,833,976	\$		\$	÷	\$		\$	÷	\$	-	\$		\$	
Combined NPV of Program	\$ 126,111,85	3 \$	16,772,399	\$	17,191,709	\$	17,621,502	\$	18,062,039	\$	18,513,590	\$	18,976,430	\$	19,450,8
Ratio of NPV Benefits to NPV Costs	4.0														

\$ 106,577,069 \$ 123,768,778 \$ 141,390,280 \$ 159,452,319 \$ 177,965,909 \$ 196,942,339 \$ 216,393,180

AREA/PROJECT/PROGRAM	Distribution H&R Storm - 7b
PERIOD:	2024-2026
REGULATORY JURISDICTION:	DEC
STATE:	NC

	NPV of COST/BENEFIT													
	STREAM		2042		2044		2045	_			2017		2242	2010
			2043		2044		2045		2046		2047		2048	2049
							2.5				23		20	
COSTS		_												
Program Capital Costs	\$ 36,974,775	100	-	\$	1-	\$	-	\$	-4	\$	-	\$	4	\$
Program Capital Contingency Costs	\$ 4,067,225	-		\$	-	\$	-	\$		\$	-	\$		\$
Total Program Capital Costs	\$ 41,042,000	\$		\$	-	\$	-	\$	100	\$	-	\$	-	\$
Program O&M Costs	\$ 791,975			\$	-	\$		\$		\$	1-	\$		\$
Total Program Costs	\$ 41,833,976	\$		\$	-	\$		\$		\$		\$	4	\$
	\$ -	\$	- 5	\$	- 6	\$	5	\$		\$		\$		\$ _ =
Total On-Going Costs	\$ -	\$	-	\$	~	\$		\$	-	\$	-	\$	-	\$
DPERATIONAL BENEFITS														
Avoided Outage Benefits	\$ 2,201,659	\$	261,159	\$	267,688	\$	274,380	\$	281,239	\$	288,270	\$	295,477	\$ 302,86
Total Operational Benefits	\$ 2,201,659	\$	261,159	\$	267,688	\$	274,380	\$	281,239	\$	288,270	\$	295,477	\$ 302,86
CUSTOMER BENEFITS	AT4 000	7.0	F2 545		F 4 007		56 353	4	F2 224		E0 245		50 505	62.24
Avoided Sustained Outage Benefits (Non-MED) - Residential Customers	\$ 451,898	11.75%	53,646		54,987		56,362		57,771		59,215		60,696	62,21
Avoided Sustained Outage Benefits (Non-MED) - Small C&I Customers Avoided Sustained Outage Benefits (Non-MED) - Medium & Large C&I Customers	\$ 12,215,374 \$ 20,927,566		1,450,121 2,484,370	-0	1,486,374 2,546,479		1,523,534 2,610,141	7	1,561,622 2,675,395		1,600,662 2,742,279		1,640,679 2,810,836	1,681,69 2,881,10
Avoided Sustained Outage Benefits (MED) - Residential Customers	\$ 1,463,999	\$	173,795	\$	178,140	\$	182,594	\$	187,159	\$	191,838	\$	196,634	\$ 201,54
Avoided Sustained Outage Benefits (MED) - Small C&I Customers	\$ 56,279,522	\$	6,681,099	\$	6,848,127	\$	7,019,330	\$	7,194,813	\$	7,374,683	\$	7,559,050	\$ 7,748,02
Avoided Sustained Outage Benefits (MED) - Medium & Large C&I Customers	\$ 74,405,811	1000	8,832,922		9,053,745		9,280,088		9,512,090	\$	9,749,893		9,993,640	10,243,48
Total Customer Benefits	\$ 165,744,170	\$	19,675,953	\$ 2	20,167,852	\$	20,672,048	\$	21,188,850	\$	21,718,571	\$	22,261,535	\$ 22,818,07
COMBINED COSTS AND BENEFITS														
Total PV of Operational Benefits	\$ 2,201,659	S	261,159	Ś	267,688	\$	274,380	5	281,239	5	288,270	\$	295,477	\$ 302,86
Total PV of Customer Benefits	\$ 165,744,170		19,675,953		20,167,852		20,672,048		21,188,850		21,718,571		22,261,535	22,818,07
Total PV of Combined Benefits	\$ 167,945,829		19,937,112		20,435,540	_	20,946,428	_	21,470,089		22,006,841	_	22,557,012	23,120,93
Total PV Program and On-Going Costs	\$ 41,833,976	\$		\$	-	\$		\$	<u>.</u>	\$		\$		\$ - Jės
Combined NPV of Program	\$ 126,111,853	\$	19,937,112	\$ 2	20,435,540	\$	20,946,428	\$	21,470,089	\$	22,006,841	\$	22,557,012	\$ 23,120,93
Ratio of NPV Benefits to NPV Costs	4.0													

\$ 236,330,292 \$ 256,765,832 \$ 277,712,260 \$ 299,182,348 \$ 321,189,189 \$ 343,746,202 \$ 366,867,139

AREA/PROJECT/PROGRAM	Distribution H&R Storm - 7b
PERIOD:	2024-2026
REGULATORY JURISDICTION:	DEC
STATE:	NC

	The second second	OST/BENEFIT REAM								-5.00
	311	- All		2050		2051		2052		TOTAL
				28		29		30		
COSTS								1		
Program Capital Costs	\$	36,974,775	\$	-	\$	-	\$	-	\$	43,980,734
Program Capital Contingency Costs	\$	4,067,225	\$	-	\$		\$	-	\$	4,837,88
Total Program Capital Costs	\$	41,042,000	\$		\$		\$	1.0	\$	48,818,61
Program O&M Costs	\$	791,975	\$	-	\$		\$	- 4	\$	942,03
Total Program Costs	\$	41,833,976	\$		\$		\$	1.	\$	49,760,65
	\$	4	\$		\$		\$	- 4	\$	
Total On-Going Costs	\$	3	\$		\$	-	\$	-	\$	
OPERATIONAL BENEFITS				210122				luze(/ex)		12/46/01/11
Avoided Outage Benefits Total Operational Benefits	\$	2,201,659 2,201,659	_	310,435 310,435	_	318,196 318,196	_	326,151 326,151	\$	6,414,416
CUSTOMER BENEFITS							- 2			
Avoided Sustained Outage Benefits (Non-MED) - Residential Customers	\$	451,898	100	63,768		65,362		66,997	\$	1,317,167
Avoided Sustained Outage Benefits (Non-MED) - Small C&I Customers	\$	12,215,374	\$	1,723,738	-	1,766,832		1,811,003	\$	35,604,73
Avoided Sustained Outage Benefits (Non-MED) - Medium & Large C&I Customers	\$	20,927,566	>	2,953,135	>	3,026,963	Þ	3,102,637	\$	60,998,58
Avoided Sustained Outage Benefits (MED) - Residential Customers	\$	1,463,999	\$	206,588	\$	211,753	\$	217,047	\$	4,267,189
Avoided Sustained Outage Benefits (MED) - Small C&I Customers	\$	56,279,522	\$	7,941,727	\$	8,140,271	\$	8,343,777	\$	164,040,62
Avoided Sustained Outage Benefits (MED) - Medium & Large C&I Customers	\$	74,405,811	\$	10,499,568	-	10,762,057		11,031,109	\$	216,874,19
Total Customer Benefits	\$	165,744,170	\$	23,388,525	\$	23,973,238	\$	24,572,569	\$	483,102,492
COMBINED COSTS AND BENEFITS										
Total PV of Operational Benefits	\$	2,201,659	\$	310,435	\$	318,196	\$	326,151	\$	6,414,416
Total PV of Customer Benefits	\$	165,744,170	\$	23,388,525	\$	23,973,238	\$	24,572,569	\$	483,102,492
Total PV of Combined Benefits	\$	167,945,829	\$	23,698,961	\$	24,291,435	\$	24,898,721	\$	489,516,908
Total PV Program and On-Going Costs	\$	41,833,976	\$		\$		\$	-	\$	49,760,65
Combined NPV of Program	\$	126,111,853	\$	23,698,961	\$	24,291,435	\$	24,898,721	\$	439,756,255
Ratio of NPV Benefits to NPV Costs		4.0								
Cumulative Not Panefits (Payback Paried)			ċ	200 ECC 400	¢	44.4 057.534	¢	420 7EC 2EC		970 543 544
Cumulative Net Benefits (Payback Period)			\$	390,566,100	5	414,857,534	Ş	439,756,255	3	879,512,510

AREA/PROJECT/PROGRAM	Long Duration Interruption (LDI) - 10
PERIOD:	2024-2026
REGULATORY JURISDICTION:	DEC
STATE:	NC

	NPV of COST/BENEFIT											
	STREAM	2022	-	2023		2024	2025	1	2026	2027	_	2028
		0		1		2	3		4	5		6
COSTS												
Program Capital Costs	\$ 17,157,123	\$ 17,216	\$	6,608,495	\$	4,225,860 \$	4,165,292	\$	4,861,677	\$ -	\$	
Program Capital Contingency Costs	\$ 1,858,473	\$ 1,865		715,837		457,748 \$	451,188		526,621		\$	
Total Program Capital Costs	\$ 19,015,596	\$ 19,081	\$	7,324,332	\$	4,683,608 \$	4,616,480	\$	5,388,298	\$ -	\$	-
Program O&M Costs	\$ 683,560	\$ 686	5 \$	263,290	\$	168,363 \$	165,950	\$	193,695	\$ -	\$	
Total Program Costs	\$ 19,699,156	\$ 19,767	\$	7,587,622	\$	4,851,972 \$	4,782,430	\$	5,581,993	\$ -	\$	
	\$ -	\$ -	\$		\$	- \$	-	\$		\$ -	\$	-
Total On-Going Costs	\$ -	\$ -	\$	~	\$	- \$		\$	-	\$	\$	7
OPERATIONAL BENEFITS												
Avoided Outage Benefits	\$ 203,202	\$ -	\$	-	\$	- \$	4,439		7,879			16,300
Avoided Vegetation Management Benefits Total Operational Benefits	\$ 508,006 s \$ 711,208	\$ -	\$	-	\$	- \$ - \$	11,097 15,536		19,699 27,578			40,751 57,05 1
Avoided Sustained Outage Benefits (Non-MED) - Residential Customers Avoided Sustained Outage Benefits (Non-MED) - Small C&I Customers Avoided Sustained Outage Benefits (Non-MED) - Medium & Large C&I Customers	\$ 1,694,870 \$ 48,047,743 \$ 80,920,778		\$ \$	+	\$ \$ \$	- \$ - \$	35,296 1,000,591 1,685,169	\$	64,221 1,820,606 3,066,218	\$ 3,766,309	\$	136,177 3,860,467 6,501,699
		7	7		7	*						
Avoided Sustained Outage Benefits (MED) - Residential Customers	\$ 2,079,379	\$ -	\$	-	\$	- \$	43,303	177	78,791			167,071
Avoided Sustained Outage Benefits (MED) - Small C&I Customers	\$ 81,901,508	\$	\$	-	\$	- \$	1,705,593		3,103,379			6,580,497
Avoided Sustained Outage Benefits (MED) - Medium & Large C&I Customers Total Customer Benefits	\$ 104,854,765 s \$ 319,499,044	\$ -	\$		\$	- \$	2,183,593 6,653,544		3,973,115 12,106,331			8,424,710 25,670,621
COMPUNED COSTS AND DENIFFITS												
COMBINED COSTS AND BENEFITS Total PV of Operational Benefits	\$ 711,208	\$ -	\$	10	S	- \$	15,536	5	27,578	\$ 55,660	1 5	57,051
Total PV of Customer Benefits	\$ 319,499,044		S	2	5	- S	6,653,544		12,106,331			25,670,621
Total PV of Combined Benefits	\$ 320,210,253		\$		\$	- \$	6,669,080		12,133,909			25,727,672
Total PV Program and On-Going Costs	\$ 19,699,156	\$ 19,767	\$	7,587,622	\$	4,851,972 \$	4,782,430	\$	5,581,993	\$ -	\$	
Combined NPV of Program	\$ 300,511,097	\$ (19,767) \$	(7,587,622)	\$	(4,851,972) \$	1,886,650	\$	6,551,916	\$ 25,100,168	\$	25,727,672
Ratio of NPV Benefits to NPV Costs	16.3											
Cumulative Net Benefits (Payback Period)		\$ (19,767	1 6	(7,607,389)	¢	(12,459,361) \$	(10,572,711)	¢	(4,020,795)	\$ 21,079,373		46,807,045

AREA/PROJECT/PROGRAM	Long Duration Interruption (LDI) - 10
PERIOD:	2024-2026
REGULATORY JURISDICTION:	DEC
STATE:	NC

	NPV of COST/BENEFIT												
	STREAM		2029	2030	_	2031	_	2032	2033		2034		2035
			7	8		9		10	11		12		13
OSTS													
Program Capital Costs	\$ 17,157,123	\$	4	\$ -	\$	1.0	\$	(2)	\$ 114	\$. A	\$	
Program Capital Contingency Costs	\$ 1,858,473	\$		\$ -	\$	9	\$	14	\$ 	\$		\$	
Total Program Capital Costs	\$ 19,015,596	\$	-	\$ -	\$	-	\$	9	\$ -	\$	-	\$	
Program O&M Costs	\$ 683,560	\$	-	\$ 3	\$	-	\$	4	\$	\$		\$	
Total Program Costs	\$ 19,699,156	\$		\$	\$	-	\$	*	\$	\$		\$	
	\$ -	\$	-	\$ -	\$	-	\$	- 4	\$	\$	- 4	\$	
Total On-Going Costs	\$	\$	+	\$ -	\$	H	\$	-	\$ - 4	\$	-	\$	
PERATIONAL BENEFITS		_											
Avoided Outage Benefits	\$ 203,202		16,708	17,126		17,554		17,993	18,442		18,903		19,37
Avoided Vegetation Management Benefits Total Operational Benefit	\$ 508,006 cs \$ 711,208		41,770 58,478	42,814 59,940	_	43,884 61,438		44,981 62,974	 46,106 64,548		47,259 66,162		48,44 67,81
Avoided Sustained Outage Benefits (Non-MED) - Residential Customers Avoided Sustained Outage Benefits (Non-MED) - Small C&I Customers	\$ 1,694,870 \$ 48,047,743		139,581 3,956,978	143,071 4,055,903		146,648 4,157,300		150,314 4,261,233	154,072 4,367,764		157,923 4,476,958		161,87 4,588,88
Avoided Sustained Outage Benefits (Non-MED) - Medium & Large C&I Customers	\$ 80,920,778		6,664,241	6,830,848		7,001,619		7,176,659	7,356,076		7,539,978		7,728,47
Avoided Sustained Outage Benefits (MED) - Residential Customers	\$ 2,079,379	100	171,248	\$ 175,529		179,917	70	184,415	\$ 189,025	1	193,751	333	198,59
Avoided Sustained Outage Benefits (MED) - Small C&I Customers	\$ 81,901,508	- 37	6,745,010	6,913,635		7,086,476		7,263,638	7,445,229	5.0	7,631,359		7,822,14
Avoided Sustained Outage Benefits (MED) - Medium & Large C&I Customers Total Customer Benefit	\$ 104,854,765 s \$ 319,499,044	100	8,635,328 26,312,386	8,851,211 26,970,196		9,072,492 27,644,451		9,299,304 28,335,562	9,531,787 29,043,951		9,770,081 29,770,050		10,014,33 30,514,30
OMBINED COSTS AND BENEFITS													
Total PV of Operational Benefits	\$ 711,208	3 \$	58,478	\$ 59,940	\$	61,438	\$	62,974	\$ 64,548	\$	66,162	\$	67,81
Total PV of Customer Benefits	\$ 319,499,044		26,312,386	26,970,196		27,644,451		28,335,562	29,043,951		29,770,050		30,514,30
Total PV of Combined Benefits	\$ 320,210,253	_	26,370,864	27,030,136		27,705,889		28,398,536	29,108,500		29,836,212		30,582,11
Total PV Program and On-Going Costs	\$ 19,699,156	\$		\$ 	\$		\$	1.4	\$ 	\$		\$	-
Combined NPV of Program	\$ 300,511,097	\$	26,370,864	\$ 27,030,136	\$	27,705,889	\$	28,398,536	\$ 29,108,500	\$	29,836,212	\$	30,582,11
Ratio of NPV Benefits to NPV Costs	16.3												

\$ 73,177,909 \$ 100,208,045 \$ 127,913,934 \$ 156,312,471 \$ 185,420,970 \$ 215,257,183 \$ 245,839,300

AREA/PROJECT/PROGRAM	Long Duration Interruption (LDI) - 10
PERIOD:	2024-2026
REGULATORY JURISDICTION:	DEC
STATE:	NC

	NPV of COST/BENEFIT STREAM			YEAR	-									
		2036		2037	7		38		2039	2040		2041		2042
		14		15		1	.6		17	18		19		20
COSTS														
Program Capital Costs	\$ 17,157,123	\$	1.4	\$	-	\$	-	\$	-	\$ PA.	\$	4	\$	
Program Capital Contingency Costs	\$ 1,858,473	\$		\$		\$		\$	-	\$ 	\$		\$	
Total Program Capital Costs	\$ 19,015,596	\$	-	\$		\$	-	\$	1	\$ -	\$	-	\$	
Program O&M Costs	\$ 683,560	\$	_	\$	3	\$	-	\$	72	\$	\$		\$	
Total Program Costs	\$ 19,699,156	\$		\$		\$	-	\$	Ŷ	\$	\$		\$	
	\$ -	\$	÷	\$	-	\$	-	\$	-	\$	\$	14	\$	
Total On-Going Costs	\$	\$	+	\$	-	\$	-	\$	2*	\$ 4	\$	4	\$	F*
PERATIONAL BENEFITS														
Avoided Outage Benefits	\$ 203,202		19,860		20,357		20,866		21,388	21,922		22,470		23,03
Avoided Vegetation Management Benefits Total Operational Benefits	\$ 508,006 \$ 711,208	1100	49,651 5 9,512		50,892 71,249		52,165 73,031		53,469 74,856	 54,806 76,728		56,176 78,646		57,58 80,61
CUSTOMER BENEFITS														
Avoided Sustained Outage Benefits (Non-MED) - Residential Customers	\$ 1,694,870		55,918		70,066		174,318		178,676	183,143		187,721		192,41
Avoided Sustained Outage Benefits (Non-MED) - Small C&I Customers	\$ 48,047,743	The state of the s	03,604		21,194		,941,724		5,065,267	5,191,898		5,321,696		5,454,73
Avoided Sustained Outage Benefits (Non-MED) - Medium & Large C&I Customers	\$ 80,920,778	\$ 7,9	21,689	\$ 8,1	19,731	\$ 8	,322,724	\$	8,530,793	\$ 8,744,062	\$	8,962,664	\$	9,186,73
Avoided Sustained Outage Benefits (MED) - Residential Customers	\$ 2,079,379	\$ 20	03,560	\$ 2	08,649	\$	213,865	\$	219,211	\$ 224,692	\$	230,309	\$	236,06
Avoided Sustained Outage Benefits (MED) - Small C&I Customers	\$ 81,901,508	\$ 8,0	17,697	\$ 8,2	18,139	\$ 8	,423,593	\$	8,634,183	\$ 8,850,037	\$	9,071,288	\$	9,298,07
Avoided Sustained Outage Benefits (MED) - Medium & Large C&I Customers	\$ 104,854,765	\$ 10,2	54,692	\$ 10,5	21,309	\$ 10	,784,342	\$	11,053,950	\$ 11,330,299	\$	11,613,556	\$	11,903,89
Total Customer Benefits	\$ 319,499,044	\$ 31,2	77,159	\$ 32,0	59,088	\$ 32,	,860,565	\$	33,682,079	\$ 34,524,131	\$	35,387,234	\$	36,271,91
OMBINED COSTS AND BENEFITS														
Total PV of Operational Benefits	\$ 711,208	\$	59,512	S	71,249	5	73,031	S	74,856	\$ 76,728	S	78,646	5	80,61
Total PV of Customer Benefits	\$ 319,499,044		77,159		59,088		,860,565		33,682,079	34,524,131		35,387,234		36,271,91
Total PV of Combined Benefits	\$ 320,210,253		46,670		30,337		,933,596	_	33,756,936	34,600,859		35,465,880		36,352,52
Total PV Program and On-Going Costs	\$ 19,699,156	\$, <u>.</u> .	\$		\$		\$		\$ 	\$		\$	-
Combined NPV of Program	\$ 300,511,097	\$ 31,34	16,670	\$ 32,1	30,337	\$ 32	,933,596	\$	33,756,936	\$ 34,600,859	\$	35,465,880	\$	36,352,52
Ratio of NPV Benefits to NPV Costs	16.3	1												

\$ 277,185,971 \$ 309,316,308 \$ 342,249,904 \$ 376,006,839 \$ 410,607,698 \$ 446,073,579 \$ 482,426,106

AREA/PROJECT/PROGRAM	Long Duration Interruption (LDI) - 10
PERIOD:	2024-2026
REGULATORY JURISDICTION:	DEC
STATE:	NC

	NPV of COST/BENEFIT STREAM														
	- THE III		2043		2044		2045		2046		2047		2048		2049
			21		22		23		24		25		26		27
OSTS															
Program Capital Costs	\$ 17,157,123	\$	-	\$	-	\$		\$		\$	114	\$	4	\$	
Program Capital Contingency Costs	\$ 1,858,473	\$	- 4	\$	- 2	\$		\$		\$		\$	-	\$	
Total Program Capital Costs	\$ 19,015,596	\$	- 5	\$		\$		\$		\$	-	\$	-	\$	
Program O&M Costs	\$ 683,560	\$		\$	3	\$	-	\$	4	\$		\$	1	\$	
Total Program Costs	\$ 19,699,156	\$		\$		\$	7	\$	1	\$		\$	•	\$	
	\$ -	\$		\$		\$	-	\$		\$		\$		\$	
Total On-Going Costs	\$	\$	Ť	\$	-	\$	H	\$		\$	- 4	\$	+	\$	
PERATIONAL BENEFITS															
Avoided Outage Benefits	\$ 203,202	1000	23,608	\$	24,198	\$	24,803	\$	25,423	\$	26,059	\$	26,710	\$	27,3
Avoided Vegetation Management Benefits	\$ 508,006	\$	59,020	\$	60,495	\$	62,007	\$	63,558	\$	65,147	\$	66,775	\$	68,4
Total Operational Benefits	\$ 711,208		82,627		84,693		86,810		88,981		91,205		93,485		95,8
JSTOMER BENEFITS															
Avoided Sustained Outage Benefits (Non-MED) - Residential Customers	\$ 1,694,870	\$	197,225		202,155		207,209		212,389		217,699		223,142		228,7
Avoided Sustained Outage Benefits (Non-MED) - Small C&I Customers	\$ 48,047,743	\$	5,591,107		5,730,884		5,874,156		6,021,010		6,171,536		6,325,824		6,483,9
Avoided Sustained Outage Benefits (Non-MED) - Medium & Large C&I Customers	\$ 80,920,778	\$	9,416,399	Ş	9,651,809	\$	9,893,104	\$	10,140,432	\$	10,393,942	\$	10,653,791	\$	10,920,1
Avoided Sustained Outage Benefits (MED) - Residential Customers	\$ 2,079,379	\$	241,968	\$	248,018	\$	254,218	\$	260,573	\$	267,088	\$	273,765	\$	280,6
Avoided Sustained Outage Benefits (MED) - Small C&I Customers	\$ 81,901,508	\$	9,530,522	\$	9,768,785	\$	10,013,005	\$	10,263,330	\$	10,519,913	\$	10,782,911	\$	11,052,4
Avoided Sustained Outage Benefits (MED) - Medium & Large C&I Customers	\$ 104,854,765	\$	12,201,493	\$	12,506,530	\$	12,819,193	\$	13,139,673	\$	13,468,165	\$	13,804,869	\$	14,149,9
Total Customer Benefits	\$ 319,499,044	\$	37,178,713	\$	38,108,181	\$	39,060,886	\$	40,037,408	\$	41,038,343	\$	42,064,301	\$	43,115,9
OMBINED COSTS AND BENEFITS															
Total PV of Operational Benefits	\$ 711,208	¢	82,627	¢	84,693	¢	86,810	¢	88,981	¢	91,205	c	93,485	Ċ	95,8
Total PV of Customer Benefits	\$ 711,208 \$ 319,499,044		37,178,713	ç	38,108,181		39,060,886		40,037,408		41,038,343		42,064,301	ç	43,115,9
Total PV of Combined Benefits	\$ 320,210,253	_	37,261,341	\$	38,192,874		39,147,696		40,126,388		41,129,548	_	42,157,787	\$	43,211,7
Total PV Program and On-Going Costs	\$ 19,699,156	\$	*	\$		\$		\$		\$, le	\$		\$	
Combined NPV of Program	\$ 300,511,097	4	37,261,341	5	38,192,874	5	39,147,696	5	40,126,388	5	41,129,548	5	42,157,787	s	43,211,7

\$ 519,687,447 \$ 557,880,321 \$ 597,028,017 \$ 637,154,405 \$ 678,283,953 \$ 720,441,740 \$ 763,653,472

AREA/PROJECT/PROGRAM	Long Duration Interruption (LDI) - 10
PERIOD:	2024-2026
REGULATORY JURISDICTION:	DEC
STATE:	NC

	NPV of COST/BENEFIT							
	STREAM		2050		2051	2052		TOTAL
			28		29	30		
COSTS								
Program Capital Costs	\$ 17,157,12		A	\$	-	\$ 14	\$	19,878,54
Program Capital Contingency Costs	\$ 1,858,47	1000		\$	-	\$ -	\$	2,153,25
Total Program Capital Costs	\$ 19,015,59	6 \$	-	\$	-	\$ -	\$	22,031,79
Program O&M Costs	\$ 683,56	0 \$		\$		\$ - 4	\$	791,98
Total Program Costs	\$ 19,699,15	6 \$		\$		\$	\$	22,823,78
	\$ -	\$	÷	\$		\$ -	\$	
Total On-Going Costs	\$	\$	+	\$	-	\$ -	\$	
PERATIONAL BENEFITS								
Avoided Outage Benefits	\$ 203,20	1000	28,062		28,764	29,483	3	585,00
Avoided Vegetation Management Benefits Total Operational Benefits	\$ 508,00 \$ 711,20		70,156 98,218		71,910 100,674	73,707 103,190	\$	1,462,51 2,047,52
USTOMER BENEFITS								
Avoided Sustained Outage Benefits (Non-MED) - Residential Customers	\$ 1,694,87	0 \$	234,438	\$	240,299	\$ 246,307	\$	4,883,86
Avoided Sustained Outage Benefits (Non-MED) - Small C&I Customers	\$ 48,047,74	200	6,646,069		6,812,221	6,982,526	100	138,452,41
Avoided Sustained Outage Benefits (Non-MED) - Medium & Large C&I Customers	\$ 80,920,77	8 \$	11,193,139	\$	11,472,968	\$ 11,759,792	\$	233,178,00
Avoided Sustained Outage Benefits (MED) - Residential Customers	\$ 2,079,37	9 \$	287,624	\$	294,815	\$ 302,185	\$	5,991,85
Avoided Sustained Outage Benefits (MED) - Small C&I Customers	\$ 81,901,50		11,328,796		11,612,016	11,902,316	100	236,004,04
Avoided Sustained Outage Benefits (MED) - Medium & Large C&I Customers	\$ 104,854,76	5 \$	14,503,741	\$	14,866,334	\$ 15,237,992	\$	302,145,20
Total Customer Benefits	\$ 319,499,04	4 \$	44,193,807	\$	45,298,652	\$ 46,431,118	\$	920,655,39
OMBINED COSTS AND BENEFITS								
Total PV of Operational Benefits	\$ 711,20	2 5	98,218	¢	100,674	\$ 103,190	c	2,047,52
Total PV of Customer Benefits	\$ 319,499,04		44,193,807		45,298,652	46,431,118		920,655,39
Total PV of Combined Benefits	\$ 320,210,25		44,292,025		45,399,325	 46,534,309	\$	922,702,91
Total PV Program and On-Going Costs	\$ 19,699,15	6 \$	-	\$	-	\$ -	\$	22,823,78
Combined NPV of Program	\$ 300,511,09	7 \$	44,292,025	\$	45,399,325	\$ 46,534,309	\$	899,879,13
Ratio of NPV Benefits to NPV Costs	16	3						
							ı	

Santani Cartani da	Targeted Underground (TUG) -
AREA/PROJECT/PROGRAM	11
PERIOD:	2024-2026

REGULATORY JURISDICTION:

STATE:	NC NC									
	NPV of COST/BENEFIT									
	STREAM	2022	2023	2024	2025	2026	2027	2028	2029	2030
		0	1	2	3	4	5	6	7	8
OSTS										
Program Capital Costs	\$ 143,222,365 \$	28,642 \$	36,777,966 \$	54,853,284 \$	49,153,637 \$	25,423,961 \$	- \$	- \$	- \$	
Program Capital Contingency Costs	\$ 15,754,460 \$	3,151 \$	4,045,576 \$	6,033,861 \$	5,406,900 \$	2,796,636 \$	- \$	- \$	- \$	
Total Program Capital Costs	\$ 158,976,825 \$	31,793 \$	40,823,542 \$	60,887,145 \$	54,560,537 \$	28,220,597 \$	- \$	- \$	- \$	
Program O&M Costs	\$ 114,741 \$	23 \$	29,464 \$	43,945 \$	39,379 \$	20,368 \$	- \$	- \$	- \$	
Total Program Costs	\$ 159,091,566 \$	31,816 \$	40,853,007 \$	60,931,090 \$	54,599,916 \$	28,240,965 \$	- \$	- \$	- \$	
	\$ - \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	
Total On-Going Costs	\$ - \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	
PERATIONAL BENEFITS										
Avoided Outage Benefits	\$ 4,238,784 \$	- \$	- \$	- \$	65,898 \$	181,158 \$	332,475 \$	340,787 \$	349,307 \$	358,039
Avoided Vegetation Management Benefits	\$ 4,238,784 \$	- \$	- \$	- \$	65,898 \$	181,158 \$	332,475 \$	340,787 \$	349,307 \$	358,039
Total Operational Benefit	ts \$ 8,477,567 \$	- \$	- \$	- \$	131,796 \$	362,316 \$	664,950 \$	681,574 \$	698,613 \$	716,078
USTOMER BENEFITS										
Avoided Sustained Outage Benefits (Non-MED/MED) - Residential Customers	\$ 504,276 \$	- \$	- \$	- \$	7,473 \$	21,056 \$	39,610 \$	40,600 \$	41,615 \$	42,656
Avoided Sustained Outage Benefits (Non-MED/MED) - Small C&I Customers	\$ - \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	+
Avoided Sustained Outage Benefits (Non-MED/MED) - Medium & Large C&I Custome	er \$ - \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	-
Avoided Momentary Outage Benefits (Non-MED/MED) - Residential Customers	\$ 11,215,749 \$	- \$	- \$	- \$	166,200 \$	468,318 \$	880,981 \$	903,006 \$	925,581 \$	948,720
Avoided Momentary Outage Benefits (Non-MED/MED) - Small C&I Customers	\$ 131,047,684 \$	- \$	- \$	- \$	1,941,927 \$	5,471,949 \$	10,293,610 \$	10,550,950 \$	10,814,724 \$	11,085,092
Avoided Momentary Outage Benefits (Non-MED/MED) - Medium & Large C&I Custon	m \$ 335,755,317 \$	- \$	- \$	- \$	4,975,382 \$	14,019,598 \$	26,373,104 \$	27,032,431 \$	27,708,242 \$	28,400,948
Total Customer Benefit	ts \$ 478,523,026 \$	- \$	- \$	- \$	7,090,982 \$	19,980,921 \$	37,587,304 \$	38,526,987 \$	39,490,162 \$	40,477,416
CAMPANIED COCKY AND DENIFFIE										
OMBINED COSTS AND BENEFITS Total PV of Operational Benefits	\$ 8,477,567 \$	- \$	- \$	- \$	131,796 \$	362,316 \$	664,950 \$	681,574 \$	698,613 \$	716,078
Total PV of Customer Benefits	\$ 478,523,026 \$		- \$	- \$	7,090,982 \$	19,980,921 \$	37,587,304 \$	38,526,987 \$		40,477,416
Total PV of Combined Benefits	\$ 487,000,593 \$		- \$	- \$	7,222,777 \$	20,343,237 \$	38,252,254 \$	39,208,561 \$	40,188,775 \$	41,193,494
Total PV Program and On-Going Costs	\$ 159,091,566 \$	31,816 \$	40,853,007 \$	60,931,090 \$	54,599,916 \$	28,240,965 \$	- \$	- \$	- \$	
Combined NPV of Program	\$ 327,909,028 \$	(31,816) \$	(40,853,007) \$	(60,931,090) \$	(47,377,139) \$	(7,897,728) \$	38,252,254 \$	39,208,561 \$	40,188,775 \$	41,193,494
Ratio of NPV Benefits to NPV Costs	3.1									
Cumulative Net Benefits (Payback Period)	ė	(31,816) \$	(40.884.822) \$	(101 815 912) ¢	(149,193,051) \$	(157 090 779) ¢	(118,838,524) \$	(79,629,963) \$	(39,441,189) \$	1,752,306
Culturative thet benefits (Fayback Fellou)	*	(31,010) \$	(-0,004,022) \$	(101,010,012) \$	(TANITANIONI) 3	(201,000,115) \$	(110,030,324) \$	1,0,020,000 \$	(33,441,103) \$	1,752,300

AREA/PROJECT/PROGRAM	Targeted Underground (TUG) - 11
PERIOD:	2024-2026
REGULATORY JURISDICTION:	DEC
STATE:	NC

	NPV	of COST/BENEFIT							YEAR		
		STREAM	2031	2032	2033	2034	2035	2036	2037	2038	2039
			9	10	11	12	13	14	15	16	17
COSTS											
Program Capital Costs	\$	143,222,365	\$ -	\$ - :	- 1	\$ - :	\$ - \$	- \$	- \$	- \$	
Program Capital Contingency Costs	\$		\$ -	\$ -	3	\$ - :	\$ - \$	- \$	- \$	- \$	
Total Program Capital Costs	\$	158,976,825	\$	\$ - :	-	\$ - :	\$ - \$	- \$	- \$	- \$	
Program O&M Costs	\$	114,741	\$ -	\$ -	-	\$ - :	\$ - \$	- \$	- \$	- \$	9
Total Program Costs	\$	159,091,566	\$	\$ -	-	\$	\$ - \$	- \$	- \$	- \$	6
	\$	-	\$ -								
Total On-Going Costs	\$	-	\$	\$ -	-	\$ -	\$ - \$	- \$	- \$	- \$	
OPERATIONAL BENEFITS	-		Supress .					and devices.	The Series W.		70 mm 2
Avoided Outage Benefits	\$	4,238,784	366,990				1.0000000000000000000000000000000000000	415,216 \$	425,596 \$		447,142
Avoided Vegetation Management Benefits	Total Operational Benefits \$	4,238,784 \$ 8,477,567	366,990 733,980					415,216 \$ 830,431 \$	425,596 \$ 851,192 \$	436,236 \$ 872,472 \$	447,142 894,284
CUSTOMER REPUERTS	and the second second second						oreways.				
CUSTOMER BENEFITS Avoided Sustained Outage Benefits (Non-MED/MED) - Re	esidential Customers \$	504,276	43,722	44,815	45,936	\$ 47,084 \$	48,261 \$	49,468 \$	50,704 \$	51,972 \$	53,271
Avoided Sustained Outage Benefits (Non-MED/MED) - Sn		- 3	-			\$ - \$		- \$	- \$		55,27
Avoided Sustained Outage Benefits (Non-MED/MED) - M		- 3	-			\$ - \$		- \$	- \$		i e
Avoided Momentary Outage Benefits (Non-MED/MED) -	Residential Customers \$	11,215,749	972,438	996,749	1,021,668	\$ 1,047,210 \$	1,073,390 \$	1,100,225 \$	1,127,730 \$	1,155,924 \$	1,184,822
Avoided Momentary Outage Benefits (Non-MED/MED) -		131,047,684	11,362,219	11,646,274 \$	11,937,431	\$ 12,235,867 \$	12,541,764 \$	12,855,308 \$	13,176,691 \$	13,506,108 \$	13,843,760
Avoided Momentary Outage Benefits (Non-MED/MED) -	Medium & Large C&I Custom \$	335,755,317	29,110,972	29,838,746	30,584,715	\$ 31,349,333 \$	32,133,066 \$	32,936,392 \$	33,759,802 \$	34,603,797 \$	35,468,892
	Total Customer Benefits \$	478,523,026	41,489,351	42,526,585	43,589,750	\$ 44,679,493 \$	45,796,481 \$	46,941,393 \$	48,114,928 \$	49,317,801 \$	50,550,746
COMPINED COSTS AND DENIFFITS											
COMBINED COSTS AND BENEFITS Total PV of Operational Benefits	4	8,477,567	733,980	752,330	771,138	\$ 790,417 \$	810,177 \$	830,431 \$	851,192 \$	872,472 \$	894,284
Total PV of Customer Benefits	4	478,523,026						46,941,393 \$	48,114,928 \$	49,317,801 \$	
Total PV of Combined Benefits	\$	487,000,593				\$ 45,469,910 \$		47,771,824 \$	48,966,120 \$	50,190,273 \$	
Total PV Program and On-Going Costs	\$	159,091,566		- 5		\$ - \$	- \$	- \$	- \$	- \$	
Combined NPV of Program	\$	327,909,028	42,223,332	43,278,915	44,360,888	\$ 45,469,910 \$	46,606,658 \$	47,771,824 \$	48,966,120 \$	50,190,273 \$	51,445,030
Ratio of NPV Benefits to NPV Costs		3.1									
Cumulative Net Benefits (Payback Period)			43,975,637	87,254,552	131,615,440	\$ 177,085,350 \$	223,692,007 \$	271,463,831 \$	320,429,951 \$	370,620,224 \$	422,065,253

AREA/PROJECT/PROGRAM	Targeted Underground (TUG)
PERIOD:	2024-2026
REGULATORY JURISDICTION:	DEC
STATE:	NC

	NPV of COST/BENEFIT									
	STREAM									
		2040	2041	2042	2043	2044	2045	2046	2047	2048
	L	18	19	20	21	22	23	24	25	26
COSTS										
Program Capital Costs	\$ 143,222,365	\$ - \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	
Program Capital Contingency Costs	\$ 15,754,460	\$ - \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	
Total Program Capital Costs	\$ 158,976,825	\$ - \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	
Program O&M Costs	\$ 114,741	\$ - \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	
Total Program Costs	\$ 159,091,566	\$ - \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	
	\$ -	\$ - 5	Y Y	- \$		- \$	- \$	- \$	- \$	
Total On-Going Costs	\$	\$ - 5	- \$	- \$	- \$	- \$	- \$	- \$	- \$	
OPERATIONAL BENEFITS										
Avoided Outage Benefits	\$ 4,238,784			481,523 \$		505,900 \$	518,548 \$	531,511 \$	544,799 \$	558,419
Avoided Vegetation Management Benefits		\$ 458,320 \$		481,523 \$		505,900 \$	518,548 \$	531,511 \$	544,799 \$	558,419
Total Operational Benefit	ts \$ 8,477,567	\$ 916,641 \$	939,557 \$	963,046 \$	987,122 \$	1,011,800 \$	1,037,095 \$	1,063,022 \$	1,089,598 \$	1,116,838
CUSTOMER BENEFITS										
Avoided Sustained Outage Benefits (Non-MED/MED) - Residential Customers	\$ 504,276	\$ 54,603 \$		57,367 \$	58,802 \$	60,272 \$	61,778 \$	63,323 \$	64,906 \$	66,529
Avoided Sustained Outage Benefits (Non-MED/MED) - Small C&I Customers	\$ -	\$ - \$		- \$		- \$	- \$	- \$	- \$	7
Avoided Sustained Outage Benefits (Non-MED/MED) - Medium & Large C&I Custome	er \$ -	\$ - \$	- \$	- \$	- \$	- \$	- \$	\$	- \$	
Avoided Momentary Outage Benefits (Non-MED/MED) - Residential Customers	\$ 11,215,749	\$ 1,214,442 \$	1,244,803 \$	1,275,923 \$	1,307,822 \$	1,340,517 \$	1,374,030 \$	1,408,381 \$	1,443,590 \$	1,479,680
Avoided Momentary Outage Benefits (Non-MED/MED) - Small C&I Customers	\$ 131,047,684	\$ 14,189,854 \$	14,544,601 \$	14,908,216 \$	15,280,921 \$	15,662,944 \$	16,054,518 \$	16,455,881 \$	16,867,278 \$	17,288,960
Avoided Momentary Outage Benefits (Non-MED/MED) - Medium & Large C&I Custon	m \$ 335,755,317	\$ 36,355,615 \$	37,264,505 \$	38,196,118 \$	39,151,021 \$	40,129,796 \$	41,133,041 \$	42,161,367 \$	43,215,401 \$	44,295,786
Total Customer Benefit	ts \$ 478,523,026	\$ 51,814,514 \$	53,109,877 \$	54,437,624 \$	55,798,565 \$	57,193,529 \$	58,623,367 \$	60,088,951 \$	61,591,175 \$	63,130,954
COMBINED COSTS AND BENEFITS										
Total PV of Operational Benefits	\$ 8,477,567	\$ 916,641 \$	939,557 \$	963,046 \$	987,122 \$	1,011,800 \$	1,037,095 \$	1,063,022 \$	1,089,598 \$	1,116,838
Total PV of Customer Benefits	\$ 478,523,026			54,437,624 \$		57,193,529 \$	58,623,367 \$	60,088,951 \$	61,591,175 \$	63,130,954
Total PV of Combined Benefits	\$ 487,000,593			55,400,670 \$		58,205,329 \$	59,660,462 \$	61,151,974 \$	62,680,773 \$	64,247,792
Total PV Program and On-Going Costs	\$ 159,091,566	\$ - \$	- \$	- \$	- \$	- \$	- \$	- \$	- \$	
Combined NPV of Program	\$ 327,909,028	\$ 52,731,155 \$	54,049,434 \$	55,400,670 \$	56,785,687 \$	58,205,329 \$	59,660,462 \$	61,151,974 \$	62,680,773 \$	64,247,792
Ratio of NPV Benefits to NPV Costs	3.1									
		a december		Laureum 1		All of the A		1000000000	10000000	
Cumulative Net Renefits (Payhack Period)		\$ 474 796 409 \$	528 845 843 \$	584 246 513 S	641 032 200 S	699 237 529 S	758 897 991 S	870 049 964 \$	887 730 737 S	946 978 53

	Targeted Underground (TUG) - 11
PERIOD:	2024-2026
REGULATORY JURISDICTION:	DEC
STATE:	NC

	STREAM	_		2050			_	2000		TOTAL
			2049		2050	2051		2052		
			27		28	29		30		
STS							1.0			
Program Capital Costs	\$ 143,222,365	\$	10	\$	-	\$ 1.5	\$	- 5	\$	166,237,49
Program Capital Contingency Costs	\$ 15,754,460	\$	- (2)	\$		\$ 	\$	-	\$	18,286,12
Total Program Capital Costs	\$ 158,976,825	\$		\$		\$	\$		\$	184,523,6
Program O&M Costs	\$ 114,741	\$	1-1	\$		\$ 	\$		\$	133,1
Total Program Costs	\$ 159,091,566	\$		\$	-	\$ 	\$		\$	184,656,7
	\$	\$	-	\$		\$	\$		\$	
Total On-Going Costs	\$ +	\$	-	\$		\$,	\$		\$	
ERATIONAL BENEFITS										
Avoided Outage Benefits	\$ 4,238,784		572,379	\$	586,689	601,356	\$	616,390		
Avoided Vegetation Management Benefits	\$ 4,238,784	\$	572,379		586,689	601,356	_	616,390	\$	12,220,04
Total Operational Benefits	\$ 8,477,567	\$	1,144,759	\$	1,173,378	\$ 1,202,712	\$	1,232,780	\$	12,220,04
STOMER BENEFITS										
Avoided Sustained Outage Benefits (Non-MED/MED) - Residential Customers	\$ 504,276	\$	68,192		69,897	\$ 71,644	\$	73,435	\$	1,454,95
Avoided Sustained Outage Benefits (Non-MED/MED) - Small C&I Customers	\$ 7	\$	-	\$	-	\$ -	\$		\$	-
Avoided Sustained Outage Benefits (Non-MED/MED) - Medium & Large C&I Customer	\$ 	\$	5	\$	-	\$ 8	\$		\$	
Avoided Momentary Outage Benefits (Non-MED/MED) - Residential Customers	\$ 11,215,749	\$	1,516,672	\$	1,554,589	\$ 1,593,454	\$	1,633,290	\$	32,360,15
Avoided Momentary Outage Benefits (Non-MED/MED) - Small C&I Customers	\$ 131,047,684	\$	17,721,184	\$	18,164,213	\$ 18,618,319	\$	19,083,777	\$	378,104,33
Avoided Momentary Outage Benefits (Non-MED/MED) - Medium & Large C&I Custom	\$ 335,755,317	\$	45,403,181	\$	46,538,260	\$ 47,701,717	\$	48,894,260	\$	968,735,48
Total Customer Benefits	\$ 478,523,026	\$	64,709,228	\$	66,326,959	\$ 67,985,133	\$	69,684,761	\$ 1	,380,654,93
MBINED COSTS AND BENEFITS										
Total PV of Operational Benefits	\$ 8,477,567	\$	1,144,759	\$	1,173,378	\$ 1,202,712	\$	1,232,780	\$	24,440,09
Total PV of Customer Benefits	\$ 478,523,026	\$	64,709,228	\$	66,326,959	\$ 67,985,133	\$	69,684,761	_	,380,654,93
Total PV of Combined Benefits	\$ 487,000,593	\$	65,853,987	\$	67,500,337	\$ 69,187,845	\$	70,917,541	\$ 1	,405,095,03
Total PV Program and On-Going Costs	\$ 159,091,566	\$	/	\$	- 2	\$ 2	\$	14-3	\$	184,656,79
Combined NPV of Program	\$ 327,909,028	\$	65,853,987	\$	67,500,337	\$ 69,187,845	\$	70,917,541	\$ 1	,220,438,24
Ratio of NPV Benefits to NPV Costs	3.1									
I MANAGEMENT AND										

Duke Energy Carolinas, LLC
DOCKET NO. E-7, SUB 1276
Guyton Direct Exhibit 8 - MYRP Distribution - CBA - TUG
4 of 4
Page 29 of 31

Page 30 of 31

uke Energy Carolinas (DEC) NORT Phase I and II deployments specific to		INA IVVO EVALUAT	Years (for refe	erence only)	FORECAST												
				,,													
	Units	NPV (calculated)	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032
enefits	\$	\$842,602,640	•	\$ 2,965,726	¢ 5,805,308	¢ 13 704 536	¢ 21 283 023	\$23,259,315	\$31,702,446	\$36,997,943	\$119,910,641	\$47,171,200	\$49,721,752	\$52,169,957	\$63,045,918	\$70,227,088	\$72,644,9
osts	\$	\$540,187,727		\$ 65,044,843					and the second second		\$ 33,240,530	\$ 8,144,418				\$11,090,498	THE RESERVE AND ADDRESS.
let	\$	\$302,414,913		\$(62,079,118)							\$ 86,670,111						
CR	-	1.6	ψ(1,110,004)	4(02,010,110)	4(01,201,001)	\$(00,230,000)	\$(45,424,540)	\$14,000,000	¥ 100,100	\$ (2,044,000)	ψ 00,070,111	400,020,102	441,000,000	\$00,100,004	\$00,001,001	400,100,000	\$00,000,0
OSTS																	
otal Capital																	
Transmission	\$	\$174,749,914	\$	\$ 16,550,882	The second secon	\$ 17,349,799	THE RESIDENCE OF THE PERSON NAMED IN	\$ 3,776,429	\$14,247,438	\$17,604,265	\$ 11,481,871	\$ -	\$ -	\$ 3,954,914	\$ 4,053,787	\$ 4,155,131	\$ 4,259,0
Distribution	\$	\$210,481,241	\$ 598,239	\$ 34,691,140	\$ 35,518,080	\$ 36,365,694	\$ 37,096,447	\$ 855,496	\$ 8,977,423	\$12,652,885	\$ 10,361,002	\$ -	\$ -	\$ -	\$ -	\$ -	\$
Telecom	\$	\$ 30,973,700	\$ -	\$ 5,636,317	\$ 5,770,671	\$ 5,908,383	\$ 6,049,539	\$ 527,875	\$ 2,646,808	\$ 3,448,238	\$ 2,489,310	\$ 0	\$ 0	\$ (0)	\$ 0	\$ 0	\$
IT	\$	\$ 11,112,374	\$ -	\$ 1,704,280	\$ 1,628,557	\$ 1,667,421	\$ 1,585,287	\$ 155,239	\$ 778,379	\$ 1,014,066	\$ 732,062	\$ -	\$ -	\$ 367,395	\$ 349,645	\$ 358,386	\$ 339,0
PM	\$	\$ 19,707,587	\$ 232,892	\$ 4,407,400	\$ 4,925,234	\$ 5,038,744	\$ 5,103,316	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$
Ongoing	\$	\$ 27,349,339	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 3,485,900	\$ 3,573,048	\$ 3,662,374	\$ 3,753,933	\$ 308,470	\$ 1,546,691	\$ 2,015.
	\$	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$
otal Capital	\$	\$474,374,155	\$ 831,131	\$ 62,990,019	\$ 64,787,951	\$ 66,330,041	\$ 67,598,887	\$ 5,315,039	\$26,650,048	\$34,719,454	\$ 28,550,145	\$ 3,573,048	\$ 3,662,374	\$ 8,076,242	\$ 4,711,901	\$ 6,060,209	\$ 6,613,
otal O&M																	
Transmission	\$	\$ 1,409,686	\$ -	\$ 148,965	\$ 152,689	\$ 156,506	\$ 160,419	\$ 75.529	\$ 284,949	\$ 352.085	\$ 229,637	\$ =	\$ -	\$ -	\$ -	\$ -	\$
Distribution	4	\$ 7,818,516	\$ 288,502	\$ 1.686.479	\$ 1,728,641	\$ 1,771,857	\$ 1,752,463	\$ 29,486	\$ 213,620	\$ 238,161	\$ 229,234	¢	9	4	4	œ.	4
	5		φ 200,302 Φ			The second second second			100	The second second	\$ 49.786	•		•	•	•	•
Telecom	2	\$ 374,663	.	\$ 53,572	\$ 54,911	\$ 56,284	\$ 57,691	\$ 10,588	\$ 52,936	\$ 68,965	1000	\$ 4 0C4 4FE	0 4 400 250	\$ 4 070 DOE	\$ 4 DZ0 00E	\$ -	0 4 070
IT	D.	\$ 13,151,937	D -	\$ 54,923	\$ 137,309	\$ 277,688	\$ 418,067	\$ 544,409	\$ 674,194	\$ 802,217	\$ 929,089	\$ 1,064,455	\$ 1,190,358	\$ 1,278,095	\$ 1,278,095	\$ 1,278,095	\$ 1,278,
PM	2	\$	•	3	\$ -	5	\$ -	\$ -	\$ -	\$ -	5	\$ -	\$ -	\$	* * * * * * * * * * * * * * * * * * * *	5	*
Ongoing otal O&M	\$	\$ 43,058,769 \$ 65,813,571	\$ 288,502	\$ 110,886 \$ 2,054,825	\$ 301,465 \$ 2,375,015	\$ 500,741 \$ 2,763,075	\$ 721,336 \$ 3,109,976	\$ 2,980,429 \$ 3,640,441	\$ 3,071,599 \$ 4,297,298	The state of the s	-		\$ 3,565,983 \$ 4,756,340	The second second second	and the same of th	\$ 3,752,195 \$ 5,030,289	The state of the s
7 1 2 3	g _	\$ 00,013,071	\$ 200,502	\$ 2,004,020	φ 2,373,013	\$ 2,703,073	\$ 3,109,970	\$ 3,040,441	\$ 4,251,250	\$ 4,025,295	\$ 4,050,363	\$ 4,571,570	\$ 4,750,540	\$ 4,504,022	φ 4,900,000	\$ 5,050,265	\$ 5,055,4
otal Costs																	
Total Capital	\$	\$474,374,155	\$ 831,131	\$ 62,990,019	\$ 64,787,951	\$ 66,330,041	\$ 67,598,887	\$ 5,315,039	\$26,650,048	\$34,719,454	\$ 28,550,145	\$ 3,573,048	\$ 3,662,374	\$ 8,076,242	\$ 4,711,901	\$ 6,060,209	\$ 6,613,
Total O&M	\$	\$ 65,813,571		\$ 2,054,825					\$ 4,297,298							\$ 5,030,289	-
otal Capital & O&M	\$	\$540,187,727	\$ 1,119,634	\$ 65,044,843	\$ 67,162,966	\$ 69,093,117	\$ 70,708,863	\$ 8,955,480	\$30,947,346	\$39,342,749	\$ 33,240,530	\$ 8,144,418	\$ 8,418,714	\$12,980,863	\$ 9,678,581	\$11,090,498	\$11,708,5
ENEFITS																	
perational Benefits												The state of the s	A Section				
Improved VAR Mgmt	\$	\$ 89,711,275	\$ -	\$ 1,207,215	\$ 2,333,710	\$ 3,548,006	\$ 4,813,044	\$ 4,955,475	\$ 5,561,915	\$ 5,791,848	\$ 6,003,446	\$ 6,298,053	\$ 6,530,947	\$ 7,025,943	\$ 7,449,689	\$ 7,828,080	\$ 8,393,
Avoided Capacity Costs	\$	\$109,962,860	\$ -								\$ 7,683,706						
Avoided Fixed O&M Generation C	\$	\$ 4,608,029	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 76,644	\$ 775,033	\$ 796,
Avoided Variable O&M Generatio	\$	\$ 23,796,894	\$ -	\$ -	\$ -	\$ 324,455	\$ 524,156	\$ 703,705	\$ 1,017,079	\$ 1,246,780	\$ 2,057,398	\$ 1,746,073	\$ 2,082,388	\$ 2,107,452	\$ 1,943,778	\$ 2,121,024	\$ 2,411
Avoided Reagent Cost Generation	\$	\$ 281,705	\$ -	\$ -	\$ -	\$ (583)	\$ 5,062	\$ 2,879	\$ 18,955	\$ 28,968	\$ 12,315	\$ 15,546	\$ 28,534	\$ 20,907	\$ 16,667	\$ 22,253	\$ 30,
Avoided Start Cost Generation	\$	\$ 12,056,328	\$ -	\$ -	\$ -	\$ (65,368)	\$ 323,528	\$ (641,605)	\$ 706,323	\$ 301,058	\$ 594,130	\$ 243,998	\$ 594,646	\$ 161,042	\$ 568,154	\$ 1,030,232	\$ 844.
JBTOTAL:	\$	\$240,417,091	\$ -	\$ 2,965,726	\$ 5,895,398	\$ 9,216,892	\$ 12,971,249	\$12,418,692	\$14,796,468	\$14,956,000	\$ 16,350,995	\$16,084,958	\$17,116,627	\$17,295,533	\$18,136,469	\$19,960,794	\$20,763,
ustomer Benefits																	
Avoided Fuel Costs	\$	\$368,653,700	\$ -	\$ -	\$ -	\$ 4,571,386	\$ 8,297,974	\$10.819.947	\$16,880,652	\$19,785.832	\$ 25,929,170	\$23,399,839	\$22,687,340	\$23,375,724	\$29,390,479	\$32,099,674	\$33.764
UBTOTAL:	\$	\$368,653,700	\$ -	\$ -	\$ -						\$ 25,929,170						
	Vanarira																
BETOTAL:	\$	\$609,070,791	0	2,965,726	5,895,398	13,788,278	21,269,222	23,238,639	31,677,120	34,741,831	42,280,165	39,484,797	39,803,966	40,671,257	47,526,949	52,060,468	54,527
vironmental Benefits				- 11.77													
SO2	\$	\$ 7,387	\$	\$	\$	\$ 105	\$ 374	\$ 591	\$ 471	\$ 419	\$ 1,324	\$ 793	\$ 778	\$ 636	\$ 1.069	\$ 1.084	\$
NOX	\$	\$ 337,765	•	•	\$	\$ 6,154	The second second	\$ 20.085		The same of the sa		\$ 28,310					
	\$		•	•	4	0,134	¢ 14,321	\$ 20,003	¢ 24,000	AND DESCRIPTION OF	\$ 77,587,091		The second secon		The second second		
CO2 UBTOTAL:	\$	\$233,186,698 \$233,531,849	\$ -	\$ -	\$ -	\$ 6,259	\$ 14,701	\$ 20,675	\$ 25 326		\$ 77,587,091						
DOTOTAL.		ψ200,001,043	•	*	•	9 0,209	4 14,701	¥ 20,013	¥ 20,020	¥ 2,200,112	¥ 11,000,410	¥ 1,000,403	¥ 3,311,100	¥11,430,700	ψ10,010,910	\$ 10,100,020	¥ 10,110,
OTAL (all benefits)	\$	\$842,602,640	\$ -	\$ 2,965,726	\$ 5,895,398	\$ 13,794,536	\$ 21,283,923	\$23,259,315	\$31,702,446	\$36,997,943	\$119,910,641	\$47,171,200	\$49,721,752	\$52,169,957	\$63,045,918	\$70,227,088	\$72,644

Duke Energy Carolinas (DEC) NORTH CAROLINA IVVC EVALUAT

*Phase I and II deployments specific to DEC NC

1	Inits	NPV (calculated)	2033	2034	2035	2036	2037	2038	2039	2040	2041	2042	2043	Total
Benefits	\$	\$842,602,640	\$79,575,256	\$91.175.775	\$75,084,935	\$83,206,541	\$88,306,843	\$109,021,424	\$126 122 046	\$109,733,512	\$129 468 955	\$119,236,368	\$129,624,599	\$1,751,347,019
Costs	¢	\$540.187.727		\$49,749,189			\$45,180,488	\$ 9,632,237		and the second s			\$ 11.274.227	1 3 C 1 C 1 C 1 C 1 C 1 C 1 C 1 C 1 C 1
	\$		\$67,930,563										\$118,350,372	
BCR	3	\$302,414,913	\$67,930,563	\$41,420,560	\$23,431,293	\$31,000,041	\$43,120,355	\$ 99,369,167	\$ 90,470,027	\$ 66,062,455	\$ 90,310,021	\$102,331,420	\$110,000,072	\$ 951,000,720
de la companya de la		1.0												
COSTS														
Total Capital														
Transmission	\$	\$174,749,914	\$ 852,627	\$20,810,441	\$22,008,175	\$21,076,725	\$18,946,505	\$ 3,640,042	\$ 18,795,510	\$ 22,157,669	\$ 16,386,118	\$ 5,451,893	\$ -	\$ 282,268,937
Distribution	\$	\$210,481,241	\$ -	\$19,018,735	\$19,494,204	\$19,981,559	\$20,481,098	\$ 443,568	\$ 4,654,726	\$ 6,560,426	\$ 5,372,102	\$ -	\$ -	\$ 273,122,823
Telecom	\$	\$ 30,973,700	\$ (0)	\$ 0	\$ (0)	\$ 0	\$ -	\$ -	\$ -	\$ (0)	\$ (0)	\$ 0	\$ 0	\$ 32,477,14
IT	\$	\$ 11,112,374	\$ 31,452	\$ 441,962	\$ 496,820	\$ 446,969	\$ 306,117	\$ 26,247	\$ 601,901	\$ 619,028	\$ 582,538	\$ 434,009	\$ 40,261	\$ 14,707,068
PM	\$	\$ 19,707,587	The second second	\$ -	\$ -	\$ -	\$	\$ -	\$ -	\$ -	\$	\$ -	\$	\$ 19,707,58
Ongoing	\$	\$ 27,349,339		\$ 4 247 231	\$ 4353 411	\$ 4,462,247	\$ -	\$	\$ -	\$ 6,654,614	\$ 5,048,623	\$ 5,174,838	\$ 5,304,209	\$ 59,188,899
Origonia	\$	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Total Capital	\$	\$474,374,155	\$ 6,482,374	\$44,518,370	\$46,352,610	\$45,967,499	\$39,733,720	\$ 4,109,857	\$ 24,052,137	\$ 35,991,737	\$ 27,389,380	\$ 11,060,740	\$ 5,344,470	\$ 681,472,45
Total O&M		-												
Transmission	\$	\$ 1,409,686	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 1,560,77
Distribution	\$	\$ 7,818,516	2	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 7,938,44
Telecom	S	\$ 374.663	750	\$ -	\$ -	\$	\$	\$ -	\$ -	\$	\$	\$ -	\$	\$ 404,73
IT	9	\$ 13,151,937	THE R. LEWIS CO., LANSING	\$ 1.278.095	\$ 1,278,095	\$ 1,278,095	\$ 1,278,095	\$ 1,278,095	\$ 1,278,095	\$ 1,278,095	\$ 1,278,095	\$ 1,278,095	\$ 1,278,095	\$ 25,264,12
PM	9	φ 15,151,957	\$ 1,270,093	\$ 1,210,033 \$	\$ 1,210,033	φ 1,270,033 Φ	¢ 1,210,035	\$ 1,270,033	0 1,270,033	¢ 1,270,095	¢ 1,270,093	¢ 1,270,095	0 1,270,095	\$ 20,204,12
	D.	\$ 40.050.700	P P P P P P P P P P	D 0.050 705	\$ 4000 000	P + 00+ 000	0 1 100 071	\$	a 4 004 700	0 4 404 007	a 4 400 000	ф • 1500 111	4 1051000	• • • • • • • • • • • • • • • • • • • •
Ongoing Total O&M	\$	\$ 43,058,769 \$ 65,813,571			The second second second second			\$ 4,244,286 \$ 5,522,380	\$ 4,321,788 \$ 5,599,882	\$ 4,401,227 \$ 5,679,322	\$ 4,482,653 \$ 5,760,747	The second second	The second secon	\$ 82,849,75 \$ 118,017,83
Total Odivi	Ø.	\$ 00,810,071	\$ 0,102,319	\$ 5,250,619	\$ 5,501,052	\$ 5,575,001	\$ 5,440,700	φ 5,522,560	\$ 0,055,002	\$ 0,019,022	\$ 5,700,747	\$ 5,644,209	\$ 0,929,700	\$ 110,017,035
Total Costs		A 171 071 155	A 0 400 074	* * * * * * * * * *	A 40 050 040	A45 007 400	* 20 700 700	A 4400.057	A 04.050.407	A 05 004 707	A 07 000 000	A 44 000 740	A 5044.470	A 004 470 45
Total Capital	\$	\$474,374,155				Print of the Park of the Park	The second secon	A CO. THE REAL PROPERTY AND ADDRESS OF THE PARTY AND ADDRESS OF THE PAR		\$ 35,991,737	The second secon		The second secon	\$ 681,472,45
Total O&M Total Capital & O&M	\$									\$ 5,679,322			\$ 5,929,756 \$ 11,274,227	
		\$040,101,121	\$11,044,030	443,143,103	ψ01,000,04 <u>2</u>	ψ01,040,000	\$40,100,400	ψ 3,002,201	¥ 23,002,013	\$ 41,071,000	ψ 00,100,127	ψ 10,304,343	¥ 11,214,221	V 100,400,20
BENEFITS														
Operational Benefits													1	· Sulling
Improved VAR Mgmt	\$	\$ 89,711,275	\$ 8,936,560	\$ 6,633,301	\$ 6,828,770	\$ 7,100,741	\$ 7,333,229	\$ 7,709,856	\$ 8,056,471	\$ 8,361,270	\$ 8,648,115	\$ 8,774,514	\$ 8,903,115	\$ 165,026,78
Avoided Capacity Costs	\$	\$109,962,860	\$ 8,393,371	\$ 8,499,966	\$ 8,607,916	\$ 8,717,236	\$ 8,827,945	\$ 8,940,060	\$ 9,053,599	\$ 9,168,580	\$ 9,285,021	\$ 9,402,940	\$ 9,522,358	\$ 194,811,92
Avoided Fixed O&M Generation C	\$	\$ 4,608,029	\$ 814,267	\$ 834,629	\$ 855,491	\$ 879,284	\$ 898,800	\$ 921,270		\$ 970,562	\$ 992,112	\$ 1,016,907	\$ 1,042,330	\$ 11,818,21
Avoided Variable O&M Generatio	S	\$ 23,796,894	\$ 3,352,826	\$ 2 910 272	\$ 1922 811	\$ 2 551 824	\$ 2454 961	\$ 2612847	\$ 2662879	\$ 2572 940	\$ 2651723	\$ 2735 164	\$ 3,663,994	\$ 48,377,53
Avoided Reagent Cost Generation		\$ 281,705			\$ 83,665									
	\$											The second secon	\$ 2,267,126	
	\$												\$ 25,432,138	
Customer Benefits														
	\$	\$368 653 700	\$34 973 815	\$41 503 769	\$35 313 935	\$38 898 316	\$40 103 484	\$ 52 667 044	\$ 65 422 888	\$ 52 646 840	\$ 61 917 963	\$ 56 595 389	\$ 63,168,975	\$ 794.214.59
SUBTOTAL:	\$												\$ 63,168,975	
	L SU L	\$000,000,700	\$04,310,010	\$41,000,703	φυσ,σ10,300	\$50,030,010	\$40,100,404	ψ 02,001,044	\$ 00,422,000	\$ 02,040,040	\$ 01,511,500	\$ 50,555,565	\$ 00,100,570	7 7 7 7 7 7 7 7 7 7 7 7 7 7 7 7 7 7 7 7
Operational Benefits & Customer B SUBTOTAL:	enerits \$	\$609,070,791	56,693,443	61,394,528	54,915,172	59,603,431	61,746,988	76,767,519	90,419,469	76,272,688	88,709,838	80,943,916	88,601,113	1,245,999,91
F														
Environmental Benefits			-											
SO2	\$	\$ 7,387												
NOX	\$	\$ 337,765	\$ 34,030	\$ 35,668	\$ 23,636	\$ 32,041	\$ 24,855	\$ 29,035	\$ 24,549	\$ 26,964	\$ 34,037	\$ 26,874	\$ 20,645	\$ 615,11
CO2	\$	\$233 186 698	\$22 846 504	\$29 744 225	\$20 145 962	\$23 571 115	\$26 534 805	\$ 32 224 706	\$ 35,677,984	\$ 33 433 800	\$ 40 725 026	\$ 38 265 496	\$ 41 002 819	\$ 504.720.48
CO2	*	Ψ200, 100,000	4	Arci, Little	420,110,002	420,011,110	420,001,000	A 05'55 1'100	4 00,011,001	\$ 00,100,000	Ψ τυ, ι ευ, υευ	4 00,200,100	Ψ 41,002,010	+,,
SUBTOTAL:	\$												\$ 41,023,486	

DEC NC COST-BENEFIT ANALYSIS - DISTRIBUTION PORTFOLIO SUMMARY

Net Present Value (Primary Costs and Benefits)

Substation and Line Projects



Program				NPV Costs				NPV Benefits									
Flogram		Capital	0&M		Total			Operational		Customer		Other		Total	B/C Ratio		
Self-Optimizing Grid (Full SOG and Partial SOG)	\$	228,970,448	\$	9,478,670	\$	238,449,118	\$	14.	\$	1,311,577,330	\$	36,971,634	\$	1,348,548,964	5.7		
Distribution H&R: Laterals	\$	354,750,158	\$	6,797,936	\$	361,548,093	\$	9,487,387	\$	889,006,803	\$	Α.	\$	898,494,190	2.5		
Distribution H&R: Storm	\$	41,042,000	\$	791,975	\$	41,833,976	\$	2,201,659	\$	165,744,170	\$	9 -	\$	167,945,829	4.0		
Distribution H&R: Public Interference	\$	78,800,972	ş.	1,507,044	\$	80,308,016	\$		\$	99,946,384	\$		\$	99,946,384	1.2		
Distribution Automation: Fuse Replacement	\$	24,245,934	\$	648,187	\$	24,894,120	-		\$	66,978,669	\$	å	\$	66,978,669	2.7		
Long Duration Interruptions (LDI)	\$	19,015,596	\$	683,560	\$	19,699,156	\$	711,208	\$	319,499,044	\$	-	\$	320,210,253	16.3		
Targeted Undergrounding (TUG)	\$	158,976,825	\$	114,741	\$	159,091,566	\$	8,477,567	\$	478,523,026	\$	~	\$	487,000,593	3.1		
Total NPV Costs and Benefits (Programs with CBAs	\$	905,801,932	\$	20,022,113	\$	925,824,045	\$	20,877,821	\$	3,331,275,426	\$	36,971,634	\$	3,389,124,882	3.7		
Total NPV Costs and Benefits (Non-CBA Programs)	\$	631,052,237		10,120,808	\$	641,173,045	\$	-	\$	- 3 1	\$		\$		-		
Total NPV Costs and Benefits (All Programs)	\$ 1	1,536,854,169	\$	30,142,921	\$	1,566,997,090	\$	20,877,821	\$	3,331,275,426	\$	36,971,634	\$	3,389,124,882	2.2		



Financial cost-benefit analyses methodology

DISTRIBUTION

Overall methodology

- Benefits calculation and cost-benefits analysis completed using methodology from previous rate case filings
- · Expected financial benefits based primarily on customer (e.g., reliability improvements) and operational savings
- · Cost-benefit analyses completed at the improvement program level; similar to analysis for SOG in previous rate case filings

Data inputs

- Aggregate resource / input requirements determined based:
 - Substation characteristics
 - Historical project data: average requirements for completion of work
- Expected reliability improvements determined based on:
 - Historic performance for identified circuits
 - Historical project data: average improvements associated with program

Methodology for benefits and costs

- Program costs calculated using aggregate resource / input requirements and projected unit costs (based on historic project data)
- Program benefits calculated as financial value of:
 - Customer savings (expected reliability improvements, using Interruption Cost Estimate (ICE) Calculator used as data input)
 - Operational savings (e.g., avoided O&M)
 - Other savings (e.g., fuel costs, environmental)
- Timing of costs and benefits determined from expected project schedules

Excel-based cost-benefit analysis (CBA)

- Projected schedule of program costs and benefits tabulated in excel
 - Benefits segmented by (1) sustained outage avoidance, (2) momentary outage avoidance, and (3) operational savings
 - Costs segmented by (1) capital, (2) contingency, (3) O&M, and (4) ongoing
- Present value (as of current year) calculated for costs and benefits
- Net present value and benefit-cost ratio calculated for each program
- Sensitivity analysis tab included for variance on key inputs








Overview of ICE Calculator



- Interruption Cost Estimate (ICE) Calculator is an electric reliability, online planning tool developed by Lawrence Berkeley National Laboratory (LBNL) and Nexant, Inc with funding from the U.S. Dept. of Energy (DoE)
- Tool is designed for electric reliability planners at utilities, government organizations, and other entities
 that are interested in estimating interruption costs and/or the benefits associated with reliability improvements in
 the United States
- Translates reliability improvements into value by using data from 34 previous Customer Interruption Cost studies from 10 utilities between 1989-2012.

Data inputs to ICE

- State
- Customers
 - Non-residential
 - Residential
- · Reliability metrics
 - SAIDI
 - SAIFI



Outputs from ICE / inputs to CBA

- Cost data by customer sector (Residential, Small C&I, Med./Large C&I)
 - Cost per Outage Event
 - Cost per Average kW
 - Cost per Unserved kWh

Generalized CBA Calculated Reliability Improvement Value:

Number of Events Eliminated * Average Number of Customers Impacted * ICE Cost per Outage Event (Based on Duration)

Source: ICE Calculator