

**STATE OF NORTH CAROLINA
UTILITIES COMMISSION
RALEIGH**

DOCKET NO. E-2, SUB 1321

BEFORE THE NORTH CAROLINA UTILITIES COMMISSION

In the Matter of)	
Application of Duke Energy Progress, LLC)	DIRECT TESTIMONY OF
Pursuant to G.S. 62-133.2 and NCUC Rule)	TOM SIMRIL FOR
R8-55 Relating to Fuel and Fuel-Related)	DUKE ENERGY PROGRESS, LLC
Charge Adjustments for Electric Utilities)	

1 **Q. PLEASE STATE YOUR NAME AND BUSINESS ADDRESS.**

2 A. My name is Tom Simril, and my business address is 4800 Concord Road, York, South
3 Carolina.

4 **Q. BY WHOM ARE YOU EMPLOYED AND IN WHAT CAPACITY?**

5 A. I am Senior Vice President of Nuclear Operations for Duke Energy Corporation
6 (“Duke Energy”) with direct executive accountability for Duke Energy’s North
7 Carolina nuclear stations, including Duke Energy Progress, LLC’s (“DEP” or the
8 “Company”) Brunswick Nuclear Plant (“Brunswick”) in Brunswick County, North
9 Carolina; the Harris Nuclear Plant (“Harris”) in Wake County, North Carolina; and
10 Duke Energy Carolinas, LLC’s McGuire Nuclear Station, located in Mecklenburg
11 County, North Carolina.

12 **Q. WHAT ARE YOUR RESPONSIBILITIES AS SENIOR VICE PRESIDENT
13 OF NUCLEAR OPERATIONS?**

14 A. As Senior Vice President of Nuclear Operations, I am responsible for providing
15 oversight for the safe and reliable operation of Duke Energy’s nuclear stations in
16 North Carolina. I am also involved in the operations of Duke Energy’s other nuclear
17 stations, including DEP’s Robinson Nuclear Plant (“Robinson”) located in Darlington
18 County, South Carolina.

19 **Q. PLEASE SUMMARIZE YOUR EDUCATIONAL BACKGROUND AND
20 PROFESSIONAL EXPERIENCE.**

21 A. I have a Bachelor of Science degree in mechanical engineering from Clemson
22 University and received a senior reactor operator license from Duke Energy’s
23 Catawba Nuclear Station. My career in the nuclear power industry spans over 37

1 years. I began my nuclear career as an engineer at Catawba Nuclear Station. From
2 1998 to 2007, I served in a variety of leadership positions at Catawba in operations
3 and engineering. In 2007, I joined the McGuire Nuclear Station team as the operations
4 superintendent before being transferred to serve as the operations manager at Catawba
5 from 2010 to 2013. In 2013, I was named the plant manager at Catawba and served
6 in this role until being promoted as the site vice president for Catawba in 2016. I held
7 that position until January 2023 when I assumed my current role.

8 **Q. HAVE YOU TESTIFIED BEFORE THIS COMMISSION IN ANY PRIOR**
9 **PROCEEDINGS?**

10 A. No.

11 **Q. WHAT IS THE PURPOSE OF YOUR TESTIMONY IN THIS**
12 **PROCEEDING?**

13 A. The purpose of my testimony is to describe the performance of the Brunswick, Harris,
14 and Robinson nuclear plants during the period of April 1, 2022 through March 31,
15 2023 (the “test period”). I will provide information regarding scheduled refueling
16 outages and discuss the nuclear capacity factor being proposed by the Company in
17 determining the fuel factor to be reflected in customer rates during the billing period
18 of December 1, 2023 through November 30, 2024 (“billing period”).

19 **Q. PLEASE DESCRIBE SIMRIL EXHIBIT 1 INCLUDED WITH YOUR**
20 **TESTIMONY.**

21 A. Simril Exhibit 1 is a confidential exhibit outlining the planned schedule for refueling
22 outages for DEP’s nuclear units for the period of April 1, 2023 through November 30,

1 2024. This exhibit represents DEP's current plan, which is subject to adjustment due
2 to changes in operational and maintenance requirements.

3 **Q. PLEASE DESCRIBE DEP'S NUCLEAR GENERATION PORTFOLIO.**

4 A. The Company's nuclear generation portfolio consists of approximately 3,593¹
5 megawatts ("MWs") of generating capacity, made up as follows:

6 Brunswick - 1,870 MWs

7 Harris - 964 MWs

8 Robinson - 759 MWs

9 **Q. PLEASE PROVIDE A GENERAL DESCRIPTION OF DEP'S NUCLEAR**
10 **GENERATION ASSETS.**

11 A. DEP's nuclear fleet consists of three generating stations and a total of four units.
12 Brunswick is a boiling water reactor facility with two units and was the first nuclear
13 plant built in North Carolina. Unit 2 began commercial operation in 1975, followed
14 by Unit 1 in 1977. The operating licenses for Brunswick were renewed in 2006 by
15 the Nuclear Regulatory Commission ("NRC"), extending operations up to 2036 and
16 2034 for Units 1 and 2, respectively. Harris is a single unit pressurized water reactor
17 that began commercial operation in 1987. The NRC issued a renewed license for
18 Harris in 2008, extending operation up to 2046. Robinson is also a single unit
19 pressurized water reactor that began commercial operation in 1971. The license
20 renewal for Robinson Unit 2 was issued by the NRC in 2004, extending operation up
21 to 2030.

¹ As of January 1, 2022.

1 On March 24, 2023, Robinson submitted a letter to the NRC stating the intent
2 to pursue subsequent license renewal (“SLR”), and file the application in the second
3 quarter of 2025. If the license renewal is granted by the NRC, the Company would
4 be authorized to operate Robinson for an additional 20-year period. As announced
5 previously, Duke Energy intends to seek SLR for all nuclear units in the fleet.

6 **Q. WERE THERE ANY CAPACITY CHANGES WITHIN DEP’S NUCLEAR**
7 **PORTFOLIO DURING THE TEST PERIOD?**

8 A. No.

9 **Q. WHAT ARE DEP’S OBJECTIVES IN THE OPERATION OF ITS NUCLEAR**
10 **GENERATION ASSETS?**

11 A. The primary objective of DEP’s nuclear generation department is to safely provide
12 reliable and cost-effective electricity to DEP’s Carolinas customers. The Company
13 achieves this objective by focusing on a number of key areas. Operations personnel
14 and other station employees are well-trained and execute their responsibilities to the
15 highest standards in accordance with detailed procedures. The Company maintains
16 station equipment and systems reliably and ensures timely implementation of work
17 plans and projects that enhance the performance of systems, equipment, and
18 personnel. Station refueling and maintenance outages are conducted through the
19 execution of well-planned, well-executed, and high-quality work activities, which
20 effectively ready the plant for operation until the next planned outage.

21 **Q. PLEASE DISCUSS THE PERFORMANCE OF DEP’S NUCLEAR FLEET**
22 **DURING THE TEST PERIOD.**

1 A. The Company operated its nuclear stations in a reasonable and prudent manner during
2 the test period, providing approximately 49.2% of the total power generated by DEP.
3 The four nuclear units operated at an actual system average capacity factor of 92.12%
4 during the test period, which included three refueling outages.

5 The performance results discussed in my testimony demonstrate DEP's
6 continued commitment to achieving high performance without compromising safety
7 and reliability.

8 **Q. HOW DOES THE PERFORMANCE OF DEP'S NUCLEAR FLEET**
9 **COMPARE TO INDUSTRY AVERAGES?**

10 A. The Company's nuclear fleet has a history of strong operational performance that has
11 historically exceeded industry averages. Industry averages were developed utilizing
12 the North American Electric Reliability Council's ("NERC") Generating Unit
13 Statistical Brochure ("NERC Brochure"), which is considered by the North Carolina
14 Utilities Commission in Rule R8-55(k) in establishing fuel factors in proceedings such
15 as this. The most recently published NERC Brochure indicates an industry average
16 capacity factor of 93.92% for comparable units for the five-year period of 2017
17 through 2021. The Company's had a test period capacity factor of 92.12%, and 2-
18 year average² capacity factor of 93.06%.

19 **Q. GIVEN THE COMPANY'S TEST PERIOD CAPACITY FACTOR OF 92.12%**
20 **AND THE 2-YEAR AVERAGE CAPACITY FACTOR OF 93.06%, WAS THE**
21 **COMPANY PRUDENT IN ITS OPERATIONS?**

² This represents the simple average for the current test period and prior test period of 12 months ended March 2021 for the DEP nuclear fleet.

1 A. Yes. Capacity factor is one of several metrics that should be taken into account when
2 determining if the DEP fleet operated prudently. For the DEP nuclear fleet, safe
3 operations is fundamental, and the fleet utilizes sound, conservative decision making
4 that supports safe and reliable operations while maximizing generation.

5 Over the five-year period from 2017-2021, the DEP fleet operated above a
6 90% capacity factor, and the combined DEP and Duke Energy Carolinas (“DEC”)
7 nuclear fleet has exceeded a 90% annual capacity factor for the past 24 consecutive
8 years (1999 – 2022). Additionally, during this five-year period the DEP fleet has
9 accomplished multiple operational achievements including a record DEP fleet net
10 generation in 2021, Brunswick producing a record net generation in 2021, Harris
11 producing a record net generation in 2020, Robinson having its shortest ever refueling
12 outage in 2020, and both Brunswick Unit 2 and Harris achieving their shortest
13 refueling outages on record in 2021.

14 Finally, as further evidence of the Company’s prudent management, DEP’s
15 nuclear fleet operated through Winter Storm Elliott in December 2022, providing
16 baseload generation during that critical period

17 **Q. WHAT IMPACTS A UNIT’S AVAILABILITY AND WHAT IS DEP’S**
18 **PHILOSOPHY FOR SCHEDULING REFUELING AND MAINTENANCE**
19 **OUTAGES?**

20 A. In general, refueling requirements, maintenance requirements, and NRC operating
21 requirements impact the availability of DEP’s nuclear system. Prior to a planned
22 outage, DEP develops a detailed schedule for the outage and for major tasks to be
23 performed including sub-schedules for particular activities.

1 The Company’s scheduling philosophy is to plan for a best possible outcome
2 for each outage activity within the outage plan. For example, if the “best ever” time
3 a particular outage task was performed is 10 days, then 10 days or less becomes the
4 goal for that task in subsequent outages barring known conflicts. Those individual
5 aspirational goals are incorporated into an overall outage schedule. The Company
6 aggressively works to meet, and measures itself against, that aspirational schedule.
7 Further, to minimize potential impacts to outage schedules, “discovery activities”
8 (walk-downs, inspections, etc.) are scheduled at the earliest opportunity so that any
9 maintenance or repairs identified through those activities can be promptly
10 incorporated into the outage plan. Those discovery activities also have pre-planned
11 contingency actions to ensure that, when incorporated into the schedule, the activities
12 required for appropriate repair can be performed as efficiently as possible.

13 As noted, the Company uses the schedule for measuring outage planning and
14 execution and driving continuous improvement efforts. However, in order to provide
15 reasonable, rather than best ever, total outage time for planning purposes, particularly
16 with the dispatch and system operating center functions, DEP also develops an
17 allocation of outage time, which incorporates unforeseen, reasonable schedule delays
18 that may be needed for unplanned equipment repairs found during inspections. The
19 development of each outage allocation is dependent on maintenance and repair
20 activities included in the outage, as well as major projects to be implemented during
21 the outage. Both schedule and allocation are set aggressively to drive continuous
22 improvement in outage planning and execution.

1 **Q. HOW DOES DEP HANDLE OUTAGE EXTENSIONS AND FORCED**
2 **OUTAGES?**

3 A. When an outage extension becomes necessary, DEP believes that work completed in
4 the extension results in more reliable operations and fewer forced outages, thereby
5 reducing fuel costs in the long run. Therefore, if an unanticipated issue that has the
6 potential to become an on-line reliability issue is discovered while a unit is off-line for
7 a scheduled outage and repair cannot be completed within the planned work window,
8 the outage is usually extended to perform necessary maintenance or repairs prior to
9 returning the unit to service. In the event that a unit is forced off-line, every effort is
10 made to safely perform the repair and return the unit to service as quickly as possible.

11 **Q. DOES DEP PERFORM POST-OUTAGE CRITIQUES AND CAUSE**
12 **ANALYSES FOR INTERNAL IMPROVEMENT EFFORTS?**

13 A. Yes. The nuclear industry recognizes that constant focus on operational excellence
14 results in improved nuclear safety and reliability. As such, DEP applies self-critical
15 analysis to each outage to identify every potential cause of an outage delay or event
16 resulting in a forced or extended outage. These critiques and cause analyses do not
17 document the broader context of the outage or event, and thus rarely reflect strengths
18 and successes.

19 **Q. IS SUCH ANALYSES INTENDED TO ASSESS OR MAKE A**
20 **DETERMINATION REGARDING THE PRUDENCE OR**
21 **REASONABLENESS OF A PARTICULAR ACTION OR DECISION?**

22 A. No. Given this focus on identifying opportunities for improvement, these critiques
23 and cause analyses are not intended to document the broader context of the outage nor

1 do they make any attempt to assess whether the actions taken were reasonable in light
2 of what was known at the time of the events in question. Instead, the reports utilize
3 hindsight (*e.g.*, subsequent developments or information not known at the time) to
4 identify every potential cause of the incident in question. However, such a review is
5 quite different from evaluating whether the actions or decisions in question were
6 reasonable given the circumstances that existed at that time.

7 **Q. WHAT REFUELING OUTAGES WERE COMPLETED AT DEP'S**
8 **NUCLEAR FACILITIES DURING THE TEST PERIOD?**

9 A. There were three refueling outages³ completed during the test period: Harris and
10 Robinson in the fall of 2022, followed by Brunswick Unit 2 during the spring of 2023.

11 The Harris fall 2022 refueling outage began on October 8, 2022. In addition
12 to refueling, maintenance activities, safety and reliability enhancements, and testing
13 and inspections were completed. Reliability enhancements completed during the
14 outage included the inspection of sections of the circulating water system's pre-
15 stressed concrete cylinder pipe, and installation of a carbon fiber reinforced polymer
16 wrap to extend the longevity and address reliability concerns that could threaten unit
17 operations, and replacement of 'B' service water piping and valves. Electrical system
18 reliability enhancements included emergency response facility information system
19 monitor replacement, replacement of 480V breakers to ensure continued reliability of
20 plant equipment, and installation of the main generator ground detection system. The
21 outage was successfully completed with no recordable injuries or environmental
22 events and the unit was returned to service on October 30, 2022 — an outage duration

³ The Brunswick Unit 1 spring 2022 refueling outage (B1R24) began on 3/4/2022 and ended on 4/4/2022; 4 days into this test period. The outage was reviewed in the 2022 fuel proceeding.

1 of 22.2 days compared to a scheduled allocation of 25 days. Shortly after the unit was
2 synchronized to grid, the unit increased power to approximately 16 percent when post-
3 maintenance testing of a breaker from the unit auxiliary transformer to the auxiliary
4 bus was performed. During this testing, a wiring fault resulted in the loss of the
5 auxiliary bus causing two reactor coolant pumps to lose power causing an automatic
6 reactor trip on October 30, 2022. Following the reactor trip, the impacted wiring
7 connection was identified, corrected, and the unit was returned to service 3.4 days
8 later on November 2, 2022.

9 The Robinson fall 2022 refueling outage began on November 19, 2022. In
10 addition to refueling, maintenance activities, safety and reliability enhancements, and
11 testing and inspections were completed. Testing and inspection activities completed
12 included the reactor vessel internals inspections, containment vessel liner panel
13 inspections, 'B' component cooling water heat exchanger inspection and Eddy current
14 testing, and emergency diesel generator fuel oil storage tank internal inspection.
15 Safety and reliability enhancements completed during the outage included installation
16 of upgraded rod control circuit boards; replacement of core exit thermocouples; heater
17 drain pump and condensate pump replacements and motor refurbishments;
18 installation of NERC protective relays for the main generator and main and unit
19 auxiliary transformers mitigating operational and regulatory risks; main generator
20 exciter replacement, main generator and exciter ground detection system replacement;
21 and installation of remote monitoring equipment for various electrical components.
22 During the inspection of the reactor vessel internals indications were discovered in the
23 core barrel. These indications were identified, assessed, and mitigated prior to the unit

1 returning to service, which resulted in an outage extension of 11.6 days. Robinson
2 was returned to service on December 30, 2022 — a total outage duration of 41.6 days
3 compared to an allocation of 30 days. Shortly after synchronizing to the grid,
4 Robinson experienced a main generator lockout due to a configuration issue with a
5 protection relay which resulted in a turbine trip. The relay configuration was
6 addressed, and the unit was returned to service 1.9 days later on January 1, 2023.

7 The Brunswick Unit 2 spring 2023 refueling outage began on February 7,
8 2023. In addition to refueling, maintenance activities, safety and reliability
9 enhancements, and testing and inspections were completed. Testing and inspection
10 activities completed during the outage included ‘2A’ reactor feed pump steam path
11 inspection, conventional service water header inspection, and Eddy current testing for
12 the condenser water box. Maintenance activities completed during the outage
13 included ultrasonic fuel cleaning, identification and discharge of a defective fuel
14 bundle, replacement of safety relief valve main body assemblies, and seal
15 replacements for the ‘2A’ and ‘2B’ reactor recirculation pumps. Additionally, 32
16 single point vulnerabilities were eliminated via design modifications that will help
17 ensure continued safe and reliable operations of Brunswick Unit 2 in the future. The
18 outage was successfully completed with no recordable injuries or environmental
19 events and the unit was returned to service on March 8, 2023 — a duration of 28.3
20 days compared to a scheduled allocation of 29 days.

21 **Q. OTHER THAN REFUELING, WHAT OUTAGES OCCURRED AT DEP’S**
22 **NUCLEAR FACILITIES DURING THE TEST PERIOD?**

1 A. In addition to the short duration outages immediately following the Harris and
2 Robinson refueling outages discussed above, there were two additional outages
3 unrelated to refueling at the Harris Nuclear Plant, and one additional outage unrelated
4 to refueling at the Robinson Nuclear Plant.

5 On April 29, 2022, Harris entered a forced outage due to a loss of condenser
6 vacuum that resulted in a manual reactor trip. During monthly equipment swaps for
7 the condenser vacuum pumps, the suction isolation valve for one of the pumps failed
8 shut, resulting in a rapid decrease in the main condenser vacuum. The rate of decrease
9 was too great for local isolation attempts to be successful, resulting in a manual reactor
10 trip. Replacement and inspection of components included a control relay for the
11 suction isolation valve and repair of a discharge check valve stuck in the open position.
12 The unit was safely returned to service on April 30, 2022 – an outage duration of 1.4
13 days.

14 On August 28, 2022, the Harris Nuclear Plant operators manually tripped the
15 reactor following the loss of the ‘B’ condensate pump and ‘B’ condensate boost pump.
16 Investigations revealed damage to the ‘B’ condensate pump motor due to a lightning
17 strike, and the motor was replaced. The unit was safely returned to service on August
18 29, 2022 – an outage duration of 1.5 days.

19 On September 24, 2022, the Robinson Nuclear Plant was disconnected from
20 the grid to address a seal leak on the ‘C’ reactor coolant pump. The seal for the ‘C’
21 reactor coolant pump was replaced, and the unit began its return to service when the
22 seal leak-off flow for the ‘B’ reactor coolant pump was below the threshold for
23 continued operation, requiring the ‘B’ reactor coolant pump seal to be replaced. After

1 the 'B' reactor coolant pump seal was replaced, the unit was safely returned to service
2 on October 10, 2022 – an outage duration of 16.3 days.

3 **Q. WHAT CAPACITY FACTOR DOES DEP PROPOSE TO USE IN**
4 **DETERMINING THE FUEL FACTOR FOR THE BILLING PERIOD?**

5 A. The Company proposes to use a 92.27% capacity factor, which is a reasonable value
6 for use in this proceeding based upon the operational history of DEP's nuclear units
7 and the number of planned outage days scheduled during the billing period. This
8 proposed percentage is reflected in the testimony and exhibits of Company witness
9 Harrington.

10 **Q. DOES THIS CONCLUDE YOUR PRE-FILED DIRECT TESTIMONY?**

11 A. Yes, it does.