

Duke Energy Progress, LLC  
Transitional Cluster Study  
Phase 1 Report  
February 28, 2022



**Duke Energy Progress, LLC (“Duke EnergyProgress” or “DEP”)** is issuing this report as Transmission Provider under the applicable joint Open Access Transmission Tariff (OATT) Attachment J Large Generator Interconnection Procedures and as the interconnecting Utility under the applicable North Carolina Interconnection Procedures (NCIP) and South Carolina Generator Interconnection Procedures (SC GIP). This report summarizes the Transitional Cluster Study Phase 1 results for all Interconnection Requests studied by Duke Energy Progress in the Transitional Cluster.

## Contents

Summary of Each Interconnection Request

Transmission Report

Distribution Report

## Transmission Interconnections

### ID 005703

ID 005703 is a proposed 70.2MW solar Generating Facility connecting to the Blewett -Tillery 115 kV transmission line in Montgomery County, NC. The estimated cost of Interconnection Facilities is \$5.368M and the total estimated cost of Upgrades currently assigned to 005703 is \$22.750M. The thermal Upgrades are detailed in tables 7.1.1, 7.1.2, 7.1.3, 7.1.4, 7.1.22, and 7.1.23.

### ID 010586

ID 010586 is a proposed 70.1MW solar Generating Facility connecting to the Marion - Whiteville 230 kV transmission line in Caswell County, NC. The estimated cost of Interconnection Facilities is \$5.559M and the total estimated cost of Upgrades currently assigned to 010586 is \$7.345M. The thermal Upgrades are detailed in tables 7.1.14, 7.1.15, and 7.1.24.

### ID 016321

ID 016321 is a proposed 70MW solar Generating Facility connecting to the Pageland Tap, Robinson-Rockingham 115 kV transmission line in Chesterfield County, SC. The estimated cost of Interconnection Facilities is \$5.221M and the total estimated cost of Upgrades currently assigned to 016321 is \$38.349M. The thermal Upgrades are detailed in tables 7.1.1, 7.1.2, 7.1.4, 7.1.6, 7.1.7, 7.1.8, 7.1.9, 7.1.14, 7.1.15, 7.1.18, 7.1.19, 7.1.20, 7.1.22, and 7.1.23.

### ID 017658

ID 017658 is a proposed 80MW solar Generating Facility connecting to the Florence DuPont - Marion 115 kV transmission line in Marion County, SC. The estimated cost of Interconnection Facilities is \$5.458M and the total estimated cost of Upgrades currently assigned to 017658 is \$10.568M. The thermal Upgrades are detailed in tables 7.1.14, 7.1.15, 7.1.16, 7.1.17, 7.1.24.

### ID 019397

ID 019397 is a proposed 75MW solar Generating Facility connecting to the Florence DuPont - SCPSA Hemingway 115 kV transmission line in Florence County, SC. The estimated cost of Interconnection Facilities is \$5.458M and the total estimated cost of Upgrades currently assigned to 019397 is \$8.527M. The thermal Upgrades are detailed in tables 7.1.14, 7.1.15, 7.1.16, 7.1.17, 7.1.18, 7.1.19, and 7.1.24.

### ID 021764

ID 021764 is a proposed 8MW solar Generating Facility connecting to the Kinston DuPont 115kV transmission line in Lenoir County, NC. The estimated cost of Interconnection Facilities is \$2.231M and the total estimated cost of Upgrades currently assigned to 021764 is \$4.000M.

### ID 021772

ID 021772 is a proposed 8MW solar Generating Facility connecting to the Kinston DuPont 115kV transmission line in Lenoir County, NC. The estimated cost of Interconnection Facilities is \$2.231M and the total estimated cost of Upgrades currently assigned to 021772 is \$4.000M.

### ID 022128

ID 022128 is a proposed 79.8MW solar Generating Facility connecting to the Lee - Wommack 230 kV North transmission line in Lenoir County, NC. The estimated cost of Interconnection Facilities is \$5.322M and the total estimated cost of Upgrades currently assigned to 022128 is \$2.598M. The thermal Upgrades are detailed in tables 7.1.1, 7.1.2, 7.1.22, and 7.1.23.

### ID 024078

ID 024078 is a proposed 79.8MW solar Generating Facility connecting to the Robinson - Camden Junction 115 kV transmission line in Kershaw County, SC. The estimated cost of Interconnection Facilities is \$5.494M and the total estimated cost of Upgrades currently assigned to 024078 is \$8.712M. The thermal Upgrades are detailed in tables 7.1.14, 7.1.15, 7.1.18, 7.1.19, and 7.1.24.

**ID 030708**

ID 030708 is a proposed 78.32MW solar Generating Facility connecting to the Person - Rocky Mount 230 kV transmission line in Nash County, NC. The estimated cost of Interconnection Facilities is \$2.064M and the total estimated cost of Upgrades currently assigned to 030708 is \$11.229M.

**ID 032986**

ID 032986 is a proposed 80MW solar Generating Facility connecting to the Cumberland - Whiteville 230 kV transmission line in Bladen County, NC. The estimated cost of Interconnection Facilities is \$5.559M and the total estimated cost of Upgrades currently assigned to 032986 is \$15.826M. The thermal Upgrades are detailed in tables 7.1.1, 7.1.2, 7.1.10, 7.1.11, 7.1.12, 7.1.13, 7.1.14, 7.1.15, 7.1.21, 7.1.22, and 7.1.23.

**ID 067146**

ID 067146 is a proposed 80MW solar Generating Facility connecting to the Robinson - Florence 230 kV transmission line in Darlington County, SC. The estimated cost of Interconnection Facilities is \$5.826M and the total estimated cost of Upgrades currently assigned to 067146 is \$14.824M. The thermal Upgrades are detailed in tables 7.1.6, 7.1.7, 7.1.8, 7.1.9, 7.1.14, 7.1.15, 7.1.16, 7.1.17, 7.1.18, 7.1.19, and 7.1.24.

**ID 119904**

ID 119904 is a proposed 18.4MW storage Generating Facility connecting to the Fort Bragg Longstreet Rd 230 kV transmission line in Cumberland County, NC. The estimated cost of Transmission Provider Interconnection Facilities is \$1.103M and the total estimated cost of Network Upgrades currently assigned to 119904 is \$3.519M. The thermal Upgrades are detailed in tables 7.1.14 and 7.1.15.

**ID 126008**

ID 126008 is a proposed 75MW solar Generating Facility connecting to the Rocky Mount - Wilson 230 kV transmission line in Wilson County, NC. The estimated cost of Interconnection Facilities is \$5.818M and the total estimated cost of Upgrades currently assigned to 126008 is \$2.106M.

**ID 138340**

ID 138340 is a proposed 74MW solar Generating Facility connecting to the Weatherspoon - LOF 115 kV transmission line in Robeson County, NC. The estimated cost of Interconnection Facilities is \$5.393M and the total estimated cost of Upgrades currently assigned to 138340 is \$25.357M. The thermal Upgrades are detailed in tables 7.1.1, 7.1.2, 7.1.6, 7.1.7, 7.1.8, 7.1.9, 7.1.10, 7.1.11, 7.1.12, 7.1.13, 7.1.14, 7.1.15, 7.1.16, 7.1.17, 7.1.22, and 7.1.23.

**ID 169712**

ID 169712 is a proposed 80MW solar Generating Facility connecting to the Biscoe - Rockingham 230 kV transmission line in Montgomery County, NC. The estimated cost of Interconnection Facilities is \$5.559M and the total estimated cost of Upgrades currently assigned to 169712 is \$4.939M. The thermal Upgrades are detailed in tables 7.1.1, 7.1.2, 7.1.4, 7.1.22, and 7.1.23.

**ID 169716**

ID 169716 is a proposed 80MW solar Generating Facility connecting to the Cumberland - Delco 230 kV transmission line in Bladen County, NC. The estimated cost of Interconnection Facilities is \$2.064M and the total estimated cost of Upgrades currently assigned to 169716 is \$16.762M. The thermal Upgrades are detailed in tables 7.1.1, 7.1.2, 7.1.14, 7.1.15, 7.1.21, 7.1.22, and 7.1.23.

**ID 170274**

ID 170274 is a proposed 275MW solar and storage Generating Facility connecting to the Laurinburg - Richmond 230 kV transmission line in Richmond County, NC. The estimated cost of Transmission Provider Interconnection Facilities is \$2.064M and the total estimated cost of Upgrades currently assigned to 170274 is \$89.682M. The thermal Network Upgrades are detailed in tables 7.1.1, 7.1.2, 7.1.4, 7.1.5, 7.1.6, 7.1.7, 7.1.8, 7.1.9, 7.1.10, 7.1.11, 7.1.12, 7.1.13, 7.1.14, 7.1.15, 7.1.16, 7.1.17, 7.1.20, 7.1.22, and 7.1.23.

**ID 177122**

ID 177122 is a proposed 69.9MW solar Generating Facility connecting to the Bennettsville - Laurinburg 230 kV transmission line in Scotland County, NC. The estimated cost of Transmission Provider Interconnection Facilities is \$5.322M and the total estimated cost of Network Upgrades currently assigned to 177122 is \$13.913M. The thermal Upgrades are detailed in tables 7.1.6, 7.1.7, 7.1.8, 7.1.9, 7.1.14, 7.1.15, 7.1.16, and 7.1.17.

**ID 179866**

ID 179866 is a proposed 150MW solar Generating Facility connecting to the Florence - Kingstree 230 kV transmission line in Williamsburg County, SC. The estimated cost of Transmission Provider Interconnection Facilities is \$5.559M and the total estimated cost of Network Upgrades currently assigned to 179866 is \$22.655M. The thermal Upgrades are detailed in tables 7.1.1, 7.1.2, 7.1.4, 7.1.10, 7.1.11, 7.1.12, 7.1.13, 7.1.14, 7.1.15, 7.1.16, 7.1.17, 7.1.18, 7.1.19, 7.1.22, 7.1.23, and 7.1.24.

**ID 179996**

ID 179996 is a proposed 74.9MW solar Generating Facility connecting to the Kingstree - Sumter 115 kV transmission line in Williamsburg County, SC. The estimated cost of Transmission Provider Interconnection Facilities is \$5.368M and the total estimated cost of Network Upgrades currently assigned to 179996 is \$7.525M. The thermal Upgrades are detailed in tables 7.1.14, 7.1.15, 7.1.18, 7.1.19, and 7.1.24.

**ID 186310**

ID 186310 is a proposed 23.3MW storage Generating Facility connecting to the Durham - DPC East Durham 230 kV transmission line in Durham County, NC. The estimated cost of Transmission Provider Interconnection Facilities is \$5.559M and the total estimated cost of Network Upgrades currently assigned to 186310 is \$1.142M.

**ID 187960**

ID 187960 is a proposed 165MW solar Generating Facility connecting to the Darlington County Plant 230 kV Switchyard transmission line in Darlington County, SC. The estimated cost of Transmission Provider Interconnection Facilities is \$3.123M and the total estimated cost of Network Upgrades currently assigned to 187960 is \$39.004M. The thermal Upgrades are detailed in tables 7.1.1, 7.1.2, 7.1.4, 7.1.6, 7.1.7, 7.1.8, 7.1.9, 7.1.10, 7.1.11, 7.1.12, 7.1.13, 7.1.14, 7.1.15, 7.1.16, 7.1.17, 7.1.18, 7.1.19, 7.1.22, 7.1.23, and 7.1.24.

**ID 191894**

ID 191894 is a proposed 30.5MW storage Generating Facility connecting to the Craggy 230 kV transmission line in Buncombe County, NC. The estimated cost of Transmission Provider Interconnection Facilities is \$1.735M and the total estimated cost of Network Upgrades currently assigned to 191894 is \$2.668M.

**ID 200482**

ID 200482 is a proposed 60MW solar Generating Facility connecting to the Rockingham - West End 230 kV East transmission line in Richmond County, NC. The estimated cost of Interconnection Facilities is \$5.322M and the total estimated cost of Upgrades currently assigned to 200482 is \$22.923M. The thermal Upgrades are detailed in tables 7.1.1, 7.1.2, 7.1.4, 7.1.6, 7.1.7, 7.1.8, 7.1.9, 7.1.14, 7.1.15, 7.1.20, 7.1.22, and 7.1.23.

**ID 205718**

ID 205718 is a proposed 74.9MW solar Generating Facility connecting to the Bennettsville - Laurinburg 230 kV transmission line in Marlboro County, SC. The estimated cost of Interconnection Facilities is \$5.322M and the total estimated cost of Upgrades currently assigned to 205718 is \$15.227M. The thermal Upgrades are detailed in tables 7.1.1, 7.1.2, 7.1.4, 7.1.6, 7.1.7, 7.1.8, 7.1.9, 7.1.14, 7.1.15, 7.1.16, 7.1.17, 7.1.22, and 7.1.23.

## Distribution Interconnections

**ID 002115**

ID 002115 is a proposed 4.998 MW solar Generating Facility connecting to Feeder T2631B03 from the Weatherspoon 230kV substation in Robeson County, NC. The estimated cost of Interconnection Facilities is \$125,000. The estimated transmission upgrade allocation is \$0, and the estimated distribution upgrade is \$366,000. The total estimated cost is **\$491,000**. The distribution upgrades are detailed in section 5.7 of the distribution report. The customer will be required to build distribution facilities to a new POI 2.2 miles from the solar facility. In the event that this request chooses to move forward, it will proceed to an individual distribution-level System Impact Study (NCIP 4.4.7.1).

**ID 002156**

ID 002156 is a proposed 4.999 MW solar Generating Facility connecting to Feeder T2631B03 from the Weatherspoon 230kV substation in Robeson County, NC. The estimated cost of Interconnection Facilities is \$125,000. The estimated transmission upgrade allocation is \$0, and the estimated distribution upgrade is \$366,000. The total estimated cost is **\$491,000**. The distribution upgrades are detailed in section 5.7 of the distribution report. The customer will be required to build distribution facilities to a new POI 3 miles from the solar facility. In the event that this request chooses to move forward, it will proceed to an individual distribution-level System Impact Study (NCIP 4.4.7.1).

**ID 004484**

ID 004484 is a proposed 2.0 MW solar Generating Facility connecting to Feeder T2750B04 from the Dillon 115kV substation in Dillon County, SC. The estimated cost of Interconnection Facilities is \$125,000. The estimated transmission upgrade allocation is \$0, and the estimated distribution upgrade is \$0. The total estimated cost is **\$125,000**. The distribution upgrades are detailed in section 5.1 of the distribution report. The customer will be required to build distribution facilities to a new POI 5.1 miles from the solar facility. In the event that this request chooses to move forward, it will proceed to an individual distribution-level System Impact Study (SC GIP Appendix SC 5.3.7.1).

**ID 004540**

ID 004540 is a proposed 8.0 MW solar Generating Facility connecting to Feeder T3760B02 from the McColl 230kV substation in Marlboro County, SC. The estimated cost of Interconnection Facilities is \$125,000. The estimated transmission upgrade allocation is \$1,383,000 and the estimated distribution upgrade is \$2,007,000. The total estimated cost is **\$3,515,000**. The transmission upgrades are detailed in tables 7.1.6, 7.1.7, 7.1.8, 7.1.9, 7.1.14, 7.1.15, and 7.1.17 in the transmission report. The distribution upgrades are detailed in section 5.4 of the distribution report.

**ID 004538**

ID 004538 is a proposed 10.0 MW solar Generating Facility connecting to Feeder T2750B04 from the Dillon 115kV substation in Dillon County, SC. The estimated cost of Interconnection Facilities is \$125,000. The estimated transmission upgrade allocation is \$1,151,000 and the estimated distribution upgrade is \$0. The total estimated cost is **\$1,276,000**. The transmission upgrades are detailed in tables 7.1.14, 7.1.15, 7.1.16 and 7.1.17 in the transmission report. The distribution upgrades are detailed in section 5.1 of the distribution report. The customer will be required to build distribution facilities to a new POI 3 miles from the solar facility.

**ID 005037**

ID 005037 is a proposed 1.998 MW solar Generating Facility connecting to Feeder T6670B03 from the Whiteville 115kV substation in Columbus County, NC. The estimated cost of Interconnection Facilities is \$125,000. The estimated transmission upgrade allocation is \$0, and the estimated distribution upgrade is \$0. The total estimated cost is **\$125,000**. The distribution upgrades are detailed in section 5.8 of the distribution report. In the event that this request chooses to move forward, it will proceed to an individual distribution-level System Impact Study (NCIP 4.4.7.1).

**ID 008286**

ID 008286 is a proposed 4.992 MW solar Generating Facility connecting to Feeder T1672B03 from the Wadesboro Bowman School 230kV substation in Anson County, NC. The estimated cost of Interconnection Facilities is \$125,000. The estimated transmission upgrade allocation is \$0, and the estimated distribution upgrade is \$1,412,000. The total estimated cost is **\$1,537,000**. The distribution upgrades are detailed in section 5.6 of the distribution report. In the event that this request chooses to move forward, it will proceed to an individual distribution-level System Impact Study (NCIP 4.4.7.1).

**ID 016227**

ID 016227 is a proposed 1.98 MW solar Generating Facility connecting to Feeder T3665B05 from the Hartsville Segars Mill 230kV substation in Darlington County, SC. The estimated cost of Interconnection Facilities is \$125,000. The estimated transmission upgrade allocation is \$0, and the estimated distribution upgrade is \$0. The total estimated cost is **\$125,000**. The distribution upgrades are detailed in section 5.2 of the distribution report. In the event that this request chooses to move forward, it will proceed to an individual distribution-level System Impact Study (SC GIP Appendix SC 5.3.7.1).

**ID 016257**

ID 016257 is a proposed 1.98 MW solar Generating Facility connecting to Feeder T3665B04 from the Hartsville Segars Mill 230kV substation in Darlington County, SC. The estimated cost of Interconnection Facilities is \$125,000. The estimated transmission upgrade allocation is \$0, and the estimated distribution upgrade is \$0. The total estimated cost is **\$125,000**. The distribution upgrades are detailed in section 5.2 of the distribution report. The customer will be required to build distribution facilities to a new POI 3.5 miles from the solar facility. In the event that this request chooses to move forward, it will proceed to an individual distribution-level System Impact Study (SC GIP Appendix SC 5.3.7.1).



**ID 019139**

ID 019139 is a proposed 2.0 MW solar Generating Facility connecting to Feeder T3030B01 from the Mullins 115kV substation in Dillon County, SC. The estimated cost of Interconnection Facilities is \$125,000. The estimated transmission upgrade allocation is \$0, and the estimated distribution upgrade is \$541,000. The total estimated cost is **\$666,000**. The distribution upgrades are detailed in section 5.5 of the distribution report. In the event that this request chooses to move forward, it will proceed to an individual distribution-level System Impact Study (SC GIP Appendix SC 5.3.7.1).

**ID 016328**

ID 016328 is a proposed 2.0 MW solar Generating Facility connecting to Feeder T3760B02 from the McColl 230kV substation in Marlboro County, SC. The estimated cost of Interconnection Facilities is \$125,000. The estimated transmission upgrade allocation is \$314,000 and the estimated distribution upgrade is \$637,000. The total estimated cost is **\$1,076,000**. The transmission upgrades are detailed in tables 7.1.6, 7.1.7, 7.1.8, 7.1.9, 7.1.14, 7.1.15, and 7.1.17 in the transmission report. The distribution upgrades are detailed in section 5.4 of the distribution report.

**ID 019170**

ID 019170 is a proposed 2.0 MW solar Generating Facility connecting to Feeder T3760B01 from the McColl 230kV substation in Marlboro County, SC. The estimated cost of Interconnection Facilities is \$125,000. The estimated transmission upgrade allocation is \$314,000 and the estimated distribution upgrade is \$581,000. The total estimated cost is **\$1,020,000**. The transmission upgrades are detailed in tables 7.1.6, 7.1.7, 7.1.8, 7.1.9, 7.1.14, 7.1.15, and 7.1.17 in the transmission report. The distribution upgrades are detailed in section 5.4 of the distribution report.

**ID 016326**

ID 016326 is a proposed 2.0 MW solar Generating Facility connecting to Feeder T3760B01 from the McColl 230kV substation in Marlboro County, SC. The estimated cost of Interconnection Facilities is \$125,000. The estimated transmission upgrade allocation is \$314,000 and the estimated distribution upgrade is \$581,000. The total estimated cost is **\$1,020,000**. The transmission upgrades are detailed in tables 7.1.6, 7.1.7, 7.1.8, 7.1.9, 7.1.14, 7.1.15, and 7.1.17 in the transmission report. The distribution upgrades are detailed in section 5.4 of the distribution report.

**ID 016327**

ID 016327 is a proposed 2.0 MW solar Generating Facility connecting to Feeder T3760B01 from the McColl 230kV substation in Marlboro County, SC. The estimated cost of Interconnection Facilities is \$125,000. The estimated transmission upgrade allocation is \$314,000 and the estimated distribution upgrade is \$581,000. The total estimated cost is **\$1,020,000**. The transmission upgrades are detailed in tables 7.1.6, 7.1.7, 7.1.8, 7.1.9, 7.1.14, 7.1.15, and 7.1.17 in the transmission report. The distribution upgrades are detailed in section 5.4 of the distribution report.

**ID 019176**

ID 019176 is a proposed 2.0 MW solar Generating Facility connecting to Feeder T3760B02 from the McColl 230kV substation in Marlboro County, SC. The estimated cost of Interconnection Facilities is \$125,000. The estimated transmission upgrade allocation is \$314,000 and the estimated distribution upgrade is \$637,000. The total estimated cost is **\$1,076,000**. The transmission upgrades are detailed in tables 7.1.6, 7.1.7, 7.1.8, 7.1.9, 7.1.14, 7.1.15, and 7.1.17 in the transmission report. The distribution upgrades are detailed in section 5.4 of the distribution report.



**ID 019261**

ID 019261 is a proposed 6.201 MW solar Generating Facility connecting to Feeder T2200B23 from the Laurinburg 230kV substation in Scotland County, NC. The estimated cost of Interconnection Facilities is \$125,000. The estimated transmission upgrade allocation is \$1,209,000 and the estimated distribution upgrade is \$572,000. The total estimated cost is **\$1,906,000**. The transmission upgrades are detailed in tables 7.1.6, 7.1.7, 7.1.8, 7.1.9, 7.1.14, 7.1.15, 7.1.16, and 7.1.17 in the transmission report. The distribution upgrades are detailed in section 5.3 of the distribution report.

**ID 020832**

ID 020832 is a proposed 2.0 MW solar Generating Facility connecting to Feeder T3030B01 from the Mullins 115kV substation in Dillon County, SC. The estimated cost of Interconnection Facilities is \$125,000. The estimated transmission upgrade allocation is \$0, and the estimated distribution upgrade is \$541,000. The total estimated cost is **\$666,000**. The distribution upgrades are detailed in section 5.5 of the distribution report. In the event that this request chooses to move forward, it will proceed to an individual distribution-level System Impact Study (SC GIP Appendix SC 5.3.7.1).

**ID 021892**

ID 021892 is a proposed 2.0 MW solar Generating Facility connecting to Feeder T3030B01 from the Mullins 115kV substation in Dillon County, SC. The estimated cost of Interconnection Facilities is \$125,000. The estimated transmission upgrade allocation is \$0, and the estimated distribution upgrade is \$2,400. The total estimated cost is **\$127,400**. The distribution upgrades are detailed in section 5.5 of the distribution report. In the event that this request chooses to move forward, it will proceed to an individual distribution-level System Impact Study (SC GIP Appendix SC 5.3.7.1).

# Duke Energy Progress, LLC Transmission Transitional Cluster Study Phase 1 Report

## Table of Contents

|        |  |    |
|--------|--|----|
| 1.0    | Purpose .....  | 14 |
| 2.0    | Study Assumptions .....  | 14 |
| 3.0    | Cluster Information.....   | 15 |
| 3.1    | FERC Requests .....  | 16 |
| 3.1.1  | Energy Resource Interconnection Service (ERIS) Only.....                                 | 16 |
| 3.1.2  | Network Resource Interconnection Service (NRIS) Only.....                                | 16 |
| 3.1.3  | ERIS & NRIS .....  | 16 |
| 3.2    | State Requests .....   | 16 |
| 4.0    | Transmission Cost Estimate Summary.....  | 17 |
| 4.1    | Transmission Interconnections .....  | 17 |
| 4.2    | Distribution Interconnections.....   | 18 |
| 5.0    | Transmission Interconnections .....  | 19 |
| 5.1    | Tap to 230 kV or 115 kV Transmission Circuit.....  | 19 |
| 5.2    | Tap to Line With Three-Breaker Ring Bus .....  | 21 |
| 5.3    | Interconnection to an Existing Station .....   | 23 |
| 6.0    | Relay and Communication Equipment .....  | 23 |
| 7.0    | Power-Flow Analysis Results .....  | 23 |
| 7.1    | Network Resource Interconnection Service Evaluation.....                                 | 24 |
| 7.1.1  | Badin 115/100 Transformer #1 (Cube Hydro owned) .....                                    | 26 |
| 7.1.2  | Badin 115/100 Transformer #2 (Cube Hydro owned) .....                                    | 27 |
| 7.1.3  | Reconductor Blewett – Rockingham 115 kV Line (Blewett – Str #1A) .....                   | 27 |
| 7.1.4  | Reconductor Blewett – Tillery 115 kV Line (Q381 – Tillery).....                          | 28 |
| 7.1.5  | Raise Cape Fear – Method 115 kV (Cape Fear – Moncure).....                               | 28 |
| 7.1.6  | Reconductor Cape Fear – West End 230 kV Line (Sanford US1 – Sanford Garden St.) .....    | 29 |
| 7.1.7  | Reconductor Cape Fear – West End 230 kV Line (Sanford Garden St. – CEMC Center Ch.)..    | 30 |
| 7.1.8  | Reconductor Cape Fear – West End 230 kV Line (CEMC Center Church – West End).....        | 31 |
| 7.1.9  | Raise Cape Fear – West End 230 kV Line (Sanford Deep River – Sanford Horner Blvd.) ..... | 32 |
| 7.1.10 | Reconductor Erwin – Fayetteville 115 kV (Erwin Mills Tap – Godwin).....                  | 33 |
| 7.1.11 | Reconductor Erwin – Fayetteville 115 kV (SREMC Wade - Beard) .....                       | 33 |

|         |   |    |
|---------|---|----|
| 7.1.12  | Reconductor Erwin – Fayetteville 115 kV (Beard – Fay Slocomb Tap) .....                     | 34 |
| 7.1.13  | Reconductor Erwin – Fayetteville 115 kV (Erwin 115 – Erwin Mills Tap) .....                 | 34 |
| 7.1.14  | Reconductor Erwin – Fayetteville East 230 kV (Linden – Fay East) .....                      | 35 |
| 7.1.15  | Reconductor Erwin – Fayetteville East 230 kV (Erwin - Linden) .....                         | 36 |
| 7.1.16  | Reconductor Fayetteville – Fay. DuPont 115 kV (Fayetteville – Hope Mills Church St.) .....  | 37 |
| 7.1.17  | Reconductor Laurinburg - Raeford 115 kV (Maxton Airport Tap – LREMC Allendale) .....        | 38 |
| 7.1.18  | Reconductor Robinson - Rockingham 115 kV (Sneedsboro Solar - Cordova) .....                 | 39 |
| 7.1.19  | Reconductor Robinson - Rockingham 115 kV (Cordova - Rockingham) .....                       | 39 |
| 7.1.20  | Raise Rockingham – West End 230 kV West (Eden Solar – West End) .....                       | 40 |
| 7.1.21  | Raise Sutton Plant - Wallace 230 kV (Crooked Run Solar - Wallace) .....                     | 40 |
| 7.1.22  | Raise Tillery – Badin 115 kV Black Line .....   | 41 |
| 7.1.23  | Raise Tillery – Badin 115 kV White Line .....   | 42 |
| 7.1.24  | Raise Weatherspoon – Marion 115 kV (Dillon Tap – Marion) .....                              | 43 |
| 7.2     | ERIS Evaluation .....   | 44 |
| 7.2.1   | Reconductor Fayetteville – Fay. DuPont 115 kV (Fayetteville – Hope Mills Church St.) .....  | 45 |
| 7.3     | Contingent Facilities .....   | 46 |
| 7.3.1   | Prior Interconnection Requests and/or Clusters .....  | 46 |
| 7.3.2   | Utility Transmission Plan .....   | 46 |
| 7.3.2.1 | Asheboro East – Biscoe 115 kV Line (REMC Ether – Biscoe 115 kV) .....                       | 46 |
| 7.3.2.2 | Asheboro East – Biscoe 115 kV Line (Seagrove – REMC Ether) .....                            | 46 |
| 7.3.2.3 | Asheboro East – Biscoe 115 kV Line (REMC Ulah – Seagrove) .....                             | 47 |
| 7.3.2.5 | Fayetteville – Fayetteville DuPont 115 kV Line (Hope Mills Church St. – Roslin Solar) ..... | 48 |
| 7.3.2.6 | Richmond 500/230 kV Transformer #1 .....  | 49 |
| 7.3.2.7 | Richmond 500/230 kV Transformer #2 .....  | 50 |
| 8.0     | Reactive Power Capability .....   | 51 |
| 9.0     | Affected Systems .....  | 53 |
| 1       | Preface .....   | 56 |
| 2       | Cost Allocation Summary .....   | 57 |
| 3       | Queue Summary .....   | 58 |
| 4       | Interconnection Facilities .....  | 60 |



|     |   |    |
|-----|---|----|
| 5   | Distribution Impacts Summary .....              | 61 |
| 5.1 | Substation: Dillon 115kV.....                   | 61 |
| 5.2 | Substation: Hartsville Segars Mill 230kV.....   | 62 |
| 5.3 | Substation: Laurinburg 230kV.....               | 63 |
| 5.4 | Substation: McColl 230kV .....                  | 64 |
| 5.5 | Substation: Mullins 115kV.....                  | 65 |
| 5.6 | Substation: Wadesboro Bowman School 230kV ..... | 66 |
| 5.7 | Substation: Weatherspoon 230kV .....            | 67 |
| 5.8 | Substation: Whiteville 115kV.....               | 67 |

## 1.0 Purpose

Following are the results of the **Duke Energy Progress, LLC (DEP)** Transitional Cluster Study (Phase 1). This analysis is focused on impacts to the Duke Energy Progress Transmission system. Impacts to the **Duke Energy Progress** Distribution system are addressed in the distribution report. Where applicable, impacts to neighboring transmission systems (meaning systems other than DEP's system, referred to as Affected Systems) are identified for further evaluation as part of an Affected System Study that must be performed by the external system.

## 2.0 Study Assumptions

The following Transitional Cluster Study (Phase 1) results are developed from the DEP Base Cases that reflect specific conditions of the DEP system at points in time consistent with the study conditions being evaluated. At the time of the study, the Base Cases included the most recent information for load, generation, transmission, interchange, and other pertinent data necessary for analysis. Future years may include generation, transmission, and interchange modifications that are not budgeted and for which no firm commitments have been made. Further, DEP retains the right to make modifications to the Base Cases as needed if additional information is available or if specific scenarios necessitate changes. For the systems surrounding DEP, data is based on the ERAG MMWG model. For the Transitional Cluster Study, Transitional Serial projects and their associated upgrades were considered when modifying the Base Cases. Collectively, these considerations constitute the Transitional Cluster Base Cases. The suitability of the Transitional Cluster Base Cases for use by others is the sole responsibility of the user.

The results of this analysis were based on the information provided by cluster participants at the time of the study. Modifications to generation facilities' technical data or points of interconnection may require reevaluation of one or more parts of the study.

This study was based on the assumptions that the Customer would construct, own and operate the electrical infrastructure that would connect their generation to DEP's facilities, including any step up transformers and lines from the generators, but excluding the circuit breaker in the new breaker station, where applicable.

### 3.0 Cluster Information

The following table lists the DEP interconnection requests studied as part of the Transitional Cluster Phase 1 study:

| ID     | MW<br>(Summer<br>Peak) | MW<br>(Winter<br>Peak) | Generation<br>Type | Transmission/<br>Distribution | Transmission<br>POI                         |
|--------|------------------------|------------------------|--------------------|-------------------------------|---|
| 002115 | 4.998                  | 0                      | Solar              | Distribution                  | Weatherspoon 230 kV                         |
| 002156 | 4.999                  | 0                      | Solar              | Distribution                  | Weatherspoon 230 kV                         |
| 004484 | 2                      | 0                      | Solar              | Distribution                  | Dillon 115 kV                               |
| 004538 | 10                     | 0                      | Solar              | Distribution                  | Dillon 115 kV                               |
| 004540 | 8.8                    | 0                      | Solar              | Distribution                  | McColl 230 kV                               |
| 005037 | 1.998                  | 0                      | Solar              | Distribution                  | Whiteville 115 kV                           |
| 005703 | 70.2                   | 0                      | Solar              | Transmission                  | Blewett-Tillery 115 kV                      |
| 008286 | 4.992                  | 0                      | Solar              | Distribution                  | Wadesboro Bowman School 230 kV              |
| 010586 | 70.1                   | 0                      | Solar              | Transmission                  | Marion - Whiteville 230 kV                  |
| 016227 | 1.98                   | 0                      | Solar              | Distribution                  | Hartsville Segars Mill 230 kV               |
| 016257 | 1.98                   | 0                      | Solar              | Distribution                  | Hartsville Segars Mill 230 kV               |
| 016321 | 70                     | 70                     | Solar+<br>Storage  | Transmission                  | Pageland Tap, Robinson-Rockingham<br>115 kV |
| 016326 | 2                      | 0                      | Solar              | Distribution                  | McColl 230 kV                               |
| 016327 | 2                      | 0                      | Solar              | Distribution                  | McColl 230 kV                               |
| 016328 | 2                      | 0                      | Solar              | Distribution                  | McColl 230 kV                               |
| 017658 | 80                     | 0                      | Solar              | Transmission                  | Florence DuPont - Marion 115 kV             |
| 019139 | 2                      | 0                      | Solar              | Distribution                  | Mullins 115 kV                              |
| 019170 | 2                      | 0                      | Solar              | Distribution                  | McColl 230 kV                               |
| 019176 | 2                      | 0                      | Solar              | Distribution                  | McColl 230 kV                               |
| 019261 | 6.201                  | 0                      | Solar              | Distribution                  | Laurinburg 230 kV                           |
| 019397 | 75                     | 0                      | Solar              | Transmission                  | Florence DuPont - SCPSA Hemingway<br>115 kV |
| 020832 | 2                      | 0                      | Solar              | Distribution                  | Mullins 115 kV                              |
| 021764 | 8                      | 0                      | Solar              | Transmission                  | Kinston DuPont 115kV                        |
| 021772 | 8                      | 0                      | Solar              | Transmission                  | Kinston DuPont 115kV                        |
| 021892 | 2                      | 0                      | Solar              | Distribution                  | Mullins 115 kV                              |
| 022128 | 79.8                   | 0                      | Solar              | Transmission                  | Lee - Wommack 230 kV North                  |
| 024078 | 79.8                   | 0                      | Solar              | Transmission                  | Robinson - Camden Junction 115 kV           |
| 030708 | 78.32                  | 0                      | Solar              | Transmission                  | Person - Rocky Mount 230 kV                 |
| 032986 | 80                     | 0                      | Solar              | Transmission                  | Cumberland - Whiteville 230kV               |
| 067146 | 80                     | 0                      | Solar              | Transmission                  | Robinson - Florence 230 kV                  |
| 119904 | 18.4                   | 18.4                   | Storage            | Transmission                  | Fort Bragg Longstreet Rd 230 kV             |
| 126008 | 75                     | 0                      | Solar              | Transmission                  | Rocky Mount - Wilson 230 kV                 |
| 138340 | 74                     | 0                      | Solar              | Transmission                  | Weatherspoon - LOF 115 kV                   |
| 169712 | 80                     | 0                      | Solar              | Transmission                  | Biscoe - Rockingham 230 kV                  |
| 169716 | 80                     | 0                      | Solar              | Transmission                  | Cumberland - Delco 230 kV                   |
| 170274 | 275                    | 68.75                  | Solar+<br>Storage  | Transmission                  | Laurinburg - Richmond 230 kV                |
| 177122 | 69.9                   | 0                      | Solar              | Transmission                  | Bennettsville - Laurinburg 230 kV           |
| 179866 | 150                    | 0                      | Solar              | Transmission                  | Florence - Kingstree 230 kV                 |
| 179996 | 74.9                   | 0                      | Solar              | Transmission                  | Kingstree - Sumter 115 kV                   |



| ID     | MW<br>(Summer<br>Peak) | MW<br>(Winter<br>Peak) | Generation<br>Type | Transmission/<br>Distribution | Transmission<br>POI                          |
|--------|------------------------|------------------------|--------------------|-------------------------------|--|
| 186310 | 23.3                   | 23.3                   | Storage            | Transmission                  | Durham - DPC East Durham 230 kV              |
| 187960 | 165                    | 0                      | Solar              | Transmission                  | Darlington County Plant 230 kV<br>Switchyard |
| 191894 | 30.5                   | 30.5                   | Storage            | Transmission                  | Craggy 230 kV                                |
| 200482 | 60                     | 0                      | Solar              | Transmission                  | Rockingham - West End 230 kV East            |
| 205718 | 74.9                   | 0                      | Solar              | Transmission                  | Bennettsville - Laurinburg 230 kV            |

### 3.1 FERC Requests

#### 3.1.1 Energy Resource Interconnection Service (ERIS) Only

The following FERC projects (ID) requested evaluation of only ERIS:

- none

#### 3.1.2 Network Resource Interconnection Service (NRIS) Only

The following FERC projects (ID) requested evaluation of only NRIS:

- 177122
- 187960

#### 3.1.3 ERIS & NRIS

The following FERC projects (ID) requested evaluation of both ERIS & NRIS:

- 119904
- 191894
- 186310
- 170274
- 179866
- 179996

### 3.2 State Requests

Non-FERC Interconnection Requests submitted under the NC and SC state interconnection processes are studied similarly to and in conjunction with the FERC NRIS requests.

## 4.0 Transmission Cost Estimate Summary

### 4.1 Transmission Interconnections

Shown below are Class 5 cost estimates for Transmission Provider's Interconnection Facilities, Network Upgrades at the POI (including upgrades at the remote ends of the line for relaying and communication), and Network Upgrades due to power flow thermal impacts. Upgrade and Interconnection Facilities cost estimates are assigned consistent with LGIP 10.4, NCIP 4.4, and SC GIP Appendix Duke CS 5.3.4.

| ID     | TRANSMISSION NETWORK UPGRADES |   |                              | Transmission Provider's Interconnection Facilities (\$M) |
|--------|-------------------------------|---|------------------------------|--|
|        | POI Network Upgrades (\$M)    | Power Flow (Thermal) Network Upgrades (\$M) | Total Network Upgrades (\$M) |  |
| 005703 | 2.062                         | 20.688                                      | 22.750                       | 5.368  |
| 010586 | 2.241                         | 5.104                                       | 7.345                        | 5.559  |
| 016321 | 1.632                         | 36.717                                      | 38.349                       | 5.221  |
| 017658 | 1.968                         | 8.600                                       | 10.568                       | 5.458  |
| 019397 | 1.186                         | 7.341                                       | 8.527                        | 5.458  |
| 021764 | 4.000                         | 0   | 4.000                        | 2.231  |
| 021772 | 4.000                         | 0   | 4.000                        | 2.231  |
| 022128 | 2.088                         | 0.510                                       | 2.598                        | 5.322  |
| 024078 | 1.805                         | 6.907                                       | 8.712                        | 5.494  |
| 030708 | 11.229                        | 0   | 11.229                       | 2.064  |
| 032986 | 1.544                         | 14.282                                      | 15.826                       | 5.559  |
| 067146 | 2.174                         | 12.650                                      | 14.824                       | 5.826  |
| 119904 | 0                             | 3.519                                       | 3.519                        | 1.103  |
| 126008 | 2.106                         | 0   | 2.106                        | 5.818  |
| 138340 | 3.280                         | 22.077                                      | 25.357                       | 5.393  |
| 169712 | 1.790                         | 3.149                                       | 4.939                        | 5.559  |
| 169716 | 11.136                        | 5.626                                       | 16.762                       | 2.064  |
| 170274 | 11.136                        | 78.546                                      | 89.682                       | 2.064  |
| 177122 | 1.706                         | 12.207                                      | 13.913                       | 5.322  |
| 179866 | 1.916                         | 20.739                                      | 22.655                       | 5.559  |
| 179996 | 2.419                         | 5.106                                       | 7.525                        | 5.368  |
| 186310 | 1.142                         | 0   | 1.142                        | 5.559  |
| 187960 | 1.901                         | 37.103                                      | 39.004                       | 3.123  |
| 191894 | 2.668                         | 0   | 2.668                        | 1.735  |
| 200482 | 2.467                         | 20.456                                      | 22.923                       | 5.322  |
| 205718 | 1.530                         | 13.697                                      | 15.227                       | 5.322  |

## 4.2 Distribution Interconnections

Shown below are Class 5 cost estimates for only the transmission network upgrades assigned to distribution interconnections. Distribution system interconnection and upgrade costs and Retail/T-D substation upgrade costs are separately identified in the distribution report section of this Transitional Cluster Report.

| ID     | TRANSMISSION NETWORK UPGRADES |   |   |                              | Transmission Provider's Interconnection Facilities (\$M) |
|--------|-------------------------------|---|---|------------------------------|--|
|        | POI Network Upgrades (\$M)    | Relaying and Communication (Remote End) (\$M) | Power Flow (Thermal) Network Upgrades (\$M) | Total Network Upgrades (\$M) |  |
| 004538 | 0                             | 0   | 1.151                                       | <b>1.151</b>                 | <b>0</b>   |
| 004540 | 0                             | 0   | 1.383                                       | <b>1.383</b>                 | <b>0</b>   |
| 016326 | 0                             | 0   | 0.314                                       | <b>0.314</b>                 | <b>0</b>   |
| 016327 | 0                             | 0   | 0.314                                       | <b>0.314</b>                 | <b>0</b>   |
| 016328 | 0                             | 0   | 0.314                                       | <b>0.314</b>                 | <b>0</b>   |
| 019170 | 0                             | 0   | 0.314                                       | <b>0.314</b>                 | <b>0</b>   |
| 019176 | 0                             | 0   | 0.314                                       | <b>0.314</b>                 | <b>0</b>   |
| 019261 | 0                             | 0   | 1.209                                       | <b>1.209</b>                 | <b>0</b>   |

The following distribution interconnection requests are Attachment D projects under the Interconnection Settlement Agreement, as filed in North Carolina Utilities Commission in Docket No. E-100, Sub 101 on September 3, 2020 and with the Public Service Commission of South Carolina on September 4, 2020 in Docket No. 2015-362-E. Attachment D projects are subject to Transmission Contingency Violation Curtailment as defined in the Settlement and have not been assigned transmission network upgrades.

| IDs under Attachment D | Total Network Upgrades (\$M) |
|------------------------|------------------------------|
| 002115                 | <b>0</b>                     |
| 002156                 | <b>0</b>                     |
| 004484                 | <b>0</b>                     |
| 005037                 | <b>0</b>                     |
| 008286                 | <b>0</b>                     |
| 016227                 | <b>0</b>                     |
| 016257                 | <b>0</b>                     |
| 019139                 | <b>0</b>                     |
| 020832                 | <b>0</b>                     |
| 021892                 | <b>0</b>                     |

## 5.0 Transmission Interconnections


Customer should verify that the MVA ratings of the Customer's Interconnection Facilities are sufficient to accommodate delivering the total MVA output to the point of interconnection at the required power factor.

### 5.1 Tap to 230 kV or 115 kV Transmission Circuit

The following projects are proposing interconnection to a 230 kV or 115 kV Transmission Circuit:

| Single Breaker Tap Station |        |
|----------------------------|--------|
| 115 kV                     | 230 kV |
| 005703                     | 010586 |
| 016321                     | 022128 |
| 017658                     | 032986 |
| 019397                     | 067146 |
| 024078                     | 126008 |
| 138340                     | 169712 |
| 179996                     | 169716 |
|                            | 177122 |
|                            | 186310 |
|                            | 200482 |
|                            | 205718 |

For projects tapping to a 230 kV or 115 kV transmission circuit, a general one-line diagram is shown below. The line switch on either side of the tap may be unnecessary if there is an existing switch within one mile on that side of the solar tap.




## 5.2 Tap to Line With Three-Breaker Ring Bus

For projects connecting to the DEP transmission system with a total generation at a site greater than 100 MW, a full transmission switching station with a three-breaker ring bus will be required. For projects that contribute to a total tapped generation along a line exceeding 200 MW, a full transmission switching station will be required at some location on the line. The exact location will be determined on a case-by-case basis considering specific local conditions.

The following projects will require interconnection with a new three-breaker ring bus switching station:

| Three-Breaker Ring Bus |        |
|------------------------|--------|
| 115 kV                 | 230 kV |
|                        | 030708 |
|                        | 170274 |
|                        | 179866 |

For projects requiring interconnection to a new switching station with a three-breaker ring bus, a general one-line diagram is shown below:





### 5.3 Interconnection to an Existing Station

The following projects will interconnect to an existing station. Each has a unique arrangement as described:

| ID     | Interconnection Summary  |
|--------|--|
| 021764 | Connect to 115 kV side of existing station                           |
| 021772 | Connect to 115 kV side of existing station                           |
| 119904 | Connect to existing 12kV bus at existing station                     |
| 187960 | Connect to new 230 kV double breaker bay in existing station         |
| 191894 | Connect to existing 230kV breaker-and-a-half bay in existing station |

### 6.0 Relay and Communication Equipment

In DEP, communications for Direct Transfer Trip of tapped generators will be through the existing communication medium on the line, which is either Optical Ground Wire (OPGW) or Power Line Carrier (PLC). If the line does not currently have communication, PLC will be installed. In either case, preliminary estimates of these costs are included in the “POI Network Upgrades” costs of section 4.0.

### 7.0 Power-Flow Analysis Results

The power-flow cases used in the study were developed from the following DEP Transitional Cluster Base Cases: 2025 summer and 2025/26 winter. The Transitional Cluster Base Cases were modified to include the generation proposed in the Transitional Cluster Study. The economic generation dispatch was modified by adding the new generation and forcing it on prior to the dispatch of the remaining DEP Balancing Authority Area units. Generators requesting only Energy Resource Interconnection Service (ERIS) are not dispatched as part of the Network Resource Interconnection Service (NRIS) evaluation. State requests are included in the NRIS analysis.

Facilities that may require upgrade within the first five years following the study years are identified. Based on projected load growth on the DEP transmission system, facilities of concern are those with pre- or post-contingency loadings of **95%** or greater of their thermal rating and low voltage of **92%** and below, in the study cases. The identification of these facilities is crucial due to the construction lead times necessary for certain system upgrades. This study methodology will ensure that appropriate focus is given to these problem areas to investigate whether construction of upgrade projects is achievable to accommodate the requested in-service and commercial operation dates.

## 7.1 Network Resource Interconnection Service Evaluation

The NRIS power-flow study uses the results of DEP Transmission Planning's annual internal screening and prior generator interconnection studies as a baseline to determine the impact of new generation.

The following Network Upgrades are required to mitigate thermal loading issues due to the addition of generation in this cluster:

| Network Upgrade   | Mileage | Estimated Cost (\$ M) | Estimated Lead Time (months) <sup>1</sup> |
|---|---------|-----------------------|---|
| Badin 115/100 Transformer #1 (Cube Hydro owned)   | N/A     | 6.938                 | 42  |
| Badin 115/100 Transformer #2 (Cube Hydro owned)   | N/A     | 6.938                 | 42  |
| Reconductor Blewett – Rockingham 115 kV Line<br>(Blewett – Str #1A)                       | 0.07    | 0.934                 | 60  |
| Reconductor Blewett – Tillery 115 kV Line<br>(Q381 – Tillery)                             | 4.83    | 13.682                | 54  |
| Raise Cape Fear – Method 115 kV<br>(Cape Fear – Moncure)                                  | 0.68    | 0.520                 | 24  |
| Reconductor Cape Fear – West End 230 kV Line<br>(Sanford US1 – Sanford Garden St.)        | 2.57    | 8.704                 | 66  |
| Reconductor Cape Fear – West End 230 kV Line<br>(Sanford Garden St. – CEMC Center Church) | 6.48    | 20.661                | 66  |
| Reconductor Cape Fear – West End 230 kV Line<br>(CEMC Center Church – West End)           | 17.6    | 57.258                | 66  |
| Raise Cape Fear – West End 230 kV Line<br>(Sanford Deep River – Sanford Horner Blvd.)     | 4.44    | 1.261                 | 66  |
| Reconductor Erwin – Fayetteville 115 kV<br>(Erwin Mills Tap – Godwin)                     | 7.99    | 20.621                | 54  |
| Reconductor Erwin – Fayetteville 115 kV<br>(SREMC Wade - Beard)                           | 6.8     | 20.752                | 54  |
| Reconductor Erwin – Fayetteville 115 kV<br>(Beard – Fay Slocumb Tap)                      | 1.92    | 5.589                 | 54  |
| Reconductor Erwin – Fayetteville 115 kV<br>(Erwin 115 – Erwin Mills Tap)                  | 0.05    | 0.129                 | 54  |
| Reconductor Erwin – Fayetteville East 230 kV<br>(Linden – Fay East)                       | 12.2    | 54.720                | 60  |
| Reconductor Erwin – Fayetteville East 230 kV<br>(Erwin - Linden)                          | 10.95   | 50.197                | 60  |
| Reconductor Fayetteville – Fay. DuPont 115 kV<br>(Fayetteville – Hope Mills Church St.)   | 4.88    | 12.036                | 48  |

<sup>1</sup> Unless otherwise noted, the estimated lead time reflects the duration of time required to complete the specific project after the applicable generators have executed an Interconnection Agreement.

| <b>Network Upgrade</b>  | <b>Mileage</b> | <b>Estimated Cost (\$ M)</b> | <b>Estimated Lead Time (months)<sup>1</sup></b> |
|---|----------------|------------------------------|---|
| Reconductor Laurinburg - Raeford 115 kV<br>(Maxton Airport Tap – LREMC Allendale) | 1.97           | 5.549                        | 36  |
| Reconductor Robinson - Rockingham 115 kV<br>(Sneedsboro Solar - Cordova)          | 13.07          | 29.26                        | 54  |
| Reconductor Robinson - Rockingham 115 kV<br>(Cordova - Rockingham)                | 4.01           | 9.022                        | 54  |
| Raise Rockingham – West End 230 kV West<br>(Eden Solar – West End)                | 3.55           | 1.749                        | 36  |
| Raise Sutton Plant - Wallace 230 kV<br>(Crooked Run Solar - Wallace)              | 7.75           | 0.589                        | 24  |
| Raise Weatherspoon – Marion 115 kV<br>(Dillon Tap – Marion)                       | 14.6           | 6.686                        | 48  |
| Raise Tillery – Badin 115 kV Black Line   | 14.3           | 3.133                        | 42  |
| Raise Tillery – Badin 115 kV White Line   | 14.3           | 3.133                        | 42  |

For each identified network upgrade, cost allocations were developed consistent with LGIP 10.4, NCIP 4.4, and SC GIP Appendix Duke CS 5.3.4 and the associated cost allocation is provided.

- MW Output = Real power output of the generator
- Distribution Factor (DFax): The proportion of a generator's MW Output that flows on a transmission facility under the worst contingency
- MW Impact = MW Output x DFax
- Loading Impact = MW Impact / Facility Rating
- Cost Allocation Factor (%) = Individual MW Impact / Total MW Impact
- Cost Allocation (\$) = Cost Allocation Factor x Total (\$)

### 7.1.1 Badin 115/100 Transformer #1 (Cube Hydro owned)

| ID     | MW Output<br>(MW) | DFax<br>(%) | Loading<br>Impact<br>(%) | MW Impact<br>(MW) | Cost<br>Allocation<br>Factor<br>(%) | Cost<br>Allocation<br>(MM \$) |
|--------|-------------------|-------------|--------------------------|-------------------|-------------------------------------|-------------------------------|
| 005703 | 70.2              | 28.620      | 20.091                   | 20.091            | 48.192                              | 3.344                         |
| 032986 | 80                | 1.338       | 1.070                    | 1.070             | 2.568                               | 0.178                         |
| 016321 | 70                | 2.507       | 1.755                    | 1.755             | 4.209                               | 0.292                         |
| 205718 | 74.9              | 1.401       | 1.049                    | 1.049             | 2.517                               | 0.175                         |
| 200482 | 60                | 2.018       | 1.211                    | 1.211             | 2.904                               | 0.202                         |
| 022128 | 79.8              | 1.322       | 1.055                    | 1.055             | 2.530                               | 0.176                         |
| 138340 | 74                | 1.485       | 1.099                    | 1.099             | 2.636                               | 0.183                         |
| 170274 | 275               | 1.668       | 4.587                    | 4.587             | 11.003                              | 0.763                         |
| 169716 | 80                | 1.384       | 1.107                    | 1.107             | 2.656                               | 0.184                         |
| 169712 | 80                | 6.974       | 5.579                    | 5.579             | 13.383                              | 0.928                         |
| 179866 | 150               | 0.867       | 1.301                    | 1.301             | 3.119                               | 0.216                         |
| 187960 | 165               | 1.082       | 1.785                    | 1.785             | 4.282                               | 0.297                         |
|        |                   |             |                          | 41.690            | 100                                 | 6.938                         |

### 7.1.2 Badin 115/100 Transformer #2 (Cube Hydro owned)

| ID     | MW Output<br>(MW) | DFax<br>(%) | Loading<br>Impact<br>(%) | MW Impact<br>(MW) | Cost<br>Allocation<br>Factor<br>(%) | Cost<br>Allocation<br>(MM \$) |
|--------|-------------------|-------------|--------------------------|-------------------|-------------------------------------|-------------------------------|
| 005703 | 70.2              | 27.894      | 19.582                   | 19.582            | 48.196                              | 3.344                         |
| 032986 | 80                | 1.304       | 1.043                    | 1.043             | 2.568                               | 0.178                         |
| 016321 | 70                | 2.443       | 1.710                    | 1.710             | 4.209                               | 0.292                         |
| 205718 | 74.9              | 1.365       | 1.022                    | 1.022             | 2.516                               | 0.175                         |
| 200482 | 60                | 1.967       | 1.180                    | 1.180             | 2.905                               | 0.202                         |
| 022128 | 79.8              | 1.289       | 1.029                    | 1.029             | 2.532                               | 0.176                         |
| 138340 | 74                | 1.447       | 1.071                    | 1.071             | 2.636                               | 0.183                         |
| 170274 | 275               | 1.625       | 4.469                    | 4.469             | 10.999                              | 0.763                         |
| 169716 | 80                | 1.349       | 1.079                    | 1.079             | 2.656                               | 0.184                         |
| 169712 | 80                | 6.797       | 5.438                    | 5.438             | 13.384                              | 0.929                         |
| 179866 | 150               | 0.845       | 1.268                    | 1.268             | 3.120                               | 0.216                         |
| 187960 | 165               | 1.054       | 1.739                    | 1.739             | 4.280                               | 0.297                         |
|        |                   |             |                          | 40.629            | 100                                 | 6.938                         |

### 7.1.3 Reconductor Blewett – Rockingham 115 kV Line (Blewett – Str #1A)

| ID     | MW Output<br>(MW) | DFax<br>(%) | Loading<br>Impact<br>(%) | MW Impact<br>(MW) | Cost<br>Allocation<br>Factor<br>(%) | Cost<br>Allocation<br>(MM \$) |
|--------|-------------------|-------------|--------------------------|-------------------|-------------------------------------|-------------------------------|
| 005703 | 70.2              | 100.000     | 58.992                   | 70.200            | 100.000                             | 0.934                         |
|        |                   |             |                          | 70.200            | 100                                 | 0.934                         |

### 7.1.4 Reconductor Blewett – Tillery 115 kV Line (Q381 – Tillery)

| ID     | MW Output<br>(MW) | DFax<br>(%) | Loading<br>Impact<br>(%) | MW Impact<br>(MW) | Cost<br>Allocation<br>Factor<br>(%) | Cost<br>Allocation<br>(MM \$) |
|--------|-------------------|-------------|--------------------------|-------------------|-------------------------------------|-------------------------------|
| 005703 | 70.2              | 70.485      | 41.580                   | 49.480            | 73.428                              | 10.046                        |
| 016321 | 70                | 4.606       | 2.709                    | 3.224             | 4.785                               | 0.655                         |
| 205718 | 74.9              | 1.622       | 1.021                    | 1.215             | 1.803                               | 0.247                         |
| 200482 | 60                | 2.601       | 1.311                    | 1.561             | 2.316                               | 0.317                         |
| 170274 | 275               | 2.073       | 4.791                    | 5.701             | 8.460                               | 1.157                         |
| 169712 | 80                | 2.794       | 1.878                    | 2.235             | 3.317                               | 0.454                         |
| 179866 | 150               | 1.065       | 1.342                    | 1.598             | 2.371                               | 0.324                         |
| 187960 | 165               | 1.438       | 1.994                    | 2.373             | 3.521                               | 0.482                         |
|        |                   |             |                          | 67.386            | 100                                 | 13.682                        |

### 7.1.5 Raise Cape Fear – Method 115 kV (Cape Fear – Moncure)

| ID     | MW Output<br>(MW) | DFax<br>(%) | Loading<br>Impact<br>(%) | MW Impact<br>(MW) | Cost<br>Allocation<br>Factor<br>(%) | Cost<br>Allocation<br>(MM \$) |
|--------|-------------------|-------------|--------------------------|-------------------|-------------------------------------|-------------------------------|
| 170274 | 275               | 0.784       | 1.428                    | 2.156             | 100.000                             | 0.520                         |
|        |                   |             |                          | 2.156             | 100                                 | 0.520                         |

### 7.1.6 Reconductor Cape Fear – West End 230 kV Line (Sanford US1 – Sanford Garden St.)

| ID     | MW Output<br>(MW) | DFax<br>(%) | Loading<br>Impact<br>(%) | MW Impact<br>(MW) | Cost<br>Allocation<br>Factor<br>(%) | Cost<br>Allocation<br>(MM \$) |
|--------|-------------------|-------------|--------------------------|-------------------|-------------------------------------|-------------------------------|
| 016321 | 70                | 5.496       | 0.751                    | 3.847             | 8.492                               | 0.739                         |
| 205718 | 74.9              | 3.894       | 0.570                    | 2.917             | 6.438                               | 0.560                         |
| 200482 | 60                | 13.534      | 1.586                    | 8.120             | 17.924                              | 1.560                         |
| 067146 | 80                | 3.329       | 0.520                    | 2.663             | 5.878                               | 0.512                         |
| 138340 | 74                | 3.485       | 0.504                    | 2.579             | 5.692                               | 0.495                         |
| 170274 | 275               | 5.785       | 3.107                    | 15.909            | 35.114                              | 3.056                         |
| 187960 | 165               | 3.366       | 1.085                    | 5.554             | 12.259                              | 1.067                         |
| 177122 | 69.9              | 3.936       | 0.537                    | 2.751             | 6.073                               | 0.529                         |
| 004540 | 8.8               | 3.876       | 0.067                    | 0.341             | 0.753                               | 0.066                         |
| 016328 | 2                 | 3.876       | 0.015                    | 0.078             | 0.171                               | 0.015                         |
| 019170 | 2                 | 3.876       | 0.015                    | 0.078             | 0.171                               | 0.015                         |
| 016326 | 2                 | 3.876       | 0.015                    | 0.078             | 0.171                               | 0.015                         |
| 016327 | 2                 | 3.876       | 0.015                    | 0.078             | 0.171                               | 0.015                         |
| 019176 | 2                 | 3.876       | 0.015                    | 0.078             | 0.171                               | 0.015                         |
| 019261 | 6.201             | 3.819       | 0.046                    | 0.237             | 0.523                               | 0.045                         |
|        |                   |             |                          | 45.306            | 100                                 | 8.704                         |



**7.1.7 Reconductor Cape Fear – West End 230 kV Line  
 (Sanford Garden St. – CEMC Center Ch.)**

| ID     | MW Output<br>(MW) | DFax<br>(%) | Loading<br>Impact<br>(%) | MW Impact<br>(MW) | Cost<br>Allocation<br>Factor<br>(%) | Cost<br>Allocation<br>(MM \$) |
|--------|-------------------|-------------|--------------------------|-------------------|-------------------------------------|-------------------------------|
| 016321 | 70                | 5.496       | 0.710                    | 3.847             | 8.492                               | 1.754                         |
| 205718 | 74.9              | 3.894       | 0.538                    | 2.917             | 6.438                               | 1.330                         |
| 200482 | 60                | 13.534      | 1.498                    | 8.120             | 17.924                              | 3.703                         |
| 067146 | 80                | 3.329       | 0.491                    | 2.663             | 5.878                               | 1.215                         |
| 138340 | 74                | 3.485       | 0.476                    | 2.579             | 5.692                               | 1.176                         |
| 170274 | 275               | 5.785       | 2.935                    | 15.909            | 35.114                              | 7.255                         |
| 187960 | 165               | 3.366       | 1.025                    | 5.554             | 12.259                              | 2.533                         |
| 177122 | 69.9              | 3.936       | 0.508                    | 2.751             | 6.073                               | 1.255                         |
| 004540 | 8.8               | 3.876       | 0.063                    | 0.341             | 0.753                               | 0.156                         |
| 016328 | 2                 | 3.876       | 0.014                    | 0.078             | 0.171                               | 0.035                         |
| 019170 | 2                 | 3.876       | 0.014                    | 0.078             | 0.171                               | 0.035                         |
| 016326 | 2                 | 3.876       | 0.014                    | 0.078             | 0.171                               | 0.035                         |
| 016327 | 2                 | 3.876       | 0.014                    | 0.078             | 0.171                               | 0.035                         |
| 019176 | 2                 | 3.876       | 0.014                    | 0.078             | 0.171                               | 0.035                         |
| 019261 | 6.201             | 3.819       | 0.044                    | 0.237             | 0.523                               | 0.108                         |
|        |                   |             |                          | 45.306            | 100                                 | 20.661                        |

### 7.1.8 Reconductor Cape Fear – West End 230 kV Line (CEMC Center Church – West End)

| ID     | MW Output<br>(MW) | DFax<br>(%) | Loading<br>Impact<br>(%) | MW Impact<br>(MW) | Cost<br>Allocation<br>Factor<br>(%) | Cost<br>Allocation<br>(MM \$) |
|--------|-------------------|-------------|--------------------------|-------------------|-------------------------------------|-------------------------------|
| 016321 | 70                | 5.496       | 0.710                    | 3.847             | 8.492                               | 4.862                         |
| 205718 | 74.9              | 3.894       | 0.538                    | 2.917             | 6.438                               | 3.686                         |
| 200482 | 60                | 13.534      | 1.498                    | 8.120             | 17.924                              | 10.263                        |
| 067146 | 80                | 3.329       | 0.491                    | 2.663             | 5.878                               | 3.366                         |
| 138340 | 74                | 3.485       | 0.476                    | 2.579             | 5.692                               | 3.259                         |
| 170274 | 275               | 5.785       | 2.935                    | 15.909            | 35.114                              | 20.106                        |
| 187960 | 165               | 3.366       | 1.025                    | 5.554             | 12.259                              | 7.019                         |
| 177122 | 69.9              | 3.936       | 0.508                    | 2.751             | 6.073                               | 3.477                         |
| 004540 | 8.8               | 3.876       | 0.063                    | 0.341             | 0.753                               | 0.431                         |
| 016328 | 2                 | 3.876       | 0.014                    | 0.078             | 0.171                               | 0.098                         |
| 019170 | 2                 | 3.876       | 0.014                    | 0.078             | 0.171                               | 0.098                         |
| 016326 | 2                 | 3.876       | 0.014                    | 0.078             | 0.171                               | 0.098                         |
| 016327 | 2                 | 3.876       | 0.014                    | 0.078             | 0.171                               | 0.098                         |
| 019176 | 2                 | 3.876       | 0.014                    | 0.078             | 0.171                               | 0.098                         |
| 019261 | 6.201             | 3.819       | 0.044                    | 0.237             | 0.523                               | 0.299                         |
|        |                   |             |                          | 45.306            | 100                                 | 57.258                        |

**7.1.9 Raise Cape Fear – West End 230 kV Line  
 (Sanford Deep River – Sanford Horner Blvd.)**

| ID     | MW Output<br>(MW) | DFax<br>(%) | Loading<br>Impact<br>(%) | MW Impact<br>(MW) | Cost<br>Allocation<br>Factor<br>(%) | Cost<br>Allocation<br>(MM \$) |
|--------|-------------------|-------------|--------------------------|-------------------|-------------------------------------|-------------------------------|
| 016321 | 70                | 5.496       | 0.763                    | 3.847             | 8.492                               | 0.107                         |
| 205718 | 74.9              | 3.894       | 0.579                    | 2.917             | 6.438                               | 0.081                         |
| 200482 | 60                | 13.534      | 1.611                    | 8.120             | 17.924                              | 0.226                         |
| 067146 | 80                | 3.329       | 0.528                    | 2.663             | 5.878                               | 0.074                         |
| 138340 | 74                | 3.485       | 0.512                    | 2.579             | 5.692                               | 0.072                         |
| 170274 | 275               | 5.785       | 3.156                    | 15.909            | 35.114                              | 0.443                         |
| 187960 | 165               | 3.366       | 1.102                    | 5.554             | 12.259                              | 0.155                         |
| 177122 | 69.9              | 3.936       | 0.546                    | 2.751             | 6.073                               | 0.077                         |
| 004540 | 8.8               | 3.876       | 0.068                    | 0.341             | 0.753                               | 0.009                         |
| 016328 | 2                 | 3.876       | 0.015                    | 0.078             | 0.171                               | 0.002                         |
| 019170 | 2                 | 3.876       | 0.015                    | 0.078             | 0.171                               | 0.002                         |
| 016326 | 2                 | 3.876       | 0.015                    | 0.078             | 0.171                               | 0.002                         |
| 016327 | 2                 | 3.876       | 0.015                    | 0.078             | 0.171                               | 0.002                         |
| 019176 | 2                 | 3.876       | 0.015                    | 0.078             | 0.171                               | 0.002                         |
| 019261 | 6.201             | 3.819       | 0.047                    | 0.237             | 0.523                               | 0.007                         |
|        |                   |             |                          | 45.306            | 100                                 | 1.261                         |

**7.1.10 Reconductor Erwin – Fayetteville 115 kV  
(Erwin Mills Tap – Godwin)**

| ID     | MW Output<br>(MW) | DFax<br>(%) | Loading<br>Impact<br>(%) | MW Impact<br>(MW) | Cost<br>Allocation<br>Factor<br>(%) | Cost<br>Allocation<br>(MM \$) |
|--------|-------------------|-------------|--------------------------|-------------------|-------------------------------------|-------------------------------|
| 032986 | 80                | 1.553       | 1.044                    | 1.242             | 14.468                              | 2.984                         |
| 138340 | 74                | 1.704       | 1.060                    | 1.261             | 14.684                              | 3.029                         |
| 170274 | 275               | 1.179       | 2.725                    | 3.242             | 37.756                              | 7.788                         |
| 179866 | 150               | 0.877       | 1.105                    | 1.316             | 15.319                              | 3.160                         |
| 187960 | 165               | 0.925       | 1.283                    | 1.526             | 17.773                              | 3.666                         |
|        |                   |             |                          | 8.587             | 100                                 | 20.627                        |

**7.1.11 Reconductor Erwin – Fayetteville 115 kV  
(SREMC Wade - Beard)**

| ID     | MW Output<br>(MW) | DFax<br>(%) | Loading<br>Impact<br>(%) | MW Impact<br>(MW) | Cost<br>Allocation<br>Factor<br>(%) | Cost<br>Allocation<br>(MM \$) |
|--------|-------------------|-------------|--------------------------|-------------------|-------------------------------------|-------------------------------|
| 032986 | 80                | 1.553       | 1.044                    | 1.242             | 14.468                              | 3.002                         |
| 138340 | 74                | 1.704       | 1.060                    | 1.261             | 14.684                              | 3.047                         |
| 170274 | 275               | 1.179       | 2.725                    | 3.242             | 37.756                              | 7.835                         |
| 179866 | 150               | 0.877       | 1.105                    | 1.316             | 15.319                              | 3.179                         |
| 187960 | 165               | 0.925       | 1.283                    | 1.526             | 17.773                              | 3.688                         |
|        |                   |             |                          | 8.587             | 100                                 | 20.752                        |

**7.1.12 Reconductor Erwin – Fayetteville 115 kV  
(Beard – Fay Slocomb Tap)**

| ID     | MW Output<br>(MW) | DFax<br>(%) | Loading<br>Impact<br>(%) | MW Impact<br>(MW) | Cost<br>Allocation<br>Factor<br>(%) | Cost<br>Allocation<br>(MM \$) |
|--------|-------------------|-------------|--------------------------|-------------------|-------------------------------------|-------------------------------|
| 032986 | 80                | 1.553       | 1.044                    | 1.242             | 14.468                              | 0.848                         |
| 138340 | 74                | 1.704       | 1.060                    | 1.261             | 14.684                              | 0.860                         |
| 170274 | 275               | 1.179       | 2.725                    | 3.242             | 37.756                              | 2.212                         |
| 179866 | 150               | 0.877       | 1.105                    | 1.316             | 15.319                              | 0.898                         |
| 187960 | 165               | 0.925       | 1.283                    | 1.526             | 17.773                              | 1.041                         |
|        |                   |             |                          | 8.587             | 100                                 | 5.859                         |

**7.1.13 Reconductor Erwin – Fayetteville 115 kV  
(Erwin 115 – Erwin Mills Tap)**

| ID     | MW Output<br>(MW) | DFax<br>(%) | Loading<br>Impact<br>(%) | MW Impact<br>(MW) | Cost<br>Allocation<br>Factor<br>(%) | Cost<br>Allocation<br>(MM \$) |
|--------|-------------------|-------------|--------------------------|-------------------|-------------------------------------|-------------------------------|
| 032986 | 80                | 1.553       | 1.044                    | 1.242             | 14.468                              | 0.019                         |
| 138340 | 74                | 1.704       | 1.060                    | 1.261             | 14.684                              | 0.019                         |
| 170274 | 275               | 1.179       | 2.725                    | 3.242             | 37.756                              | 0.049                         |
| 179866 | 150               | 0.877       | 1.105                    | 1.316             | 15.319                              | 0.020                         |
| 187960 | 165               | 0.925       | 1.283                    | 1.526             | 17.773                              | 0.023                         |
|        |                   |             |                          | 8.587             | 100                                 | 0.129                         |

### 7.1.14 Reconductor Erwin – Fayetteville East 230 kV (Linden – Fay East)

| ID     | MW Output<br>(MW) | DFax<br>(%) | Loading<br>Impact<br>(%) | MW Impact<br>(MW) | Cost<br>Allocation<br>Factor<br>(%) | Cost<br>Allocation<br>(MM \$) |
|--------|-------------------|-------------|--------------------------|-------------------|-------------------------------------|-------------------------------|
| 032986 | 80                | 6.092       | 0.899                    | 4.874             | 6.475                               | 3.543                         |
| 010586 | 70.1              | 4.709       | 0.609                    | 3.301             | 4.386                               | 2.400                         |
| 016321 | 70                | 4.092       | 0.528                    | 2.864             | 3.806                               | 2.082                         |
| 017658 | 80                | 4.518       | 0.667                    | 3.614             | 4.802                               | 2.628                         |
| 019397 | 75                | 3.859       | 0.534                    | 2.894             | 3.845                               | 2.104                         |
| 024078 | 79.8              | 3.251       | 0.479                    | 2.594             | 3.447                               | 1.886                         |
| 205718 | 74.9              | 5.397       | 0.746                    | 4.042             | 5.371                               | 2.939                         |
| 200482 | 60                | 4.096       | 0.453                    | 2.458             | 3.265                               | 1.787                         |
| 067146 | 80                | 3.864       | 0.570                    | 3.091             | 4.107                               | 2.247                         |
| 119904 | 18.4              | 13.719      | 0.466                    | 2.524             | 3.354                               | 1.835                         |
| 138340 | 74                | 6.369       | 0.870                    | 4.713             | 6.262                               | 3.426                         |
| 170274 | 275               | 5.584       | 2.833                    | 15.356            | 20.402                              | 11.164                        |
| 169716 | 80                | 4.143       | 0.612                    | 3.314             | 4.403                               | 2.410                         |
| 179866 | 150               | 3.452       | 0.955                    | 5.178             | 6.879                               | 3.764                         |
| 179996 | 74.9              | 3.225       | 0.446                    | 2.416             | 3.209                               | 1.756                         |
| 187960 | 165               | 3.810       | 1.160                    | 6.287             | 8.352                               | 4.570                         |
| 177122 | 69.9              | 5.448       | 0.703                    | 3.808             | 5.059                               | 2.769                         |
| 004540 | 8.8               | 5.375       | 0.087                    | 0.473             | 0.628                               | 0.344                         |
| 004538 | 10                | 5.378       | 0.099                    | 0.538             | 0.715                               | 0.391                         |
| 016328 | 2                 | 5.375       | 0.020                    | 0.108             | 0.143                               | 0.078                         |
| 019170 | 2                 | 5.375       | 0.020                    | 0.108             | 0.143                               | 0.078                         |
| 016326 | 2                 | 5.375       | 0.020                    | 0.108             | 0.143                               | 0.078                         |
| 016327 | 2                 | 5.375       | 0.020                    | 0.108             | 0.143                               | 0.078                         |
| 019176 | 2                 | 5.375       | 0.020                    | 0.108             | 0.143                               | 0.078                         |
| 019261 | 6.201             | 6.300       | 0.072                    | 0.391             | 0.519                               | 0.284                         |
|        |                   |             |                          | 75.268            | 100                                 | 54.720                        |

### 7.1.15 Reconductor Erwin – Fayetteville East 230 kV (Erwin - Linden)

| ID     | MW Output<br>(MW) | DFax<br>(%) | Loading<br>Impact<br>(%) | MW Impact<br>(MW) | Cost<br>Allocation<br>Factor<br>(%) | Cost<br>Allocation<br>(MM \$) |
|--------|-------------------|-------------|--------------------------|-------------------|-------------------------------------|-------------------------------|
| 032986 | 80                | 6.092       | 0.899                    | 4.874             | 6.475                               | 3.250                         |
| 010586 | 70.1              | 4.709       | 0.609                    | 3.301             | 4.386                               | 2.201                         |
| 016321 | 70                | 4.092       | 0.528                    | 2.864             | 3.806                               | 1.910                         |
| 017658 | 80                | 4.518       | 0.667                    | 3.614             | 4.802                               | 2.410                         |
| 019397 | 75                | 3.859       | 0.534                    | 2.894             | 3.845                               | 1.930                         |
| 024078 | 79.8              | 3.251       | 0.479                    | 2.594             | 3.447                               | 1.730                         |
| 205718 | 74.9              | 5.397       | 0.746                    | 4.042             | 5.371                               | 2.696                         |
| 200482 | 60                | 4.096       | 0.453                    | 2.458             | 3.265                               | 1.639                         |
| 067146 | 80                | 3.864       | 0.570                    | 3.091             | 4.107                               | 2.062                         |
| 119904 | 18.4              | 13.719      | 0.466                    | 2.524             | 3.354                               | 1.683                         |
| 138340 | 74                | 6.369       | 0.870                    | 4.713             | 6.262                               | 3.143                         |
| 170274 | 275               | 5.584       | 2.833                    | 15.356            | 20.402                              | 10.241                        |
| 169716 | 80                | 4.143       | 0.612                    | 3.314             | 4.403                               | 2.210                         |
| 179866 | 150               | 3.452       | 0.955                    | 5.178             | 6.879                               | 3.453                         |
| 179996 | 74.9              | 3.225       | 0.446                    | 2.416             | 3.209                               | 1.611                         |
| 187960 | 165               | 3.810       | 1.160                    | 6.287             | 8.352                               | 4.193                         |
| 177122 | 69.9              | 5.448       | 0.703                    | 3.808             | 5.059                               | 2.540                         |
| 004540 | 8.8               | 5.375       | 0.087                    | 0.473             | 0.628                               | 0.315                         |
| 004538 | 10                | 5.378       | 0.099                    | 0.538             | 0.715                               | 0.359                         |
| 016328 | 2                 | 5.375       | 0.020                    | 0.108             | 0.143                               | 0.072                         |
| 019170 | 2                 | 5.375       | 0.020                    | 0.108             | 0.143                               | 0.072                         |
| 016326 | 2                 | 5.375       | 0.020                    | 0.108             | 0.143                               | 0.072                         |
| 016327 | 2                 | 5.375       | 0.020                    | 0.108             | 0.143                               | 0.072                         |
| 019176 | 2                 | 5.375       | 0.020                    | 0.108             | 0.143                               | 0.072                         |
| 019261 | 6.201             | 6.300       | 0.072                    | 0.391             | 0.519                               | 0.261                         |
|        |                   |             |                          | 75.268            | 100                                 | 50.197                        |



**7.1.16 Reconductor Fayetteville – Fay. DuPont 115 kV  
 (Fayetteville – Hope Mills Church St.)**

| ID     | MW Output<br>(MW) | DFax<br>(%) | Loading<br>Impact<br>(%) | MW Impact<br>(MW) | Cost<br>Allocation<br>Factor<br>(%) | Cost<br>Allocation<br>(MM \$) |
|--------|-------------------|-------------|--------------------------|-------------------|-------------------------------------|-------------------------------|
| 017658 | 80                | 2.854       | 1.919                    | 2.283             | 11.574                              | 1.393                         |
| 019397 | 75                | 2.098       | 1.322                    | 1.574             | 7.977                               | 0.960                         |
| 205718 | 74.9              | 2.450       | 1.542                    | 1.835             | 9.303                               | 1.120                         |
| 067146 | 80                | 1.603       | 1.078                    | 1.282             | 6.501                               | 0.782                         |
| 138340 | 74                | 4.775       | 2.969                    | 3.534             | 17.913                              | 2.156                         |
| 170274 | 275               | 0.616       | 1.424                    | 1.694             | 8.587                               | 1.034                         |
| 179866 | 150               | 1.662       | 2.095                    | 2.493             | 12.638                              | 1.521                         |
| 187960 | 165               | 1.511       | 2.095                    | 2.493             | 12.639                              | 1.521                         |
| 177122 | 69.9              | 2.466       | 1.449                    | 1.724             | 8.738                               | 1.052                         |
| 004538 | 10                | 6.201       | 0.521                    | 0.620             | 3.144                               | 0.378                         |
| 019261 | 6.201             | 3.141       | 0.164                    | 0.195             | 0.987                               | 0.119                         |
|        |                   |             |                          | 19.726            | 100                                 | 12.036                        |

Note: This upgrade is also required for ERIS requests that impact this line.

**7.1.17 Reconductor Laurinburg - Raeford 115 kV  
 (Maxton Airport Tap – LREMC Allendale)**

| ID     | MW Output<br>(MW) | DFax<br>(%) | Loading<br>Impact<br>(%) | MW Impact<br>(MW) | Cost<br>Allocation<br>Factor<br>(%) | Cost<br>Allocation<br>(MM \$) |
|--------|-------------------|-------------|--------------------------|-------------------|-------------------------------------|-------------------------------|
| 017658 | 80                | 3.487       | 1.461                    | 2.790             | 3.235                               | 0.179                         |
| 019397 | 75                | 2.936       | 1.153                    | 2.202             | 2.553                               | 0.142                         |
| 205718 | 74.9              | 11.018      | 4.321                    | 8.252             | 9.569                               | 0.531                         |
| 067146 | 80                | 2.864       | 1.200                    | 2.291             | 2.657                               | 0.147                         |
| 138340 | 74                | 18.115      | 7.018                    | 13.405            | 15.544                              | 0.863                         |
| 170274 | 275               | 13.432      | 19.339                   | 36.938            | 42.831                              | 2.377                         |
| 179866 | 150               | 2.607       | 2.047                    | 3.911             | 4.534                               | 0.252                         |
| 187960 | 165               | 2.897       | 2.503                    | 4.780             | 5.543                               | 0.308                         |
| 177122 | 69.9              | 11.343      | 4.151                    | 7.929             | 9.194                               | 0.510                         |
| 004540 | 8.8               | 10.878      | 0.501                    | 0.957             | 1.110                               | 0.062                         |
| 004538 | 10                | 3.546       | 0.186                    | 0.355             | 0.411                               | 0.023                         |
| 016328 | 2                 | 10.878      | 0.114                    | 0.218             | 0.252                               | 0.014                         |
| 019170 | 2                 | 10.878      | 0.114                    | 0.218             | 0.252                               | 0.014                         |
| 016326 | 2                 | 10.878      | 0.114                    | 0.218             | 0.252                               | 0.014                         |
| 016327 | 2                 | 10.878      | 0.114                    | 0.218             | 0.252                               | 0.014                         |
| 019176 | 2                 | 10.878      | 0.114                    | 0.218             | 0.252                               | 0.014                         |
| 019261 | 6.201             | 21.666      | 0.703                    | 1.344             | 1.558                               | 0.086                         |
|        |                   |             |                          | 86.241            | 100                                 | 5.549                         |

**7.1.18 Reconductor Robinson - Rockingham 115 kV  
(Sneedsboro Solar - Cordova)**

| ID     | MW Output<br>(MW) | DFax<br>(%) | Loading<br>Impact<br>(%) | MW Impact<br>(MW) | Cost<br>Allocation<br>Factor<br>(%) | Cost<br>Allocation<br>(MM \$) |
|--------|-------------------|-------------|--------------------------|-------------------|-------------------------------------|-------------------------------|
| 016321 | 70                | 48.692      | 20.783                   | 34.084            | 61.336                              | 17.947                        |
| 019397 | 75                | 2.292       | 1.048                    | 1.719             | 3.093                               | 0.905                         |
| 024078 | 79.8              | 5.405       | 2.630                    | 4.313             | 7.762                               | 2.271                         |
| 067146 | 80                | 3.243       | 1.582                    | 2.594             | 4.669                               | 1.366                         |
| 179866 | 150               | 2.356       | 2.155                    | 3.534             | 6.359                               | 1.861                         |
| 179996 | 74.9              | 2.480       | 1.133                    | 1.858             | 3.343                               | 0.978                         |
| 187960 | 165               | 4.526       | 4.554                    | 7.468             | 13.439                              | 3.932                         |
|        |                   |             |                          | 55.570            | 100                                 | 29.260                        |

Note: This upgrade is also required for ERIS requests that impact this line.

**7.1.19 Reconductor Robinson - Rockingham 115 kV  
(Cordova - Rockingham)**

| ID     | MW Output<br>(MW) | DFax<br>(%) | Loading<br>Impact<br>(%) | MW Impact<br>(MW) | Cost<br>Allocation<br>Factor<br>(%) | Cost<br>Allocation<br>(MM \$) |
|--------|-------------------|-------------|--------------------------|-------------------|-------------------------------------|-------------------------------|
| 016321 | 70                | 48.692      | 21.437                   | 34.084            | 61.336                              | 5.534                         |
| 019397 | 75                | 2.292       | 1.081                    | 1.719             | 3.093                               | 0.279                         |
| 024078 | 79.8              | 5.405       | 2.713                    | 4.313             | 7.762                               | 0.700                         |
| 067146 | 80                | 3.243       | 1.632                    | 2.594             | 4.669                               | 0.421                         |
| 179866 | 150               | 2.356       | 2.223                    | 3.534             | 6.359                               | 0.574                         |
| 179996 | 74.9              | 2.480       | 1.168                    | 1.858             | 3.343                               | 0.302                         |
| 187960 | 165               | 4.526       | 4.697                    | 7.468             | 13.439                              | 1.212                         |
|        |                   |             |                          | 55.570            | 100                                 | 9.022                         |

Note: This upgrade is also required for ERIS requests that impact this line.

### 7.1.20 Raise Rockingham – West End 230 kV West (Eden Solar – West End)

| ID     | MW Output<br>(MW) | DFax<br>(%) | Loading<br>Impact<br>(%) | MW Impact<br>(MW) | Cost<br>Allocation<br>Factor<br>(%) | Cost<br>Allocation<br>(MM \$) |
|--------|-------------------|-------------|--------------------------|-------------------|-------------------------------------|-------------------------------|
| 016321 | 70                | 3.569       | 0.488                    | 2.498             | 15.907                              | 0.278                         |
| 200482 | 60                | 5.640       | 0.661                    | 3.384             | 21.547                              | 0.377                         |
| 170274 | 275               | 3.572       | 1.919                    | 9.823             | 62.546                              | 1.094                         |
|        |                   |             |                          | 15.705            | 100                                 | 1.749                         |

### 7.1.21 Raise Sutton Plant - Wallace 230 kV (Crooked Run Solar - Wallace)

| ID     | MW Output<br>(MW) | DFax<br>(%) | Loading<br>Impact<br>(%) | MW Impact<br>(MW) | Cost<br>Allocation<br>Factor<br>(%) | Cost<br>Allocation<br>(MM \$) |
|--------|-------------------|-------------|--------------------------|-------------------|-------------------------------------|-------------------------------|
| 032986 | 80                | 3.060       | 0.515                    | 2.448             | 20.088                              | 0.118                         |
| 169716 | 80                | 12.173      | 2.050                    | 9.738             | 79.912                              | 0.471                         |
|        |                   |             |                          | 12.186            | 100                                 | 0.589                         |

**7.1.22 Raise Tillery – Badin 115 kV Black Line**

| ID     | MW Output<br>(MW) | DFax<br>(%) | Loading<br>Impact<br>(%) | MW Impact<br>(MW) | Cost<br>Allocation<br>Factor<br>(%) | Cost<br>Allocation<br>(MM \$) |
|--------|-------------------|-------------|--------------------------|-------------------|-------------------------------------|-------------------------------|
| 005703 | 70.2              | 28.620      | 20.091                   | 20.091            | 48.192                              | 1.510                         |
| 032986 | 80                | 1.338       | 1.070                    | 1.070             | 2.568                               | 0.080                         |
| 016321 | 70                | 2.507       | 1.755                    | 1.755             | 4.209                               | 0.132                         |
| 205718 | 74.9              | 1.401       | 1.049                    | 1.049             | 2.517                               | 0.079                         |
| 200482 | 60                | 2.018       | 1.211                    | 1.211             | 2.904                               | 0.091                         |
| 022128 | 79.8              | 1.322       | 1.055                    | 1.055             | 2.530                               | 0.079                         |
| 138340 | 74                | 1.485       | 1.099                    | 1.099             | 2.636                               | 0.083                         |
| 170274 | 275               | 1.668       | 4.587                    | 4.587             | 11.003                              | 0.345                         |
| 169716 | 80                | 1.384       | 1.107                    | 1.107             | 2.656                               | 0.083                         |
| 169712 | 80                | 6.974       | 5.579                    | 5.579             | 13.383                              | 0.419                         |
| 179866 | 150               | 0.867       | 1.301                    | 1.301             | 3.119                               | 0.098                         |
| 187960 | 165               | 1.082       | 1.785                    | 1.785             | 4.282                               | 0.134                         |
|        |                   |             |                          | 41.690            | 100                                 | 3.133                         |

**7.1.23 Raise Tillery – Badin 115 kV White Line**

| ID     | MW Output<br>(MW) | DFax<br>(%) | Loading<br>Impact<br>(%) | MW Impact<br>(MW) | Cost<br>Allocation<br>Factor<br>(%) | Cost<br>Allocation<br>(MM \$) |
|--------|-------------------|-------------|--------------------------|-------------------|-------------------------------------|-------------------------------|
| 005703 | 70.2              | 27.894      | 19.582                   | 19.582            | 48.196                              | 1.510                         |
| 032986 | 80                | 1.304       | 1.043                    | 1.043             | 2.568                               | 0.080                         |
| 016321 | 70                | 2.443       | 1.710                    | 1.710             | 4.209                               | 0.132                         |
| 205718 | 74.9              | 1.365       | 1.022                    | 1.022             | 2.516                               | 0.079                         |
| 200482 | 60                | 1.967       | 1.180                    | 1.180             | 2.905                               | 0.091                         |
| 022128 | 79.8              | 1.289       | 1.029                    | 1.029             | 2.532                               | 0.079                         |
| 138340 | 74                | 1.447       | 1.071                    | 1.071             | 2.636                               | 0.083                         |
| 170274 | 275               | 1.625       | 4.469                    | 4.469             | 10.999                              | 0.345                         |
| 169716 | 80                | 1.349       | 1.079                    | 1.079             | 2.656                               | 0.083                         |
| 169712 | 80                | 6.797       | 5.438                    | 5.438             | 13.384                              | 0.419                         |
| 179866 | 150               | 0.845       | 1.268                    | 1.268             | 3.120                               | 0.098                         |
| 187960 | 165               | 1.054       | 1.739                    | 1.739             | 4.280                               | 0.134                         |
|        |                   |             |                          | 40.629            | 100                                 | 3.133                         |

**7.1.24 Raise Weatherspoon – Marion 115 kV (Dillon Tap – Marion)**

| ID     | MW Output<br>(MW) | DFax<br>(%) | Loading<br>Impact<br>(%) | MW Impact<br>(MW) | Cost<br>Allocation<br>Factor<br>(%) | Cost<br>Allocation<br>(MM \$) |
|--------|-------------------|-------------|--------------------------|-------------------|-------------------------------------|-------------------------------|
| 010586 | 70.1              | 2.551       | 1.844                    | 1.788             | 7.519                               | 0.503                         |
| 017658 | 80                | 8.844       | 7.294                    | 7.075             | 29.748                              | 1.989                         |
| 019397 | 75                | 4.841       | 3.743                    | 3.631             | 15.265                              | 1.021                         |
| 024078 | 79.8              | 1.426       | 1.173                    | 1.138             | 4.784                               | 0.320                         |
| 067146 | 80                | 2.036       | 1.679                    | 1.629             | 6.848                               | 0.458                         |
| 179866 | 150               | 2.622       | 4.055                    | 3.933             | 16.536                              | 1.106                         |
| 179996 | 74.9              | 2.183       | 1.686                    | 1.635             | 6.875                               | 0.460                         |
| 187960 | 165               | 1.791       | 3.047                    | 2.955             | 12.425                              | 0.831                         |
|        |                   |             |                          | 23.784            | 100                                 | 6.686                         |

## 7.2 ERS Evaluation

The ERS power-flow study utilizes the Transitional Cluster Study Cases. The new generation economically displaces DEP Balancing Authority Area units. Transmission capacity is available as long as no transmission element is overloaded under N-1 transmission conditions. The thermal evaluation will only consider the Transitional Cluster Study under N-1 transmission contingencies to determine the availability of transmission capacity. ERS is service using transmission capacity on an “as available” basis; therefore, adverse generation dispatches that could make the transmission capacity unavailable are not used. If the full output of the Customer’s generating facility cannot be delivered at the time of the study, the study will identify the maximum allowable output at the time of the study that does not require additional Network Upgrades beyond those necessary to establish the interconnection.

Under the terms of ERS service, the full output of the following generating facilities can be delivered:

| ID     | MW Deliverable |
|--------|----------------|
| 119004 | 20             |
| 179996 | 74.9           |
| 186310 | 23.3           |
| 191894 | 30.5           |



Under the terms of ERIS service, the full output of the following generating facilities **cannot** be delivered:

| ID     | MW Deliverable <sup>2</sup> |
|--------|-----------------------------|
| 170274 | 0                           |
| 179866 | 0                           |

Delivery of the full output of the preceding generating facilities requires the following Network Upgrades to mitigate thermal loading issues:

| Network Upgrade   | Mileage | Estimated Cost (\$ M) | Estimated Lead Time (months) <sup>3</sup> |
|---|---------|-----------------------|---|
| Fayetteville – Fay. DuPont 115kV Line (Hope Mills Church Street – Roslin Solar) | 3.0     | In Transmission Plan  | 36  |
| Fayetteville – Fay. DuPont 115kV Line (Fayetteville - Hope Mills Church Street) | 4.9     | 12.036                | 36  |

For each identified network upgrade, the associated cost allocation is provided.

### 7.2.1 Reconductor Fayetteville – Fay. DuPont 115 kV (Fayetteville – Hope Mills Church St.)

| ID     | MW Output (MW) | DFax (%) | Loading Impact (%) | MW Impact (MW) | Cost Allocation Factor (%) | Cost Allocation (MM \$) |
|--------|----------------|----------|--------------------|----------------|----------------------------|-------------------------|
| 170274 | 275            | 0.616    | 1.424              | 1.694          | 8.587                      | 1.034                   |
| 179866 | 150            | 1.662    | 2.095              | 2.493          | 12.638                     | 1.521                   |

<sup>2</sup> The maximum output that can be delivered without requiring Network Upgrades to mitigate thermal loading issues

<sup>3</sup> Unless otherwise noted, the estimated lead time reflects the duration of time required to complete the specific project after the applicable generators have executed an Interconnection Agreement.

### 7.3 Contingent Facilities

Contingent Facilities shall mean those unbuilt Interconnection Facilities and Network Upgrades upon which the Interconnection Request's costs, timing, and study findings are dependent, and if delayed or not built, could cause a need for Re-Studies of the Interconnection Request or a reassessment of the Interconnection Facilities and/or Network Upgrades and/or costs and timing. The criteria for identifying Contingent Facilities is provided in the joint OATT (LGIP § 4.8).

#### 7.3.1 Prior Interconnection Requests

No Upgrades assigned to Interconnection Customers in Transitional Cluster are dependent upon upgrades associated prior interconnection requests.

#### 7.3.2 Utility Transmission Plan

The outage causing overload of all four sections of the Asheboro East – Biscoe 115 kV Line mentioned below is failure of 230CB25 at Asheboro 230kV Substation, which takes out two of the three 230kV transmission lines at that substation. The solution in progress is moving one of the lines to a new bay, resulting in a double-breaker arrangement. Expected In Service Date (ISD) is 6/2023.

##### 7.3.2.1 Asheboro East – Biscoe 115 kV Line (REMC Ether – Biscoe 115 kV)

| ID     | MW Output<br>(MW) | DFax<br>(%) | Loading<br>Impact<br>(%) | MW Impact<br>(MW) |
|--------|-------------------|-------------|--------------------------|-------------------|
| 005703 | 70.2              | 6.486       | 3.076                    | 4.553             |
| 170274 | 275               | 0.564       | 1.048                    | 1.551             |
| 169712 | 80                | 9.371       | 5.065                    | 7.497             |
|        |                   |             |                          | 13.601            |

##### 7.3.2.2 Asheboro East – Biscoe 115 kV Line (Seagrove – REMC Ether)

| ID     | MW Output<br>(MW) | DFax<br>(%) | Loading<br>Impact<br>(%) | MW Impact<br>(MW) |
|--------|-------------------|-------------|--------------------------|-------------------|
| 005703 | 70.2              | 6.486       | 3.076                    | 4.553             |
| 170274 | 275               | 0.564       | 1.048                    | 1.551             |
| 169712 | 80                | 9.371       | 5.065                    | 7.497             |
|        |                   |             |                          | 13.601            |

**7.3.2.3 Asheboro East – Biscoe 115 kV Line  
(REMC Ulah – Seagrove)**

| ID     | MW Output<br>(MW) | DFax<br>(%) | Loading<br>Impact<br>(%) | MW Impact<br>(MW) |
|--------|-------------------|-------------|--------------------------|-------------------|
| 005703 | 70.2              | 6.486       | 3.076                    | 4.553             |
| 170274 | 275               | 0.564       | 1.048                    | 1.551             |
| 169712 | 80                | 9.371       | 5.065                    | 7.497             |
|        |                   |             |                          | 13.601            |

**7.3.2.4 Asheboro East – Biscoe 115 kV Line  
(Asheboro South Tap – REMC Ulah)**

| ID     | MW Output<br>(MW) | DFax<br>(%) | Loading<br>Impact<br>(%) | MW Impact<br>(MW) |
|--------|-------------------|-------------|--------------------------|-------------------|
| 005703 | 70.2              | 6.486       | 3.299                    | 4.553             |
| 170274 | 275               | 0.564       | 1.124                    | 1.551             |
| 169712 | 80                | 9.371       | 5.432                    | 7.497             |
|        |                   |             |                          | 13.601            |

The solution to overload of the Hope Mills Church St. – Roslin Solar section of the Fayetteville – Fayetteville DuPont 115 kV Line is reconductoring. Expected ISD is 6/2026.

**7.3.2.5 Fayetteville – Fayetteville DuPont 115 kV Line  
(Hope Mills Church St. – Roslin Solar)**

| ID     | MW Output<br>(MW) | DFax<br>(%) | Loading<br>Impact<br>(%) | MW Impact<br>(MW) |
|--------|-------------------|-------------|--------------------------|-------------------|
| 017658 | 80                | 2.854       | 1.919                    | 2.283             |
| 019397 | 75                | 2.098       | 1.322                    | 1.574             |
| 205718 | 74.9              | 2.450       | 1.542                    | 1.835             |
| 067146 | 80                | 1.603       | 1.078                    | 1.282             |
| 138340 | 74                | 4.775       | 2.969                    | 3.534             |
| 170274 | 275               | 0.616       | 1.424                    | 1.694             |
| 179866 | 150               | 1.662       | 2.095                    | 2.493             |
| 187960 | 165               | 1.511       | 2.095                    | 2.493             |
| 177122 | 69.9              | 2.466       | 1.449                    | 1.724             |
| 004538 | 10                | 6.201       | 0.521                    | 0.620             |
| 019261 | 6.201             | 3.141       | 0.164                    | 0.195             |
|        |                   |             |                          | 19.726            |

The solution to the overload of the Richmond 500/230kV autotransformers is a tap change on the Current Transformers and adjustment of protection settings. Expected ISD is 12/2022.

### 7.3.2.6 Richmond 500/230 kV Transformer #1

| ID     | MW Output<br>(MW) | DFax<br>(%) | Loading<br>Impact<br>(%) | MW Impact<br>(MW) |
|--------|-------------------|-------------|--------------------------|-------------------|
| 005703 | 70.2              | 6.269       | 0.552                    | 4.401             |
| 016321 | 70                | 9.099       | 0.799                    | 6.369             |
| 019397 | 75                | 3.309       | 0.311                    | 2.482             |
| 024078 | 79.8              | 4.610       | 0.462                    | 3.679             |
| 205718 | 74.9              | 8.358       | 0.785                    | 6.260             |
| 200482 | 60                | 12.916      | 0.972                    | 7.750             |
| 067146 | 80                | 5.200       | 0.522                    | 4.160             |
| 138340 | 74                | 7.371       | 0.684                    | 5.455             |
| 170274 | 275               | 15.568      | 5.372                    | 42.812            |
| 169712 | 80                | 5.389       | 0.541                    | 4.311             |
| 179866 | 150               | 3.446       | 0.649                    | 5.169             |
| 179996 | 74.9              | 3.491       | 0.328                    | 2.615             |
| 187960 | 165               | 5.338       | 1.105                    | 8.808             |
| 177122 | 69.9              | 8.542       | 0.749                    | 5.971             |
| 004540 | 8.8               | 8.278       | 0.091                    | 0.728             |
| 016328 | 2                 | 8.278       | 0.021                    | 0.166             |
| 019170 | 2                 | 8.278       | 0.021                    | 0.166             |
| 016326 | 2                 | 8.278       | 0.021                    | 0.166             |
| 016327 | 2                 | 8.278       | 0.021                    | 0.166             |
| 019176 | 2                 | 8.278       | 0.021                    | 0.166             |
| 019261 | 6.201             | 8.542       | 0.066                    | 0.530             |
|        |                   |             |                          | 112.326           |

**7.3.2.7 Richmond 500/230 kV Transformer #2**

| ID     | MW Output<br>(MW) | DFax<br>(%) | Loading<br>Impact<br>(%) | MW Impact<br>(MW) |
|--------|-------------------|-------------|--------------------------|-------------------|
| 005703 | 70.2              | 6.240       | 0.550                    | 4.380             |
| 016321 | 70                | 9.056       | 0.795                    | 6.339             |
| 019397 | 75                | 3.293       | 0.310                    | 2.470             |
| 024078 | 79.8              | 4.588       | 0.459                    | 3.661             |
| 205718 | 74.9              | 8.319       | 0.782                    | 6.231             |
| 200482 | 60                | 12.855      | 0.968                    | 7.713             |
| 067146 | 80                | 5.175       | 0.519                    | 4.140             |
| 138340 | 74                | 7.336       | 0.681                    | 5.429             |
| 170274 | 275               | 15.495      | 5.346                    | 42.611            |
| 169712 | 80                | 5.363       | 0.538                    | 4.290             |
| 179866 | 150               | 3.430       | 0.646                    | 5.145             |
| 179996 | 74.9              | 3.474       | 0.326                    | 2.602             |
| 187960 | 165               | 5.313       | 1.100                    | 8.766             |
| 177122 | 69.9              | 8.502       | 0.746                    | 5.943             |
| 004540 | 8.8               | 8.239       | 0.091                    | 0.725             |
| 016328 | 2                 | 8.239       | 0.021                    | 0.165             |
| 019170 | 2                 | 8.239       | 0.021                    | 0.165             |
| 016326 | 2                 | 8.239       | 0.021                    | 0.165             |
| 016327 | 2                 | 8.239       | 0.021                    | 0.165             |
| 019176 | 2                 | 8.239       | 0.021                    | 0.165             |
| 019261 | 6.201             | 8.502       | 0.066                    | 0.527             |
|        |                   |             |                          | <b>111.797</b>    |

## 8.0 Reactive Power Capability

For transmission-connected generators in DEP, the reactive capability requirement at the Point of Interconnection (POI) is the Mvar required to achieve 0.95 lagging power factor to 0.95 leading power factor at the maximum requested MW output of the plant. The calculated Mvar capability, shown in the table below, is required at all plant MW output levels.

Reactive Capability will be evaluated in Phase 2 by modeling a Customer's generating facility at various taps and system voltage conditions. The reactive capability of the facility can be affected by many factors including but not limited to generator/inverter capability limits, transformer impedances, and bus voltage limits. The evaluation determines whether sufficient reactive support will be available at the Point of Interconnection based on the requirements set forth in **DEP's Facility Interconnection Requirements (FIR)** for generation connected to the Transmission System. For more information on reactive requirements for generation, reference the FIR on the **DEP OASIS** site<sup>4</sup>.

The MW value included in the Interconnection Agreement shall not exceed a MW value higher than that at which the Customer's generating facility meets the reactive capability requirements. Additionally, batteries, if any, must be operated in a manner that does not restrict the ability of the Customer's generating facility to supply or absorb reactive power within the appropriate reactive power range.

For projects that cannot meet the reactive capability requirements at their requested MW output, two mitigation options will be offered: 1) MW reduction or 2) capacitor addition. If a capacitor bank is installed at the Customer's generating facility, it may be used only to compensate for plant reactive power losses. If the capacitor bank is capable of providing compensation beyond the plant losses, that additional compensation shall not be factored into the determination of whether or not the Customer's generating facility meets the reactive capability requirements. If a capacitor bank is installed but is not capable of being placed into service, the MW output of the Customer's generating facility may be restricted. Any capacitor installed to meet the power factor requirement shall be automatically switched by the power plant controller as needed to meet the voltage, power factor, or reactive power schedule provided by the utility.

---

<sup>4</sup> = <http://www.oatioasis.com/cpl/index.html>

| ID     | Requested MW | MVAR Capability Required |         |
|--------|--------------|--------------------------|---------|
|        |              | Lagging                  | Leading |
| 005703 | 70.2         | 23.0                     | -23.0   |
| 032986 | 80           | 26.2                     | -26.2   |
| 010586 | 70.1         | 23.0                     | -23.0   |
| 016321 | 70           | 23.0                     | -23.0   |
| 017658 | 80           | 26.2                     | -26.2   |
| 019397 | 75           | 24.6                     | -24.6   |
| 024078 | 79.8         | 26.2                     | -26.2   |
| 021764 | 8            | 2.6                      | -2.6    |
| 021772 | 8            | 2.6                      | -2.6    |
| 030708 | 78.32        | 25.7                     | -25.7   |
| 205718 | 74.9         | 24.6                     | -24.6   |
| 200482 | 60           | 19.7                     | -19.7   |
| 022128 | 79.8         | 26.2                     | -26.2   |
| 126008 | 75           | 24.6                     | -24.6   |
| 067146 | 80           | 26.2                     | -26.2   |
| 119904 | 18.4         | 6.0                      | -6.0    |
| 138340 | 74           | 24.3                     | -24.3   |
| 170274 | 275          | 90.4                     | -90.4   |
| 169716 | 80           | 26.2                     | -26.2   |
| 169712 | 80           | 26.2                     | -26.2   |
| 179866 | 150          | 49.3                     | -49.3   |
| 179996 | 74.9         | 24.6                     | -24.6   |
| 186310 | 23.3         | 7.6                      | -7.6    |
| 187960 | 165          | 54.2                     | -54.2   |
| 177122 | 69.9         | 22.9                     | -22.9   |
| 191894 | 30.5         | 10.0                     | -10.0   |



## 9.0 Affected Systems

Generator interconnections to the DEP system may have an adverse impact on neighboring systems. As such, additional studies may be required by neighboring systems, which may result in increased cost of interconnection. DEP screened requests in the Transitional Cluster against all tie lines with neighboring utilities using a 5% DFax to determine which requests to notify potential Affected Systems about. In addition, requests that have less than 5% DFax but are close to a potential Affected System based on engineering judgement were added to the notification list. Distribution requests are not included in the potential Affected System lists due to their significantly smaller impact. The potential Affected System will determine if they need to perform an Affected System Study.

At the time of this Transitional Cluster Phase 1 study, the following potential Affected Systems have been identified for the listed projects:

- **American Electric Power (AEP)**
  - None
- **Dominion Energy South Carolina (DESC/SCEG)**
  - 067146
  - 179996
  - 187960
- **Duke Energy Carolinas (DEC)**
  - 005703
  - 019397
  - 024078
  - 169712
  - 170274
  - 179866
  - 179996
  - 186310
  - 200482
- **South Carolina Public Service Authority (SCPSA/Santee Cooper)**
  - 010586
  - 016321
  - 017658
  - 019397
  - 024078
  - 032986
  - 067146
  - 177122
  - 179866
  - 179996
  - 187960
  - 205718

- **Dominion Virginia Power (DVP)**
    - 021764
    - 021772
    - 022128
    - 030708
    - 126008
    - 186310
  - **Tennessee Valley Authority (TVA)**
    - None
  - **Cube Hydro (YAD/Yadkin)**
    - 005703
    - 169712
- 

Report Prepared By:

William Quaintance, PE, Principal Engineer, DEP

Kyle Hord, PE, Senior Engineer, DEP



**Duke Energy Progress, LLC**  
**Distribution Phase 1 Power Flow**  
**Transitional Cluster Report**

Prepared By:  
Distributed Energy Group

**2/28/2022**

## 1 Preface

The distribution Phase 1 Power Flow study is designed to identify the electric system impacts, from a voltage and thermal perspective, associated with interconnecting the proposed Transitional Cluster Study Generation Facilities and to identify System Upgrades required to correct any system violations identified within this phase of the Transitional Cluster study process. Protection related System Upgrades that do not require study to identify are also included due to the significant impact the upgrades could have on the System Upgrade cost estimates. The Interconnection Facilities required to interconnect the Facilities to the Duke Energy distribution system are also detailed. The study is based on the point of interconnections proposed by the Interconnection Customers and on technical information provided in the Interconnection Requests.

In addition to detailing the required Interconnection Facilities and System Upgrades, the study provides a ***preliminary, non-binding*** estimate of the cost of the System Upgrades. The cost estimate provided in this report is a Class 5 estimate (under the Association for the Advancement of Cost Engineering standards) and therefore has a maximum expected accuracy range of -50% to +100%.

## 2 Cost Allocation Summary

As a result of the power flow analysis performed within Phase 1, System Upgrades were identified for the distribution system to accommodate the Generating Facilities. System Upgrades were localized to the individual circuits and/or substations, as detailed in Section 5 below. Therefore, only impacting projects were assigned allocated costs for each of the System Upgrades identified. The total allocated distribution costs for each project is detailed in the table below. The assigned costs for the Transmission impacts are included below and can be found within the Transmission.

**Table 1 – Cost Allocations Per Project**

| ID      | Distribution Allocation | Transmission Allocation | Interconnection Facilities | Total Cost  |
|---------|-------------------------|-------------------------|----------------------------|-------------|
| #004484 | \$0 <sup>5</sup>        | \$0 <sup>6</sup>        | \$125,000                  | \$125,000   |
| #004538 | \$0 <sup>5</sup>        | \$1,151,000             | \$125,000                  | \$1,276,000 |
| #016257 | \$0 <sup>5</sup>        | \$0 <sup>6</sup>        | \$125,000                  | \$125,000   |
| #016227 | \$0                     | \$0 <sup>6</sup>        | \$125,000                  | \$125,000   |
| #019261 | \$572,000               | \$1,209,000             | \$125,000                  | \$1,906,000 |
| #016327 | \$581,000               | \$314,000               | \$125,000                  | \$1,020,000 |
| #016326 | \$581,000               | \$314,000               | \$125,000                  | \$1,020,000 |
| #019170 | \$581,000               | \$314,000               | \$125,000                  | \$1,020,000 |
| #004540 | \$2,007,000             | \$1,383,000             | \$125,000                  | \$3,515,000 |
| #016328 | \$637,000               | \$314,000               | \$125,000                  | \$1,076,000 |
| #019176 | \$637,000               | \$314,000               | \$125,000                  | \$1,076,000 |
| #019139 | \$541,000               | \$0 <sup>6</sup>        | \$125,000                  | \$666,000   |
| #020832 | \$541,000               | \$0 <sup>6</sup>        | \$125,000                  | \$666,000   |
| #021892 | \$2,400                 | \$0 <sup>6</sup>        | \$125,000                  | \$127,400   |
| #008286 | \$1,412,000             | \$0 <sup>6</sup>        | \$125,000                  | \$1,537,000 |
| #002115 | \$366,000 <sup>5</sup>  | \$0 <sup>6</sup>        | \$125,000                  | \$491,000   |
| #002156 | \$366,000 <sup>5</sup>  | \$0 <sup>6</sup>        | \$125,000                  | \$491,000   |
| #005037 | \$0                     | \$0 <sup>6</sup>        | \$125,000                  | \$125,000   |

<sup>5</sup> Allocation does not factor in costs to construct new customer-owned distribution facilities along new right-of-way to relocate POIs. The costs and construction of these new lines are solely the responsibility of the individual Interconnection Customers. Reference the results in Section 5 for further details.

<sup>6</sup> Attachment D projects under the Interconnection Settlement Agreement, as filed in North Carolina Utilities Commission in Docket No. E-100, Sub 101 on September 3, 2020 and filed with the Public Service Commission of South Carolina on September 4, 2020 in Docket No. 2015-362-E. Attachment D projects are subject to Transmission Contingency Violation Curtailment as defined in the Settlement and have not been assigned transmission network upgrades.

For Distribution-level Interconnection Customers determined through Transitional Cluster Phase 1 not to cause or contribute to the need for Network Upgrades requiring further study in Phase 2, DEP shall complete a distribution level System Impact Study if the Interconnection Customer elects to continue through the System Impact Study process. (NCIP 4.4.6, 4.4.7.1; SC GIP Appendix Duke CS 5.3.6; 5.3.7.1).

### 3 Queue Summary

The table below represents an overview of all Generating Facilities proposed to interconnect to the Duke Energy distribution system within the Transitional Cluster. These Generating Facilities have been grouped together by substation and feeder to detail the grouping of Facilities that will be responsible for circuit, and substation, level System Upgrades that may be required.

**Table 2 – Transitional Cluster Proposed Projects**

| Substation                    | Page #   | Feeder   | ID      | Requested Capacity (kW) |
|-------------------------------|----------|----------|---------|-------------------------|
| DILLON 115KV                  | Page #6  | T2750B04 | #004484 | 2,000                   |
|                               |          |          | #004538 | 10,000                  |
| HARTSVILLE SEGARS MILL 230KV  | Page #7  | T3665B04 | #016257 | 1,980                   |
|                               |          | T3665B05 | #016227 | 1,980                   |
| LAURINBURG 230KV              | Page #8  | T2200B23 | #019261 | 6,201                   |
| MCCOLL 230KV                  | Page #9  | T3760B01 | #016327 | 2,000                   |
|                               |          |          | #016326 | 2,000                   |
|                               |          |          | #019170 | 2,000                   |
|                               |          | T3760B02 | #004540 | 8,000                   |
|                               |          |          | #016328 | 2,000                   |
|                               |          |          | #019176 | 2,000                   |
| MULLINS 115KV                 | Page #10 | T3030B01 | #019139 | 2,000                   |
|                               |          |          | #020832 | 2,000                   |
|                               |          | T3030B04 | #021892 | 2,000                   |
| WADESBORO BOWMAN SCHOOL 230KV | Page #11 | T1672B03 | #008286 | 4,992                   |
| WEATHERSPOON 230KV            | Page #12 | T2631B03 | #002115 | 4,998                   |
|                               |          |          | #002156 | 4,999                   |
| WHITEVILLE 115KV              | Page #12 | T6670B03 | #005037 | 1,998                   |

The table below details the aggregate generation capacity and groups together by substation and circuit. The “Existing DER” represent Facilities that are currently connected, or have committed to connecting, prior to the introduction of the Facilities proposed as part of the Transitional Cluster. The “Total DER” represent the aggregate of the Existing DER and the Generating Facilities proposed within Transitional Cluster. Capacity violations, in accordance with the Method of Service Guidelines, that will require

remediation are detailed in red below. Further details regarding the remediation of these violations can be found in the Section 5 below.

**Table 3 - Aggregate Queue State**

| Substation                   | Feeder   | Existing DER on Circuit (MW) | Total DER on Circuit (MW) | Existing DER on Substation (MW) | Total DER on Substation (MW) |
|------------------------------|----------|------------------------------|---------------------------|---------------------------------|------------------------------|
| DILLON 115KV                 | T2750B04 | 6.2                          | 18.2                      | 6.2                             | 18.2                         |
| HARTSVILLE SEGARS MILL 230KV | T3665B04 | 8.9                          | 10.88                     | 10.9                            | 14.86                        |
|                              | T3665B05 | 0                            | 1.98                      |                                 |                              |
| LAURINBURG 230KV             | T2200B23 | 6.999                        | 13.2                      | 6.999                           | 13.2                         |
| MCCOLL 230KV                 | T3760B01 | 0                            | 6                         | 10                              | 28                           |
|                              | T3760B02 | 10                           | 22                        |                                 |                              |
| MULLINS 115KV                | T3030B01 | 2                            | 6                         | 2                               | 8                            |
|                              | T3030B04 | 0                            | 2                         |                                 |                              |
| WADESBORO BOWMAN             | T1672B03 | 7.192                        | 12.19                     | 12.198                          | 17.19                        |
| WEATHERSPOON 230KV           | T2631B03 | 6.997                        | 16.994                    | 26.288                          | 36.285                       |
| WHITEVILLE 115KV             | T6670B03 | 6.997                        | 8.995                     | 16.947                          | 18.945                       |

## 4 Interconnection Facilities

The Interconnection Facilities for each of the Generating Facilities within the Transitional Cluster will be as per Figure 71B of the Requirements for Electric Service and Meter Installations manual, link provided below.

[https://www.duke-energy.com/\\_media/pdfs/partner-with-us/service-requirements-manual.pdf](https://www.duke-energy.com/_media/pdfs/partner-with-us/service-requirements-manual.pdf)

The requirements for the Generating Facility are as follows, as per Figure 75C:

- a) Interconnection protection will be owned and operated by DEP and is to include a recloser, relaying (control), and remote communications for monitoring and operations.
  - i. Protection will utilize overcurrent, under/over voltage, and under/over frequency relaying.
- b) Duke Energy Progress shall provide a manual load-break rated disconnect switch to serve as a clear visible indication of switch position between the utility and the Interconnection Customer. The switch must be readily accessible to Duke Energy personnel.
- c) Interconnection Customer's inverters are required to be tested and listed for compliance with the latest published edition of Underwriter Laboratories Inc., UL 1741 for utility interactive inverters.
- d) Interconnection Customer shall comply with the latest edition of IEEE 1547 and applicable series standards.

These requirements and the interconnection Figure are subject to change at any time.

A power quality (PQ) meter will also be installed with the Interconnection Facilities to continuously monitor the power quality impacts of the Generating Facility to the DEP system.

The Generating Facility is to be operated such that unity power factor is continuously maintained at the Point of Interconnection (where utility-owned metering is located).



## 5 Distribution Impacts Summary

The proposed Generating Facilities were evaluated for adverse impacts on the distribution system based on each substation and circuit being proposed to interconnect to. Each of the impacted substations and circuits are detailed below summarizing the impacts from the relevant Generating Facilities.

### 5.1 Substation: Dillon 115kV

#### Feeder: T2750B04

The interconnection of ID #004484 and #004538 results in steady state voltage violations that cannot be remediated with System Upgrades. The existing Generating Facilities increase the circuit voltages to their limit during peak and valley loading periods. The addition of the proposed Facilities increases the voltages beyond the limit. Modifying the distribution system to the largest standard equipment does not remediate these violations. To accommodate the proposed generation capacities, both Facilities are required to construct, own, and maintain new distribution facilities along new right-of-way for each installation to bring the Point of Interconnections (POIs) to near DIS# A2BP (34.432001°, -79.354923°), just outside of the substation. Interconnection Facilities for each project would extend off this location and each Interconnection Customer's new lines would connect to the Point of Deliveries (POD).

#### High Level Scope of Work:

1. New Line Construction:
  - a. ID #004484 must obtain, build, and maintain new right-of-way and distribution facilities from the project site to the POI. The new POI for this project is located near DIS# A2BP (34.432001°, -79.354923°), approximately 5.1 miles from the project site assuming DOT roadways are followed (actual distance may vary depending on the path chosen by the Interconnection Customer). The costs for this work are outside of Duke Energy's area of responsibility. Cost allocations do not include the cost to perform this work.
  - b. ID #004538 must obtain, build, and maintain new right-of-way and distribution facilities from the project site to the POI. The new POI for this project is located near DIS# A2BP (34.432001°, -79.354923°), approximately 3 miles from the project site assuming DOT roadways are followed (actual distance may vary depending on the path chosen by the Interconnection Customer). The costs for this work are outside of Duke Energy's area of responsibility. Cost allocations do not include the cost to perform this work.

## 5.2 Substation: Hartsville Segars Mill 230kV

### Feeder: T3665B04

The interconnection of ID #016257 results in steady state voltage violations that cannot be remediated with System Upgrades due to the existing distribution facilities already being their largest standard size. The existing Generating Facilities increase the circuit voltages to the limit during valley loading periods. The addition of the proposed Facility increases the voltages over the limit. To accommodate the proposed generation capacity, the Facility is required to construct, own, and maintain new distribution facilities along new right-of-way to bring the Point of Interconnection (POI) to near DIS# HE85BW (34.381249°, -80.146551°) just outside of the substation. The Interconnection Facilities would extend off of this location and the Interconnection Customer's new lines would connect to the Point of Delivery (POD).

#### High Level Scope of Work:

1. New Line Construction:
  - a. ID #016257 must obtain, build, and maintain new right-of-way and distribution facilities from the project site to the POI. The new POI for this project is located near DIS# HE85BW (34.381249°, -80.146551°), approximately 3.5 miles from the project site assuming DOT roadways are followed (actual distance may vary depending on the path chosen by the Interconnection Customer). The costs for this work are outside of Duke Energy's area of responsibility. Cost allocations do not include the cost to perform this work.

### Feeder: T3665B05

The interconnection of ID #016227 did not result in any steady state voltage or rapid voltage change violations on the circuit. No power flow related System Upgrades have been identified at this time.

### 5.3 Substation: Laurinburg 230kV

**Feeder: 01522408**

The interconnection of ID #019261 results in steady state voltage violations on the distribution system. Reconductoring existing line sections between the substation and the Point of Interconnection (POI) to remediate these violations is required. Additionally, certain protective devices that lie between the substation and the POI required alternation to maintain proper protection/coordination on the circuit with the addition of the Facility.

**High Level Scope of Work:**

1. Distribution Line System Upgrades:
  - a. Upgrade existing 3 -336 ACSR circuit with 3-477 AAC circuit from DIS# PC134 to DIS# T93AH (approximately 0.0248 miles). The circuit should be built to High Capacity Standards, which typically includes 4/0 Neutral, 84" Primary to Neutral spacing, 280 ft. maximum spans, etc.
  - b. Upgrade existing 3 – 1/0 ACSR circuit with 3 - 477 AAC circuit from DIS# T93AH to DIS# U10AH (approximately 0.254 miles). The circuit should be built to High Capacity Standards, which typically includes 4/0 Neutral, 84" Primary to Neutral spacing, 280 ft. maximum spans, etc.
  - c. Replace existing 3 – 1/0 ACSR circuit with 3-477 AAC circuit from DIS# U10AH to DIS# A002AH (approximately 0.497 miles). The existing neutral should be replaced with a 4/0 AAAC neutral.
  - d. Replace existing 3 -336 ACSR circuit with 3-477 AAC circuit from DIS# T93AH to DIS# A022AH (approximately 0.0439 miles). The existing neutral should be replaced with a 4/0 AAAC neutral
2. Protection/Sectionalization System Upgrades:
  - a. Replace 65A Fuse with G&W Viper recloser at DIS# T96AH
  - b. Move 25A fuse at DIS #A005AH to within line section A002AH\_A003AH

## 5.4 Substation: McColl 230kV

### McColl 230kV BK1

The interconnection of ID #016327, #016326, #019170, #004540, #016328, and #019176 results in the aggregate generation capacity on this substation to exceed the substation transformer capacity, which requires the capacity to be increased. A new transformer is to be added in parallel with the existing transformer to increase the total capacity of the substation transformer bank to a large enough size to accommodate all the proposed Facilities. Additionally, the aggregate generation proposed on the T3760B02 feeder exceeds the loading limit. A new 24kV feeder breaker position is to be added off the 24kV unregulated bus along with a set of feeder voltage regulators to create a new feeder. With this new breaker position, the T3760B02 feeder will be reconfigured to move portions of the existing feeder to this new feeder. Reconfiguring portions of the existing feeder to this new breaker will relocate some of the Facilities to this feeder, which will remediate the overloads on feeder T3760B02.

#### High Level Scope of Work:

1. Substation Transformer System Upgrades
  - a. Install one 3Ø 230kV/24kV 15MVA ONAN transformer in parallel with the existing 3Ø 230kV/24kV 15MVA ONAN transformer.
2. 24kV Unregulated Bus System Upgrades
  - a. Install additional 24kV feeder breaker position; including one 24kV circuit breaker, associated relaying equipment, and three single-phase voltage regulators.

### Feeder: T3760B01

Portions of the existing distribution circuit between the substation and the point of interconnections (POIs) exceed their capacity limits with the combined generation capacity of ID #016327, #016326, and #019170. Reconductoring these line sections to heavy conductors is required to increase the capacity to an amount that can accommodate these Facilities.

#### High Level Scope of Work:

1. Distribution Line System Upgrades:
  - a. Replace existing conductors with 3Ø 477 AAC conductor with a 4/0 ACSR neutral from DIS# GE09BV to DIS# GK50BV; approximately 1.11 miles.

### Feeder: T3760B02

Portions of the existing distribution circuit do not have the capacity to accommodate the combined generation capacity of ID #019176 and #016328. Therefore, reconductoring of these line sections is to be performed to increase the capacity. Additionally, certain protective devices that lie between the substation and the POI required alternation to maintain proper protection and coordination on the circuit with the addition of the Facilities.

#### High Level Scope of Work:

1. Distribution Line System Upgrades:
  - a. Replace existing conductors with 3Ø 1/0 ACSR conductors keeping existing neutral from DIS# GC33BV to DIS# SXB60; approximately 0.45 miles

- b. Verify line sections are built to High Capacity Standards, and rebuild as necessary, from the T3760B02 feeder exit to DIS# FA03BV (approximately 0.09 miles), which typically includes 4/0 Neutral, 84" Primary to Neutral spacing, 280 ft. maximum spans, etc.
- 2. Protection/Sectionalization System Upgrades:
  - c. Replace 3Ø fuse with G&W Viper recloser at DIS#GC33BV.
  - d. Relocate 3Ø fuse at DIS #GC33BV to section downstream of the ID # 016328 point of interconnection.

**Feeder: T3760B## (New Position Number To Be Assigned)**

To relieve the overload that occurs on feeder T3760B02 as a result of the aggregate generation capacity, a new feeder is being created out of the McColl 230kV substation. Feeder T3750B02 is then going to be reconfigured just outside of the substation to bring the southbound portions of the circuit to this new feeder. This reconfiguration will transfer ID #004540 to this new feeder.

**High Level Scope of Work:**

- 1. Distribution Line System Upgrades:
  - a. Construct new 3Ø 477 AAC lines with a 4/0 ACSR neutral from the new feeder breaker position to near DIS# FA01BV; approximately 100 ft.
  - b. Transfer sections of the T3760B02 feeder starting at ID #421611618 to the end of the new lines constructed for the new feeder breaker position.

## 5.5 Substation: Mullins 115kV

**Feeder: T3030B01**

The interconnection of ID#019139 and #020832 results in steady state voltage violations on the circuit. To remediate these violations, portions of the circuit were reconducted to heavy conductors. All violations were remediated on the circuit when this change is made.

**High Level Scope of Work**

- 1. Distribution Line System Upgrades:
  - a. Replace existing 3Ø #2 ACSR circuit with 3Ø 477 AAC circuit from DIS#AT80BS to DIS#AU92BS (approximately 1.185 miles). The existing neutral should be replaced with a 4/0 AAAC neutral.
  - b. Replace existing 3Ø #2 ACSR circuit with 3Ø 477 AAC circuit from DIS# AU92BS to DIS#AV3BS (approximately 0.619 miles). The existing neutral should be replaced with a 4/0 AAAC neutral.

**Feeder: T3030B04**

With the existing circuit conditions, a Section 3.2.2 line voltage regulator, in accordance with the Method of Service Guidelines, would be needed between the substation and the point of interconnection for ID#021892. To remediate the impact this device would have on the Facility, load is to be reconfigured so that more balanced conditions are achieved on the circuit which in turn reduces the voltage drop on the circuit. The circuit does not experience any steady state voltage or rapid voltage change violations with the addition of the Facility once this change is made.

**High Level Scope of Work**

1. Circuit Reconfiguration:
  - a. Rephase 1Ø C phase tap line at DIS#6AR99 to B phase

## 5.6 Substation: Wadesboro Bowman School 230kV

### Feeder: T1672B03

The interconnection of ID #008286 is proposed at the end of a single phase tap line off of the existing distribution system. In order to accommodate the proposed Facility, this 2.22 mile long tap line would need to be converted to three phase. Additionally, certain protective devices that lie between the substation and the POI required alternation to maintain proper protection/coordination on the circuit with the addition of the Facility. Once these System Upgrades are performed, the interconnection of the Facility does not result in any steady state voltage or rapid voltage change violations on the circuit.

#### High Level Scope of Work

1. Distribution Line System Upgrades:
  - a. Reconductor existing 1 – 1/0 ACSR circuit with 3-477 AAC circuit from DIS# BC20AL to DIS# BC23AL (approximately 0.1 miles). The existing neutral should be replaced with a 4/0 AAAC neutral due to single phase path to POI.
  - b. Reconductor existing 1 – 2 ACSR circuit with 3-477 AAC circuit from DIS# BC23AL to DIS# BC09AL (approximately 0.3 miles). The existing neutral should be replaced with a 4/0 AAAC neutral due to single phase path to POI.
  - c. Reconductor existing 1 – 1/0 ACSR circuit with 3-477 AAC circuit from DIS# BC09AL to DIS# BB78AL (approximately 1.21 miles). The existing neutral should be replaced with a 4/0 AAAC neutral due to single phase path to POI.
  - d. Reconductor existing 1 – 2 AAAC circuit with 3-477 AAC circuit from DIS# BB78AL to DIS# BS40AL (approximately 0.61miles). The existing neutral should be replaced with a 4/0 AAAC neutral due to single phase path to POI.
2. Protection/Sectionalization System Upgrades:
  - a. Replace 1Ø 100A TripSaver at DIS# BC20AL with G&W Viper.
  - b. Remove 1Ø 25KS fuse at DIS# BB78AL and replace with solid blades.

## 5.7 Substation: Weatherspoon 230kV

### Feeder: T2631B03

The interconnection of ID #002115 and #002156 results in steady state voltage violations that can only be partially remediated with System Upgrades. The existing Generating Facilities increase the circuit voltages to the limit during peak and valley loading periods and the addition of the proposed Facilities increase the voltages beyond the limit. Modifying the distribution to the largest standard equipment does not completely remediate these violations. The remainder of the remediation requires relocation of the Point of Interconnections (POIs) for both Generating Facilities. To accommodate the proposed generation capacities, both Facilities are required to construct, own, and maintain new distribution facilities along new right-of-way for each installation to bring the Point of Interconnections (POIs) to near DIS# 9LL07 (34.597245°, -78.961050°). The Interconnection Facilities for each project would extend off this location and each Interconnection Customer's new lines would connect to the Point of Deliveries (POD).

#### High Level Scope of Work

1. New Line Construction:
  - a. ID #002115 must obtain, build, and maintain new right-of-way and distribution facilities from the project site to the POI. The studied POI for this project is located near DIS# 9LL07 (34.597245°, -78.961050°), approximately 2.2 miles from the project site assuming DOT roadways are followed (actual distance may vary depending on the path chosen by the Interconnection Customer).
  - b. ID #002156 must obtain, build, and maintain new right-of-way and distribution facilities from the project site to the POI. The studied POI for this project is located near DIS# 9LL07 (34.597245°, -78.961050°), approximately 3 miles from the project site assuming DOT roadways are followed (actual distance may vary depending on the path chosen by the Interconnection Customer).
2. Distribution Line System Upgrades:
  - a. Verify line sections are built to High Capacity Standards, and rebuild as necessary, from the T2631B03 feeder exit to DIS# 9LL07 (approximately 1.22 miles), which typically includes 4/0 Neutral, 84" Primary to Neutral spacing, 280 ft. maximum spans, etc.

## 5.8 Substation: Whiteville 115kV

### Feeder: T6670B03

The interconnection of ID #005037 did not result in any steady state voltage or rapid voltage change violations on the circuit. No power flow related System Upgrades have been identified at this time.