

Becker / Pearce Excess Capacity Rebuttal Exhibit 15
W-218 Sub 526

The Westfall Service Area Design Flow Summary

Completed by Joseph Pearce PE

Number of Dwelling Units	181
Number of Bedrooms per Dwelling Unit	4.06
Design Standard	120 gpd per bedroom
Dwelling Unit Design Flow	88183 gpd
Dwelling Units Under Construction	3600 gpd
Total Dwelling Units (incl in progress)	91783

*Did not include a value for pool/recreation area